

# H.E. Woolley

## Fire Protection & Security



1a Startforth Road, Riverside Park, Middlesbrough TS2 1PT.

Tel: 01642 247337 Email: info@he-woolley.co.uk

www.fireriskassessment.com

## Emergency Lighting Periodic Inspection and Test

Customer <u>INFRATEC</u>	Date <u>6/10/23</u>
Address <u>UNIT 9 OFFICE</u>	Order No. ....
Invoice Address if different from above .....	Account Ref.. ....
	Invoice No. ....

I/we hereby certify that the emergency lighting installation at the above premises has been inspected/tested by me/us in accordance with the schedule below, and to the best of my/our knowledge and belief with BS 5266-1:2011, except for the variations, if any, stated in this certificate.

Annual Inspection and Test ☒ 1 Hour Burn ☒ 3 Hour Burn ☐ Remedial Work ☐

RESULTS OF EMERGENCY LIGHT SERVICE		Yes	No
Regular test results logged			
Installation in a satisfactory condition			
Central battery system			
Self-contained luminaires and signs			
Devices operate on mains failure			
Maintained devices			
Non-maintained devices			
Defective devices			
REMEDIAL WORK / PARTS SUPPLIED & FITTED		Quantity	
Twin Spot Light			
Bulkhead Light			
Battery			
8w Tube			

*NOTE: Because of the possibility of failure of the supply to the normal lighting occurring shortly after a period of testing, all tests should be undertaken at times of minimal risk. Alternatively, suitable temporary arrangements should be made until the batteries are recharged.*

### Comments and Variations, if any, from BS 5266-1:2011

All passed apart from 1 that doesn't have power going to it.

Adjacent WC Running Man

Engineer's Signature <u>[Signature]</u>	Print <u>EP</u>	Total	
Customer's Signature <u>[Signature]</u>		VAT	
Print Name .....		Total	
Position .....	Date <u>6/10/23</u>		