

## **SECTION 26 09 23 - LIGHTING CONTROL DEVICES**

### **PART 1 - GENERAL**

#### **1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### **1.2 SUMMARY**

- A. Section Includes:
  - 1. Time switches.
  - 2. Photoelectric switches.
  - 3. Outdoor photoelectric switches, solid state, flexible mounting.
  - 4. Outdoor photoelectric switches, low voltage.
  - 5. Daylight-harvesting dimming controls, analog.
  - 6. Daylight-harvesting dimming controls, digital.
  - 7. Indoor occupancy and vacancy sensors.
  - 8. Switchbox-mounted occupancy sensors.
  - 9. Digital timer light switch.
  - 10. High-bay occupancy sensors.
  - 11. Extreme-temperature occupancy sensors.
  - 12. Lighting contactors.
  - 13. Conductors and Cables.
- B. Related Requirements:
  - 1. Section 262726 "Wiring Devices" for manual light switches.

#### **1.3 ACTION SUBMITTALS**

- A. Product Data: For each type of product.
  - 1. Interconnection diagrams showing field-installed wiring.
  - 2. Include diagrams for power, signal, and control wiring.

#### **1.4 INFORMATIONAL SUBMITTALS**

- A. Field quality-control reports.
- B. Sample Warranty: For manufacturer's warranties.

#### **1.5 CLOSEOUT SUBMITTALS**

- A. Operation and Maintenance Data: For each type of lighting control device to include in operation and maintenance manuals.

#### **1.6 WARRANTY**

- A. Manufacturer's Warranty: Manufacturer and Installer agree to repair or replace lighting control devices that fail(s) in materials or workmanship within specified warranty period.
  - 1. Failures include, but are not limited to, the following:

- a. Faulty operation of lighting control devices.
2. Warranty Period: Five years from date of Substantial Completion.

## **PART 2 - PRODUCTS**

### **2.1 ELECTRONIC TIME SWITCHES**

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following (no substitutions accepted):
  1. Wattstopper).
- B. Electronic Time Switches: Solid state, programmable, with alphanumeric display; complying with UL 917.
  1. Listed and labeled as defined in NFPA 70 and marked for intended location and application.
  2. Contact Configuration: SPST
  3. Contact Rating: 30-A inductive or resistive, 240-V ac
  4. Programs: 12 channels; each channel is individually programmable with eight on-off set points on a 24-hour schedule.
  5. Circuitry: Allow connection of a photoelectric relay as substitute for on-off function of a program on selected or all channels.
  6. Astronomic Time: All channels.
  7. Automatic daylight savings time changeover.
  8. Battery Backup: Not less than seven days reserve, to maintain schedules and time clock.

### **2.2 OUTDOOR PHOTOELECTRIC SWITCHES, SOLID STATE, FLEXIBLE MOUNTING**

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following (no substitutions accepted):
  1. Wattstopper.
- B. Description: Solid state, with SPST dry contacts rated for 1000W LED or 1800 VA inductive, to operate connected relay, contactor coils, or microprocessor input; complying with UL 773A, and compatible with ballasts and LED lamps.
  1. Listed and labeled as defined in NFPA 70, by a agency NRTL, and marked for intended location and application.
  2. Light-Level Monitoring Range: 1.5 to 10 fc (16.14 to 108 lux), with an adjustment for turn-on and turn-off levels within that range, and a directional lens in front of the photocell to prevent fixed light sources from causing turn-off.
  3. Time Delay: Fifteen-second minimum, to prevent false operation.
  4. Surge Protection: Metal-oxide varistor.
  5. Mounting: Twist lock complies with ANSI C136.10, with base-and-stem mounting or stem-and-swivel mounting accessories as required to direct sensor to the north sky exposure from same source and manufacturer as switch.
  6. Failure Mode: Luminaire stays ON.

### **2.3 OUTDOOR PHOTOELECTRIC SWITCHES, LOW VOLTAGE**

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following (no substitutions accepted):
  1. Wattstopper (The).

- B. Description: Solid state; one set of NO dry contacts rated for 24 V to operate connected load, complying with UL 773, and compatible with lighting control panelboard.
  - 1. Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
  - 2. Light-Level Monitoring Range: 1.5 to 10 fc (16.14 to 108 lux), with an adjustment for turn-on and turn-off levels within that range.
  - 3. Time Delay: Thirty-second minimum, to prevent false operation.
  - 4. Mounting: 1/2-inch (13-mm) threaded male conduit.
  - 5. Failure Mode: Luminaire stays ON.
  - 6. Compatible with digital addressable lighting interface.

## 2.4 DAYLIGHT-HARVESTING DIMMING CONTROLS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following (no substitutions accepted):
  - 1. Wattstopper
- B. Description: Sensing daylight and electrical lighting levels, the system adjusts the indoor electrical lighting levels. As daylight increases, the lights are dimmed.
  - 1. Lighting control set point is based on two lighting conditions:
    - a. When no daylight is present (target level).
    - b. When significant daylight is present.
  - 2. LEED Credit IEQ Interior Lighting - Dimming Requirements:
    - a. At least (3) lighting levels (on, off, midlevel) are required for dimmable lighting
    - b. Midlevel is 30-70% of the maximum illumination level (not including daylight contributions)
  - 3. System programming is done with two hand-held, remote-control tools.
    - a. Initial setup tool.
    - b. Tool for occupants to adjust the target levels by increasing the set point up to 25 percent, or by minimizing the electric lighting level.
- C. Ceiling-Mounted Dimming Controls: Solid-state, light-level sensor unit, with separate power pack, to detect changes in indoor lighting levels that are perceived by the eye.
- D. Electrical Components, Devices, and Accessories:
  - 1. Listed and labeled as defined in National Electrical Code, by a qualified testing agency, and marked for intended location and application.
  - 2. Sensor Output: 0- to 10-V dc to operate luminaires. Sensor is powered by controller unit.
  - 3. Light-Level Sensor Set-Point Adjustment Range: 10 to 60 fc .
  - 4. Compatible with digital addressable lighting interface where required
- E. Power Pack: Dry contacts rated for 20-A ballast or LED load at 120- and 277-V ac, for 13-A tungsten at 120-V ac, and for 1 hp at 120-V ac. Sensor has 24-V dc, 150-mA, Class 2 power source, as defined by National Electrical Code,
  - 1. LED status lights to indicate load status.
  - 2. Plenum rated.

- F. Power Pack: Digital controller capable of accepting 4 RJ45 inputs with two outputs rated for 20-A incandescent or LED load at 120- and 277-V ac, for 16-A ballast load at 120- and 277-V ac, and for 1 hp at 120-V ac. Sensor has 24-V dc Class 2 power source, as defined by National Electrical Code.
  - 1. With integral current monitoring
    - a. Compatible with digital addressable lighting interface.
- G. Where installed within washdown areas, sensors and power packs shall be built to IP66 rated construction.

## **2.5 INDOOR OCCUPANCY AND VACANCY SENSORS**

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following (no substitutions accepted):
  - 1. Wattstopper
- B. General Requirements for Sensors:
  - 1. Wall or Ceiling-mounted, solid-state indoor occupancy and vacancy sensors.
  - 2. Dual technology.
  - 3. Separate power pack.
  - 4. Hardwired connection to switch, BAS and lighting control system.
  - 5. Listed and labeled as defined in National Electrical Code, by a qualified testing agency, and marked for intended location and application.
  - 6. Operation:
    - a. Occupancy Sensor: Unless otherwise indicated, turn lights on when coverage area is occupied, and turn them off when unoccupied; with a time delay for turning lights off, adjustable over a minimum range of 1 to 15 minutes.
    - b. Vacancy Sensor: Unless otherwise indicated, lights are manually turned on and sensor turns lights off when the room is unoccupied; with a time delay for turning lights off, adjustable over a minimum range of 1 to 15 minutes.
    - c. Combination Sensor: Unless otherwise indicated, sensor shall be programmed to turn lights on when coverage area is occupied and turn them off when unoccupied, or to turn off lights that have been manually turned on; with a time delay for turning lights off, adjustable over a minimum range of 1 to 15 minutes.
  - 7. Sensor Output: Sensor is powered from the power pack.
  - 8. Power: Line voltage.
  - 9. Power Pack: Dry contacts rated for 20-A ballast or LED load at 120- and 277-V ac, for 13-A tungsten at 120-V ac, and for 1 hp at 120-V ac. Sensor has 24-V dc, 150-mA, Class 2 power source, as defined by NFPA 70.
  - 10. Mounting:
    - a. Sensor: Suitable for mounting in any position on a standard outlet box.
    - b. Relay: Externally mounted through a 1/2-inch knockout in a standard electrical enclosure.
    - c. Time-Delay and Sensitivity Adjustments: Recessed and concealed behind hinged door.
  - 11. Indicator: Digital display, to show when motion is detected during testing and normal operation of sensor.
  - 12. Bypass Switch: Override the "on" function in case of sensor failure.

13. Automatic Light-Level Sensor: Adjustable from 2 to 200 fc ; turn lights off when selected lighting level is present.
  14. Able to be programmed to occupancy style or vacancy style sensing.
- C. Dual-Technology Type: Wall or Ceiling mounted; detect occupants in coverage area using PIR and ultrasonic detection methods. The particular technology or combination of technologies that control on-off functions is selectable in the field by operating controls on unit.
1. Sensitivity Adjustment: Separate for each sensing technology.
  2. Detector Sensitivity: Detect occurrences of 6-inch- minimum movement of any portion of a human body that presents a target of not less than 36 sq. in. , and detect a person of average size and weight moving not less than 12 inches in either a horizontal or a vertical manner at an approximate speed of 12 inches/s.
  3. Detection Coverage (Standard Room): Detect occupancy anywhere within a circular area of 1000 sq. ft. when mounted on a 96-inch- high ceiling.
  4. Detection Coverage (Room, Wall Mounted): Detect occupancy anywhere within a 180-degree pattern centered on the sensor over an area as indicated on floor plans when mounted 48 inches above finished floor.
  5. Provide multiple sensors when required for complete coverage.
- D. Where installed within washdown areas, sensors shall be built to IP66 rated construction.

## **2.6 SWITCHBOX-MOUNTED OCCUPANCY SENSORS**

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following (no substitutions accepted):
1. Wattstopper
- B. General Requirements for Sensors: Automatic-wall-switch occupancy sensor with manual on-off switch, suitable for mounting in a single gang switchbox, with provisions for connection to BAS using hardwired connection.
1. Listed and labeled as defined in National Electrical Code, by a qualified testing agency, and marked for intended location and application.
  2. Occupancy Sensor Operation: Unless otherwise indicated, turn lights on when coverage area is occupied, and turn lights off when unoccupied; with a time delay for turning lights off, adjustable over a minimum range of 1 to 15 minutes.
  3. Operating Ambient Conditions: Dry interior conditions, 32 to 120 deg F.
  4. Switch Rating: Not less than 800-VA ballast or LED load at 120 V, 1200-VA ballast or LED load at 277 V, and 800-W incandescent.
  5. Dual technology
- C. Wall-Switch Sensor Details:
1. Standard Range: 180-degree field of view, field adjustable from 180 to 40 degrees; with a minimum coverage area of 900 sq. ft. (84 sq. m), 2100 sq. ft (196 sq. m) for larger areas.
  2. Sensing Technology: Dual technology - PIR and ultrasonic.
  3. Switch Type – any of the following may be required: SP; SP, dual circuit; SP, field-selectable automatic "on," or manual "on," automatic "off."
  4. Capable of controlling load in three-way application.
  5. Voltage: Match the circuit voltage
  6. Ambient-Light Override: Concealed, field-adjustable, light-level sensor from 10 to 150 fc . The switch prevents the lights from turning on when the light level is higher than the set point of the sensor.

7. Concealed, field-adjustable, "off" time-delay selector at up to 30 minutes.
  8. Able to be locked to Manual-On mode.
  9. Concealed, "off" time-delay selector at 30 seconds and 5, 10, and 20 minutes.
  10. Adaptive Technology: Self-adjusting circuitry detects and memorizes usage patterns of the space and helps eliminate false "off" switching.
  11. Able to be programmed to occupancy style or vacancy style sensing.
  12. Color: as selected by architect.
  13. Faceplate: Color matched to switch.
  14. Connections: Provisions for connection to BAS.
  15. Connections: RJ-45 communications outlet.
  16. Connections: Integral wireless networking.
- D. All devices must be UL listed as a standalone device.
- E. Where installed within washdown areas, sensors and switches shall be built to IP66 rated construction.

## **2.7 DIGITAL TIMER LIGHT SWITCH**

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following (no substitutions accepted):
1. Wattstopper
- B. Description: Combination digital timer and conventional switch lighting control unit. Switchbox-mounted, backlit LCD display, with selectable time interval in 5 minute increments.
1. Rated 960 W at 120-V ac for tungsten lighting, 10 A at 120-V ac or 10 amps at 277-V ac for ballast or LED, and 1/4 horsepower at 120-V ac.
  2. Integral relay for connection to BAS.
  3. Voltage: Match the circuit voltage
  4. Visual flash warning: flashes lights at 5 minutes and 1 minute prior to time out.
  5. Audible warning: beeps every 5 seconds 1 minute prior to time out.
  6. Time scroll for setting time interval and temporary override of the preset time period.
  7. Integral relay for connection to BAS.
  8. Connections: RJ-45 communications outlet.
  9. Connections: Integral wireless networking.
  10. Color: as selected by architect.
  11. Faceplate: Color matched to switch.
- C. All devices must be UL listed as a standalone device.
- D. Where installed within washdown areas, switches shall be built to IP66 rated construction.

## **2.8 WALL PLATES**

- A. Single and combination types to match corresponding wiring devices.
1. Material and color as specified in Specification Section 262726 'Wiring Devices'.
  2. Wall plate openings and configurations shall match provided devices.

## **2.9 FINISHES**

- A. Color

1. Lighting Control Devices Connected to Normal Power System: Coordinate with other wiring devices specified under Section 'Wiring Devices' and lighting control wall stations as specified in Section 'Network Lighting Control System' unless otherwise indicated or required by NEC or device listing.
2. Wiring Devices Connected to Emergency Power System: Red.

## **2.10 HIGH-BAY OCCUPANCY SENSORS**

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following (no substitutions accepted):
  1. Wattstopper
- B. Description: Solid-state unit. The unit is designed to operate with the lamp and ballasts indicated.
  1. Listed and labeled in accordance with NFPA 70, by a qualified electrical testing laboratory recognized by authorities having jurisdiction, and marked for intended location and application.
  2. Operation: Turn lights on when coverage area is occupied, and to half-power when unoccupied; with a time delay for turning lights to half-power that is adjustable over a minimum range of 1 to 16 minutes.
  3. Continuous Lamp Monitoring: When lamps are dimmed continuously for 24 hours, automatically turn lamps on to full power for 15 minutes for every 24 hours of continuous dimming.
  4. Power: Line voltage.
  5. Operating Ambient Conditions: 32 to 149 deg F (0 to 65 deg C).
  6. Mounting: Threaded pipe.
  7. Time-Delay and Sensitivity Adjustments: Recessed and concealed behind hinged door.
  8. Detector Technology: PIR.
- C. Detector Coverage: User selectable by interchangeable PIR lenses, suitable for mounting heights from 12 to 50 ft. (3.7 to 15.2 m).
- D. Accessories: Obtain manufacturer's installation and maintenance kit with laser alignment tool for sensor positioning and power port connectors.

## **2.11 EXTREME-TEMPERATURE OCCUPANCY SENSORS**

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following (no substitutions accepted):
  1. Wattstopper
- B. Description: Ceiling-mounted, solid-state, extreme-temperature occupancy sensors with a separate power pack.
  1. Listed and labeled in accordance with NFPA 70, by a qualified electrical testing laboratory recognized by authorities having jurisdiction, and marked for intended application in damp locations.
  2. Operation: Turn lights on when coverage area is occupied, and turn them off when unoccupied; with a time delay for turning lights off, adjustable over a minimum range of 1 to 30 minutes.
  3. Operating Ambient Conditions: From minus 40 to plus 125 deg F (minus 40 to plus 52 deg C).
  4. Sensor Output: Contacts rated to operate the connected relay, complying with UL 773A. Sensor is powered from the power pack.
  5. Power Pack: Dry contacts rated for 20 A LED load at 120 and 277 V(ac), for 13 A tungsten at 120 V(ac), and for 1 hp at 120 V(ac). Sensor has 24 V(dc), 150 mA, Class 2 power source.
  6. Mounting:

- a. Sensor: Suitable for mounting in any position in a standard device box or outlet box.
  - b. Relay: Externally mounted through a 1/2 inch (13 mm) knockout in a standard electrical enclosure.
  - c. Time-Delay and Sensitivity Adjustments: Recessed and concealed behind cover.
- 7. Bypass Switch: Override the "on" function in case of sensor failure.
- 8. Automatic Light-Level Sensor: Adjustable from 2 to 10 fc (21.5 to 108 lx); keep lighting off when selected lighting level is present.
- C. Detector Technology: PIR. Ceiling mounted; detect occupants in coverage area by their heat and movement.
  - 1. Detector Sensitivity: Detect occurrences of 6 inch (150 mm) minimum movement of any portion of a human body that presents a target of not less than 36 sq. inch (23 200 sq. mm).
  - 2. Detection Coverage (Room): Detect occupancy anywhere in a circular area of 1500 sq. ft. (139 sq. m) when mounted on a 96 inch (2440 mm) high ceiling.
  - 3. Detection Coverage (High Bay): Detect occupancy within 25 ft. (7.6 m) when mounted on a 25 ft. (7.6 m) high ceiling.

## **2.12 LIGHTING CONTACTORS**

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following (no substitutions accepted):
  - 1. Wattstopper
- B. Description: Electrically operated and mechanically held, combination-type lighting contactors with nonfused disconnect, complying with NEMA ICS 2 and UL 508.
  - 1. Current Rating for Switching: Listing or rating consistent with type of load served, including tungsten filament, inductive, and high-inrush ballast (ballast with 15 percent or less THD of normal load current).
  - 2. Fault Current Withstand Rating: Equal to or exceeding the available fault current at the point of installation.
  - 3. Enclosure: Comply with NEMA 250.
  - 4. Provide with control and pilot devices as indicated on Drawings, matching the NEMA type specified for the enclosure.
- C. Interface with DDC System for HVAC: Provide hardware interface to enable the DDC system for HVAC to monitor and control lighting contactors.
  - 1. Monitoring: On-off status
  - 2. Control: On-off operation
  - 3. Any other points required by DFW standards.

## **2.13 CONDUCTORS AND CABLES**

- A. Power Wiring to Supply Side of Remote-Control Power Sources: Not smaller than No. 12 AWG. Comply with requirements in Section 260519 "Low-Voltage Electrical Power Conductors and Cables."
- B. Classes 2 and 3 Control Cable: Multiconductor cable with stranded-copper conductors not smaller than No. 18 AWG. Comply with requirements in Section 260519 "Low-Voltage Electrical Power Conductors and Cables."
- C. Class 1 Control Cable: Multiconductor cable with stranded-copper conductors not smaller than No. 14 AWG. Comply with requirements in Section 260519 "Low-Voltage Electrical Power Conductors and Cables."



## **PART 3 - EXECUTION**

### **3.1 EXAMINATION**

- A. Examine lighting control devices before installation. Reject lighting control devices that are wet, moisture damaged, or mold damaged.
- B. Examine walls and ceilings for suitable conditions where lighting control devices will be installed.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### **3.2 SENSOR INSTALLATION**

- A. Comply with NECA 1.
- B. Coordinate layout and installation of ceiling-mounted devices with other construction that penetrates ceilings or is supported by them, including light fixtures, HVAC equipment, smoke detectors, fire-suppression systems, and partition assemblies.
- C. Install and aim sensors in locations to achieve not less than 90 percent coverage of areas indicated. Do not exceed coverage limits specified in manufacturer's written instructions.

### **3.3 CONTACTOR INSTALLATION**

- A. Comply with NECA 1.
- B. Mount electrically held lighting contactors with elastomeric isolator pads to eliminate structure-borne vibration unless contactors are installed in an enclosure with factory-installed vibration isolators.

### **3.4 WIRING INSTALLATION**

- A. Comply with NECA 1.
- B. Wiring Method: Comply with Section 260519 "Low-Voltage Electrical Power Conductors and Cables." Minimum conduit size is 1/2 inch (13 mm).
- C. Wiring within Enclosures: Comply with NECA 1. Separate power-limited and nonpower-limited conductors according to conductor manufacturer's written instructions.
- D. Size conductors according to lighting control device manufacturer's written instructions unless otherwise indicated.
- E. Splices, Taps, and Terminations: Make connections only on numbered terminal strips in junction, pull, and outlet boxes; terminal cabinets; and equipment enclosures.

### **3.5 DEVICE INSTALLATION**

- A. Replace devices that have been in temporary use during construction and that were installed before building finishing operations were complete.
- B. Keep each wiring device in its package or otherwise protected until it is time to connect conductors.
- C. Do not remove surface protection, such as plastic film and smudge covers, until the last possible moment.
- D. Connect devices to branch circuits using pigtails that are not less than 6 inches (152 mm) in length.
- E. When there is a choice, use side wiring with binding-head screw terminals. Wrap solid conductor tightly clockwise, two-thirds to three-fourths of the way around terminal screw.
- F. Use a torque screwdriver when a torque is recommended or required by manufacturer.

- G. When conductors larger than No. 12 AWG are installed on 15- or 20-A circuits, splice No. 12 AWG pigtails for device connections.
- H. Tighten unused terminal screws on the device.
- I. When mounting into metal boxes, remove the fiber or plastic washers used to hold device-mounting screws in yokes, allowing metal-to-metal contact.
- J. Device Plates: Do not use oversized or extra-deep plates. Repair wall finishes and remount outlet boxes when standard device plates do not fit flush or do not cover rough wall opening.
- K. Arrangement of Devices: Unless otherwise indicated, mount flush, with long dimension vertical. Group adjacent switches under single, multi-gang wall plates.

### **3.6 DIMMER INSTALLATION**

- A. Install dimmers within terms of their listing.
- B. Verify that dimmers used for fan-speed control are listed for that application.
- C. Install unshared neutral conductors on line and load side of dimmers according to manufacturers' device, listing conditions in the written instructions.
- D. Arrangement of Devices: Unless otherwise indicated, mount flush, with long dimension vertical. Group adjacent switches under single, multi-gang wall plates.

### **3.7 IDENTIFICATION**

- A. Identify components and power and control wiring according to Section 260553 "Identification for Electrical Systems."
  - 1. Identify controlled circuits in lighting contactors.
  - 2. Identify circuits or luminaires controlled by photoelectric and occupancy sensors at each sensor.
- B. Label time switches and contactors with a unique designation.

### **3.8 FIELD QUALITY CONTROL**

- A. Perform the following tests and inspections with the assistance of a factory-authorized service representative:
  - 1. Operational Test: After installing time switches and sensors, and after electrical circuitry has been energized, start units to confirm proper unit operation.
  - 2. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
- B. Lighting control devices will be considered defective if they do not pass tests and inspections.
- C. Prepare test and inspection reports.

### **3.9 ADJUSTING**

- A. Occupancy Adjustments: When requested within 12 months from date of Substantial Completion, provide on-site assistance in adjusting lighting control devices to suit actual occupied conditions. Provide up to four visits to Project during other-than-normal occupancy hours for this purpose.
  - 1. For occupancy and motion sensors, verify operation at outer limits of detector range. Set time delay to suit Owner's operations.

2. For daylighting controls, adjust set points and deadband controls to suit Owner's operations.
3. Align high-bay occupancy sensors using manufacturer's laser aiming tool.

### **3.10 SOFTWARE SERVICE AGREEMENT**

- A. Technical Support: Beginning at Substantial Completion, service agreement shall include software support for two years.
- B. Upgrade Service: At Substantial Completion, update software to latest version. Install and program software upgrades that become available within two years from date of Substantial Completion. Upgrading software shall include operating system and new or revised licenses for using software.
  1. Upgrade Notice: At least 30 days to allow Owner to schedule and access the system and to upgrade computer equipment if necessary.

### **3.11 DEMONSTRATION**

- A. Coordinate demonstration of products specified in this Section with demonstration requirements for low-voltage, programmable lighting control systems specified in Section 260943.16 "Addressable-Luminaire Lighting Controls" and Section 260943.23 "Relay-Based Lighting Controls."
- B. **Train** Owner's maintenance personnel to adjust, operate, and maintain lighting control devices.

### **END OF SECTION**