#### **SECTION 26 05 33.16 - BOXES FOR ELECTRICAL SYSTEMS**

#### **PART 1 GENERAL**

## 1.1 SECTION INCLUDES

- A. Outlet and device boxes up to 100 cubic inches (1,650 cu cm), including those used as junction and pull boxes.
- B. Cabinets and enclosures, including junction and pull boxes larger than 100 cubic inches (1,650 cu cm).

## 1.2 RELATED REQUIREMENTS

- A. Section 26 05 26.01 Grounding and Bonding for Electrical Systems.
- B. Section 33 52 43.31 Fuel System Conduit for Electrical Systems:
  - Conduit bodies and other fittings.
- C. Section 33 52 43.33 Fuel System Identification for Electrical Systems: Identification products and requirements.

# 1.3 REFERENCE STANDARDS

- A. NEMA 250 Enclosures for Electrical Equipment (1000 Volts Maximum) 2020.
- B. NEMA FB 1 Fittings, Cast Metal Boxes, and Conduit Bodies for Conduit, Electrical Metallic Tubing, and Cable 2014.
- C. NEMA OS 1 Sheet-Steel Outlet Boxes, Device Boxes, Covers, and Box Supports 2013 (Reaffirmed 2020).
- D. NFPA 70 National Electrical Code Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- E. UL 50 Enclosures for Electrical Equipment, Non-Environmental Considerations Current Edition, Including All Revisions.
- F. UL 50E Enclosures for Electrical Equipment, Environmental Considerations Current Edition, Including All Revisions.
- G. UL 508A Industrial Control Panels Current Edition, Including All Revisions.
- H. UL 514A Metallic Outlet Boxes Current Edition, Including All Revisions.

#### **PART 2 PRODUCTS**

## 2.1 BOXES

- A. General Requirements:
  - Do not use boxes and associated accessories for applications other than as permitted by NFPA 70 and product listing.
  - 2. Provide all boxes, fittings, supports, and accessories required for a complete raceway system and to accommodate devices and equipment to be installed.
  - 3. Provide products listed, classified, and labeled as suitable for the purpose intended.
  - 4. Where box size is not indicated, size to comply with NFPA 70 but not less than applicable minimum size requirements specified.
  - 5. Provide grounding terminals within boxes where equipment grounding conductors terminate.
- B. Outlet and Device Boxes Up to 100 cubic inches (1,650 cu cm), Including Those Used as Junction and Pull Boxes:
  - 1. Use sheet-steel boxes for dry locations unless otherwise indicated or required.
  - 2. Use cast iron boxes or cast aluminum boxes for damp or wet locations unless otherwise indicated or required; furnish with compatible weatherproof gasketed covers.
  - 3. Use suitable concrete type boxes where flush-mounted in concrete.
  - 4. Use suitable masonry type boxes where flush-mounted in masonry walls.
  - 5. Use raised covers suitable for the type of wall construction and device configuration where required.
  - 6. Use shallow boxes where required by the type of wall construction.
  - 7. Do not use "through-wall" boxes designed for access from both sides of wall.
  - 8. Sheet-Steel Boxes: Comply with NEMA OS 1, and list and label as complying with UL 514A.
  - 9. Cast Metal Boxes: Comply with NEMA FB 1, and list and label as complying with UL 514A; furnish with threaded hubs.
  - Boxes for Supporting Luminaires and Ceiling Fans: Listed as suitable for the type and weight of load to be supported; furnished with fixture stud to accommodate mounting of luminaire where required.
  - 11. Boxes for Ganged Devices: Use multigang boxes of single-piece construction. Do not use field-connected gangable boxes unless specifically indicated or permitted.
- C. Cabinets and Enclosures, Including Junction and Pull Boxes Larger Than 100 cubic inches (1,650 cu cm):
  - 1. Comply with NEMA 250, and list and label as complying with UL 50 and UL 50E, or UL 508A.
  - 2. NEMA 250 Environment Type, Unless Otherwise Indicated:
  - 3. Junction and Pull Boxes Larger Than 100 cubic inches (1,650 cu cm):
    - a. Provide screw-cover or hinged-cover enclosures unless otherwise indicated.
  - 4. Finish for Painted Steel Enclosures: Manufacturer's standard grey unless otherwise indicated.

## **END OF SECTION 26 05 33.16**