

## **SECTION 26 28 16 – ENCLOSED SWITCHES**

### **PART 1 – GENERAL**

#### **1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

#### **1.2 SUMMARY**

- A. Section Includes:
  - 1. Fusible switches.
  - 2. Non Fusible switches.
  - 3. Enclosures.

#### **1.3 DEFINITIONS**

- A. NC: Normally closed.
- B. NO: Normally open.
- C. SPDT: Single pole, double throw.

#### **1.4 ACTION SUBMITTALS**

- A. Product Data: For each type of enclosed switch, accessory, and component indicated. Include nameplate ratings, dimensioned elevations, sections, weights, and manufacturers' technical data on features, performance, electrical characteristics, ratings, accessories, and finishes.
  - 1. Enclosure types and details for types other than NEMA 250, Type 1.
  - 2. Current and voltage ratings.
  - 3. Short-circuit current ratings (interrupting and withstand, as appropriate).
  - 4. Include evidence of nationally recognized testing laboratory (NRTL) listing for series rating of installed devices.
  - 5. Detail features, characteristics, ratings, and factory settings of individual overcurrent protective devices, accessories, and auxiliary components.
  - 6. Include time-current coordination curves (average melt) for each type and rating of overcurrent protective device; include selectable ranges for each type of overcurrent protective device. Provide in PDF format.
- B. Shop Drawings: For enclosed switches.
  - 1. Include plans, elevations, sections, details, and attachments to other work.

2. Include wiring diagrams for power, signal, and control wiring.

## **1.5 INFORMATIONAL SUBMITTALS**

- A. Qualification Data: For qualified testing agency.
- B. Seismic Qualification Data: Certificates, for enclosed switches, accessories, and components, from manufacturer.
  1. Basis for Certification: Indicate whether withstand certification is based on actual test of assembled components or on calculation.
  2. Dimensioned Outline Drawings of Equipment Unit: Identify center of gravity and locate and describe mounting and anchorage provisions.
  3. Detailed description of equipment anchorage devices on which certification is based and their installation requirements.
- C. Field quality-control reports.

## **1.6 CLOSEOUT SUBMITTALS**

- A. Operation and Maintenance Data: For enclosed switches to include in emergency, operation, and maintenance manuals.
  1. In addition to items specified in Section 017823 "Operation and Maintenance Data," include following:
    - a. Manufacturer's written instructions for testing and adjusting enclosed switches.
    - b. Time-current coordination curves (average melt) for each type and rating of overcurrent protective device; include selectable ranges for each type of overcurrent protective device. Provide in PDF format.

## **1.7 MAINTENANCE MATERIAL SUBMITTALS**

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  1. Fuses: Equal to 10 percent of quantity installed for each size and type, but no fewer than 3 of each size and type.
  2. Fuse Pullers: Two for each size and type.

## **1.8 QUALITY ASSURANCE**

- A. Testing Agency Qualifications: Accredited by NETA. Testing Agency's Field Supervisor: Currently certified by NETA to supervise on-site testing.

## **1.9 FIELD CONDITIONS**

- A. Environmental Limitations: Rate equipment for continuous operation under following conditions unless otherwise indicated:

1. Ambient Temperature: Not less than minus 22 degrees F and not exceeding 104 degrees F.

#### **1.10 WARRANTY**

- A. Manufacturer's Warranty: Manufacturer and Installer agree to repair or replace components that fail in materials or workmanship within specified warranty period.
  1. Warranty Period: One year from date of Substantial Completion.

### **PART 2 - PRODUCTS**

#### **2.1 GENERAL REQUIREMENTS**

- A. Source Limitations: Obtain enclosed switches, overcurrent protective devices, components, and accessories, within same product category, from single manufacturer.
- B. Switches shall be manufactured by ABB, Eaton, Schneider Electric, or Siemens.
- C. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by NRTL, and marked for intended location and application.
- D. Comply with NFPA 70.

#### **2.2 FUSIBLE SWITCHES**

- A. Type HD, Heavy Duty:
  1. Single throw.
  2. Three pole.
  3. 240 or 600V ac, as indicated.
  4. 200A and smaller.
  5. UL 98 and NEMA KS 1, horsepower rated, with clips or bolt pads to accommodate indicated fuses.
  6. Lockable handle with capability to accept 3 padlocks and interlocked with cover in closed position.
- B. Accessories:
  1. Equipment Ground Kit: Internally mounted and labeled for copper and aluminum ground conductors.
  2. Neutral Kit: Internally mounted; insulated, capable of being grounded and bonded; labeled for copper and aluminum neutral conductors.
  3. Class R Fuse Kit: Provides rejection of other fuse types when Class R fuses are specified.
  4. Auxiliary Contact Kit: One NO/NC (Form "C") auxiliary contact(s), arranged to activate before switch blades open. Contact rating – 120V ac.

5. Hook-Stick Handle: Allows use of hook-stick to operate handle.
6. Lugs: Mechanical type, suitable for number, size, and conductor material.
7. Service-Rated Switches: Labeled for use as service equipment.

## **2.3 NONFUSIBLE SWITCHES**

- A. Type HD, Heavy Duty, 3-Pole, Single Throw, 240 or 600V ac, 1200A and Smaller: UL 98 and NEMA KS 1, horsepower rated, lockable handle with capability to accept 3 padlocks, and interlocked with cover in closed position.
- B. Type HD, Heavy Duty, 3-Pole, Double Throw, 600V ac, 1200A and Smaller: UL 98 and NEMA KS 1, horsepower rated, lockable handle with capability to accept 3 padlocks, and interlocked with cover in closed position.
- C. Accessories:
  1. Equipment Ground Kit: Internally mounted and labeled for copper and aluminum ground conductors.
  2. Neutral Kit: Internally mounted; insulated, capable of being grounded and bonded; labeled for copper and aluminum neutral conductors.
  3. Class R Fuse Kit: Provides rejection of other fuse types when Class R fuses are specified.
  4. Auxiliary Contact Kit: One NO/NC (Form "C") auxiliary contact(s), arranged to activate before switch blades open. Contact rating – 120V ac.
  5. Hook-Stick Handle: Allows use of hook-stick to operate handle.
  6. Lugs: Mechanical type, suitable for number, size, and conductor material.
  7. Service-Rated Switches: Labeled for use as service equipment.

## **2.4 ENCLOSURES**

- A. Enclosed Switches: UL 489, NEMA KS 1, NEMA 250, and UL 50, to comply with environmental conditions at installed location.
- B. Enclosure Finish: Enclosure shall be finished with gray baked enamel paint, electrodeposited on cleaned, phosphatized steel (NEMA 250 Type 1) or brush finish on Type 304 stainless steel (NEMA 250 Type 4X stainless steel).
- C. Conduit Entry: NEMA 250 Type 4X enclosures shall contain no knockouts.

## **PART 3 - EXECUTION**

### **3.1 EXAMINATION**

- A. Examine elements and surfaces to receive enclosed switches for compliance with installation tolerances and other conditions affecting performance of Work.

- B. Proceed with installation only after unsatisfactory conditions have been corrected. Commencement of work shall indicate Installer's acceptance of areas and conditions as satisfactory.

### **3.2 ENCLOSURE ENVIRONMENTAL RATING APPLICATIONS**

- A. Enclosed Switches: Provide enclosures at installed locations with following environmental ratings.
  - 1. Indoor, Dry and Clean Locations: NEMA 250, Type 1.
  - 2. Outdoor Locations: NEMA 250, Type 4X.

### **3.3 INSTALLATION**

- A. Coordinate layout and installation of switches, and components with equipment served and adjacent surfaces. Maintain required workspace clearances and required clearances for equipment access doors and panels.
- B. Install individual wall-mounted switches with tops at uniform height unless otherwise indicated.
- C. Temporary Lifting Provisions: Remove temporary lifting of eyes, channels, and brackets and temporary blocking of moving parts from enclosures and components.
- D. Install fuses in fusible devices.
- E. Comply with NFPA 70 and NECA 1.

### **3.4 IDENTIFICATION**

- A. Comply with requirements in Section 260553 "Identification."
  - 1. Identify field-installed conductors, interconnecting wiring, and components; provide warning signs.
  - 2. Label each enclosure with engraved metal or laminated-plastic nameplate.

### **3.5 FIELD QUALITY CONTROL**

- A. Perform tests and inspections.
- B. Tests and Inspections for Switches:
  - 1. Visual and Mechanical Inspection:
    - a. Inspect physical and mechanical condition.
    - b. Inspect anchorage, alignment, grounding, and clearances.
    - c. Verify that unit is clean.
    - d. Verify blade alignment, blade penetration, travel stops, and mechanical operation.
    - e. Verify that fuse sizes and types match Specifications and Drawings.

- f. Verify that each fuse has adequate mechanical support and contact integrity.
    - g. Inspect bolted electrical connections for high resistance using one of 2 following methods:
      - 1) Use low-resistance ohmmeter. Compare bolted connection resistance values to values of similar connections. Investigate values that deviate from those of similar bolted connections by more than 50 percent of lowest value.
      - 2) Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method per manufacturer's published data or NETA ATS Table 100.12. Bolt-torque levels shall be per manufacturer's published data. In absence of manufacturer's published data, use NETA ATS Table 100.12.
    - h. Verify that operation and sequencing of interlocking systems is as described in Specifications and shown on Drawings.
    - i. Verify correct phase barrier installation.
    - j. Verify lubrication of moving current-carrying parts and moving and sliding surfaces.
  - 2. Electrical Tests:
    - a. Perform resistance measurements through bolted connections with low-resistance ohmmeter. Compare bolted connection resistance values to values of similar connections. Investigate values that deviate from adjacent poles or similar switches by more than 50 percent of lowest value.
    - b. Measure contact resistance across each switchblade fuse-holder. Drop values shall not exceed high level of manufacturer's published data. If manufacturer's published data are not available, investigate values that deviate from adjacent poles or similar switches by more than 50 percent of lowest value.
    - c. Perform insulation-resistance tests for one minute on each pole, phase-to-phase and phase-to-ground with switch closed, and across each open pole. Apply voltage per manufacturer's published data. In absence of manufacturer's published data, use Table 100.1 from NETA ATS. Investigate values of insulation resistance less than those published in Table 100.1 or as recommended in manufacturer's published data.
    - d. Measure fuse resistance. Investigate fuse-resistance values that deviate from each other by more than 15 percent.
    - e. Perform ground fault test per NETA ATS 7.14 "Ground Fault Protection Systems, Low-Voltage."
- C. Enclosed switches will be considered defective if they do not pass tests and inspections.
- D. Prepare test and inspection reports.
  - 1. Test procedures used.
  - 2. Include identification of each enclosed switch and circuit breaker tested and describe test results.
  - 3. List deficiencies detected, remedial action taken, and observations after remedial action.

**3.6 ADJUSTING**

- A. Adjust moving parts and operable components to function smoothly and lubricate as recommended by manufacturer.

**END OF SECTION**