

## **SECTION 26 05 33 – RACEWAYS AND BOXES**

### **PART 1 - GENERAL**

#### **1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### **1.2 SUMMARY**

- A. Section Includes:
  - 1. Metal conduits and fittings.
  - 2. Metal wireways and auxiliary gutters.
  - 3. Boxes, enclosures, and cabinets.
- B. Related Requirements:
  - 1. Section 078413 "Penetration Firestopping" for firestopping at conduit and box entrances.
  - 2. Section 260543 "Underground Ducts and Raceways" for exterior duct banks, manholes, and underground utility construction.

#### **1.3 DEFINITIONS**

- A. GRC: Galvanized rigid steel conduit.

#### **1.4 ACTION SUBMITTALS**

- A. Product Data: For wireways and fittings, hinged-cover enclosures, and cabinets.

#### **1.5 INFORMATIONAL SUBMITTALS**

- A. Source quality-control reports.

### **PART 2 - PRODUCTS**

#### **2.1 METAL CONDUITS AND FITTINGS**

- A. Metal Conduit:
  - 1. Listing and Labeling: Listed and labeled as defined in NFPA 70, by qualified testing agency, and marked for intended location and application.
  - 2. GRC: Comply with ANSI C80.1 and UL 6.
  - 3. EMT: Comply with ANSI C80.3 and UL 797.

4. FMC: Comply with UL 1; zinc-coated steel.
  5. LFMC: Flexible steel conduit with PVC jacket and complying with UL 360.
- B. Metal Fittings:
1. Comply with NEMA FB 1 and UL 514B.
  2. Listing and Labeling: Listed and labeled as defined in NFPA 70, by qualified testing agency, and marked for intended location and application.
  3. Fittings, General: Listed and labeled for type of conduit, location, and use.
  4. Fittings for EMT:
    - a. Material: Steel.
    - b. Type: Set-screw.
  5. Expansion Fittings: Steel, complying with UL 651, rated for environmental conditions where installed, and including flexible external bonding jumper.
- C. Joint Compound for GRC: Approved, as defined in NFPA 70, by authorities having jurisdiction for use in conduit assemblies, and compounded for use to lubricate and protect threaded conduit joints from corrosion and to enhance their conductivity.

## **2.2 METAL WIREWAYS AND AUXILIARY GUTTERS**

- A. Description: Sheet metal, complying with UL 870 and NEMA 250, Type 1 unless otherwise indicated or required, and sized per NFPA 70.
1. Metal wireways installed outdoors shall be listed and labeled as defined in NFPA 70, by qualified testing agency, and marked for intended location and application.
- B. Fittings and Accessories: Include covers, couplings, offsets, elbows, expansion joints, adapters, hold-down straps, end caps, and other fittings to match and mate with wireways as required for complete system.
- C. Wireway Covers: Hinged type unless otherwise indicated.
- D. Finish: Manufacturer's standard enamel finish.

## **2.3 BOXES, ENCLOSURES, AND CABINETS**

- A. General Requirements for Boxes, Enclosures, and Cabinets: Boxes, enclosures, and cabinets installed in wet locations shall be listed for use in wet locations.
- B. Sheet Metal Outlet and Device Boxes: Comply with NEMA OS 1 and UL 514A.
- C. Luminaire Outlet Boxes: Nonadjustable, designed for attachment of luminaire weighing 50 pounds. Outlet boxes designed for attachment of luminaires weighing more than 50 pounds shall be listed and marked for maximum allowable weight.
- D. Small Sheet Metal Pull and Junction Boxes: NEMA OS 1.

- E. Box extensions used to accommodate new building finishes shall be of same material as recessed box.
- F. Device Box Dimensions: 4 inches square by 2-1/8 inches deep or as required.
- G. Gangable boxes are prohibited.
- H. Hinged-Cover Enclosures: Comply with UL 50 and NEMA 250, Type 1 with continuous-hinge cover with flush latch unless otherwise indicated or required.
  - 1. Metal Enclosures: Steel, finished inside and out with manufacturer's standard enamel.
  - 2. Interior Panels: Steel; sides finished with manufacturer's standard enamel.
- I. Cabinets:
  - 1. NEMA 250, Type 1 galvanized-steel box with removable interior panel and removable front, finished inside and out with manufacturer's standard enamel.
  - 2. Hinged door in front cover with flush latch and concealed hinge.
  - 3. Key latch to match panelboards.
  - 4. Metal barriers to separate wiring of different systems and voltage.
  - 5. Accessory feet where required for freestanding equipment.

### **PART 3 - EXECUTION**

#### **3.1 RACEWAY APPLICATION**

- A. Outdoors: Apply raceway products as specified below unless otherwise indicated:
  - 1. Exposed Conduit: GRC.
  - 2. Concealed Conduit, Aboveground: GRC.
  - 3. Connection to Vibrating Equipment (Including Transformers and Hydraulic, Pneumatic, Electric Solenoid, or Motor-Driven Equipment): LFMC.
  - 4. Boxes and Enclosures, Aboveground: NEMA 250, Type 3R.
  - 5. Boxes and Enclosures, Aboveground at Jet Bridges: NEMA 250, Type 4X.
- B. Indoors: Apply raceway products as specified below unless otherwise indicated:
  - 1. Exposed: GRC.
  - 2. Concealed in Ceilings and Interior Walls and Partitions: EMT.
  - 3. Connection to Vibrating Equipment (Including Transformers and Hydraulic, Pneumatic, Electric Solenoid, or Motor-Driven Equipment): FMC, except use LFMC in damp or wet locations.
  - 4. Damp or Wet Locations: GRC.
  - 5. Boxes and Enclosures: NEMA 250, Type 1.
- C. Minimum Raceway Size: 3/4-inch trade size.

- D. Raceway Fittings: Compatible with raceways and suitable for use and location.
  - 1. Rigid Steel Conduit: Use threaded rigid steel conduit fittings unless otherwise indicated. Comply with NEMA FB 2.10.
  - 2. EMT: Use set-screw, steel fittings. Comply with NEMA FB 2.10.
  - 3. Flexible Conduit: Use only fittings listed for use with flexible conduit. Comply with NEMA FB 2.20.

### 3.2 INSTALLATION

- A. Comply with requirements in Section 260529 "Hangers and Supports" for hangers and supports.
- B. Comply with NECA 1 and NECA 101 for installation requirements except where requirements on Drawings or in this article are stricter. Comply with NFPA 70 limitations for types of raceways allowed in specific occupancies and number of floors.
- C. Do not fasten conduits onto bottom side of metal deck roof.
- D. Keep raceways at least 6 inches away from parallel runs of flues and steam or hot-water pipes. Install horizontal raceway runs above water and steam piping.
- E. Complete raceway installation before starting conductor installation.
- F. Arrange stub-ups so curved portions of bends are not visible above finished slab.
- G. Install no more than equivalent of three 90-degree bends in conduit run except for control wiring conduits, for which fewer bends are allowed. Support within 12 inches of changes in direction.
- H. Make bends in raceway using large-radius preformed ells. Field bending shall be per NFPA 70 minimum radii requirements. Use only equipment specifically designed for material and size involved.
- I. Conceal conduit within finished walls, ceilings, and floors unless otherwise indicated. Install conduits parallel or perpendicular to building lines.
- J. Support conduit within 12 inches of enclosures to which attached.
- K. Raceways Embedded in Slabs:
  - 1. Run conduit larger than one-inch trade size, parallel or at right angles to main reinforcement. Where at right angles to reinforcement, place conduit close to slab support. Secure raceways to reinforcement at maximum 10-foot intervals.
  - 2. Arrange raceways to cross building expansion joints at right angles with expansion fittings.
  - 3. Arrange raceways to keep minimum of one inch of concrete cover in all directions.
  - 4. Do not embed threadless fittings in concrete unless specifically approved for each specific location.
- L. Stub-Ups to Above Recessed Ceilings:

1. Use EMT or RMC for raceways.
  2. Use conduit bushing or insulated fitting to terminate stub-ups not terminated in hubs or in enclosure.
- M. Threaded Conduit Joints, Exposed to Wet, Damp, Corrosive, or Outdoor Conditions: Apply listed compound to threads of raceway and fittings before making up joints. Follow compound manufacturer's written instructions.
- N. Coat field-cut threads on PVC-coated raceway with corrosion-preventing conductive compound before assembly.
- O. Raceway Terminations at Locations Subject to Moisture or Vibration: Use insulating bushings to protect conductors including conductors smaller than 4 AWG.
- P. Terminate threaded conduits into threaded hubs or with locknuts on inside and outside of boxes or cabinets. Install bushings on conduits up to 1-1/4-inch trade size and insulated throat metal bushings on 1-1/2-inch trade size and larger conduits terminated with locknuts. Install insulated throat metal grounding bushings on service conduits.
- Q. Install raceways square to enclosure and terminate at enclosures with locknuts. Install locknuts hand tight plus 1/4 turn more.
- R. Do not rely on locknuts to penetrate nonconductive coatings on enclosures. Remove coatings in locknut area before assembling conduit to enclosure to assure continuous ground path.
- S. Cut conduit perpendicular to length. For conduits 2-inch trade size and larger, use roll cutter or guide to make cut straight and perpendicular to length.
- T. Install pull wires in empty raceways. Use polypropylene or monofilament plastic line with not less than 200-pound tensile strength. Leave at least 12 inches of slack at each end of pull wire. Cap underground raceways designated as spare above grade alongside raceways in use.
- U. Install raceway sealing fittings at accessible locations per NFPA 70 and fill them with listed sealing compound. For concealed raceways, install each fitting in flush steel box with blank cover plate having finish like that of adjacent plates or surfaces. Install raceway sealing fittings per NFPA 70.
- V. Install devices to seal raceway interiors at accessible locations. Locate seals so no fittings or boxes are between seal and following changes of environments. Seal interior of raceways at following points.
1. Where underground service raceway enters building or structure.
  2. Conduit extending from interior to exterior of building.
  3. Where otherwise required by NFPA 70.
- W. Comply with manufacturer's written instructions for solvent welding RNC and fittings.
- X. Expansion-Joint Fittings:
1. Install in each run of aboveground RMC and EMT conduit that is located where environmental temperature change may exceed 100 degrees F and that has straight-run length that exceeds 100 feet.

2. Install type and quantity of fittings that accommodate temperature change listed for each of following locations:
    - a. Outdoor Locations Not Exposed to Direct Sunlight: 125 degrees F temperature change.
    - b. Outdoor Locations Exposed to Direct Sunlight: 155 degrees F temperature change.
    - c. Indoor Spaces Connected with Outdoors without Physical Separation: 125 degrees F temperature change.
  3. Install fitting(s) that provide expansion and contraction for at least 0.000078 inch per foot of length of straight run per degree F of temperature change for metal conduits.
  4. Install expansion fittings at locations where conduits cross building or structure expansion joints.
  5. Install each expansion-joint fitting with position, mounting, and piston setting selected per manufacturer's written instructions for conditions at specific location at time of installation. Install conduit supports to allow for expansion movement.
- Y. Flexible Conduit Connections: Comply with NEMA RV 3. Use maximum of 72 inches of flexible conduit for recessed and semi-recessed luminaires, equipment subject to vibration, noise transmission, or movement; and for transformers and motors.
1. Use LFMC in damp or wet locations subject to severe physical damage.
  2. Use LFMC in damp or wet locations not subject to severe physical damage.
- Z. Mount boxes at heights indicated on Drawings. If mounting heights of boxes are not individually indicated, give priority to ADA and Texas Accessibility Standards requirements. Install boxes with height measured to center of box unless otherwise indicated.
- AA. Recessed Boxes in Masonry Walls: Saw-cut opening for box in center of cell of masonry block, and install box flush with surface of wall. Prepare block surfaces to provide flat surface for raintight connection between box and cover plate or supported equipment and box.
- BB. Horizontally separate boxes mounted on opposite sides of walls so they are not in same vertical channel.
- CC. Locate boxes so that cover or plate will not span different building finishes.
- DD. Support boxes of 3 gangs or more from more than one side by spanning 2 framing members or mounting on brackets specifically designed for purpose.
- EE. Fasten junction and pull boxes to or support from building structure. Do not support boxes by conduits.

### **3.3 SLEEVE AND SLEEVE-SEAL INSTALLATION FOR ELECTRICAL PENETRATIONS**

- A. Install sleeves and sleeve seals at penetrations of exterior floor and wall assemblies. Comply with requirements in Section 260544 "Sleeves and Sleeve Seals for Raceways and Cabling."

### **3.4 FIRESTOPPING**

- A. Install firestopping at penetrations of fire-rated floor and wall assemblies. Comply with requirements in Section 078413 "Penetration Firestopping."

### **3.5 PROTECTION**

- A. Protect coatings, finishes, and cabinets from damage and deterioration.
  - 1. Repair damage to galvanized finishes with zinc-rich paint recommended by manufacturer.
  - 2. Repair damage to paint finishes with matching touchup coating recommended by manufacturer.

**END OF SECTION**