

## **SECTION 22 05 33 - HEAT TRACING FOR PLUMBING PIPING**

### **PART 1 - GENERAL**

#### **1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### **1.2 SUMMARY**

- A. Section includes plumbing piping heat tracing for freeze prevention and grease waste temperature maintenance with the following electric heating cables:
  - 1. Self-regulating, parallel resistance.

#### **1.3 ACTION SUBMITTALS**

- A. Product Data: For each type of product.
  - 1. Include rated capacities, operating characteristics, and furnished specialties and accessories.
  - 2. Schedule heating capacity, length of cable, spacing, and electrical power requirement for each electric heating cable required.
- B. Shop Drawings: For electric heating cable.
  - 1. Include plans, elevations, sections, and attachment details.
  - 2. Include diagrams for power, signal, and control wiring.

#### **1.4 CLOSEOUT SUBMITTALS**

- A. Operation and Maintenance Data: For electric heating cables to include in operation and maintenance manuals.

#### **1.5 WARRANTY**

- A. Special Warranty: Manufacturer agrees to repair or replace electric heating cable that fails in materials or workmanship within specified warranty period.
  - 1. Period: 10 years from date of Substantial Completion.

### **PART 2 - PRODUCTS**

#### **2.1 SELF-REGULATING, PARALLEL-RESISTANCE HEATING CABLES**

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work are limited to, the following:

1. Basis-of-Design Product: Subject to compliance with requirements, provide Raychem XL; a brand of Tyco Thermal Controls LLC. or comparable product by one of the following:
  2. BriskHeat.
  3. Chromalox.
  4. Delta-Therm Corporation.
  5. Easy Heat; a division of EGS Electrical Group LLC.
  6. Nelson Heat Trace; a division of EGS Electrical Group LLC.
  7. Thermon Americas Inc.
  8. Trasor Corp.
- B. Comply with IEEE 515.1.
- C. Maximum Operating Temperature (Power On): 150 deg F.
- D. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- E. Capacities and Characteristics (Freeze Protection): 277V/1 Phase, with integral ground fault protection.
- F. Capacities and Characteristics (Grease Waste Maintenance): 277V/1 Phase, with integral ground fault protection.
- G. Furnish with integral ground fault protection.

## **2.2 CONTROLS**

- A. Pipe-Mounted Thermostats for Freeze Protection:
1. Remote bulb unit with adjustable temperature range from 30 to 50 deg F.
  2. Snap action; open-on-rise, single-pole switch with minimum current rating adequate for connected cable.
  3. Remote bulb on capillary, resistance temperature device, or thermistor for directly sensing pipe-wall temperature.
  4. Corrosion-resistant, waterproof control enclosure.
- B. Programmable Timer for Grease Waste Temperature Maintenance:
1. Microprocessor based.
  2. Minimum of four separate schedules.
  3. Minimum 24-hour battery carryover.
  4. On-off-auto switch.
  5. 365-day calendar with 20 programmable holidays.
  6. Relays with contacts to indicate operational status, on or off, and for interface to building automation system and capable of providing on-off status.

## **2.3 ACCESSORIES**

- A. Cable Installation Accessories: Fiberglass tape, heat-conductive putty, cable ties, silicone end seals and splice kits, and installation clips all furnished by manufacturer, or as recommended in writing by manufacturer.
- B. Warning Labels: Refer to Section 220553 "Identification for Plumbing Piping and Equipment."
- C. Warning Tape: Continuously printed "Electrical Tracing"; vinyl, at least 3 mils (0.08 mm) thick, and with pressure-sensitive, permanent, waterproof, self-adhesive back.
  - 1. Width for Markers on Pipes with OD, Including Insulation, Less Than 6 Inches: 3/4 inch minimum.
  - 2. Width for Markers on Pipes with OD, Including Insulation, 6 Inches or Larger: 1-1/2 inches minimum.

## **PART 3 - EXECUTION**

### **3.1 EXAMINATION**

- A. Examine surfaces and substrates to receive electric heating cables for compliance with requirements for installation tolerances and other conditions affecting performance.
  - 1. Ensure surfaces, pipes, and basins in contact with electric heating cables are free of burrs and sharp protrusions.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

### **3.2 APPLICATIONS**

- A. Install the following types of electric heating cable for the applications described:
  - 1. Temperature Maintenance for Grease Waste: Self-regulating, parallel-resistance heating cable.
  - 2. Freeze Protection: Self-regulating, parallel-resistance heating cable.

### **3.3 INSTALLATION**

- A. Install electric heating cable across expansion, construction, and control joints according to manufacturer's written instructions; use cable-protection conduit and slack cable to allow movement without damage to cable.
- B. Electric Heating-Cable Installation for Freeze Protection for Piping:
  - 1. Install electric heating cables after piping has been tested and before insulation is installed.
  - 2. Install electric heating cables according to IEEE 515.1.
  - 3. Install insulation over piping with electric cables according to Section 220700 "Plumbing Insulation."
  - 4. Install warning tape on piping insulation where piping is equipped with electric heating cables.

- C. Electric Heating-Cable Installation for Temperature Maintenance for Grease Waste:
  - 1. Install electric heating cables after piping and basins have been tested and before insulation is installed.
  - 2. Install insulation over piping and basins with electric heating cables according to Section 220700 "Plumbing Insulation."
  - 3. Install warning tape on piping and basin insulation where equipped with electric heating cables.
- D. Set field-adjustable switches and circuit-breaker trip ranges.

### **3.4 CONNECTIONS**

- A. Ground equipment according to Section 260526 "Grounding and Bonding for Electrical Systems."
- B. Connect wiring according to Section 260519 "Low-Voltage Electrical Power Conductors and Cables."

### **3.5 FIELD QUALITY CONTROL**

- A. Testing Agency: Owner will engage a qualified testing agency to perform tests and inspections.
- B. Manufacturer's Field Service: Engage a factory-authorized service representative to test and inspect components, assemblies, and equipment installations, including connections.
- C. Perform the following tests and inspections:
  - 1. Perform tests after cable installation but before application of coverings such as insulation, wall or ceiling construction, or concrete.
  - 2. Test cables for electrical continuity and insulation integrity before energizing.
  - 3. Test cables to verify rating and power input. Energize and measure voltage and current simultaneously.
- D. Repeat tests for continuity, insulation resistance, and input power after applying thermal insulation on pipe-mounted cables.
- E. Cables will be considered defective if they do not pass tests and inspections.
- F. Prepare test and inspection reports.

### **3.6 PROTECTION**

- A. Protect installed heating cables, including non-heating leads, from damage during construction.
- B. Remove and replace damaged heat-tracing cables.

### **END OF SECTION**