

SECTION 26 51 19 - LED INTERIOR LIGHTING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Interior solid-state luminaires that are designed for and exclusively use LED technology.
 - 2. Luminaire supports.
- B. Related Requirements:
 - 1. Section 260923 "Lighting Control Devices" for automatic control of lighting, including time switches, photoelectric relays, and contactors.
 - 2. Section 095113 "Decorative Interior Metal Ceiling Panels" for backlighting ceiling system.

1.3 DEFINITIONS

- A. CCT: Correlated color temperature.
- B. CRI: Color Rendering Index.
- C. Fixture: See "Luminaire."
- D. IP: International Protection or Ingress Protection Rating.
- E. LED: Light-emitting diode.
- F. Lumen: Measured output of luminaire.
- G. Luminaire: Complete lighting unit, including LED PCB, reflector, and housing.
- H. PCB: Printed Circuit Board.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product.
 - 1. Arrange in order of luminaire designation.
 - 2. Include data on features, accessories, and finishes.
 - 3. Include physical description and dimensions of luminaires.
 - 4. Luminaire output data, include life, output (lumens, CCT, and CRI), and energy-efficiency data.
 - 5. Photometric data and adjustment factors based on laboratory tests, complying with IES "Lighting Measurements Testing and Calculation Guides" for each luminaire type. The

adjustment factors shall be for lamps and accessories identical to those indicated for the luminaire as applied in this Project.

- a. Manufacturers' Certified Data: Photometric data certified by manufacturer's laboratory with a current accreditation under the National Voluntary Laboratory Accreditation Program for Energy Efficient Lighting Products.
- b. Testing Agency Certified Data: For indicated luminaires, photometric data certified by a qualified independent testing agency. Photometric data for remaining luminaires shall be certified by manufacturer.

B. Shop Drawings: For nonstandard or custom luminaires.

- 1. Include plans, elevations, sections, and mounting and attachment details.
- 2. Include details of luminaire assemblies. Indicate dimensions, weights, loads, required clearances, method of field assembly, components, and location and size of each field connection.
- 3. Include diagrams for power, signal, and control wiring.

C. Sustainable Design Documentation: Submit manufacturer's product data on lamp mercury content and rated lamp life, showing compliance with specified requirements.

- 1. Include DOE "Lighting Facts" information
- 2. Include DLC listing status
- 3. Include Efficacy information

D. Product Schedule: For luminaires and lamps. Use same designations indicated on Drawings.

E. Product Schedule: For luminaires. Use same designations indicated on Drawings.

1.5 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For testing laboratory providing photometric data for luminaires.
- B. Product Certificates: For each type of luminaire.
- C. Product Test Reports: For each type of luminaire, for tests performed by manufacturer and witnessed by a qualified testing agency.
- D. Sample warranty.

1.6 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For luminaires and lighting systems to include in operation and maintenance manuals.
 - 1. Provide cutsheets for all fixtures, including information on replacement parts.
 - 2. Provide a list of all luminaire types used on Project; use ANSI and manufacturers' codes.

1.7 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.

1. Diffusers and Lenses: One for every 50 of each type and rating installed. Furnish at least one of each type.
2. Drivers: One for every 100 of each type and rating installed. Furnish at least one of each type.
3. Globes and Guards: One for every 20 of each type and rating installed. Furnish at least one of each type.

1.8 QUALITY ASSURANCE

- A. Luminaire Photometric Data Testing Laboratory Qualifications: Luminaire manufacturer's laboratory that is accredited under the NVLAP for Energy Efficient Lighting Products, or provided by an independent agency, with the experience and capability to conduct the testing indicated, that is an NRTL as defined by OSHA in 29 CFR 1910.7, accredited under the NVLAP for Energy Efficient Lighting Products, and complying with the applicable IES testing standards.
- B. Provide luminaires from a single manufacturer for each luminaire type. Refer to fixture schedule for exact model numbers and specified luminaires. Substitutions will not be accepted.
- C. Each luminaire type shall be binned within a three-step (two-step, where deemed critical) MacAdam Ellipse to ensure color consistency among luminaires.
- D. Mockups: For interior luminaires in room or module mockups, complete with power and control connections.
 1. Obtain Architect's approval of luminaires in mockups before starting installations.
 2. Maintain mockups during construction in an undisturbed condition as a standard for judging the completed Work.
 3. Approval of mockups does not constitute approval of deviations from the Contract Documents contained in mockups unless Architect specifically approves such deviations in writing.
 4. Subject to compliance with requirements, approved mockups may become part of the completed Work if undisturbed at time of Substantial Completion.

1.9 COORDINATION

- A. Coordinate layout and installation of lighting fixtures and suspension system with other construction that penetrates ceilings or is supported by them, including HVAC equipment, fire-suppression system, and partition assemblies.
- B. Fixture locations as indicated on the electrical drawings are generalized and approximate. Carefully verify locations with Architect's plans, reflected ceiling plans and other reference data prior to installation. Check for adequacy of headroom and non-interference with other equipment, such as ducts, pipes or openings. Bring conflicts to the Architect's attention before proceeding with the work.
- C. Schedule the Work to prevent Work of this Section being damaged by other construction operations. Remove and replace Work so damaged at no cost to Owner.
- D. Where Work of this Section is to be flush or concealed, install it to assure that it does not project beyond the finished lines of floors, ceilings or walls.
- E. Verify ceiling system and furnish appropriate luminaire mounting accessories and trim needed for each fixture based on the ceiling type. Bring non-standard modifications necessary to comply

with the Contract Documents and construction conflicts to the Architect's attention before proceeding with Work.

- F. Verify mounting conditions for all fixtures, and furnish appropriate mounting details including hangers, trim sets and other hardware as necessary to assure complete and Code compliant installation. Such mounting details shall be approved by Architect.
- G. Coordinate locations of lighting fixtures and their supports with other Trades.
- H. Catalog numbers might not reflect all necessary accessories and options. Provide all necessary accessories referenced, indicated or as-needed based on the review of architectural RCPs, interior elevations and actual field conditions for a complete and Code compliant installation.
- I. Contractor shall verify each fixture type for all specific options as required for installation.

1.10 DELIVERY, STORAGE, AND HANDLING

- A. Protect finishes of exposed surfaces by applying a strippable, temporary protective covering before shipping.

1.11 WARRANTY

- A. Warranty: Manufacturer and Installer agree to repair or replace components of luminaires that fail in materials or workmanship within specified warranty period.
- B. Warranty Period: Five years from date of Substantial Completion.
- C. Coverage: warranty shall cover LEDs, drivers, and color shift over time.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Ambient Temperature: 5 to 110 deg F.
 - 1. Relative Humidity: Zero to 95 percent.

2.2 LUMINAIRE REQUIREMENTS

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. Recessed luminaires shall comply with NEMA LE 4.
- C. NRTL Compliance: Luminaires for hazardous locations shall be listed and labeled for indicated class and division of hazard by an NRTL.
- D. FM Global Compliance: Luminaires for hazardous locations shall be listed and labeled for indicated class and division of hazard by FM Global.

2.3 LUMINAIRE SPECIFIC REQUIREMENTS

- A. Refer to completed fixture schedule on Drawings for the following information:

1. Approved manufacturer (no substitutions accepted)
 2. Catalog number or product series
 3. Operating Voltage
 4. Lamping information
 5. CCT required
 6. Minimum CRI
 7. Finish.
 8. UL Listing requirements for damp locations, wet locations, hazardous locations, or others.
 9. Housing IP rating requirements, beyond IP20
- B. Dimming luminaires shall operate from 100% to 1% light output.
- C. Drivers shall be integral, unless noted otherwise in the fixture schedule.
1. Drivers shall be compatible with selected advanced digital lighting control system.
- D. Heat sinks shall be integral, and not visible as part of the final installation.
- E. LEDs and drivers shall have a minimum rate life of 70,000 hours.
- F. Provide with integral mounting provisions or universal mounting bracket.
- G. Provide with integral junction box with conduit fittings.
- H. All luminaires shall be UL listed.
- I. Refer to Architecture drawings and specifications for Arktura ceiling panel system with integral lighting for product number and layout.

2.4 LEED REQUIREMENTS

- A. Meet at least 1 of the following 4 requirements, per LEED Credit IEQ Interior Lighting:
1. Glare Control
For all regularly occupied spaces, meet one of the following requirements:
 - a. Use light fixtures with a luminance of less than 7,000 candela per square meter (cd/m)² between 45 and 90 degrees from nadir, OR
 - b. Achieve a Unified Glare Rating (UGR) rating of <19 using software modelling calculations of the designed lighting.

Exceptions include wallwash fixtures properly aimed at walls, as specified by manufacturer's data, indirect uplighting fixtures, provided there is no view down into these uplights from a regularly occupied space above, and any other specific applications (i.e. adjustable fixtures).
 2. Color Rendering
For all regularly occupied spaces meet one of the following requirements:
 - a. Use light sources that have a Color rendering Index (CRI) of at least 90.
 - b. Use light sources that have a Color Fidelity Index greater than or equal to 78 and a gamut index between 97 and 110, determined in accordance with Illuminating Engineering Society (IES) TM-30.
 3. Lighting Control

- a. Provide dimmable or multilevel lighting for 90% of all regularly occupied spaces.
- 4. Surface Reflectivity
 - a. For at least 90% regularly occupied spaces, use interior finishes with a surface reflectance greater or equal to 80% for ceilings and 55% for walls. If included in the project scope, use furniture finishes with a surface reflectance greater or equal to 45% for work surfaces and 50% for movable partitions.

2.5 MATERIALS

A. Metal Parts:

- 1. Free of burrs and sharp corners and edges.
- 2. Sheet metal components shall be steel unless otherwise indicated.
- 3. Form and support to prevent warping and sagging.

B. Steel:

- 1. ASTM A36/A36M for carbon structural steel.
- 2. ASTM A568/A568M for sheet steel.

C. Stainless Steel:

- 1. Manufacturer's standard grade.

D. Galvanized Steel: ASTM A653/A653M.

E. Aluminum: ASTM B209.

F. Doors, Frames, and Other Internal Access: Smooth operating, free of light leakage under operating conditions, and designed to permit maintenance without use of tools. Designed to prevent doors, frames, lenses, diffusers, and other components from falling accidentally during maintenance and when secured in operating position.

G. Diffusers and Globes:

- 1. Materials as indicated in fixture schedule
- 2. Acrylic Diffusers: One hundred percent virgin acrylic plastic, with high resistance to yellowing and other changes due to aging, exposure to heat, and UV radiation.
- 3. Glass: Annealed crystal glass unless otherwise indicated.
- 4. Lens Thickness: At least 0.125-inch (3.175-mm) minimum unless otherwise indicated.

2.6 METAL FINISHES

- A. Variations in finishes are unacceptable in the same piece. Variations in finishes of adjoining components are acceptable if they are within the range of approved Samples and if they can be and are assembled or installed to minimize contrast.

2.7 LUMINAIRE SUPPORT

- A. Comply with requirements in Section 260529 "Hangers and Supports for Electrical Systems" for channel and angle iron supports and nonmetallic channel and angle supports.

- B. Single-Stem Hangers: 1/2-inch (13-mm) steel tubing with swivel ball fittings and ceiling canopy. Finish same as luminaire.
- C. Wires: ASTM A641/A641M, Class 3, soft temper, zinc-coated steel, 12 gage (2.68 mm).
- D. Rod Hangers: 3/16-inch (5-mm) minimum diameter, cadmium-plated, threaded steel rod.
- E. Hook Hangers: Integrated assembly matched to luminaire, line voltage, and equipment with threaded attachment, cord, and locking-type plug.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.
- B. Examine roughing-in for luminaire to verify actual locations of luminaire and electrical connections before luminaire installation.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 TEMPORARY LIGHTING

- A. If approved by the Architect, use selected permanent luminaires for temporary lighting. When construction is sufficiently complete, clean luminaires used for temporary lighting.

3.3 INSTALLATION

- A. Comply with NECA 1.
- B. Install luminaires level, plumb, and square with ceilings and walls unless otherwise indicated.
- C. Install recessed luminaires with extra wire length. Wires shall be long enough to pull all internal devices, modules and drivers through the aperture.
 - 1. Comply with NEC requirements.
- D. Supports:
 - 1. Sized and rated for luminaire weight.
 - 2. Able to maintain luminaire position after cleaning and maintenance.
 - 3. Provide support for luminaire without causing deflection of ceiling or wall.
 - 4. Luminaire-mounting devices shall be capable of supporting a horizontal force of 100 percent of luminaire weight and a vertical force of 400 percent of luminaire weight.
- E. Flush-Mounted Luminaires:
 - 1. Secured to outlet box.
 - 2. Attached to ceiling structural members at four points equally spaced around circumference of luminaire.

3. Trim ring flush with finished surface.

F. Wall-Mounted Luminaires:

1. Attached to structural members in walls or attached to a minimum 20 gauge backing plate attached to wall structural members behind decorative finish.
2. Do not attach luminaires directly to gypsum board.

G. Suspended Luminaires:

1. Ceiling Mount:

- a. Pendant mount with two 5/32-inch- (4-mm-) diameter aircraft cable supports adjustable to 10 feet (3 m) in length.
2. Pendants and Rods: Where longer than 48 inches (1200 mm), brace to limit swinging.
3. Stem-Mounted, Single-Unit Luminaires: Suspend with twin-stem hangers. Support with approved outlet box and accessories that hold stem and provide damping of luminaire oscillations. Support outlet box vertically to building structure using approved devices.
4. Continuous Rows of Luminaires: Use tubing or stem for wiring at one point and tubing or rod for suspension for each unit length of luminaire chassis, including one at each end.
5. Do not use ceiling grid as support for pendant luminaires. Connect support wires or rods to building structure.

H. Ceiling-Grid-Mounted Luminaires:

1. Secure to any required outlet box.
2. Secure luminaire to the luminaire opening using approved fasteners in a minimum of four locations, spaced near corners of luminaire.
3. Use approved devices and support components to connect luminaire to ceiling grid and building structure in a minimum of four locations, spaced near corners of luminaire.
4. Outlet boxes for recessed lighting fixtures shall be installed with maximum 6ft of flexible conduit from fixture to outlet box.

- I. All luminaires shall be supported from building structure. No luminaire shall be supported from ducts, piping, or their support systems. Brace suspended luminaires installed near ducts or other constructions with solid pendants or threaded rods.

- J. Comply with requirements in Section 260519 "Low-Voltage Electrical Power Conductors and Cables" for wiring connections.

3.4 IDENTIFICATION

- A. Identify system components, wiring, cabling, and terminals. Comply with requirements for identification specified in Section 260553 "Identification for Electrical Systems."
- B. Identify with self-adhesive tag on each fixture the panel and circuit number for the branch circuit serving the light fixture.

3.5 FIELD QUALITY CONTROL

- A. Perform the following tests and inspections:

1. Operational Test: After installing luminaires, switches, and accessories, and after electrical circuitry has been energized, test units to confirm proper operation.
 2. Test for Emergency Lighting: Interrupt power supply to demonstrate proper operation. Verify transfer from normal power to battery power and retransfer to normal.
- B. Luminaire will be considered defective if it does not pass operation tests and inspections.
- C. Prepare test and inspection reports.

3.6 ADJUSTING

- A. Occupancy Adjustments: When requested within 12 months of date of Substantial Completion, provide on-site assistance in adjusting the direction of aim of luminaires to suit occupied conditions. Some of this work may be required during hours of darkness.
1. During adjustment visits, inspect all luminaires. Replace luminaires that are defective.
 2. Parts and supplies shall be manufacturer's authorized replacement parts and supplies.
 3. Adjust the aim of luminaires in the presence of the Architect.

END OF SECTION