

## **SECTION 22 13 19 - SANITARY WASTE PIPING SPECIALTIES**

### **PART 1 - GENERAL**

#### **1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### **1.2 SUMMARY**

- A. Section Includes:
  - 1. Cleanouts.
  - 2. Floor drains.
  - 3. Through-penetration firestop assemblies.
  - 4. Miscellaneous sanitary drainage piping specialties.

#### **1.3 DEFINITIONS**

- A. ABS: Acrylonitrile-butadiene-styrene plastic.
- B. FOG: Fats, oils, and greases.
- C. FRP: Fiberglass-reinforced plastic.
- D. HDPE: High-density polyethylene plastic.
- E. PE: Polyethylene plastic.
- F. PP: Polypropylene plastic.
- G. PVC: Polyvinyl chloride plastic.

#### **1.4 INFORMATIONAL SUBMITTALS**

- A. Field quality-control test reports.

#### **1.5 CLOSEOUT SUBMITTALS**

- A. Operation and Maintenance Data: For drainage piping specialties to include in emergency, operation, and maintenance manuals.

#### **1.6 QUALITY ASSURANCE**

- A. Drainage piping specialties shall bear label, stamp, or other markings of specified testing agency.

- B. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- C. Comply with NSF 14, "Plastics Piping Components and Related Materials," for plastic sanitary piping specialty components.

## 1.7 COORDINATION

- A. Coordinate size and location of concrete bases. Cast anchor-bolt inserts into bases.
- B. Coordinate size and location of roof penetrations.

## PART 2 - PRODUCTS

### 2.1 CLEANOUTS

- A. Exposed Metal Cleanouts:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Josam Company; Josam Div.
    - b. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.
    - c. Tyler Pipe; Wade Div.
    - d. Zurn Plumbing Products Group; Specification Drainage Operation.
    - e. Watts
  - 2. Standard: ASME A112.36.2M for cast iron for cleanout test tee.
  - 3. Size: Same as connected drainage piping
  - 4. Body Material: as required to match connected piping.
  - 5. Closure: Countersunk or raised-head, brass plug.
  - 6. Closure Plug Size: Same as or not more than one size smaller than cleanout size.
  - 7. Closure: Stainless-steel plug with seal.
- B. Metal Floor Cleanouts:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Josam Company; Josam Div.
    - b. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.
    - c. Tyler Pipe; Wade Div.
    - d. Zurn Plumbing Products Group; Specification Drainage Operation.
    - e. Watts
  - 2. Standard: ASME A112.36.2M for adjustable housing cleanout.
  - 3. Size: Same as connected branch.

4. Type: Adjustable housing.
5. Body or Ferrule: Cast iron.
6. Clamping Device: Required.
7. Outlet Connection: Inside calk.
8. Closure: Brass plug with straight threads and gasket.
9. Adjustable Housing Material: Cast iron with threads.
10. Frame and Cover Material and Finish: Nickel-bronze, copper alloy.
11. Frame and Cover Shape: Round.
12. Top Loading Classification: Heavy Duty.
13. Riser: ASTM A 74, Service class, cast-iron drainage pipe fitting and riser to cleanout.
14. Standard: ASME A112.3.1.
15. Size: Same as connected branch.
16. Housing: Stainless steel.
17. Closure: Stainless steel with seal.
18. Riser: Stainless-steel drainage pipe fitting to cleanout.

C. Cast-Iron Wall Cleanouts:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Josam Company; Josam Div.
  - b. Smith, Jay R. Mfg. Co.; d of Smith Industries, Inc.
  - c. Tyler Pipe; Wade Div.
  - d. Zurn Plumbing Products Group; Specification Drainage Operation.
  - e. Watts
2. Standard: ASME A112.36.2M. Include wall access.
3. Size: Same as connected drainage piping.
4. Body: Hubless, cast-iron soil pipe test tee as required to match connected piping.
5. Closure: Countersunk or raised-head, brass plug.
6. Closure Plug Size: Same as or not more than one size smaller than cleanout size.
7. Wall Access: Round, flat, chrome-plated brass or stainless-steel cover plate with screw.
8. Wall Access: Square, nickel-bronze, copper-alloy, or stainless-steel wall-installation frame and cover.

## 2.2 FLOOR DRAINS

A. Cast-Iron Floor Drains:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Josam Company; Josam Div.

- b. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.
  - c. Tyler Pipe; Wade Div.
  - d. Zurn Plumbing Products Group; Specification Drainage Operation.
  - e. Watts
- 2. Standard: ASME A112.6.3.
  - 3. Pattern: Floor drain.
  - 4. Body Material: Gray iron.
  - 5. Seepage Flange: Required.
  - 6. Anchor Flange: Required.
  - 7. Clamping Device: Required.
  - 8. Outlet: Bottom.
  - 9. Top or Strainer Material: Nickel bronze.
  - 10. Top of Body and Strainer Finish: Nickel bronze.
  - 11. Top Shape: Round.
  - 12. Trap Primer Connection: Required unless in Electrical Vault. In that case use waterless trap protection.

## **2.3 FLOOR DRAINS (MECHANICAL ROOMS)**

### **A. Floor Drains:**

- 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Josam Company; Josam Div.
  - b. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.
  - c. Tyler Pipe; Wade Div.
  - d. Zurn Plumbing Products Group; Specification Drainage Operation.
  - e. Watts.
- 2. Standard: ASME A112.6.3.
- 3. Material: Ductile or gray iron.
- 4. Flange: Anchor.
- 5. Clamping Device: Required.
- 6. Outlet: Bottom.
- 7. Grate Material: Ductile iron.
- 8. Trap Primer Connection: Required.
- 9. Sediment Bucket: Required.

## **2.4 STAINLESS STEEL FLOOR DRAINS (YELLOW GREASE ROOM)**

### **A. Floor Drains:**

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Josam Company; Josam Div.
  - b. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.
  - c. Tyler Pipe; Wade Div.
  - d. Zurn Plumbing Products Group; Specification Drainage Operation
  - e. StainlessDrains.com.
  - f. Watts
2. Standard: ASME A112.3.1 – 2007.
3. Material: 12 gauge, 304 Stainless Steel.
4. Flange: Anchor.
5. Clamping Device: Required.
6. Outlet: Bottom. heavy duty, adjustable
7. Grate Material: 304 Stainless Steel.
8. Trap Primer Connection: Required.
9. Round top, staggered pattern, heavy duty.

## **2.5 FLUSHING RIM FLOOR DRAINS**

### **A. Floor Drains:**

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following (See fixture schedule for further information):
  - a. Josam Company; Josam Div.
  - b. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.
  - c. Tyler Pipe; Wade Div.
  - d. Zurn Plumbing Products Group; Specification Drainage Operation.
  - e. Mifab
  - f. Watts
2. Standard: ASME A112.6.3.
3. Material: Ductile or gray iron.
4. Flange: Anchor.
5. Clamping Device: Required.
6. Outlet: Bottom.
7. Grate Material: Ductile iron.
8. Rim and P-trap Flushing Connections: Required.

## **2.6 FLOOR SINKS (MECHANICAL ROOMS)**

### **A. Cast-Iron Floor Drains:**

1. Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work are the following:
  - a. Josam Company; Josam Div.
  - b. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.
  - c. Tyler Pipe; Wade Div.
  - d. Zurn Plumbing Products Group; Specification Drainage Operation.
  - e. Watts
2. Standard: ASME A112.6.3.
3. Pattern: Floordrain.
4. Body Material: enameled cast iron
5. Seepage Flange: Required.
6. Anchor Flange: Required.
7. Clamping Device: Required.
8. Outlet: Bottom
9. Coating on Interior and Exposed Exterior Surfaces: Acid-resistant enamel.
10. Sediment Bucket: Required.
11. Top or Strainer Material: Stainless steel.
12. Top Shape: Square.
13. Top Loading Classification: Heavy
14. Trap Material: Cast iron.
15. Trap Pattern: Deep-seal P-trap
16. Trap Features: Trap-seal primer valve drain connection

## **2.7 THROUGH-PENETRATION FIRESTOP ASSEMBLIES**

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. ProSet Systems Inc.
2. Standard: UL 1479 assembly of sleeve and stack fitting with firestopping plug.
3. Size: Same as connected soil, waste, or vent stack.
4. Sleeve: Molded PVC plastic, of length to match slab thickness and with integral nailing flange on one end for installation in cast-in-place concrete slabs.
5. Stack Fitting: ASTM A 48/A 48M, gray-iron, hubless-pattern, wye branch with neoprene O-ring at base and gray-iron plug in thermal-release harness. Include PVC protective cap for plug.
6. Special Coating: Corrosion resistant on interior of fittings.

## **2.8 WATERLESS TRAP PROTECTION**

- A. P-trap protection without requiring water connection:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following or approved equal:
  - a. Trap Guard by ProSet Systems Inc.
2. Operation: Allows wastewater to open and discharge from floor drain while preventing escape of sewer gas.
3. Compliance: ASME A112.6.3, NSF/ANSI 14, CSA B.79.
4. Size: Same as floor drain or floor sink.
5. Material: Smooth, soft, flexible, elastomeric PVC material molded into shape of duck's bill, open on top with curl closure at bottom.

### **PART 3 - EXECUTION**

#### **3.1 CONNECTIONS**

- A. Comply with requirements in Section 221316 "Sanitary Waste and Vent Piping" for piping installation requirements. Drawings indicate general arrangement of piping, fittings, and specialties.
- B. Install piping adjacent to equipment to allow service and maintenance.
- C. Ground equipment according to Section 260526 "Grounding and Bonding for Electrical Systems."

#### **3.2 FLASHING INSTALLATION**

- A. Fabricate flashing from single piece unless large pans, sumps, or other drainage shapes are required. Join flashing according to the following if required:
  1. Lead Sheets: Burn joints of lead sheets 6.0-lb/sq. ft., 0.0938-inch thickness or thicker. Solder joints of lead sheets 4.0-lb/sq. ft. 0.0625-inch thickness or thinner.
  2. Copper Sheets: Solder joints of copper sheets.
- B. Install sheet flashing on pipes, sleeves, and specialties passing through or embedded in floors and roofs with waterproof membrane.
  1. Pipe Flashing: Sleeve type, matching pipe size, with minimum length of 10 inches, and skirt or flange extending at least 8 inches around pipe.
  2. Sleeve Flashing: Flat sheet, with skirt or flange extending at least 8 inches around sleeve.
  3. Embedded Specialty Flashing: Flat sheet, with skirt or flange extending at least 8 inches around specialty.
- C. Set flashing on floors and roofs in solid coating of bituminous cement.
- D. Secure flashing into sleeve and specialty clamping ring or device.
- E. Install flashing for piping passing through roofs with counterflashing or commercially made flashing fittings.

- F. Extend flashing up vent pipe passing through roofs and turn down into pipe, or secure flashing into cast-iron sleeve having calking recess.
- G. Fabricate and install flashing and pans, sumps, and other drainage shapes.

### **3.3 FIELD QUALITY CONTROL**

- A. Tests and Inspections:
  - 1. Leak Test: After installation, charge system and test for leaks. Repair leaks and retest until no leaks exist.
  - 2. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.

### **3.4 PROTECTION**

- A. Protect drains during remainder of construction period to avoid clogging with dirt or debris and to prevent damage from traffic or construction work.
- B. Place plugs in ends of uncompleted piping at end of each day or when work stops.

### **END OF SECTION**