Coolant Chemistry Procedures

Lakeside Research Reactor · Chemistry Section

Primary coolant samples are taken weekly and analysed for conductivity, pH, and dissolved oxygen. Results outside the action band are reported to the shift supervisor on the same shift.

Sampling

Samples are drawn from the sampling station using clean containers labelled before use.

Records

Results are entered in the chemistry log and trended monthly.