

Equipment ID: UPS-N4-A



# DANGER

## Arc Flash & Electric Shock

Worst Case Arc Incident Energy at Nominal Working Distance (46 cm from source)

**147.0 cal/cm<sup>2</sup>**

Arc Flash Boundary (equivalent to 1.2 cal/cm<sup>2</sup>)

**556 cm**

Nominal Voltage      **0.4kV AC**

Shock Boundaries (I.S. EN 50110-1)

Vicinity Zone      **30 cm**

Live Working Zone      **No Contact**

Prospective Arc Incident Energy & Arc Flash Boundary shown apply to the Worst Case Feeding Arrangement



# LIVE WORK PROHIBITED



[www.premium-power.com](http://www.premium-power.com)  
TEL: +353 1 8105032

Document Number:  
**16176-EL-RP-201-01-REV-04.1**

Date Issued:  
**16 April, 2024**