

LOG WEB

Help Manual

Current New Web UI

Contents

1	Introduction	4
1.1	Naming Note	4
2	Main Page	4
2.1	What You See	4
2.2	Main Table	4
2.3	Next Calibration	5
2.4	Measurement Display Rules	5
2.5	Reserved Measurement Error Codes	5
2.6	Device Status, Web Value, and OPC UA Value	6
2.7	Reading Status Together with Value	8
2.8	Search	8
2.9	Add Channel Device Search	8
2.10	Keyboard Shortcuts	8
2.10.1	Main ISO Channels Linker	8
2.10.2	Add Devices Popup	9
2.10.3	Add Channel Popup	9
2.10.4	Edit Link / Replace Link Popup	9
2.10.5	Other Popup Pages	9
3	Menu Overview	9
4	Network Configuration	9
4.1	Fields	10
4.2	Buttons	10
4.3	Operator Notes	10
5	Add Devices	10
5.1	Page Layout	10
5.2	SDAQ Operation Flow	11
5.3	NOX Operation Flow	11
5.4	IOBOX Operation Flow	11
5.5	MTI Operation Flow	11
5.6	Remove Devices	12
5.7	Operator Notes	12
6	Backup and Restore Channels	12
6.1	FTP Server Setup	12

6.2	What Is Backed Up	13
6.3	Automatic Nightly Backup	13
6.4	Manual Backup	13
6.5	Restore	13
6.6	Operator Notes	13
7	Check System Status	14
7.1	Tabs	14
7.1.1	Details	14
7.1.2	System Logs	15
7.1.3	System Journal	15
7.2	How to Use the Tabs	15
7.2.1	Details Tab	15
7.2.2	System Logs Tab	15
7.2.3	System Journal Tab	15
8	Advanced Settings	15
8.1	Machine Identifier	16
8.2	SDAQNet (CAN-IFs)	16
8.3	Time Synchronization	16
8.4	ISOstandard	16
9	System Update	16
9.1	Current Behavior	16
9.2	Reminder Dot	16
9.3	Important Note	17
10	System Reboot and System Shutdown	17
10.1	System Reboot	17
10.2	System Shutdown	17
11	Version	17
12	Import Channels	18
12.1	How Import Opens	18
12.2	Expected File Format	18
12.3	Typical Import Flow	18
12.4	Validation and Conflicts	18
12.5	Export as Import Source	18
13	Right-Click Channel Options	19
13.1	Selection Rules	19
13.2	Action Availability by Scenario	19
13.3	Edit	19
13.4	Delete	19
13.5	Export	20
13.6	Scale	20
13.7	Calibration	20
13.7.1	Purpose	20
13.7.2	Page Layout	20
13.7.3	Buttons and Validation	21
13.8	Replace	21
13.9	Replace TC16	21

14 Troubleshooting	22
14.1 The Web Page Does Not Open	22
14.2 FTP Backup Cannot Connect	22
14.3 No Backup Files Are Listed	22
14.4 Replace or Replace TC16 Option Is Missing	23
14.5 No Eligible TC16 Target Is Listed	23
14.6 Logs or Journal Look Empty	23
14.7 Red Negative Measurement Codes Are Shown	23
14.8 Update Reminder Dot Is Still Visible	23
15 Help PDF Maintenance	23
16 Legacy Documentation Status	24

Introduction

LOG WEB is the browser user interface for daily operation and configuration of the LOG system. This manual describes the current **new** LOG WEB interface and is intended for operators and service users.

Naming Note

LOG WEB is the current product and user-interface name. **Morfeas WEB** is the legacy name. Some internal paths, service names, repository names, protocol identifiers, and code comments may still use **Morfeas**, **Morfeas_WEB**, or related forms for code compatibility and to avoid breaking existing deployments. Operator-facing UI and current user documentation should use **LOG WEB**, except where an exact technical identifier must be shown.

Unless a site-specific deployment says otherwise, open the system in a browser with:

- `http://<device-ip>/`

This manual does not describe the retired legacy Morfeas WEB layout.

Main Page

The landing page is **ISO Channels Linker**. It is the main operational screen.

What You See

The page contains:

- a top bar with the FTP backup directory chip and rolling system summary,
- a search bar,
- action buttons for importing and adding channels,
- the main ISO channel table,
- a right-click context menu for channel actions,
- a menu button that opens all secondary pages.

Main Table

The table shows the configured ISO channels and related runtime information. Typical columns include:

- status,
- ISO channel name,
- device type,
- connection anchor,
- current value,
- history,
- next calibration,
- minimum and maximum values,
- description.

The page refreshes automatically while it is visible, so operators normally do not need to reload manually.

Next Calibration

The **Next Calibration** column is calculated from calibration metadata stored with each ISO channel.

- For **SDAQ** channels, calibration date and period come from the SDAQ runtime calibration data when the device reports it.
- For **IOBOX**, **MTI**, and **NOX** channels, calibration metadata is stored in the OPC UA channel configuration as **CAL_DATE** and **CAL_PERIOD**.
- When a non-SDAQ channel is added and no other calibration metadata is entered, the Add Channel popup defaults **CAL_DATE** to the current date and **CAL_PERIOD** to 12 months.
- The displayed next calibration date is **CAL_DATE** + **CAL_PERIOD** months.
- A missing or invalid calibration date or period is shown as --.

For example, a non-SDAQ channel added on 2026-05-11 with the default 12-month period is shown with next calibration 2027-05-11.

Measurement Display Rules

The **Value** column follows the runtime measurement semantics of the current system.

- Normal valid measurements are shown as numeric values with the unit when a unit is available.
- **Out of Range** and **Over Range** continue to show the actual runtime measurement value. They are not converted to an error code.
- Reserved runtime error codes are shown as **red integers** in the **Value** column.
- Reserved error codes are shown without units and without decimal formatting.
- Reserved error codes are not collapsed to --.

Reserved Measurement Error Codes

The following reserved values may appear in the **Value** column, in OPC UA downstream consumers, and in connected tools that read the same measurement path. These values are emitted by LOG core. The web interface displays them when they are present in runtime data; it does not create these numeric error codes from status text alone.

Code	Meaning	Typical Situation
-901	OFF-Line / Disconnected	Handler is alive, but an individual source, receiver, sensor, or channel is disconnected or intentionally unavailable.
-902	No Sensor	The device reports that no sensor is present on that measurement channel.
-903	Stall / Heating	SDAQ channel is not receiving fresh samples, or NOX is heating / not ready for valid measurement.
-904	Unclassified	Runtime data is invalid, but core cannot map it to a more specific condition.

-905	Unreachable / Unregistered	Device-level source is gone or unreachable. Examples: handler/source node missing, IOBOX/MTI Modbus transport failure, or retired MDAQ source.
-906	Standby / Heater off	Device is reachable but intentionally not measuring. Currently used for NOX heater-off state.
-907	Signal Invalid / Data Invalid	Data is arriving but failed validation, usually a telemetry signal-quality or link-layer problem. Currently used by MTI.

Device Status, Web Value, and OPC UA Value

The same reserved value can have a different operator-facing status depending on the device context. Read **Status** first for the reason, then **Value** for the numeric value sent to downstream consumers.

Web Status below is the linker-table **Status** text. **Web Value** comes from handler logstat files and usually represents interval data. **OPC UA mapped Value** refers to the linked ISO channel **Value** node used by downstream OPC UA clients.

Device	Web Status / Situation	Web Value	OPC UA Value	Meaning
SDAQ	Okay	actual value	actual value	Channel is valid and measuring normally.
SDAQ	Out of Range / Over Range	actual value	actual value	Channel reports a real measurement, but it is outside the expected range.
SDAQ	No sensor	-902	-902	SDAQ reports no sensor on the channel.
SDAQ	Stall	-903	-903	SDAQ is online, but fresh samples are not arriving.
SDAQ	Unclassified	-904	-904	SDAQ reports an invalid channel condition without a more specific mapping.
SDAQ	OFF-Line / source missing	-- when no logstat value is available	-905 fallback	Linked source node is missing; OPC UA still returns a numeric unavailable value.
IOBOX	Okay	actual value	actual value	Channel is valid and measuring normally.
IOBOX	Unreachable	-905	-905	IOBOX device-level Modbus transport is unreachable.
IOBOX	Disconnected	-901	-901	IOBOX handler/device is alive, but the RX/channel path is not responding.
IOBOX	Unconfigured	--	-905 fallback if source node is missing	IOBOX device is reachable, but the linked RX/channel path is not present in runtime logstat. Check IOBOX configuration and wiring.
IOBOX	No sensor	-902	-902	IOBOX reports no sensor on the channel.

IOBOX	Unclassified	-904	-904	IOBOX reports an invalid condition without a more specific mapping.
MTI	Okay	actual value	actual value	Channel is valid and measuring normally.
MTI	Unreachable	-905	-905	MTI device-level Modbus transport is unreachable.
MTI	Disconnected	-901	-901	MTI handler/device is alive, but telemetry is not responding.
MTI	Radio Disabled / Disabled	-- when logstat has no channel; otherwise -901 if core stamped the retained source	-901 when the retained source node remains; -905 if source node is gone	MTI telemetry was intentionally disabled or reconfigured. Web does not invent a numeric value.
MTI	No sensor	-902	-902	MTI telemetry reports no sensor on the channel.
MTI	Signal Invalid	-907	-907	Packets are arriving, but telemetry data failed validation.
MTI	Error / Unclassified	-904	-904	MTI telemetry is online, but the data is invalid without a more specific mapping.
NOX	Okay	actual value	actual value	UniNOx sensor is active and measuring normally.
NOX	Handler not running, NOX role removed, or sensor never detected	--	-905 fallback if ISO link exists	NOX source node is missing. Web reports missing logstat/runtime source; OPC UA reports missing mapped source.
NOX	OFF-Line after previously detected sensor timeout	-901	-905 if source node was removed	Logstat records the timed-out sensor as offline; OPC UA may only see the missing source node.
NOX	Heater off	-906	-906	Sensor is active, but heater-off state makes measurement unavailable.
NOX	Heating / Not in temperature	-903	-903	Sensor is active, but it is not ready for valid measurement.
NOX	Unclassified / invalid sensor condition	-904	-904	Sensor is active, but the reported measurement is invalid.

MTI Disabled note: Disabled is an operator-selected radio mode, not a measurement fault. If MTI telemetry is disabled, the web shows **Status = Disabled** and leaves **Value** as -- unless LOG core explicitly provides a numeric channel value. This keeps OPC UA/logstat measurement values owned by core and prevents the web interface from inventing error codes.

NOX mapped-channel note: NOX uses dynamic sensor nodes for UniNOx addresses. If the NOX handler is not running, the bus has been switched away from NOX, or a sensor address has never been detected, the web linker table may show **Status = OFF-Line** with **Value = —** because no logstat runtime source exists. The OPC UA mapped **Value** may return -905 for the same ISO link because the mapped source node is missing. These two displays describe the same missing-source condition from different layers.

Reading Status Together with Value

Operators should read the **Status** and **Value** columns together:

- **Status** = **Out of Range** or **Over Range** with a numeric **Value** means the device still reports a measurement, but the channel is flagged as outside the expected calibrated or device range.
- **Status** = **No sensor**, **OFF-Line**, **Disconnected**, **Stall**, or **Unclassified** together with a red negative **Value** means the measurement is not valid and the code should be interpreted using the error-code table above.
- **Status** = **Unconfigured** with **Value** = — means the device is reachable, but the configured runtime channel path is not present.
- **Status** = **Disabled** with **Value** = — means the function is intentionally turned off, not failed.

Search

Use **Search Input** to filter channels in the current table.

Add Channel Device Search

The Add Channel popup uses device search to choose runtime source paths for new links. Search results are limited to the selected device family and to paths that are not already linked in the current OPC UA channel configuration.

- **SDAQ**: search lists detected SDAQ channels that are not already linked. Single-channel manual offline anchors are allowed when needed.
- **IOBOX**: search lists channels from IOBOX devices whose runtime connection status is **Okay**. A receiver marked **Disconnected** is not listed. Individual channels under an online receiver may still be listed even when their current status is **No sensor** or otherwise invalid, matching the current channel-selection contract.
- **MTI**: search lists channels only when the MTI runtime connection status is **Okay** and the radio/telemetry mode provides channel data. Modes **TC4**, **TC8**, **TC16**, and **QUAD** expose their channel list. **RMSW/MUX** exposes detected **Mini_RMSW** measurement channels. **Disabled** does not expose Add Channel candidates.
- **NOX**: search lists **NOx** and **O2** entries for detected UniNOx sensor objects. The current measurement does not need to be valid; for example, heater-off, warming-up, or previously detected **OFF-Line** sensors may still be linked and controlled later. OFF-Line historical candidates are marked with (**OFF-Line**) in the search result.

The search popup and save validation both enforce device-family matching. IOBOX candidates are not accepted as MTI links, and MTI candidates are not accepted as IOBOX links, even if the physical equipment connected behind the device can be similar.

Keyboard Shortcuts

The following keyboard shortcuts and key actions are currently implemented in LOG WEB.

Main ISO Channels Linker

- **Delete**: delete the currently selected channel rows. A confirmation dialog is shown first.

- **Ctrl+Z**: undo the most recent successful delete. Only one delete step is remembered.
- **Escape**: close the main menu or an open column filter menu.

Add Devices Popup

- **Ctrl+S**: save the device currently being added when the add form is open.
- **Delete**: remove the currently selected removable devices.
- **Escape**: close the popup window.

Add Channel Popup

- **Ctrl+S**: save the current Add Channel form.
- **Enter** in the ISO field: accept the typed ISO code as a custom manual ISO value.
- **Enter** in the sensor path field: accept the typed device path when it matches an available search-pool candidate. Manual offline anchors are intended for SDAQ single-channel use only.
- **Escape**: close the popup window.

Edit Link / Replace Link Popup

- **Ctrl+S**: save the current Edit or Replace form.
- **Escape**: close the popup window.

Other Popup Pages

- **Escape**: close popups such as Advanced Settings, Backup & Restore Channels, Check System Status, Network Configuration, Version, and system control pages.

Menu Overview

The main menu is grouped as follows.

Menu Item	Purpose
Network Configuration	Edit hostname and Ethernet IPv4 settings.
Add Devices	View current devices and add or remove supported devices.
Backup & Restore Channels	Configure FTP backup target, create backups, and restore saved bundles.
Check System Status	View live runtime details, log files, and system journal output.
Advanced Settings	View MAC/CAN information, configure NTP server, and manage ISOstandard XML.
System Update	Check for available system updates, then update LOG WEB and LOG core when desired.
System Reboot	Reboot the device.
System Shutdown	Power off the device.
Version	Show current web and core version information.
Help	Download this manual as PDF.

Network Configuration

Open **Network Configuration** from the menu to edit hostname and Ethernet settings.

Fields

The page contains:

- **Hostname**
- **Mode**: Static or DHCP
- **Network IP**
- **Gateway**
- **DNS addr**

Preset buttons are available at the top of the page for quick loading of predefined values.

Buttons

- **Load Last**: reload the last confirmed configuration into the form.
- **Set**: apply the current values.
- **Close**: close the popup window.

Operator Notes

- If you change the device IP address, reconnect the browser to the new HTTP address after the change is applied.
- DHCP mode disables manual IPv4 entry.
- Presets are convenience values only. Review them before applying.

Example Message (Progress):

Applying configuration: validating and writing system network settings...

Example Message (Success):

Configuration applied. If the IP changed, reconnect to the new device address in your browser.

Example Message (Failure):

Apply failed: <error details>

Add Devices

Open **Add Devices** to manage the current device inventory.

Page Layout

The page has three main areas.

- **CAN Bus Setup**: shows each CAN bus, current mode, bitrate, state, detected device count, and available actions.
- **Configured Devices**: shows XML-backed devices that can be removed or configured.

- **Detected Devices:** shows auto-detected runtime devices, especially SDAQ devices found from logstat data.

The page refreshes while the popup is focused. Polling pauses during remove or role-change operations so the displayed state does not fight the operation in progress.

SDAQ Operation Flow

- SDAQ devices are auto-discovered from runtime `logstat` data.
- They appear in **Detected Devices**; they are not manually added with the **Add...** form.
- To use a CAN bus for SDAQ, use the **Switch to SDAQ** action in **CAN Bus Setup**. The system sets the SDAQ role and expected bitrate, restarts the LOG service, then waits for SDAQ runtime data to appear.
- After SDAQ devices are detected, link individual SDAQ channels from the main page with **Add Channels**.
- If a bus is in SDAQ mode but no SDAQ appears, check wiring, power, and CAN bitrate/state in the same table.

NOX Operation Flow

- NOX is managed by CAN bus role, not by the manual **Add...** form.
- Use **Switch to NOX** on the target CAN bus to assign that bus to NOX operation. The transition changes the role/bitrate together and restarts the LOG service.
- When a bus is in NOX mode, **Open NOX Config** opens the NOX configuration page for that bus.
- Use the NOX configuration page for sensor setup and NOX-specific live controls.
- To remove NOX from a bus, use **Switch to SDAQ**. When removing a configured NOX row, the UI may also ask whether to restore the bus to SDAQ.

IOBOX Operation Flow

1. Click **Add...**
2. Select **IO-BOX**.
3. Enter **Device Name**, for example `IOBOX_01`.
4. Enter the IOBOX IPv4 address.
5. Click **Save**.
6. Confirm the service restart warning.
7. Wait for the page to refresh and show the configured device runtime status.

Behind the UI, saving an IOBOX writes the device into the LOG configuration XML and restarts the LOG service. Duplicate device names and duplicate IPv4 addresses are blocked.

MTI Operation Flow

1. Click **Add...**
2. Select **MTI**.

3. Enter a **Device Name**; for MTI it must follow D-Bus element rules: letters, numbers, and underscore only, and it must not start with a digit.
4. Enter the MTI IPv4 address.
5. Click **Save**.
6. Confirm the service restart warning.
7. After the device is listed, use **Open MTI Config** from the configured row to manage MTI setup, telemetry mode, and MTI-specific controls.

Behind the UI, saving an MTI writes the device into the LOG configuration XML and restarts the LOG service. The page compares configured name/IP with runtime MTI logstat data to show whether the device is connected.

Remove Devices

- Select one or more rows in **Configured Devices**.
- Click **Remove** or press **Delete** while focus is not inside a form field.
- Confirm the service restart warning.
- The selected XML-backed devices are removed and the LOG service is restarted.

Operator Notes

- SDAQ rows in **Detected Devices** are auto-discovered and are not removable from this page.
- Manual add currently supports IOBOX and MTI only. SDAQ is auto-discovered; NOX is controlled through CAN bus role switching.
- If the page shows a legacy MDAQ warning, add/remove and CAN role actions are blocked until the legacy MDAQ XML configuration is removed manually.
- Any add, remove, or CAN role transition may need 10–60 seconds because the LOG service restarts.

Backup and Restore Channels

Open **Backup & Restore Channels** for FTP-based backup and restore.

FTP Server Setup

The page contains:

- **Host IP**: FTP server IPv4 address. The default expected server is 10.193.135.70.
- **Engine Number**: remote directory name for this engine/device group. It may contain letters, numbers, dot, underscore, and hyphen.
- **Connect & Fetch**: save the FTP configuration, test the FTP login, and load available backup files.
- **Disconnect**: remove the saved FTP configuration and disable automatic backups.

FTP credentials are read from the device-side credential file and are not typed in the UI. When the connection is saved, the main page FTP chip shows the active backup directory.

What Is Backed Up

Each backup bundle contains the current OPC UA channel configuration XML and the LOG device configuration XML. The bundle is compressed, uploaded to the selected FTP engine directory, and stored as an `.mb1` file.

Automatic Nightly Backup

- The deployment installs a root cron job that runs the FTP backup script every night at 00:10.
- Automatic backup only runs when a valid FTP configuration exists.
- If no FTP configuration exists, the backup script logs that no valid engine number is configured and does not change system state.
- After a backup, the script uploads the backup logs to the same FTP engine directory when possible.

Manual Backup

1. Open **Backup & Restore Channels**.
2. Confirm or enter the FTP server IP.
3. Enter the engine number.
4. Click **Connect & Fetch**.
5. Wait for **Connected to FTP... Configuration saved**.
6. Click **Backup Now**.
7. Wait for the success message and confirm that the new `.mb1` file appears in the list.

Restore

1. Connect to the FTP server and engine directory.
2. Select one backup file from the list.
3. Click **Restore Selected**.
4. Wait for the restore result message.
5. Reload the main page and verify the channel/device configuration.
 - Restore downloads the selected `.mb1` file from FTP.
 - The file must be a valid backup bundle.
 - Restore overwrites both the OPC UA channel configuration XML and the LOG device configuration XML from the bundle.
 - Backup files are listed newest-first, and old remote backups are pruned so the engine directory keeps up to 50 `.mb1` files.

Operator Notes

- Backup and restore both require a reachable FTP server.
- If the server is unavailable, the page shows an error and no configuration is changed.

- If two browser sessions edit the FTP configuration, the page detects the updated configuration and refreshes the backup list.

Example Message (Connect Success):

Connected to FTP at 10.193.135.70. Configuration saved.

Example Message (Connect Failure):

Connection failed: FTP connect failed

Example Message (Backup Success):

Backup complete

Example Message (Restore Failure):

Restore failed: <error details>

Check System Status

Open **Check System Status** to inspect runtime data and logs.

Tabs

The page has three tabs.

Details

This tab shows live system and bus information in tables. Depending on the device and services, values may include:

- CPU temperature,
- uptime,
- bus utilization,
- bus error rate,
- detected SDAQ count,
- incomplete SDAQ count,
- bus voltage,
- bus amperage,
- shunt temperature,
- last calibration timestamps.

Temperature values shown by the current web interface are displayed in degrees Celsius. This includes CPU temperature, SDAQnet shunt temperature, IOBOX/MTI temperature channels, and NOX page shunt temperature.

System Logs

This tab is used for LOG application logger files.

- **Preview Logger:** choose one log file to preview.
- **Reload:** reload the logger list.
- **Export Logs:** select one or more log files and export them as one combined text file.

The preview area shows the selected file content in a terminal-style viewer.

System Journal

This tab is used for journal output from system services.

- **Scope:** choose all services, LOG system service, Apache2, or SSH. The current UI label for the LOG system service may still appear as **Morfeas System** until that compatibility label is renamed.
- **Lines:** choose how many lines to load.
- **Reload:** reload the journal view.
- **Export Journal:** export the currently requested journal text.

How to Use the Tabs

Details Tab

Use this tab first when checking current runtime health. If a service is active but values look stale, compare with the Logs or Journal tabs.

System Logs Tab

Use this tab for LOG component logs when you want application-level detail such as handler messages, update logs, backup logs, or runtime component reports. To export logs, choose one or more files in the **Export Logs** multi-select, then click **Export Selected**. LOG WEB downloads the selected logger files as one combined text file. Use **Reload** if the file list looks stale.

System Journal Tab

Use this tab when the problem looks system-level rather than application-level, for example:

- service startup failures,
- Apache problems,
- SSH availability,
- reboot or shutdown investigation.

To export journal output, choose the **Scope**, choose the number of **Lines**, click **Reload** if needed, then click **Export Journal**. The browser downloads the currently requested journal text as a `.txt` file.

Advanced Settings

Open **Advanced Settings** for machine information, NTP, and ISOstandard management.

Machine Identifier

Displays the MAC address.

SDAQNet (CAN-IFs)

Displays the current CAN interface information for `can0` and `can1`. These values are informational and read-only on this page.

Time Synchronization

The page shows the current NTP server and allows entering a new IPv4 NTP server. Use **Apply** to store the new value.

Example Message (Apply Success):

Applied NTP server: 192.168.1.10

Example Message (Validation Error):

NTP server must be a valid IPv4 address.

ISOstandard

This section lets the user:

- view the currently selected ISOstandard source,
- select a different available ISOstandard file,
- upload a new ISOstandard XML file,
- review the loaded ISO point definitions in a table.

System Update

Open **System Update** to manage full system software updates.

Current Behavior

The page supports:

- checking whether an update is available,
- applying the update,
- deferring the update,
- reloading the page after service recovery.

Reminder Dot

A red dot on the menu item indicates that the system has recorded an available update. The reminder stays visible until a later check confirms that no update is pending, or until a successful update clears it.

Important Note

The current update flow handles the full system update path shown in the progress messages. It checks and updates LOG WEB, applies web deployment steps, checks and downloads LOG core changes, builds and installs core when needed, runs core health checks, restarts services, and waits for the web service to become reachable again.

Example Message (Update Available):

Update available. Click "Update Now" to apply, or "Update Later" to postpone.

Example Message (Update Success):

Update flow completed and web service is reachable. Refresh page (Ctrl+F5) to load latest files.

Example Message (Update Failed):

System update failed: <error details>

System Reboot and System Shutdown

The system control pages provide single-confirmation actions for reboot and shutdown.

System Reboot

Use **Reboot Now** when you want to restart the device and return to service after boot. The page shows post-action guidance so the operator knows when to reconnect and refresh the browser.

Example Message (Reboot Accepted):

Reboot command accepted. Wait about 60–90 seconds, then open the device URL again and refresh the browser.

System Shutdown

Use **Shutdown Now** when you want to power off the device. After shutdown, the device must be powered on again manually before the web interface becomes available.

Example Message (Shutdown Accepted):

Shutdown command accepted. Device will go offline. Power it on manually when needed.

Version

The **Version** page shows version and commit information for:

- the LOG WEB repository,
- the LOG core repository,
- the related commit dates.

Use this page when confirming what software is installed on a device.

Import Channels

Use **Import Channels** on the main page to create channels from a JSON file.

How Import Opens

Clicking **Import Channels** opens the browser file picker. Select a `.json` file; there is no separate import popup page.

Expected File Format

The file must contain a JSON array. Each entry must include:

- `ISO_CHANNEL`
- `INTERFACE_TYPE`
- `ANCHOR`

Optional fields include `DESCRIPTION`, `MIN`, `MAX`, alarm fields, `UNIT`, `CAL_DATE`, and `CAL_PERIOD`. For SDAQ imports, LOG WEB ignores `UNIT`, `CAL_DATE`, and `CAL_PERIOD` because SDAQ calibration data is read from the SDAQ calibration path.

Typical Import Flow

1. Prepare or export a JSON array of channel entries.
2. Click **Import Channels**.
3. Select the JSON file.
4. LOG WEB validates the file and maps each entry to the channel-create payload.
5. Valid entries are created one by one.
6. The main table refreshes after successful imports.

Validation and Conflicts

- The import fails immediately if the file is not valid JSON or is not a JSON array.
- Entries missing required fields are skipped and reported.
- Duplicate ISO channels inside the import file are rejected.
- Duplicate device paths inside the import file are rejected.
- Existing live ISO-channel or device-path conflicts are rejected before creating that entry.
- If some entries succeed and others fail, LOG WEB reports both the number imported and the failed entries.

Export as Import Source

The right-click **Export** action creates a JSON file in the same structure expected by import. This is the safest way to move selected channel definitions between devices, then review the file before importing it elsewhere.

Right-Click Channel Options

Right-click one or more channel rows in the main table to access channel operations.

Selection Rules

- With one selected row, LOG WEB can show row-specific actions.
- With two or more selected rows, LOG WEB shows only **Delete** and **Export**.
- If no row is selected and you right-click a row, that row is selected automatically.
- If several rows are already selected and you right-click one of them, the multi-row selection is kept.

Action Availability by Scenario

Scenario	Available actions
Single SDAQ row	Edit, Delete, Calibration, Export.
Single SDAQ-I or SDAQ-U row	Edit, Delete, Scale, Calibration, Export.
Offline SDAQ row	Replace is added.
Offline complete SDAQ-TC16 group	Replace TC16 is added when the selected source belongs to a full CH1–CH16 offline TC16 group.
Single IOBOX row	Edit, Delete, Export.
Single MTI row	Edit, Delete, Export.
Single NOX row	Edit, Delete, Export.
Multiple rows	Delete, Export.

Edit

1. Right-click one channel row.
2. Choose **Edit**.
3. Review or change ISO code, description, min/max, alarm fields, unit, calibration date/period when shown, and device path.
4. Click **Save**.

Edit uses the current channel data from the backend when available. The save operation updates the existing channel link.

Delete

1. Select one or more rows.
2. Right-click and choose **Delete**, or press **Delete**.
3. Confirm the delete prompt.

After a successful delete, one undo step is remembered for a short time. Press **Ctrl+Z** to restore the last deleted channel set when there is no conflict with existing live channels.

Export

1. Select one or more rows.
2. Right-click and choose **Export**.
3. The browser downloads a timestamped LOG_ISOChannel_Linker_Export_Selection JSON file.

The exported JSON can be used later with **Import Channels**. For SDAQ rows, export keeps the channel link fields; SDAQ device calibration remains owned by the SDAQ calibration data.

Scale

Scale is available only for **SDAQ-I** and **SDAQ-U** rows.

1. Right-click an SDAQ-I or SDAQ-U row.
2. Choose **Scale**.
3. Review **Current Measurement Value**.
4. Enter **Measurement Input Low**, **Measurement Input High**, **Engineering Output Low**, **Engineering Output High**, and **Engineering Unit**.
5. Review **Scaled Output Value**.
6. Click **Save**.

The scale popup writes a two-point scale into the selected SDAQ channel calibration data. It is separate from the full calibration popup.

Calibration

Calibration is available for SDAQ rows.

Purpose

The calibration popup is a manual channel calibration editor for the selected SDAQ channel. It is used to read, inspect, edit, preview, and save device calibration data.

Page Layout

The popup contains:

- **Upper Section:** device information, calibration metadata, and summary panel share the top area.
- **Current Preview:** Measured raw value and Correct value.
- **Point Table:** Uncalibrated value, Reference value, Offset, Gain, C2, and C3.
- **Preview Columns:** Calibrated value and Difference (Calibrated - Reference).
- **Summary Panel:** calibration type, slope or gain summary, offset, reference minimum and maximum, and unit.

Buttons and Validation

- **Read from SDAQ**: reload calibration directly from the device.
- **Discard Changes**: restore the last data loaded into the popup.
- **Save to SDAQ**: validate the current form and write it to the device.
- **CH's Unit** must be selected from the supported runtime SDAQ unit list.
- **Used Points** must be an integer between zero and the device maximum.
- Every field of every used point must contain a finite number.
- Empty strings and `nan` / `-nan` are rejected.
- **Measure** values of used points must be strictly increasing from top to bottom.

The calibration popup preserves entered calibration coefficients as typed after validation; it does not automatically recalculate **Offset**, **Gain**, **C2**, or **C3**.

Replace

Replace is shown only for offline SDAQ rows. It uses the Edit Link popup in replace mode.

1. Right-click the offline SDAQ channel you want to replace.
2. Choose **Replace**.
3. The popup opens with the source type locked.
4. Use device search to choose the replacement source path.
5. Review ISO code, description, min/max, alarms, unit, and any shown calibration fields.
6. Click **Save**.

Family mismatch is blocked. If the source SDAQ subtype is known, subtype mismatch is blocked. If the source subtype is unknown, replacement is allowed but the UI warns the operator to replace within the same type.

Example Message (Warning):

Subtype unknown, make sure replace within same type.

Example Message (Blocked Replace):

Subtype mismatch: expected SDAQ-TC1, got SDAQ-AI8.

Replace TC16

Replace TC16 is shown only when the selected source belongs to a resolvable offline SDAQ-TC16 group that is complete as channels CH1 through CH16.

1. Right-click any channel in the full offline TC16 source group.
2. Choose **Replace TC16**.
3. LOG WEB selects all 16 source channels.
4. The Replace TC16 popup shows the source group summary and channel mapping.

5. Choose one eligible unlinked TC16 target device.
6. Confirm the operation.
7. All 16 source channels are remapped to the target device in one atomic operation.
 - Replace TC16 is all-or-nothing.
 - If any validation fails, no channel mapping is changed.
 - Target selection is at device-group level, not one channel at a time.
 - If no eligible target is listed, there is currently no fully free TC16 target device available.

Example Message (Success):

Replace TC16 complete: 16 channels updated.

Example Message (Failure):

Failed to apply TC16 replace. [tc16_target_not_unlinked]

Troubleshooting

This section gives quick operator guidance for common problems.

The Web Page Does Not Open

- Confirm that you are using the current device IP address over HTTP.
- If the IP was recently changed, reconnect to the new address.
- If the device was rebooted or updated, wait for services to come back and refresh the browser.
- If still unavailable, check **System Journal** or use SSH to verify Apache and LOG services.

FTP Backup Cannot Connect

- Check that the FTP server IP is reachable from the device.
- Confirm that the engine number is correct.
- If the page says configuration was removed, reconnect first.
- If the internal FTP server is currently unavailable, backup and restore cannot be tested end-to-end.

No Backup Files Are Listed

- Verify that the selected engine directory contains backup files.
- Confirm that the FTP configuration belongs to the expected engine number.
- Reload after reconnecting to the FTP server.

Replace or Replace TC16 Option Is Missing

- Confirm that the selected row supports that replace mode.
- For Replace TC16, confirm that the source is a complete offline TC16 group with channels CH1 through CH16.
- If the source group is partial, use normal single-channel replace instead.

No Eligible TC16 Target Is Listed

- No full unlinked TC16 target device is currently available.
- If channels on the target are already linked, the target is blocked.
- Refresh the popup after any device or link changes.

Logs or Journal Look Empty

- Use **Reload** once to refresh the selected tab.
- Verify that the correct logger file or journal scope is selected.
- If the service has not produced messages yet, the view may be temporarily empty.

Red Negative Measurement Codes Are Shown

- -901 means the handler is alive, but the individual source, receiver, sensor, or channel is offline or disconnected.
- -902 means no sensor is present.
- -903 means the channel is stalled, heating, or not ready for valid measurement.
- -904 means the runtime data is invalid without a more specific mapping.
- -905 means the device-level source is unreachable or the mapped OPC UA source node is unregistered.
- -906 means standby / heater off.
- -907 means signal invalid / data invalid.
- When these codes are shown, the measurement should not be interpreted as a physical live value.

Update Reminder Dot Is Still Visible

- The reminder is based on the stored update flag.
- Run **Check Again** in the System Update page to refresh the latest status.
- After a successful update or a clean re-check, the reminder should clear.

Help PDF Maintenance

The Help menu downloads a PDF file from:

- `docs/help_manual.pdf`

The maintained source for this file is located under:

- `Morfeas_WEB/docs/manual/`

This keeps the active user manual next to the current LOG WEB code instead of inside the archived legacy documentation tree.

Legacy Documentation Status

The old documentation tree under `LOG-web/Docs/Morfeas_WEB_Docs` is retained only as historical reference. Its structure and API descriptions belong to the legacy Morfeas WEB implementation and should not be used as the active operator manual for the current LOG WEB UI.