

State-of-Charge Balance Using Adaptive Droop Control for Distributed Energy Storage Systems in DC Microgrid Applications

Xiaonan Lu, *Student Member, IEEE*, Kai Sun, *Member, IEEE*, Josep M. Guerrero, *Senior Member, IEEE*, Juan C. Vasquez, *Member, IEEE*, and Lipei Huang

Abstract—This paper presents the coordinated control of distributed energy storage systems in dc microgrids. In order to balance the state-of-charge (SoC) of each energy storage unit (ESU), an SoC-based adaptive droop control method is proposed. In this decentralized control method, the droop coefficient is inversely proportional to the n th order of SoC. By using a SoC-based droop method, the ESUs with higher SoC deliver more power, whereas the ones with lower SoC deliver less power. Therefore, the energy stored in the ESU with higher SoC decreases faster than that with lower SoC. The SoC difference between each ESU gradually becomes smaller, and finally, the load power is equally shared between the distributed ESUs. Meanwhile, the load sharing speed can be adjusted by changing the exponent of SoC in the adaptive droop control. The model of the SoC-based adaptive droop control system is established, and the system stability is thereby analyzed by using this model. Simulation and experimental results from a 2×2.2 kW parallel converter system are presented in order to validate the proposed approach.

Index Terms—DC microgrids, distributed energy storage system (DESS), droop control, state-of-charge (SoC).

I. INTRODUCTION

WITH THE objective to electrify remote areas and energy islands, the microgrid concept is gaining more and more popularity [1]. Nowadays, dc microgrids are becoming more attractive with the raise of dc power sources, storages, and the loads with natural dc coupling, e.g., photovoltaic modules, batteries, fuel cells, light-emitting diodes, and so on. With the comparison of the overall efficiency, it can be found that the efficiency of dc system is higher than the ac system [2]. At the same time, dc does not require for synchronization, and the problems caused by the reactive power and harmonics disap-

Manuscript received November 25, 2012; revised April 1, 2013, June 5, 2013; accepted August 4, 2013. Date of publication August 22, 2013; date of current version December 20, 2013. This work was supported in part by the National Natural Science Foundation of China under Grant 51177083 and in part by the China Scholarship Council Postgraduate Scholarship Program.

X. Lu is with the Department of Electrical Engineering and Computer Science, University of Tennessee, Knoxville, TN 37996 USA (e-mail: xiaonan.charles.lu@gmail.com).

K. Sun, and L. Huang are with the State Key Laboratory of Power Systems, Department of Electrical Engineering, Tsinghua University, Beijing 100084, China.

J. M. Guerrero is with the Institute of Energy Technology, Aalborg University, 9220 Aalborg East, Denmark.

J. C. Vasquez is with the Institute of Energy Technology, Aalborg University, 9220 Aalborg East, Denmark.

Color versions of one or more of the figures in this paper are available online at <http://ieeexplore.ieee.org>.

Digital Object Identifier 10.1109/TIE.2013.2279374




Fig. 1. Typical configuration of a dc microgrid.

pear. For these reasons, recently, there has been an increasing awareness on dc microgrids [3]–[10]. A typical configuration of a dc microgrid is shown in Fig. 1 [9].

The control of the power electronics converters in the distributed generation has been intensively studied in the past years. Among them, the droop control and its variants are commonly accepted as the methods to integrate several voltage sources in a microgrid [4], [5], [8]–[11]. Basically, by using a control loop, it linearly reduces the output voltage reference when the output power increases. The output power of the power electronics interface converter should be inversely proportional to the droop coefficient.

In order to solve the uncertainty problem of the renewable energy sources, distributed energy storage units (ESUs) are commonly adopted in a microgrid [11]. The control scheme of an energy storage system (ESS) commonly consists of two parts: One of them is the battery management system (BMS), and the other one is the power converter system (PCS). The configuration of the preceding two control systems in a microgrid with distributed ESUs is shown in Fig. 2.

The function of the BMS is to balance the SoC and the output voltage of each cell in the battery string. Several literature focus on the BMS. In [12], a modular charge equalizer for lithium




Fig. 2. Configuration of the BMS and the PCS in a microgrid with distributed ESUs.

battery strings is proposed, where the modularization is applied to a string of four cells, and the system is composed of one module balancing circuit and two intramodule equalizers. In [13], a method based on redundancy cells is presented, where the system is controlled to dynamically disconnect a redundant cell from the battery pack in order to reach an optimal balancing result. In [14], a screening process is involved to improve the performance of output voltage and SoC balancing.

Although the BMS is useful for balancing the SoC of each cell in a battery string, it is not enough for the applications of distributed generation systems, such as microgrids. Each BMS can be used for only one ESU, whereas it is not capable of the SoC balancing between different ESUs. For example, as shown in Fig. 2, ESU 1 is composed of a battery string, and the BMS is locally employed to balance the SoC of each cell in this string. However, the BMS cannot be used to balance the overall SoCs between ESUs 1 and 2. The SoC balancing between different ESUs should be accomplished by the PCS.

Aiming at the PCS, in [15], the configuration of cascade H-bridges is employed to balance the SoC of each ESU. In [16], a low-pass filter in the control diagram is employed to improve the load distribution of an ESS, which consists of composite kinds of ESUs. However, the preceding methods are all achieved by centralized controllers, which are not suitable for decentralized configuration of a microgrid. In [10], a fuzzy control system is employed to adjust the output power of each ESU. Although the method is implemented based on droop control, the calculation of the average stored energy is still necessary. As a result, the method is also communication dependent since the stored energy of each ESU is transferred to the others to calculate the average value.

The optimal SoC balancing in a microgrid with ESUs should consist of two aspects: 1) the SoC of each cell in one ESU is balanced by the BMS and 2) the overall SoC of each ESU is equalized by the PCS. Since in the existing literature there are kinds of valid methods developed for the first requirement, the BMS is not the research subject here. In this paper, an SoC-balancing method for different distributed ESUs is proposed, which is employed to meet the second requirement, and implemented in the PCS. Meanwhile, the proposed method is achieved based on droop control and locally accomplished without any communications between different interfacing con-

verters. At the same time, in this method, the droop coefficient is adaptively adjusted according to the SoC. In particular, it is set inversely proportional to the SoC^n . By changing the value of the exponent n , the SoC balancing and the output power equalization speed can be regulated. A flexible operation of a dc microgrid with distributed ESUs can be achieved. Furthermore, it should be pointed out that this work focuses on the DESS with similar kinds of ESUs. If the power ratings and capacities of the ESUs significantly differ, the variable state-of-power (SoP) can be used instead of the SoC, in order to reach the proper power sharing. The SoP balancing can be achieved in this condition.

Meanwhile, although the proposed method is validated by using the laboratory scale test, it is not just suitable for the system with low power rating. Since it is developed based on commonly used droop control, it can be used in the distribution systems with different power ratings. If the method is employed in a high-power distribution system, only an ESU with a suitable rating is required, and the approach for balancing the SoC and the output power is not necessary to change.

II. PROPOSED SoC-BASED DROOP CONTROL METHOD

A. Basic Operation Modes of the DESS

In order to clearly describe the usage of the proposed control method, the basic operation modes of the DESS are shown as follows.

When the sufficient amount of input power is provided in the microgrid, the load is fed by the renewable energy sources, and meanwhile, the ESUs operate in the charging mode. In the charging process, in order to rapidly reach the fully charged state, the ESUs are charged with maximum input power. When the ESU is fully charged, it is disconnected and waits for the discharging process.

When the input power of the renewable energy sources is not enough for feeding the load in the microgrid, the ESUs turn to discharging mode. In the discharging process, the optimal condition is that the SoC of each ESU is balanced and the output power of each ESU is equalized. Here, the proposed SoC-balancing method based on droop control is employed. With this control method, the load power is shared according to the SoCs. Meanwhile, the SoC in each ESU is balanced.

B. Model of the ESU

As aforementioned in Section I, the research subject of this paper is focused on the PCS, and the proposed method is achieved by using droop control. The function of the ESU model is only to show the key parameters, such as SoC, for the usage of the following PCS stage. Hence, a brief ESU model is used here with the configuration of a voltage source representing the open-circuit voltage v_{oc} and an internal output resistance Z_{eq} for each cell, as shown in Fig. 3. Meanwhile, the basic Coulomb counting method is employed to estimate the SoC, as shown in

$$\text{SoC}_i = \text{SoC}_{i,t=0} - \frac{1}{C_e} \int i_{in_i} dt \quad (1)$$




Fig. 3. Model of each cell.

TABLE I
DATA FITTING RESULTS OF EACH CELL

v_{oc}/V			
a_{v1}/V	$a_{v2}/-$	a_{v3}/V	$a_{v4}/-$
3.228	3.934×10^{-4}	7.681×10^{-1}	2.294×10^{-1}
Z_{eq}/Ω			
$a_{z1}/\Omega^\circ C^{-2}$	$a_{z2}/\Omega^\circ C^{-1}$	a_{z3}/Ω	
4.405×10^{-7}	4.087×10^{-5}	1.701×10^{-3}	

where $SoC_{i=0}$ is the initial value of SoC, C_e is the capacity of the ESU, i_{in_i} is the input current of the interfacing converter (the output current of the ESU), and $i = 1, 2$.

Both v_{oc} and Z_{eq} can be calculated by the function of SoC and T , where T is the ambient temperature. It can be demonstrated that the v_{oc} highly depends on SoC, whereas it does not significantly change with the variation of T [17]. Meanwhile, the ambient temperature has a major influence on Z_{eq} , which almost does not change with SoC [18]. As a result, v_{oc} and Z_{eq} can be reached as

$$v_{oc} = f_1(SoC) \quad (2a)$$

$$Z_{eq} = f_2(T) \quad (2b)$$

where T is the ambient temperature.

Functions f_1 and f_2 can be achieved by data fitting. The results are shown in the following:

$$v_{oc} = a_{v1} \cdot e^{a_{v2} \cdot SoC} - a_{v3} \cdot e^{-a_{v4} \cdot SoC} \quad (3a)$$

$$Z_{eq} = a_{z1} \cdot T^2 - a_{z2} \cdot T + a_{z3} \quad (3b)$$

where the coefficients are shown in Table I.

C. Model of the SoC-Based Droop Control System

Considering a voltage-controlled power electronics converter, the conventional droop control method can be expressed as

$$v_{dc} = v_{dc}^* - m_p \cdot p_{lpf} \quad (4)$$

where v_{dc} and v_{dc}^* are the dc output voltage and its reference values, p_{lpf} is the filtered output power by the low-pass filter, and m_p is the droop coefficient.

When the input sides of the parallel converters are connected to the distributed ESUs, it is necessary to share the power according to the SoC of each unit. It is commonly known that the droop coefficient should be inversely proportional to the




Fig. 4. Control diagram of the SoC-based adaptive droop control system.

output power. Thus, if the droop coefficient is selected to be inversely proportional to the SoC^n , the output power of each converter will be proportional to each SoC^n . In other words, the ESUs with higher SoC deliver more power, whereas the ones with lower SoC deliver less. In a parallel converter system with two modules, the droop control method can be rewritten as

$$v_{dc_i} = v_{dc}^* - (m_0/SoC_i^n) \cdot p_{lpf_i} \quad (5)$$

where m_0 is the initial droop coefficient for fully charged condition, n is the exponent of SoC, and $i = 1, 2$.

Here, the exponent n is involved to adjust the SoC-balancing speed, which will be demonstrated and evaluated in the following subsection. The control diagram of the whole system is shown in Fig. 4. Since the control diagrams for Converters 1 and 2 are the same, the latter one is not shown here for brevity.

By perturbing (5) and transferring the results into the s -domain, the following model can be obtained for both converters:

$$m_0 \cdot \hat{p}_{lpf_i} = n SoC_i^{n-1} (V_{dc}^* - V_{dc_i}) \cdot SoC_i - SoC_i^n \cdot \hat{v}_{dc_i} \quad (6)$$

where \wedge denotes the perturbed values; SoC_i , V_{dc_i} , and V_{dc}^* show the equilibrium point values; and $i = 1, 2$.

Meanwhile, neglecting the power losses in the interface converter, it yields that

$$p_i \approx p_{in_i} = v_{in_i} i_{in_i} \quad (7)$$

where p_i is the output power without filtering; p_{in_i} is the input power of the interfacing converter (output power of the

ESU); v_{in_i} and i_{in_i} are the input voltage and current of the interfacing converter (output voltage and current of the ESU), respectively; and $i = 1, 2$.

Considering that SoC varies very slowly and that the output voltage of each ESU almost remains constant in a large range of SoCs, it can be assumed that the output voltage of each unit remains constant. Therefore

$$v_{in_i} = V_{in_i} \quad (8)$$

where V_{in_i} is the constant dc output value, and $i = 1, 2$.

At the same time, based on the consideration of the SoC estimator of each ESU in (1) and the calculation of the output power of the ESU in (7), it is obtained that

$$\text{SoC}_i = \text{SoC}_{i,t=0} - \frac{1}{C_e V_{in_i}} \int p_i dt. \quad (9)$$

By perturbing (9) and transferring the results into the s -domain, the following is derived:

$$s \cdot \hat{\text{SoC}}_i = -\hat{p}_i / (C_e V_{in_i}). \quad (10)$$

Taking the first-order low-pass filter into account, i.e.,

$$\hat{p}_{lpf_i} = G_{lpf} \cdot \hat{p}_i \quad (11)$$

where G_{lpf} is shown as

$$G_{lpf} = \frac{\omega_c}{s + \omega_c} \quad (12)$$

where ω_c is the cutting frequency of the filter.

By combining (6), (10), and (11), it yields

$$m_0 \hat{p}_{lpf_i} = -n \text{SoC}_i^{n-1} (V_{dc}^* - V_{dc_i}) \cdot \hat{p}_{lpf_i} / (C_e V_{in_i} \cdot s G_{lpf}) - \text{SoC}_i^n \cdot \hat{v}_{dc_i}. \quad (13)$$

Then, (13) can be rewritten as

$$\hat{p}_{lpf_i} = -\frac{\text{SoC}_i^n \cdot s G_{lpf}}{m_0 s G_{lpf} + k_{dc_i}} \cdot \hat{v}_{dc_i} \quad (14)$$

where

$$k_{dc_i} = n \text{SoC}_i^{n-1} (V_{dc}^* - V_{dc_i}) / (C_e V_{in_i}).$$

Meanwhile, at the point of common coupling (PCC), the power flow follows the relationship

$$p_1 + p_2 = p_{load} \quad (15)$$

where p_{load} is the load power at the PCC.

It can be assumed that the power cables in a dc microgrid commonly do not present big voltage drops. This can be demonstrated by the line resistance of the power cable, as shown in Table II [19]. The line resistance of a dc system is determined by the cross-sectional area, materials, and structure of the power cable. It is shown in Table II that the line resistance is commonly less than 0.04 Ω/km . Supposing that the active power of 2 kW flows through a resistive line of 1 km and that the voltage rating of the system is about 600 V, it can be calculated

TABLE II
LINE RESISTANCE FOR CONDUCTORS OF POWER CABLES

Cross-Sectional Area /mm ²	Maximum Resistance of Conductor at 20°C		
	Annealed Copper Conductor		Aluminium or Aluminium Alloy Conductor
	Plain Wires / Ωkm^{-1}	Metal-coated Wires / Ωkm^{-1}	Ωkm^{-1}
800	0.0221	0.0224	0.0367
1600	0.0113	0.0113	0.0186
2000	0.0090	0.0090	0.0149

that the voltage drop across the transmission line is less than 0.13 V. However, with the commonly used droop control, the voltage drop caused by the droop function is about 4–6 V, when the load is approximately 2 kW and the voltage level is around 600 V. Compared with the voltage deviation caused by droop control, the voltage drop across the transmission line can be neglected. Hence

$$v_{dc_1} \approx v_{dc_2} \approx v_{dclload} \quad (16)$$

where $v_{dclload}$ is the voltage at the PCC.

At the PCC, it is obtained that

$$p_{load} = \frac{v_{dclload}^2}{R_{load}} \quad (17)$$

where R_{load} is the load resistance.

Thus, by substituting (17) into (15) and perturbing the obtained expression, with the consideration of (11), it yields

$$\hat{p}_{lpf_1} + \hat{p}_{lpf_2} = \frac{2V_{dc} \cdot G_{lpf}}{R_{load}} \hat{v}_{dclload}. \quad (18)$$

By combining (14) and (18), the characteristic equation of the control system is reached as

$$A \cdot s^3 + B \cdot s^2 + C \cdot s + D = 0 \quad (19)$$

where A , B , C , and D are

$$\begin{aligned} A &= \text{SoC}_1^n R_{load} (m_0 \omega_c + k_{dc_2}) + \text{SoC}_2^n R_{load} (m_0 \omega_c + k_{dc_1}) \\ B &= \text{SoC}_1^n R_{load} (m_0 \omega_c^2 + 2\omega_c k_{dc_2}) + \text{SoC}_2^n R_{load} \\ &\quad \times (m_0 \omega_c^2 + 2\omega_c k_{dc_1}) \\ &\quad + 2V_{dclload} (m_0 \omega_c + k_{dc_1}) (m_0 \omega_c + k_{dc_2}) \\ C &= \text{SoC}_1^n R_{load} k_{dc_2} \omega_c^2 + \text{SoC}_2^n R_{load} k_{dc_1} \omega_c^2 \\ &\quad + 2V_{dclload} \omega_c (m_0 \omega_c k_{dc_1} + m_0 \omega_c k_{dc_2} + 2k_{dc_1} k_{dc_2}) \\ D &= 2V_{dclload} k_{dc_1} k_{dc_2} \omega_c^2. \end{aligned}$$

From (19), a stability analysis based on closed-loop poles can be done. By using the parameters shown in Table III, the dominant closed-loop poles with different SoCs and exponents are shown in Fig. 5. The dominant poles with different SoCs are shown with different styles of lines, whereas the poles with different exponents are shown with different numbers. It is found that, in the given condition, the closed-loop poles are all located on the left half of the plane so that the stability of the control system can be ensured.

TABLE III
SYSTEM PARAMETERS

Item	Symbol	Value	Unit
Initial SoC_1	$SoC_{1t=0}$	90	%
Initial SoC_2	$SoC_{2t=0}$	80	%
LPF Cutting Frequency	ω_c	126	rads^{-1}
Converter #1 Input Voltage	V_{in_1}	200	V
Converter #2 Input Voltage	V_{in_2}	200	V
Load Resistance	R_{load}	200	Ω
Load Power	p_{load}	1800	W
Power Rating of the Converter	p_{max}	2500	W




Fig. 5. Root locus plot of the SoC-based droop control with different SoCs and exponents.

D. Power Sharing Speed Adjustment

As aforementioned, by using the SoC-based droop control method, the energy stored in the ESUs with higher SoC decreases faster than that in the ESUs with lower SoC. Thus, after a dynamic process, the SoC in each of the ESUs becomes equal, and the output power of the distributed ESUs is equally shared.

The power sharing speed can be adjusted by changing the exponent n of SoC in (5). By combining (5) and (16)

$$\frac{p_{lpf_1}}{SoC_1^n} = \frac{p_{lpf_2}}{SoC_2^n}. \quad (20)$$

Because the changing of SoC is much slower than that of the output power, it can be assumed that

$$p_1/p_2 \approx p_{lpf_1}/p_{lpf_2} = SoC_1^n/SoC_2^n. \quad (21)$$

Therefore, the load power can be shared according to SoC^n . Considering (9), (15), and (21), it yields

$$SoC_i = SoC_{it=0} - \frac{p_{load}}{C_e V_{in_i}} \int \frac{SoC_i^n}{\sum SoC_i^n} dt. \quad (22)$$

The numeric solutions of (22) can be achieved, and the results are shown in Fig. 6. It is shown that, with larger exponent n , SoC_1 and SoC_2 become equal in a shorter time. At $t = 1500$ s, the differences between SoC_1 and SoC_2 are 3.24%, 1.86%, and 0.34% when the exponent n is selected as 2, 3, and 6, respectively. Meanwhile, the power sharing speed becomes




Fig. 6. Speed regulation of power sharing with different exponent n . (a) Results of the SoC. (b) Detail of the square region in the waveforms of SoCs. (c) Results of the output power.


faster as n increases. At $t = 1500$ s, the differences between p_1 and p_2 are 118.2, 100.3, and 36.5 W when the exponent n is selected as 2, 3, and 6, respectively.

E. Limitation of the Exponent of SoC

As demonstrated before, the power sharing speed can be regulated by the exponent n of each SoC. In order to learn the upper limit of the exponent, the derivation is obtained as follows.

The initial sharing of the load power is changed by different exponent n . From (15) and (21), the initial output power of each converter can be derived as

$$p_{it=0} = \frac{SoC_{it=0}^n}{\sum SoC_{it=0}^n} \cdot p_{load}. \quad (23)$$


 Fig. 7. Initial output power of each converter with different exponent n .

Due to the limitation of the maximum output power of each interface converter, the following is achieved:

$$\frac{\text{SoC}_{i,t=0}^n}{\sum \text{SoC}_{i,t=0}^n} \leq \frac{p_{i \max}}{p_{\text{load}}}. \quad (24)$$

Inequality (24) shows the first limitation of the exponent n . If n is larger than its upper limit, the initial output power of the interface converter will exceed its maximum power rating. The relationship between the initial output power and the exponent n is shown in Fig. 7, where the output power of each converter should not reach the unsafe region.

Meanwhile, except for the consideration of the maximum power rating of the converter, the maximum dc voltage deviation involved by droop control should be taken into account as another restriction for the upper limit of the exponent n . Take Converter 1 as an example. It can be derived from (5) that the deviation of dc bus voltage is shown as

$$\Delta v_{\text{dc}1} = \frac{m_0}{\text{SoC}_1^n} \cdot p_{\text{lpf}1} \quad (25)$$

where the dc voltage deviation $\Delta v_{\text{dc}1}$ should not exceed its maximum acceptable value.

Considering the proportional load power sharing in (21) and the relationship in (15) and (17), it yields

$$\Delta v_{\text{dc}1} = \frac{m_0}{\text{SoC}_1^n + \text{SoC}_2^n} \cdot \frac{(v_{\text{dc}}^* - \Delta v_{\text{dc}1})^2}{R_{\text{load}}}. \quad (26)$$


The deviation of dc voltage $\Delta v_{\text{dc}1}$ can be reached by solving the quadratic equation (26), which is shown as

$$\begin{aligned} \Delta v_{\text{dc}1} &= v_{\text{dc}}^* + \frac{(\text{SoC}_1^n + \text{SoC}_2^n) R_{\text{load}} - \sqrt{\Delta}}{2m_0} \\ \Delta &= 4m_0 v_{\text{dc}}^* R_{\text{load}} (\text{SoC}_1^n + \text{SoC}_2^n) + R_{\text{load}}^2 (\text{SoC}_1^n + \text{SoC}_2^n)^2 \end{aligned} \quad (27)$$

where the other solution of (26) is rejected since $\Delta v_{\text{dc}1}$ should be less than v_{dc}^* .

Assume that

$$k = \text{SoC}_1^n + \text{SoC}_2^n. \quad (28)$$


 Fig. 8. DC voltage deviation with different k .

Therefore, (27) can be rewritten as

$$\Delta v_{\text{dc}1} = v_{\text{dc}}^* + \frac{k R_{\text{load}} - \sqrt{4m_0 v_{\text{dc}}^* R_{\text{load}} k + R_{\text{load}}^2 k^2}}{2m_0}. \quad (29)$$

$\forall k > 0$, it can be obtained that

$$\frac{d\Delta v_{\text{dc}1}}{dk} = \frac{R_{\text{load}}}{2m_0} \left(1 - \frac{2m_0 v_{\text{dc}}^* + R_{\text{load}} k}{\sqrt{4m_0 v_{\text{dc}}^* R_{\text{load}} k + R_{\text{load}}^2 k^2}} \right) < 0. \quad (30)$$

As a result, (29) is a decreasing function of k .

Meanwhile, $\forall k$, $\Delta v_{\text{dc}1}$ should be less than its maximum value, i.e.,

$$[\Delta v_{\text{dc}1}(k)]_{\max} \leq \Delta v_{\text{dc} \max}. \quad (31)$$

Notice that

$$k = \text{SoC}_1^n + \text{SoC}_2^n \geq (\text{SoC}_{1 \min})^n + (\text{SoC}_{2 \min})^n = k_{\min}. \quad (32)$$

It yields

$$[\Delta v_{\text{dc}1}(k)]_{\max} = \Delta v_{\text{dc}1}(k_{\min}) \leq \Delta v_{\text{dc} \max}. \quad (33)$$

The curve of dc deviation versus k is shown in Fig. 8. It is shown that the maximum value of dc deviation is achieved when k has the minimum value and that the maximum deviation should be lower than its upper limit. Since $0 < \text{SoC}_{i \min} \leq 1$ ($i = 1, 2$), it is achieved from (32) that, with larger exponent n , k_{\min} is smaller, which means that $[\Delta v_{\text{dc}1}(k)]_{\max}$ is larger. Therefore, it can be concluded that the upper limit of the exponent n should be determined in order to guarantee that $[\Delta v_{\text{dc}1}(k)]_{\max}$ is lower than its maximum acceptable value.

The lower limit of n is determined by minimizing the power sharing error within the acceptable range in the preset time duration. From (22), by taking the derivative of SoC_1 and SoC_2 for the condition of $i = 1$ and 2, it can be obtained that

$$\frac{d\text{SoC}_1}{\text{SoC}_1^n} = \frac{d\text{SoC}_2}{\text{SoC}_2^n}. \quad (34)$$

In order to enhance the SoC balance speed, n is selected as larger than 1 here. Thus, by solving the differential equation (34), i.e.,

$$\frac{1}{1-n} (\text{SoC}_1^{1-n} - \text{SoC}_2^{1-n}) = \frac{1}{1-n} (\text{SoC}_1^{1-n} - \text{SoC}_2^{1-n})_{t=0}. \quad (35)$$

Then, it yields that

$$\left(\frac{\text{SoC}_1}{\text{SoC}_2} \right)^{1-n} = 1 + \frac{\text{SoC}_1^{1-n} - \text{SoC}_2^{1-n}}{\text{SoC}_2^{1-n}}. \quad (36)$$

When $\text{SoC}_1|_{t=0} \geq \text{SoC}_2|_{t=0}$, it is derived that $(\text{SoC}_1/\text{SoC}_2)|_{t=T} \leq 1 + \varepsilon$. Here, ε is the variable presenting the SoC balancing accuracy, and T is the preset time duration. The acceptable accuracy should be achieved within the time duration T . It should be noticed that $(\text{SoC}_1/\text{SoC}_2)|_{t=T} \geq 1$ and that $1 - n < 0$. Therefore, by using (36), it can be concluded that

$$1 + \frac{\text{SoC}_1^{1-n} - \text{SoC}_2^{1-n}}{(\text{SoC}_2|_{t=T})^{1-n}} \geq (1 + \varepsilon)^{1-n}. \quad (37)$$

By solving the transcendental equation (37), the minimum value of n can be determined.

When $\text{SoC}_1|_{t=0} < \text{SoC}_2|_{t=0}$, it is derived that $(\text{SoC}_1/\text{SoC}_2)|_{t=T} \geq 1 - \varepsilon$. It should be also noticed that $(\text{SoC}_1/\text{SoC}_2)|_{t=T} < 1$ and that $1 - n < 0$. Therefore, also by using (36), it yields

$$1 + \frac{\text{SoC}_1^{1-n} - \text{SoC}_2^{1-n}}{(\text{SoC}_2|_{t=T})^{1-n}} \leq (1 - \varepsilon)^{1-n}. \quad (38)$$

By solving the transcendental equation (38), the minimum value of n can be determined.

A case study is provided here as an example of determining the limitation of the exponent n . If setting $T = 1500$ s and $\varepsilon = 1\%$, the numeric solution of the preceding equations can be obtained, and the lower limit of n is derived as 6. Considering the power rating of each converter, the upper limit of n is determined as 14, and considering the maximum deviation of the dc voltage, the upper limit of n is 8. As a result, the exponent n should be selected within the range of $6 \leq n \leq 8$.

For the aforementioned SoC-based adaptive droop control method, it should be noticed that the SoC of each ESU cannot be lower than its minimum value. When the SoC of the ESU reaches its minimum value SoC_{\min} , the ESU should be cut off and wait for the next charging process.

III. SIMULATION STUDY

Simulations based on MATLAB/Simulink are performed to evaluate the performance of the SoC-based droop control method. The parameters of the system are listed in Table III. Here, the ESU model employed is shown in Section II-B.

Case I—Performance of the Proposed Method With Different Exponents: When the exponent n is equal to 2, the waveforms of SoC and output power in each converter are shown in Fig. 9(a) and (b), respectively. The initial values of SoC_1 and




Fig. 9. SoC and power sharing waveforms for the SoC-based droop control when $n = 2$. (a) Waveforms of SoC_1 and SoC_2 . (b) Waveforms of the output power of each converter.

SoC_2 are 90% and 80%, respectively. During the operation, ESU 1 with larger SoC delivers more power than ESU 2 with lower SoC. As a result, SoC_1 and SoC_2 trend to balance, thus equalizing the output power of each converter. Similar results are obtained when n is equal to 6, as shown in Fig. 10. The same length of time duration is selected when capturing the figures. When $n = 2$, the difference between SoC_1 and SoC_2 changes from 10% to 1.9%, and the difference between p_1 and p_2 changes from 214.3 to 50.9 W. When $n = 6$, the difference between SoC_1 and SoC_2 changes from 10% to almost 0, and the difference between p_1 and p_2 changes from 612.0 W to almost 0. By comparing Figs. 9 and 10, it can be found that, with larger exponent n , the faster dynamic process of power sharing equalization is achieved. This is in accordance with the theoretical analysis.

Case II—Performance of the Proposed Method With Various Initial SoC Differences: In the preceding test in Case I, the difference between the initial SoCs is set to 10%. In order to test the performance of the proposed method, the scenarios with other initial differences are tested. Here, the initial SoC of ESU 1 is fixed to 90%, whereas the initial SoC of ESU 2 varies from 40% to 80%. With the proposed SoC-based droop control method, the waveforms of $\text{SoC}_1 - \text{SoC}_2$ and $p_1 - p_2$ are shown in Fig. 11. It is shown that the differences of SoC and output power gradually become zero. Hence, with various initial differences, the proposed method is still valid.

Case III—Performance of the Proposed Method With the Consideration of the Error in the SoC Estimation: The




Fig. 10. SoC and power sharing waveforms for the SoC-based droop control when $n = 6$. (a) Waveforms of SoC_1 and SoC_2 . (b) Waveforms of the output power of each converter.




Fig. 12. SoC and power sharing waveforms for the SoC-based droop control considering the random error in the estimated SoC. (a) Waveforms of $(\text{SoC}_1/\text{SoC}_2)^n$. (b) Waveforms of the output power of each converter.




Fig. 11. Waveforms of the SoC difference and the output power difference. (a) Waveforms of $\text{SoC}_1 - \text{SoC}_2$. (b) Waveforms of $p_1 - p_2$.

influence of the ampere-hour perturbation is tested by considering the error in the estimated SoC. As shown in Fig. 12, when the random error is involved, the ratio of $(\text{SoC}_1/\text{SoC}_2)^n$ is influenced. However, the ratio of SoC still gradually becomes 1, and the output power equalization is also achieved; thus, the viability of the proposed method can be shown.

Case IV—Performance of the Proposed Method With Load Peaks: The dynamic performance of the SoC-based droop control method with 60-s and 30-s load peaks are shown in Fig. 13. Take the results of 60-s load peak as an example. At the beginning of the power sharing process, the initial difference of the SoC is 10%. Then, at $t = 40$ s, the difference reduces to 4.45% with the proposed method. At that moment, the load peak occurs, and the SoC decreases with a larger slope. At $t = 100$ s, the SoC reduces to 0.47%. From that moment, the load peak ends, and in the following process, the SoC decreases with a smaller slope and then gradually becomes equal. The corresponding process is shown in the waveform of the output power. The difference of the output power changes as follows: 199.5–118.5–25.4–5.7 W.

Case V—Performance of the Proposed Method With Bus Failures: The ride-through capability of the proposed method is tested by considering the bus failure. As shown in Fig. 14, a DESS with three ESUs is taken into account. At $t = 20$ and 60 s, the local buses 3 and 2 are cut off in sequence due to the bus failures. It is shown that, at any time, the load power can be properly shared among the remaining active ESUs by using the SoC-based droop control method.




Fig. 13. SoC and power sharing waveforms for the SoC-based droop control with load peaks. (a) Waveforms of SoC_1 and SoC_2 with 60-s load peaks. (b) Waveforms of the output power of each converter with 60-s load peaks. (c) Waveforms of SoC_1 and SoC_2 with 30-s load peaks. (d) Waveforms of the output power of each converter with 30-s load peaks.




Fig. 14. SoC and power sharing waveforms for the SoC-based droop control considering bus failures. (a) Waveforms of the SoC of each converter. (b) Waveforms of the output power of each converter.

IV. EXPERIMENTAL VALIDATION

In this paper, the SoC balancing is achieved by using an improved droop control method. Therefore, this paper aims at the power sharing between the droop-controlled PCSs. The H-bridge boost converter with the pulsewidth modulation (PWM) method is employed in this paper, and the experimental setup is composed of two parallel converters. Meanwhile, limited to the existing test-bed condition, the ESU is modeled by using real-time simulation. More particularly, the prototype consists of two parts. One part is the 2×2.2 kW parallel converters (real hardware), and the other part is the models of the ESUs as shown in Section II-B (real-time simulation in dSPACE 1103). The input power for each converter is measured in the real hardware converter system and transferred to the real-time model of the ESU. Then, the key variables, such as SoC, are estimated in the real-time model and transferred to the control diagram for calculating the droop coefficients. The configuration of the experimental setup is shown in Fig. 15, and the photo of the prototype is shown in Fig. 16. In order to evaluate the efficiency of the basic interfacing circuit of the H-bridge boost converter, the commonly used loss modeling method is employed [20], and the converter efficiency is shown in Fig. 17.

Similar as that in the simulations, the SoCs and the output power waveforms are shown for $n = 2, 3$, and 6, as shown in Figs. 18–20. The same length of time duration is selected when capturing the figures. When $n = 2$, the difference between SoC_1 and SoC_2 changes from 10% to 1.4%, and the difference between p_1 and p_2 changes from 216.7 to 45.0 W. When $n = 3$,




Fig. 15. Configuration of the experimental setup.




Fig. 16. Photo of the prototype.






Fig. 17. Efficiency evaluation of the commonly used interfacing circuit of the H-bridge boost converter.

the difference between SoC_1 and SoC_2 changes from 10% to 0.95%, and the difference between p_1 and p_2 changes from 311.7 to 16.7 W. When $n = 6$, the difference between SoC_1


 Fig. 18. SoC and power sharing waveforms for the SoC-based droop control when $n = 2$. (a) Waveforms of SoC_1 and SoC_2 . (b) Waveforms of the output power of each converter.

and SoC_2 changes from 10% to almost 0, and the difference between p_1 and p_2 changes from 610.0 W to almost 0. Here, when $n = 6$, the accurate power sharing can be reached within the time duration, and the initial output power of each converter is guaranteed to be lower than the maximum power rating.





Fig. 19. SoC and power sharing waveforms for the SoC-based droop control when $n = 3$. (a) Waveforms of SoC_1 and SoC_2 . (b) Waveforms of the output power of each converter.

The following are shown from the experimental results.

- 1) With the proposed method, the SoCs in different ESUs are gradually balanced. Meanwhile, the output power is equalized.
- 2) Comparing the results in Figs. 18–20, with higher exponent n , the SoC balancing and the load power equalization speed are higher.

V. CONCLUSION

In order to reach dynamic SoC balancing and power sharing of DESSs in dc microgrids, an SoC-based adaptive droop control method has been proposed in this paper. In particular, the droop coefficient is inversely proportional to the n th order of SoC. By using this control method, the ESU with higher SoC delivers more power, whereas the one with lower SoC delivers less power. The difference between the SoCs becomes smaller, and the output power of the converters gradually becomes equal. Meanwhile, the power sharing speed is adjusted by changing the exponent n of SoC. The small-signal model of the control system is derived, and the system stability is guaranteed by the root locus analysis. The limit of the exponent is determined with respect to the power rating of each converter, the maximum value of dc voltage deviation, and the load power sharing accuracy. The proposed approach is used for balancing





Fig. 20. SoC and power sharing waveforms for the SoC-based droop control when $n = 6$. (a) Waveforms of SoC_1 and SoC_2 . (b) Waveforms of the output power of each converter.

the SoCs of distributed ESUs, and the operation does not require communications among the units. Hence, the method is suitable for the microgrid applications.


Furthermore, the proposed method in this paper can be extended to ac microgrids. In order to reach a proper active power sharing, the SoC-based approach can be employed into the $P - f$ droop control for the ac microgrids with inductive line impedances. Meanwhile, in order to reach a proper reactive power sharing, the proposed method in this paper can be employed into the $Q - f$ droop control for the ac microgrids with resistive line impedances.

REFERENCES

- [1] R. Lasseter, A. Akhil, C. Marnay, J. Stevens, J. Dagle, R. Guttromson, S. A. Meliopoulous, R. Yinger, and J. Eto, "The CERTS microgrid concept—White paper on integration of distributed energy resources," US Dept. Energy, Washington, DC, USA, Tech. Rep. LBNL-50829, Apr. 2002.
- [2] H. Kakigano, M. Nomura, and T. Ise, "Loss evaluation of dc distribution for residential houses compared with ac system," in *Proc. IPEC*, 2010, pp. 480–486.
- [3] H. Valderrama-Blavi, J. M. Bosque, F. Guinjoan, L. Marroyo, and L. Martínez-Salamero, "Power adaptor device for domestic dc microgrids based on commercial MPPT inverter," *IEEE Trans. Ind. Electron.*, vol. 60, no. 3, pp. 1191–1203, Mar. 2013.
- [4] X. Lu, J. M. Guerrero, K. Sun, and J. C. Vasquez, "An improved droop control method for dc microgrids based on low bandwidth communication

with dc bus voltage restoration and enhanced current sharing accuracy," *IEEE Trans. Power Electron.*, vol. 29, no. 4, pp. 1800–1812, Apr. 2014

- [5] J. M. Guerrero, J. C. Vasquez, J. Matas, G. G. De Vicuña, and M. Castilla, "Hierarchical control of droop-controlled ac and dc microgrids—A general approach toward standardization," *IEEE Trans. Ind. Electron.*, vol. 58, no. 1, pp. 158–172, Jan. 2011.
- [6] K. Sun, L. Zhang, Y. Xing, and J. M. Guerrero, "A distributed control strategy based on dc bus signaling for modular photovoltaic generation systems with battery energy storage," *IEEE Trans. Power Electron.*, vol. 26, no. 10, pp. 3032–3045, Oct. 2011.
- [7] M. Sechilariu, B. Wang, and F. Locment, "Building integrated photovoltaic system with energy storage and smart grid communication," *IEEE Trans. Ind. Electron.*, vol. 60, no. 4, pp. 1607–1618, Apr. 2013.
- [8] X. Lu, J. M. Guerrero, K. Sun, J. C. Vasquez, R. Teodorescu, and L. Huang, "Hierarchical control of parallel ac-dc converter interfaces for hybrid microgrids," *IEEE Trans. Smart Grid.*, to be published.
- [9] D. Dong, I. Cvetkovic, D. Boroyevich, W. Zhang, R. Wang, and P. Mattavelli, "Grid-interface bi-directional converter for residential dc distribution systems—Part one: High-density two-stage topology," *IEEE Trans. Power Electron.*, vol. 28, no. 4, pp. 1655–1666, 2013.
- [10] H. Kakigano, Y. Miura, and T. Ise, "Distribution voltage control for dc microgrids using fuzzy control and gain-scheduling technique," *IEEE Trans. Power Electron.*, vol. 28, no. 5, pp. 2246–2258, May 2013.
- [11] J. M. Guerrero, P. C. Loh, T. -L. Lee, and M. Chandorkar, "Advanced control architectures for intelligent microgrids—Part II: Power quality, energy storage, and ac/dc microgrids," *IEEE Trans. Ind. Electron.*, vol. 60, no. 4, pp. 1263–1270, Apr. 2013.
- [12] H.-S. Park, C.-E. Kim, C.-H. Kim, G.-W. Moon, and J.-H. Lee, "A modularized charge equalizer for an HEV lithium-ion battery string," *IEEE Trans. Ind. Electron.*, vol. 56, no. 5, pp. 1464–1476, May 2009.
- [13] A. Manenti, A. Abba, A. Merati, S. M. Savaresi, and A. Geraci, "A new BMS architecture based on cell redundancy," *IEEE Trans. Ind. Electron.*, vol. 58, no. 9, pp. 4314–4322, Sep. 2011.
- [14] J. Kim, J. Shin, C. Chun, and B. H. Cho, "Stable configuration of a Li-ion series battery pack based on a screening process for improved voltage/SoC balancing," *IEEE Trans. Power Electron.*, vol. 27, no. 1, pp. 411–424, Jan. 2012.
- [15] L. Maharjan, S. Inoue, H. Akagi, and J. Asakura, "State-of-charge (SOC)—Balancing control of a battery energy storage system based on a cascade PWM converter," *IEEE Trans. Power Electron.*, vol. 24, no. 6, pp. 1628–1636, Jun. 2009.
- [16] H. Zhou, T. Bhattacharya, T. Duong, T. S. T. Siew, and A. M. Khambadkone, "Composite energy storage system involving battery and ultracapacitor with dynamic energy management in microgrid applications," *IEEE Trans. Power Electron.*, vol. 26, no. 3, pp. 923–930, Mar. 2011.
- [17] V. H. Johnson, A. A. Pesaran, and T. Sack, "Temperature-dependent battery models for high-power lithium-ion batteries," presented at the Proc. 17th Annu. Electric Vehicle Symp., Montreal, QC, Canada, Oct. 15–18, 2000, Paper NREL/CP-540-28716.
- [18] D. D. González and R. Diosi, "Accelerated life testing and life-time prediction of lithium ion batteries connected to wind turbine," M.S. Thesis, Dept. Energy Technol., Aalborg University, Aalborg, Denmark, 2011.
- [19] *International Standard for Conductors of Insulated Cables*, IEC 60228, 2004.
- [20] D. Xu, H. Lu, L. Huang, S. Azuma, M. Kimata, and R. Uchida, "Power loss and junction temperature analysis of power semiconductor devices," *IEEE Trans. Ind. Appl.*, vol. 38, no. 5, pp. 1426–1431, Sep./Oct. 2002.



Xiaonan Lu (S'11) was born in Tianjin, China, in 1985. He received the B.E. and Ph.D. degrees in electrical engineering from Tsinghua University, Beijing, China, in 2008 and 2013, respectively.

From September 2010 to August 2011, he was a Guest Ph.D. Student with the Department of Energy Technology, Aalborg University, Aalborg East, Denmark. He is currently with the Department of Electrical Engineering and Computer Science, University of Tennessee, Knoxville, TN, USA. His research interests include control of power electronics

interfacing converters for renewable generation systems and microgrids, multilevel converters, high voltage dc grids, power-electronics-converter based transmission network emulators, and matrix converters.

Dr. Lu is a Student Member of the IEEE Power Electronics Society.



Kai Sun (M'12) was born in Beijing, China, in 1977. He received the B.E., M.E., and Ph.D. degrees from Tsinghua University, Beijing, China, in 2000, 2002, and 2006, respectively; all in electrical engineering.

In 2006, he joined, as a Lecturer of electrical engineering, the Faculty of Tsinghua University, where he is currently an Associate Professor. From September 2009 to August 2010, he was a Visiting Scholar with the Department of Energy Technology, Aalborg University, Aalborg East, Denmark. He has authored more than 80 technical papers, including 9 international journal papers. His main research interests are power converters for renewable generation systems and ac motor drives.

Dr. Sun was the recipient of the Delta Young Scholar Award in 2013.



Josep M. Guerrero (S'01–M'04–SM'08) received the B.S. degree in telecommunications engineering, the M.S. degree in electronics engineering, and the Ph.D. degree in power electronics from Technical University of Catalonia, Barcelona, Spain, in 1997, 2000, and 2003, respectively.

In 2004, he was responsible for the Renewable Energy Laboratory, Escola Industrial de Barcelona, Barcelona. Since 2011, he has been a Full Professor with the Department of Energy Technology, Aalborg University, Aalborg East, Denmark, where he is responsible for the microgrid research program. Since 2012, he has also been a Guest Professor with the Chinese Academy of Science in Nanjing University of Aeronautics and Astronautics, Nanjing, China. His research interests are oriented to different microgrid aspects, including power electronics, distributed energy storage systems, hierarchical control, etc.

Prof. Guerrero is an Associate Editor for the IEEE TRANSACTIONS ON POWER ELECTRONICS and the IEEE TRANSACTIONS ON INDUSTRIAL ELECTRONICS.



Juan C. Vasquez (M'12) received the B.S. degree in electronics engineering from Autonomía University of Manizales, Manizales, Colombia, in 2004 and the Ph.D. degree from Technical University of Catalonia, Barcelona, Spain, in 2009.

He was a Postdoctoral Assistant and a Lecturer, teaching courses based on renewable energy systems, with the Department of Automatic Control Systems and Computer Engineering, Technical University of Catalonia. He is currently an Assistant Professor with Aalborg University, Aalborg East, Denmark.

His research interests include modeling, simulation, networked control systems, and optimization for power management systems applied to distributed generation in ac/dc microgrids.



Lipei Huang was born in Jiangsu, China, in 1946. He received the B.E. and M.E. degrees in electrical engineering from Tsinghua University, Beijing, China, in 1970 and 1982, respectively, and the Ph.D. degree from Meiji University, Tokyo, Japan, in 1996.

In 1970, he joined the Department of Electrical Engineering, Tsinghua University, where he has been a Professor since 1994. In 1987, he was a Visiting Scholar with Tokyo Institute of Technology, Yokohama, Japan, for three months, and with Meiji University, Kawasaki, Japan. He joined the research

projects of the K. Matsuse Laboratory, Department of Electrical Engineering, Meiji University, as a Visiting Professor in 1993. His research interests are in power electronics and adjustable-speed drives.

Prof. Huang was the recipient of the Education Awards from the China Education Commission and Beijing People's Government in 1997. From 2001 to 2003, he was a Delta Scholar.