Electrical: Harness/Cables/Sockets & Distribution Boards

Perform Maintenance Check Frequency Weekly Models Harness/Cables/Sockets & Distribution Boards Estimated Time to Complete 20 Minutes

Health & Safety Hazards



Electricity

Food Safety



Wash and dry hands after performing this task



Ensure nuts, bolts & screws are tight



Inspect equipment. Do not use if damaged

Check for the following

Overhead Cable

- Electrical plug for loose screws and loose or loose/damaged wires
- 2 Power cable for kinks/nicks/splits or other damage
- 3 Socket and plug fit securely into position
- 4 Clip fitting is present and socket cover clips into position

Distribution Board

5 Distribution board covers present and lock into position Kitchen area distribution boards Grill/Fryer stations and harnesses

Harness

- 6 All screws are present and tightened (check behind the socket cover)
- 7 Socket covers are all present, in good condition
- 8 Power cable for kinks/nicks/splits or other damage

Power board

- 9 Sockets, all screws are present and tightened
- 10 Socket covers are all present, in good condition



