

Company 1	Project Name			Logo 2
Close Out Sheet				
PSD-HUC-083	MRU Barge Campaign Post Shutdown Phase CRA			Due Date: 2021-03-27
Activity	Node	Facility	Priority	
		BRG-CPP		
Project Phase			Guideword	
MRU Integration Project Post-Shutdown Phase				
Causes				
Inadequate piping system and equipment design pressure				
Safeguards				
None				
Consequences				
Overpressure of N2 skid piping, hose, fittings leading to projectiles, resulting in personnel injuries / fatality, and damage to asset / equipment.				
Initial risk		Residual Risk		
None		None		
Recommendations/ Actions				
To confirm that Leak Test Procedure and Work packs include checklists for joint verification on design pressure ratings of N2 skid assembly.				

Response		
None		
Remarks	Actionee	
Attachments		
Organisation	MMHE	Signature: Date:
Disipline and Subdisipline	HUC	Signature: Date:
COMPANY COMMENTS		Status
		<input type="checkbox"/> Agree
		<input type="checkbox"/> Agree with comments
		<input type="checkbox"/> Disagree
		<input type="checkbox"/> To be followed
COMPANY Lead Discipline:	Signature:	Date:
COMPANY Lead Safety:	Signature:	Date:
COMPANY Rep (Engineering Coordinator):	Signature:	Date:
<small>The information contained in this document is the proprietary to North Oil Company. It must not be reproduced, stored, disclosed to any third party or used for any purpose not authorized by North Oil Company. Printed documents are uncontrolled and considered as "for information only". Reference should always be made to the on-line EDMS for the updated version</small>		