

Company 1	Project Name			Logo 2
Close Out Sheet				
PSD-HUC-067	MRU Barge Campaign Post Shutdown Phase CRA			Due Date: 2021-04-10
Activity	Node	Facility	Priority	
		BRG-CPP		
Project Phase			Guideword	
MRU Integration Project Post-Shutdown Phase				
Causes				
Unavailability of removed F&G detector and Field Instrument during Post-SD (platform live)				
Safeguards				
None				
Consequences				
Reduction of F&G detection coverage and Unavailability of monitoring instrument (PDIT) on Process - Prolonged isolation, extension of Inhibit / Override certificate requiring review and reassessment for adequacy of available controls / safeguards and mitigations for continued safe operations				
Initial risk		Residual Risk		
None		None		
Recommendations/ Actions				
To perform during SD campaign or immediately after shutdown - Reinstatement of instrument and F&G detector removed during Pre-SD.				

<b>Response</b>		
None		
<b>Remarks</b>	<b>Actionee</b>	
<b>Attachments</b>		
Organisation	MMHE	Signature: Date:
Disipline and Subdisipline	HUC	Signature: Date:
<b>COMPANY COMMENTS</b>		<b>Status</b>
		<input type="checkbox"/> Agree
		<input type="checkbox"/> Agree with comments
		<input type="checkbox"/> Disagree
		<input type="checkbox"/> To be followed
COMPANY Lead Discipline:	Signature:	Date:
COMPANY Lead Safety:	Signature:	Date:
COMPANY Rep (Engineering Coordinator):	Signature:	Date:
<small>The information contained in this document is the proprietary to North Oil Company. It must not be reproduced, stored, disclosed to any third party or used for any purpose not authorized by North Oil Company. Printed documents are uncontrolled and considered as "for information only". Reference should always be made to the on-line EDMS for the updated version</small>		