

Company 1	Project Name			Logo 2
Close Out Sheet				
PSD-HUC-064	MRU Barge Campaign Post Shutdown Phase CRA			Due Date: 2021-04-10
Activity	Node	Facility	Priority	
		BRG-CPP		
Project Phase			Guideword	
MRU Integration Project Post-Shutdown Phase				
Causes				
1. Human errors - Incompetent personnel handling electrical equipment, Incorrect / Inadequate electrical isolations 2. Incorrect / Invalid tools and measurement devices 3. Unrestricted access to area where electrical equipment is energized.				
Safeguards				
None				
Consequences				
Electrocution, Electrical arc flash resulting in personnel injuries / fatality, asset / equipment damage, and inadvertent trips causing disruptions to work activities at CPP requiring investigation, verification of safe work site or rectification works				
Initial risk		Residual Risk		
None		None		
Recommendations/ Actions				
To ensure a Commissioning Work Pack is developed for testing and energization of lighting circuit, upon installation during Post-shutdown campaign.				

<b>Response</b>		
None		
<b>Remarks</b>	<b>Actionee</b>	
<b>Attachments</b>		
Organisation	MMHE	Signature:      Date:
Disipline and Subdisipline	Commissioning	Signature:      Date:
<b>COMPANY COMMENTS</b>		<b>Status</b>
		<input type="checkbox"/> Agree
		<input type="checkbox"/> Agree with comments
		<input type="checkbox"/> Disagree
		<input type="checkbox"/> To be followed
COMPANY Lead Discipline:	Signature:	Date:
COMPANY Lead Safety:	Signature:	Date:
COMPANY Rep (Engineering Coordinator):	Signature:	Date:
<small>The information contained in this document is the proprietary to North Oil Company. It must not be reproduced, stored, disclosed to any third party or used for any purpose not authorized by North Oil Company. Printed documents are uncontrolled and considered as "for information only". Reference should always be made to the on-line EDMS for the updated version</small>		