

Company 1	Project Name		Logo 2	
Close Out Sheet				
PSD-HUC-068	MRU Barge Campaign Post Shutdown Phase CRA		Due Date:	2021-04-10
Activity	Node	Facility	Priority	
		BRG-CPP		
Project Phase		Guideword		
MRU Integration Project Post-Shutdown Phase				
Causes				
Inadequate / unclear work instructions - for work at marshalling cabinet				
Safeguards				
None				
Consequences				
Inadvertent trips causing disruptions to work activities at CPP requiring investigation, verification of safe work site or rectification works, or platform inadvertent shutdown				
Initial risk		Residual Risk		
None		None		
Recommendations/ Actions				
To ensure a Commissioning Work Pack is developed for reconnecting knife switch terminal block at FGS system panel FGS, upon reinstallation during Post-shutdown campaign.				

Response		
None		
Remarks	Actionee	
Attachments		
Organisation	MMHE	Signature: Date:
Disipline and Subdisipline	HUC	Signature: Date:
COMPANY COMMENTS		Status
		<input type="checkbox"/> Agree
		<input type="checkbox"/> Agree with comments
		<input type="checkbox"/> Disagree
		<input type="checkbox"/> To be followed
COMPANY Lead Discipline:	Signature:	Date:
COMPANY Lead Safety:	Signature:	Date:
COMPANY Rep (Engineering Coordinator):	Signature:	Date:
<small>The information contained in this document is the proprietary to North Oil Company. It must not be reproduced, stored, disclosed to any third party or used for any purpose not authorized by North Oil Company. Printed documents are uncontrolled and considered as "for information only". Reference should always be made to the on-line EDMS for the updated version</small>		