

Company 1	Project Name			Logo 2
Close Out Sheet				
PSD-HUC-120	MRU Barge Campaign Post Shutdown Phase CRA			Due Date: 2021-03-27
Activity	Node	Facility	Priority	
		BRG-CPP		
Project Phase			Guideword	
MRU Integration Project Post-Shutdown Phase				
Causes				
Incompatible cat can support fabricated				
Safeguards				
None				
Consequences				
Unable to perform filling activities, requiring site adjustments and rectifications resulting in delays to complete work activities.				
Initial risk		Residual Risk		
None		None		
Recommendations/ Actions				
To ensure that cat can support structure is reviewed and verified for compatibility against cat can funnel and dimensions to be used for Gas / Condensate MRU adsorbent filling activities.				

Response		
None		
Remarks	Actionee	
Attachments		
Organisation	MMHE	Signature: Date:
Disipline and Subdisipline	Commissioning	Signature: Date:
COMPANY COMMENTS		Status
		<input type="checkbox"/> Agree
		<input type="checkbox"/> Agree with comments
		<input type="checkbox"/> Disagree
		<input type="checkbox"/> To be followed
COMPANY Lead Discipline:	Signature:	Date:
COMPANY Lead Safety:	Signature:	Date:
COMPANY Rep (Engineering Coordinator):	Signature:	Date:
<small>The information contained in this document is the proprietary to North Oil Company. It must not be reproduced, stored, disclosed to any third party or used for any purpose not authorized by North Oil Company. Printed documents are uncontrolled and considered as "for information only". Reference should always be made to the on-line EDMS for the updated version</small>		