

LABORATORY TEST RESULTS

Job Number : 18211146	Date : April 14, 2021
Customer : CV Anugerah Alam Abadi	Attention : Mrs. Arsyad
	Coordinate : South 07° 59' 42. 71" East 113° 47' 25. 01"
Customer Sampling Point : Air Limbah Industri	Laboratory Sample ID. : 18211146-3
Date Sampled : 26-Mar-21	Date Received : 29-Mar-21
Time Sampled : 13:25	Time Received : 08:00
Sample Matrix : Water	

NO.	TEST DESCRIPTION*	SAMPLE RESULT	REGULATORY LIMIT **	UNIT	METHOD
	Physical :				
1	Temperature	28.9	-	°C	SNI 06-6989.23-2005
2	Total Suspended Solid, TSS	18	50	mg/L	SNI 6989.3:2019
	Chemical :				
1	pH	8.17	6 - 9	pH Unit	SNI 6989.11:2019
2	Biological Oxygen Demand, BOD ₅	9.47	75	mg/L	SNI 6989.72:2009
3	Chemical Oxygen Demand, COD	25.95	125	mg/L	SNI 6989.2:2019
4	Ammonia, NH ₃ -N	0.094	4	mg/L	SNI 06-6989.30-2005
5	Phenol, C ₆ H ₅ OH	0.002	0.25	mg/L	SNI 06-6989.21-2004

- (*) Accredited by KAN

- (**) Water Standard Quality Regulation, Pergub Jatim 72/2013 (Attachment I.14)

- The test results relate only to the items tested

Signature

Name : Leni Marliani

Title : Technical Manager