



PT. GLOBAL QUALITY ANALITICAL

## LABORATORY TEST RESULTS

Job Number	: 18203688	Date	: November 25, 2020
Customer	: CV Anugerah Alam Abadi	Attention	: Mrs. Arsyad
		Coordinate	: South 07° 59' 42.71" East 113° 47' 25.01"
Customer Sampling Point	: Air Limbah Industri	Laboratory Sample ID.	: 18203688-3
Date Sampled	: 06-Nov-20	Date Received	: 09-Nov-20
Time Sampled	: 14:30	Time Received	: 08:25
Sample Matrix	: Water		

NO.	TEST DESCRIPTION	SAMPLE RESULT	REGULATORY LIMIT ***	UNIT	METHOD
	<b>Physical :</b>				
1	Temperature*	30.3	-	°C	SNI 06-6989.23-2005
2	Total Suspended Solid, TSS*	27	50	mg/L	SNI 06-6989.3-2004
	<b>Chemical :</b>				
1	pH*	7.94	6 - 9	pH Unit	SNI 06-6989.11-2004
2	Biological Oxygen Demand, BOD <sub>5</sub> *	44.30	75	mg/L	SNI 6989.72:2009
3	Chemical Oxygen Demand, COD*	121.38	125	mg/L	SNI 6989.2:2009
4	Ammonia, NH <sub>3</sub> -N*	2.37	4	mg/L	SNI 06-6989.30-2005
5	Fenol*	0.004	0.25	mg/L	SNI 06-6989.21-2004

- (\*) Accredited by KAN

- (\*\*) Water Standard Quality Regulation, Pergub Jatim 72/2013 (Attachment I.14)

- The test results relate only to the items tested

Signature

Name : Leni Mariani  
Title : Technical Manager