

DAILY SUMMARY SHEET

		103 Wheeler Street, Saskatoon, SK Canada S7P 0A4 Telephone: (306) 975-2122 Fax: (306) 975-2125		DATE: Tue, Apr 21, 2026		Rev. 0	
WORK SCOPE: Commissioning		JA TECH REFERENCE #: PF25119-13		CUSTOMER / LOCATION: SaskPower - E.B Campbell			
Job #: P5018.00.4A EBC 7&8 Refurb - Electrical Install		CUSTOMER REFERENCE #: PO4500541082					
DAILY REPORT							
SUMMARY				EXTRAS / DELAYS			
Energize SWGR-114 through SWGR-115 Tie-Breaker connection - Meter results				Stayed an extra 30 mins to discuss Busduct testing / remaining work			
Cold Commissioning Procedure on SWGR-408							
Inspections and mechanical checks on: G8GD1 disconnect Switch, CAB-408 SWGR,							
Point-2-points							
LABOUR							
DESCRIPTION		REPRESENTATIVE		HOURS		DESCRIPTION	
		Chris McLean		ST		See above	
				OT			
				DT			
				ST		See above	
				OT			
				DT			
				ST		10.0	
				OT		1.0	
				DT			
				ST		10.0	
				OT		1.0	
				DT			
				ST			
				OT			
				DT			
				ST			
				OT			
				DT			
				ST			
				OT			
				DT			
				ST			
				OT			
				DT			
				ST			
				OT			
				DT			
EQUIPMENT DESCRIPTION		EQUIPMENT DESCRIPTION		EQUIPMENT DESCRIPTION		EQUIPMENT DESCRIPTION	
Protective Relay Test Set		Power System Recorder		Moving & Hoisting Equipment			
GE, CH, SD Relay Test Sets		Ground Grid Tester		Cable Pulling Equipment			
10kV Power Factor Test Set		IR Camera		Portable Indirect Heater			
10kV Resonator		Online Battery Tester		High Pressure Steam Clean Equipment			
Capacitance/Dissipation Bridge		Battery Load bank Tester		Gas Cutting/Welding Equipment			
Automatic Transformer Turns Ratio Test Set		Safety Ground Test Set		Two Way Radios (set)			
Automatic Transformer Winding Resistance Test Set		Hot Stick Testing Rack		Gas Monitor (qty 2 c/w calibration unit)			
Dry Block Calibrator		Bus Punch & Bender		Portable DC Battery Bank			
Sweep Frequency Response Analyzer (SFRA)		Medium Voltage Terminating Tools		Mobile Knuckle Boom Crane (day)			
DC Over Potential Test Set		High Voltage Terminating Tools		160kW Generator			
AC Over Potential Test Set		Fiber Fusion Splicer		Portable Generators (1400-8000W)			
VLF Over Potential Test Set		Fiber/Communication Test Sets		Track Mounted Work Platform			
Tan Delta Test Set		Oil Transfer Pump/Filter Press		Load Weights			
0-5kV Insulation Resistance/Polarization Index Test Set		Oil Processing Unit		50,000 lb Load Cell			
Automatic Current Transformer Test Set (MultiTap)		Degasification, cleaning, vacuum filling (litres)		Equipment Transport Trailer/Site Trailer			
High Current Supply c/w Timer		Degasification, cleaning (circulation) (litres)		Heavy Equipment Trailer (44,000lbs)			
3 Phase Variac		Compressor & Air Dryer		Portable Oil Storage 1000L			
Contact Resistance Test Set		Oil Dielectric Tester		Portable Fuel Storage			
Circuit Breaker Timer		Dew Point Analyzer		Sea Can			
On-Line Partial Discharge Monitor		Ultrasonic Detector		Emerson Communicator			
Off-Line MV Cable Partial Discharge Unit		Pfisterer Size 6 Connector Test Plugs		Fluke Process Meter			
Sheath Integrity Tester		Safety Grounds, Sensor & Stick		Fluke Calibration Meter			
Cable Locator		Medium Voltage Phasing Sticks		Pressure Kit			
Oscilloscope Spectrum Analyzer		Electric Magnetic Drill		12x25' Oil Containment Berm			
MATERIAL							
MATERIAL DESCRIPTION							
(ATTACH ADDITIONAL BACKUP AS REQUIRED)		QTY		UNIT		QTY	
VEHICLE							
DESCRIPTION		UNIT #		DAYS		KMS	
Field Service Vehicle		210		1			
SIGN-OFF							
JA TECH REP NAME:		David Brown		CUSTOMER REP NAME:			
JA TECH REP SIGNATURE:		David Brown		CUSTOMER REP SIGNATURE:			