

[illegible]

MATERIALS & SUBCONTRACTORS	

Finished grounding in switchgear for unit #7. Cut cables to length for Unit 8 cable bus. Pulled cables down from transformer to switch gear. Installed fire blocks as needed throughout pulls.

Client Approval: _____ Date: _____