



PLEASE FILL IN ALL FIELDS

SHIFT:

DATE: Mar. 23

NAME	TIME IN	TIME OUT	HOURS	OFFICE USE	JA TECH JOB #	PHASE #	JA TECH VEHICLE UNIT #	DESCRIPTION OF WORK	EQUIPMENT USED
RJ Lacsamana	6:00	6:00	11.5		PF25119	4	112	QA/QC / Supervisor	1 x Equipment Trailer
Ryan Peng					PF25119				
Grant Bennett	6:00	6:00	11.5		PF25119	4		15kv cable testing 414T-SWGR Batt charger receptacle install + test vibe system planning	
Brendon Fehr	6:00	6:00	11.5		PF25119	4		inspect 114, 414, ground 408 SWGR, start terminating 408	
Jamie Harvey	6:00	6:00	11.5		PF25119	4	110	Terminate cables in panels / QA/QC BD-567, BD-022, BD-70B115-1, BD-016	
Brennan Hatcher	6:00	6:00	11.5		PF25119	4		Terminate Data, Pull grounds in unit 8; build rack for grounds	
Gustav Boshoff	6:00	6:00	11.5		PF25119	4		Cleaned 480V SWGR and 414T. Then finished putting cobra clamps for the 250kcmil going to 480V SWGR and started glanding ground in NGR	
FOR OFFICE USE:									

- * EVERYONE SIGNED IN AND OUT?
- * ALL TIME IN AND OUT VERIFIED?
- * CORRECT JOB # USED?
- * DETAILED DESCRIPTION OF DAILY WORK PROVIDED?
- * ALL EQUIPMENT/TRAILERS USED VERIFIED/NOTHING MISSED?

Team Lead/Foreman Name: _____
Team Lead/Foreman Signature: _____