AquaGuard Official Inspection Report

Report ID: INS-57 | Date: 2026-09-07 15:10:43
Inspector: jay (senior water analyst)
Client Name: Devika S
Water Source: Lake Water (Type: Online Inspection)

1. AquaGuard AI Diagnostic & Laboratory Values

AI Status prediction: UNSAFE

Temperature: 21.0 °C	Dissolved Oxygen: 1.0 mg/L
pH Level: 7.0	BOD: 6.0 mg/L
Conductivity: 8.0 uS/cm	Nitrate: 1.0 mg/L
Faecal Coliform: 0.0 MPN/100ml	Total Coliform: 0.0 MPN/100ml

2. Online Inspection Recommendations

Final Recommendation: Not Safe for Drinking **Purification Method: Activated Carbon Filtration**

Recommended Method Details / Remarks:

Method details for Activated Carbon Filtration: - Description: Absorption filtration using highly porous activated carbon blocks. - Used for: Removing chlorine, bad taste, odour, organic chemical compounds, and radon. - Water Quality Impact: Absorbs organic contaminants and chlorine, improving taste and clarity. - Instructions: Pitcher filters, faucet attachments, or pre-filters in larger systems. - Precautions: Does not remove heavy metals, fluoride, or pathogens on its own. - Maintenance: Change filter cartridges regularly (typically every 3-6 months) to avoid bacterial growth.

Precautions:

ghhg

Follow-up Required: Yes **Follow-up Date: 2026-09-22**