

INTERNAL CLAIMS MASTER RECORD

Standard ISO/ACORD 25 Claims Profile | Commercial General Liability - Property Damage Evaluation

1. POLICY & CLAIM REGISTRY MATRIX

The following table:

Claim Number	CL-2025-1118-892
Policy Number	GL-334981-2025
Policy Symbol	CGL-TX-PD (Commercial General Liability - Coverage A)
Insured Legal Name	Apex Mechanical & Plumbing Solutions LLC (DBA: Apex Industrial Contracting)
Policy Term	Effective: 04/01/2025 12:01 AM Expiration: 04/01/2026 12:01 AM
Limits Matrix	Each Occurrence Limit: \$1,000,000.00 Fire Damage Limit: \$100,000.00
Deductible Structure	Per Occurrence Property Deductible - Deductible Amount: \$5,000.00
Broker Info	Broker / Agency Code: BRK-TEXAS-GULF Producer: Melissa Vance (713-555-0114)
Claim Status	Open - Liability Formally Accepted
Assigned Adjuster	Marcus Vance (Senior Liability Analyst)

2. TEMPORAL & SPATIAL INCIDENT METRICS

The following table:

Date of Occurrence	11/18/2025	Exact Time of Incident	02:45 PM CST
Date Reported to Carrier	11/19/2025 08:30 AM	Intake Channel Method	Telephonic Hot-Line Agent Entry
Loss Street Address	1001 McKinney St, Floor 5	City, State, Zip Code	Houston, TX 77002
Specific Location Code	Main Server Data Core Facility	Geo Coordinates	29.7564° N, 95.3659° W
Reported By (Full Name)	Arthur Pendelton	Reporter Title / Relation	Project Operations Manager
Reporter Direct Phone	(713) 555-9844	Reporter Email Address	a.pendelton@apexmech.com

3. AGGRIEVED THIRD PARTY & CLAIMANT FINANCIAL RECONCILIATION

The following table:

Claimant Corporate Name	Sovereign Data Hosting Infrastructure Inc
Primary Property Form	Commercial High-Density Server Facility
Corporate Entity ID	TX-88391204
Registered Corporate Agent	Capitol Corporate Services, Inc.
Corporate Address	206 E 9th St, Suite 1300, Austin, TX 78701
Corporate Legal Contact	(512) 555-0166 claims@sovereigndata.io
Primary Property Damage	Severe Structural Water Flooding (Floor 5 Data Room Core)
Secondary Loss Metric	Complete Hardware Loss of Use, Cascading Business Interruption
Municipal Emergency Force	Yes - Houston Fire Dept Dispatched (HFD Station 8 Downtown Fleet)
Incident Report Link	HFD-ENGINE-08-992144 (Hazardous structural water extraction executed)
Gross Evaluated Loss	\$793,200.00 (Per Itemized Invoice VAL-2025-99821)
Less Policy Deductible	-\$5,000.00 (Insured Share Applied)
Net Claim Total	\$788,200.00 (Net Carrier Exposure Under Occurrence Limit)

4. PHYSICAL EVIDENCE INVENTORY MANIFEST

The following table:

ITEM ID	DESCRIPTION OF PHYSICAL EVIDENCE	RECOVERY LOCATION	DAMAGE STATUS
EV-01	Ruptured 4-inch copper main pipeline segment. Exhibits extensive structural tearing, thermal deformation from welding apparatus, and jagged pressure fracture lines.	Floor 6 Plumber Overhead Welding Rig Zone	DESTROYED/ CORE
EV-02	14 Enterprise Server Rack Cabinets (Serial arrays SDH-R01 to SDH-R14). Deep structural water logging, internal circuit shorting, mineral salt residual tracing.	Floor 5 Server Data Core Facility	CATASTROPHIC SHORT
EV-03	72 Integrated Blade Server Compute Nodes and Storage Controller modules extracted from ruined rack enclosures. Monitored for heavy hardware multi-point shorts.	Floor 5 Core Computing Arrays	TOTAL LOSS
EV-04	High-density anti-static raised flooring tile samples (2,500 sq ft zone affected). Warped composite cores, complete adhesive failure, and lower support channel corrosion.	Floor 5 Data Center Main Sub-floor	SEVERE WARPING
EV-05			

ITEM ID	DESCRIPTION OF PHYSICAL EVIDENCE	RECOVERY LOCATION	DAMAGE STATUS
	Houston Fire Department Incident Logs & Structural Water Extraction Receipts (HFD-ENGINE-08-992144). Documenting high-volume extraction pump routing.	HFD Station 8 Fleet Dispatch Archive	OFFICIAL RECORD

5. MATERIAL INDEPENDENT WITNESS LEDGER

The following table:

WITNESS NAME	MAILING/PHYSICAL ADDRESS	PHONE NUMBER	AFFILIATION / STANDPOINT SUMMARY
Raymond Vance	1001 McKinney St, Houston, TX 77002	(713) 555-1244	Building Chief Engineering Consultant. Confirmed main line split under 90 PSI directly above server racks; flow lasted 40 mins before street valve cutoff.
Clara Vance-Ames	1200 Travis St, Houston, TX 77002	(713) 555-7022	Facility Security Control Specialist. Noted critical moisture alarms at 02:45 PM followed by server enclosure waterfall feeds and automated panel shorts.

6. CHRONOLOGICAL CLAIMS ACTION LOG

The following table:

TIMESTAMP	ACTION ACTOR	OPERATIONAL ENTRY DESCRIPTION / ACTIVITY LOG NOTES
11/19/2025 08:30 AM	Intake Desk (System)	First Notice of Loss (FNOL) entered telephonically via reporter Arthur Pendelton. Coverage flags valid under Policy GL-334981-2025.
11/20/2025 10:15 AM	M. Vance (Adjuster)	Claim file initialized and assigned. Requested municipal extraction logs (HFD-ENGINE-08-992144). Established initial reserve buckets.
11/24/2025 04:00 PM	M. Vance (Adjuster)	Site inspection forensic data integrated. Verified accidental contact by insured's welding crew breached copper line. General Liability fault accepted.
12/05/2025 11:45 AM	M. Vance (Adjuster)	Received itemized Damage Valuation Invoice VAL-2025-99821 from third-party claimant. Adjusted active evaluation reserve target to matching net \$788,200.00. File ready for final settlement authorization.

7. DESCRIPTIVE LOSS ADMINISTRATIVE SUMMARY

"While performing high-pressure chilled-water pipe modifications on Floor 6, the insured's welding team accidentally contacted and ruptured a pressurized 4-inch structural main supply line via high-temperature torches. Water pressurized at 90 PSI escaped continuously for approximately 38 minutes prior to regional municipal valve containment. The effluent volume (~3,420 US Gallons) migrated vertically into Floor 5, directly penetrating the ceiling envelope of Sovereign Data Hosting's core server enterprise array. Over 14 structural rack enclosures containing 72 blade computing nodes suffered immediate multi-point catastrophic hardware shorts. Independent engineering reviews and itemized procurement invoicing establish a gross evaluated property and business interruption loss of \$793,200.00. Following the contractual application of the \$5,000.00 per-occurrence property deductible, the net insurance carrier settlement liability is fixed at \$788,200.00."