Entity-Token World Models and Differentiable Predictive Control for Building-Agnostic HVAC Control

Lorenzo Giannuzzo, Daniele Salvatore Schiera, Francesco Demetrio Minuto,
Andrea Lanzini
Energy Center Lab, Department of Energy "Galileo Ferraris", Politecnico di Torino
Corso Duca degli Abruzzi 24, 10129 Turin, Italy
lorenzo.giannuzzo@polito.it, daniele.schiera@polito.it,
francesco.minuto@polito.it, andrea.lanzini@polito.it

Abstract

A single controller for the Heating, Ventilation and Air Conditioning (HVAC) systems of buildings it has never seen has to cope with a different number of zones, air handlers and thermal properties in every building, as well as with climates ranging from subarctic winters to tropical summers. This work addresses the Smart Buildings Challenge with a policy that learns its own control logic, without deep reinforcement learning and without imitating an existing controller. Every zone, air handler, hot-water system and the building as a whole is represented as a token, and a transformer whose attention is biased only by the structural relation between two tokens is used both as a learned world model of the building and as the control policy, thereby making both networks independent of the building size. The policy is trained by Differentiable Predictive Control (DPC), that is, by backpropagating the competition reward, rebuilt from the predicted temperatures and power, through closed-loop rollouts of up to 24 hours inside the world model, while the world model is refined in successive on-policy rounds. On the 30 official scenarios evaluated over 14 days, the final policy reduces the mean absolute step reward from 0.0591 for the shipped PID baseline to 0.0106, and it reaches 0.013 on the Kaggle public leaderboard. The experiments further indicate that the calibration of the world model on the comfort term matters more than its average temperature error, and that a long planning horizon becomes beneficial only once the world model is accurate enough.

1 Introduction

Buildings account for a large share of energy use and carbon emissions, and their HVAC systems are still mostly operated by rule-based logic tuned by hand for each building [4, 13]. Model predictive control and reinforcement learning have repeatedly shown large savings on individual buildings, but both require a model or a training process specific to the building at hand, and this cost has so far prevented their deployment at scale [11]. The Smart Buildings Challenge [7], built on the Smart Buildings Control Suite simulator [6], makes this obstacle explicit by asking for one policy that controls buildings never seen during development, with different floor plans, numbers of zones and air handlers, envelope materials and weather, and that is scored on a reward combining occupant comfort, energy cost and carbon emissions.

The approach presented here rests on two choices. First, the building is described as a set of entities (zones, air handlers, the hot-water system and a global token for weather and time), and the same transformer architecture, with attention biased by the structural relation between entities, is used for a

Smart Buildings Competition Track at 40th Conference on Neural Information Processing Systems (NeurIPS 2026).

world model of the building and for the policy, so that both apply to any building without modification. Second, the policy is not trained by trial and error on the simulator, nor by imitation of a baseline controller, but by DPC [5]: the competition reward is rebuilt from the world-model predictions and maximized by backpropagation through closed-loop rollouts, thereby letting the policy derive its own control logic from the physics captured by the world model. The main contributions of this work are the following:

- an entity-token world model with long thermal memory, trained on procedurally generated buildings and refined in on-policy rounds, which reaches a closed-loop temperature error of 0.82 K after 24 hours on unseen buildings;
- a DPC training scheme with a 24-hour horizon, a command filter inside the rollouts and a comfort weighting of the reward, which yields a policy with a local score of 0.0106 and a Kaggle score of 0.013, starting from 0.0591 for the shipped baseline;
- an experimental analysis showing that the comfort calibration of the world model and its accuracy over long horizons, rather than its average short-term error, determine the quality of the resulting policy.

2 Related Works

The Smart Buildings Challenge [7] is the first benchmark in which a single HVAC policy is evaluated on unseen buildings generated at scale, using the simulator of the Smart Buildings Control Suite [6]; earlier benchmarks such as BOPTEST [2] provide detailed but individual test cases. Model Predictive Control (MPC) is the reference for advanced building control [4], although its dependence on a model identified for every building limits its scalability. Deep reinforcement learning has been applied to HVAC control since [14], and the review in [13] identifies sample efficiency, safety during training and the transfer to new buildings as its main obstacles; transfer learning across buildings is reviewed in [11], where most approaches still fine-tune a model on the target building.

Differentiable control combines the two families. Differentiable MPC [1] embeds an optimization problem in a policy, and Gnu-RL [3] applies it to building HVAC control with a linear model; DPC [5] instead trains an explicit neural policy offline by differentiating a control objective through a model of the system, and it is the formulation adopted in this work. Learned world models [8, 9] allow policies to be trained in imagination, and the exploitation of model errors by the policy, discussed in [10], is the main failure mode encountered in the present experiments as well; short-horizon actor-critic methods such as SHAC [15] address long horizons with a learned value function, whereas the present work relies on an accurate world model and on gradient damping to differentiate directly through horizons of 24 hours. The entity-token architecture follows the transformer [12], and the attention bias depending on the relation between two nodes is inspired by Graphormer [16].

3 Methods

3.1 Problem Setting

At every 5-minute step t, the policy receives the observation o_t of a building with V zones and K air handlers, which contains the air temperature, heating and cooling setpoints, damper and reheat readbacks and airflow setpoint of every zone, the supply-air temperature, static pressure and airflow measurements and setpoints, outside-air flow, recirculation, cooling requests and outdoor air temperature of every air handler, the supply-water temperature, differential pressure, heating requests and run status of the hot-water system, the comfort-mode flags, the number of occupants and the time, and it returns the action a_t, made of the damper and reheat-valve commands $(u_v^{\mathrm{d}}, u_v^{\mathrm{r}})$ of every zone v, the run state, supply-air temperature, static pressure and recirculation commands of every air handler k, and the run state, supply-water temperature and differential pressure of the hot-water system. Continuous commands are normalized to $[-1, 1]$ and on/off commands are binary. The step reward is

$$r_t = w_p \, R_t - w_e \, \tilde{E}_t - w_c \, \tilde{C}_t, \tag{1}$$

where $R_t \leq 0$ is the productivity regret of the occupants, computed from the deviation $\delta_{v,t} = \max(T_{v,t} - T_{v,t}^{\mathrm{c}}, \, T_{v,t}^{\mathrm{h}} - T_{v,t}, \, 0)$ of every occupied zone from its comfort band through a shortfall




Figure 1: Entity-token architecture shared by the world model and the policy (same structure, separate weights), and the DPC training loop that connects them.

that grows linearly up to a reference deviation and quadratically beyond it, and $\tilde{E}_t$ and $\tilde{C}_t$ are the energy cost and carbon emissions of electricity and natural gas at the current tariffs and carbon intensities, normalized by their values at the maximum rates. The score of a policy is the mean absolute step reward $S = \frac{1}{N}\sum_t |r_t|$ over all steps and scenarios, so that lower is better.

3.2 Entity-Token Architecture

The architecture shared by the world model and the policy is outlined in Figure 1.

As can be observed in Figure 1, a building is represented by $N = V + K + 2$ tokens, one per zone, one per air handler, one for the hot-water system and one global token. The input vector of zone v concatenates its normalized observations, its last three temperature changes, its previous commands and seven static descriptors g_v extracted once from the floor plan, namely the logarithm of the floor area, the exterior-wall fraction, the exterior wall per square root of area, the floor position, the ground-floor and top-floor flags and the number of zones served by the same air handler; air-handler and hot-water tokens concatenate their sensors, including the outdoor air temperature measured by every air handler, with their previous commands, while the global token carries the comfort-mode flags, the number of occupants, the hour and day of the week and, for the policy, the hours to the next scheduled comfort period, the hours left in the current one and a working-day flag. Each token type $c \in \{\mathrm{zone}, \mathrm{ahu}, \mathrm{hws}, \mathrm{glob}\}$ has its own two-layer encoder and a learned type embedding,

$$x_i^{(0)} = \mathrm{MLP}_c(\mathrm{in}_i) + e_c, \tag{2}$$

after which L pre-norm transformer layers [12] process all tokens jointly. The only structural information enters through the attention logits: each pair of tokens (i, j) belongs to one of ten relations $\rho(i, j)$ (two zones on the same air handler or on different ones, a zone and its own or another air handler in both directions, two air handlers, any token and the hot-water system, any token and the global token, and a token with itself), and every head h of layer ℓ adds a learned scalar to the corresponding logit,

$$A_{ij}^{(\ell,h)} = \mathrm{softmax}_j\left(\frac{q_i^{(\ell,h)} \cdot k_j^{(\ell,h)}}{\sqrt{d_h}} + b_{\rho(i,j)}^{(\ell,h)}\right), \tag{3}$$

in the spirit of Graphormer [16], with the biases initialized to zero. Since no parameter depends on V or K and the relations are defined by the zone-to-air-handler map only, the same weights apply to every building, and every zone receives the information of its air handler, of the plant and of the zones that share its supply air through attention rather than through a fixed graph. Separate linear heads read the output tokens: continuous commands pass through a hyperbolic tangent, while on/off commands use a hard threshold in the forward pass and the gradient of the underlying sigmoid in the backward pass (straight-through estimator). The sizes of both networks are reported in Table 1.

Algorithm 1 On-policy rounds of world-model and policy training.

$\mathcal{D} \leftarrow$ episodes of the exploration policy on the generated buildings; train f_ϕ on $\mathcal{D}$ with (6)
initialize π_θ by DPC on f_ϕ (Algorithm 2)
for round $n = 1, 2, \dots$ **do**
    $\mathcal{D}_n \leftarrow$ one 14-day episode per generated building with π_θ, partly with action noise
    fine-tune f_ϕ on $\mathcal{D} \cup \mathcal{D}_n$ with half of every batch from $\mathcal{D}_n$; $\mathcal{D} \leftarrow \mathcal{D} \cup \mathcal{D}_n$
    diagnose f_ϕ on clean episodes of a fixed policy (temperature error, reward-term ratios)
    $\pi_\theta \leftarrow$ DPC on f_ϕ (Algorithm 2); evaluate in the simulator on the official scenarios
end for

3.3 World Model

Given the state s_t (the token inputs above), the action a_t and the exogenous inputs x_t read from the episode (weather, setpoints, occupancy, tariffs and carbon intensities), the world model f_ϕ predicts the normalized temperature change of every zone, the next actuator readbacks of every zone, the next sensor values of every air handler and of the hot-water system, and the electric and gas power of the building, the latter as sums of non-negative contributions of the individual tokens,

$$\begin{aligned} &\hat{T}_{v,t+1} = \hat{T}_{v,t} + \sigma_{\Delta T}\, \Delta\hat{T}_{v,t}, \\ &\hat{P}^{\mathrm{el}}_t = \textstyle\sum_k \mathrm{softplus}(y^{\mathrm{el}}_k) + \mathrm{softplus}(y^{\mathrm{el}}_{\mathrm{hws}}), \qquad \hat{P}^{\mathrm{gas}}_t = \textstyle\sum_v \mathrm{softplus}(y^{\mathrm{gas}}_v) + \mathrm{softplus}(y^{\mathrm{gas}}_{\mathrm{hws}}), \end{aligned} \tag{4}$$

from which the reward (1) is rebuilt exactly. Since walls, slabs and interior mass store heat that is not observed, the air temperature and its last changes cannot distinguish a zone with cold walls after a winter weekend from one with warm walls at the same air temperature; each zone token is therefore augmented by a long memory of exponential averages,

$$m^{(\tau)}_{v,t+1} = e^{-1/\tau}\, m^{(\tau)}_{v,t} + \left(1 - e^{-1/\tau}\right) \hat{T}_{v,t+1}, \tag{5}$$

of its temperature over $\tau = 12$, 72 and 288 steps (1, 6 and 24 hours), of its reheat and damper commands over 6 and 24 hours and of the outdoor air over 6 and 24 hours, which the rollout updates from its own predictions.

The model is trained on closed-loop unrolls of $U \in \{48, 144, 288\}$ steps (4, 12 and 24 hours) in which its own predictions are fed back while the logged actions are replayed, by minimizing

$$\mathcal{L}(\phi) = \frac{1}{U} \sum_{k=1}^{U} \Big(\frac{\sum_v \omega_v (\hat{T}_{v,k} - T_{v,k})^2}{\sigma^2_{\Delta T} \sum_v \omega_v} + w_R \big(\hat{R}_k - R_k\big)^2 / \sigma^2_R + w_s\, \mathcal{L}^{\mathrm{sens}}_k + w_P \left\| \hat{P}_k - P_k \right\|^2 \Big), \tag{6}$$

where the zone weight $\omega_v = 1 + 3 \cdot \mathbb{1}[\text{occupied and within 1 K of or outside the band}]$ concentrates the accuracy where the reward is sensitive to temperature errors, the second term matches the comfort part of the reward directly, so that the error is measured in the units used by the DPC objective, with $\sigma_R = 0.1$, and $\mathcal{L}^{\mathrm{sens}}$ collects the errors on readbacks and sensors; unrolls longer than 4 hours are recomputed in the backward pass (gradient checkpointing), so that memory does not grow with U.

The training data come from about 140 buildings produced by the official generator, with seeds disjoint from all evaluation sets, under six weather stations (Atlanta, Denver, Fairbanks, Minneapolis, Phoenix and Singapore). The first episodes were collected with an exploration policy switching every few hours between the shipped PID controller, its noisy version, randomly held setpoints and extreme plant states, so that the model sees the whole range of the actuators. Afterwards, training alternates between the policy and the world model in on-policy rounds, summarized in Algorithm 1: in every round the current policy runs one long episode per building, mostly as is and partly with action noise or short idle and randomly held segments, and the world model is fine-tuned with half of each batch drawn from the new episodes, thereby correcting it precisely in the states that the policy visits, which are the states in which DPC exploits its errors.

3.4 Differentiable Predictive Control

The policy is trained by DPC [5], as detailed in Algorithm 2. From a batch of true start states s_{t_0} drawn from the collected episodes, the policy acts on the predicted states, the world model predicts

Algorithm 2 DPC training of the policy through the world model.

for iteration $i = 1, \dots, I$ **do**
  $H \leftarrow$ curriculum horizon; sample an episode and B start indices t_0; $\hat{s}_{t_0} \leftarrow s_{t_0}$; $\tilde{u} \leftarrow$ logged commands
  for $k = 0, \dots, H-1$ **do**
    $u \leftarrow \pi_\theta(\hat{s}_{t_0+k})$; $\tilde{u} \leftarrow \alpha u + (1-\alpha)\tilde{u}$ on continuous commands (9)
    $\hat{s}_{t_0+k+1} \leftarrow f_\phi(\hat{s}_{t_0+k}, \tilde{u}, x_{t_0+k})$; $\hat{r}_{t_0+k} \leftarrow$ reward (7) rebuilt from $\hat{T}$, $\hat{P}$; update memory (5)
    damp the state gradient (8) ▷ recomputed in the backward pass
  end for
  $\theta \leftarrow \mathrm{AdamW}\big(\theta, -\nabla_\theta J\big)$ with clipped gradient norm, unless the loss is not finite
end for

Table 1: Architecture and training settings of the world model and of the final policy.

World Model	
Layers, width, heads, feed-forward	4, 128, 4, 256
Parameters	0.61 M
Unroll lengths U [steps]	48, 144, 288
Loss weights w_R, w_s, w_P	5, 0.3, 10
Memory time constants τ [steps]	12, 72, 288
Batch, steps per round	16 unrolls, 1000
Optimizer, learning rate	AdamW, $5 \cdot 10^{-5}$

Policy And DPC	
Layers, width, heads, feed-forward	3, 64, 4, 128
Parameters	0.12 M
Horizon H (curriculum) [steps]	144, 288
Discount γ, damping λ	0.995, 0.99
Comfort factor κ, filter α	1.8, 0.3
Batch B, iterations I	24 starts, 400
Optimizer, learning rate	AdamW, $3 \cdot 10^{-4}$

the next state with the exogenous inputs of the episode and the reward is rebuilt from the prediction, so that the objective

$$J(\theta) = \mathbb{E}_{s_{t_0}}\Big[\frac{1}{H}\sum_{k=0}^{H-1}\gamma^k\,\hat{r}_{t_0+k}\Big], \qquad \hat{r}_t = \kappa\, w_p \hat{R}_t - w_e\hat{\tilde{E}}_t - w_c\hat{\tilde{C}}_t, \tag{7}$$

is maximized by backpropagation through the whole closed loop, where the factor $\kappa > 1$ on the comfort term counteracts the tendency of the policy to trade comfort for energy inside the world model. Three mechanisms make the optimization over horizons of hundreds of steps stable and transferable to the simulator. First, the gradient carried by the predicted state from one step to the previous one is damped without changing its value,

$$\hat{s}_{k+1} \leftarrow \mathrm{sg}(\hat{s}_{k+1}) + \lambda\big(\hat{s}_{k+1} - \mathrm{sg}(\hat{s}_{k+1})\big), \tag{8}$$

where sg stops the gradient, so that the credit assigned to an action by a reward h steps later is weighted by λ^h and the backpropagation does not explode. Second, since the policy otherwise reacts to world-model errors with fast oscillating commands, which the real plant does not reward, every continuous command is filtered both inside the rollouts and at deployment,

$$\tilde{u}_t = \alpha\, u_t + (1-\alpha)\,\tilde{u}_{t-1}, \tag{9}$$

and the policy receives the filtered commands as its previous actions, exactly as in the building. Third, the horizon follows a curriculum from 12 to 24 hours, which is long enough for the policy to experience the effect of preheating before occupancy and of letting the building drift at night and over the weekend. Every update uses gradient-norm clipping, and updates with a non-finite loss are skipped; the start states exclude the generated buildings larger than the official size range, and every policy is warm-started from the policy of the previous round. The values used for the final policy are listed in Table 1.

4 Results

4.1 Evaluation Protocol

Policies are evaluated in the simulator on the 30 official training scenarios (six buildings under five weather stations), none of which is used for training, over 14 days (4032 steps), so that every episode includes a weekend and the following Monday start-up; earlier stages were evaluated over 7 days. The local 14-day score proved to be a reliable predictor of the hidden Kaggle evaluation: for the three policies submitted, the ratio between the Kaggle score and the local score was 1.23, 1.29 and 1.23, compared with 1.39 and 1.48 for the 7-day protocol.




Figure 2: Mean absolute step reward of the shipped PID baseline and of the successive stages of the method, on the 30 official scenarios over 14 days and on the Kaggle public leaderboard.




Figure 3: Score of each official scenario over 14 days, for the filtered policy on world model v10 (horizontal axis) and the final policy (vertical axis); points below the diagonal are improvements.

4.2 Overall Performance

The progression of the method is summarized in Figure 2.

As can be observed in Figure 2, the first entity-token policy trained by DPC already reduces the score of the PID baseline from 0.0591 to 0.0155, that is, by 74%, and every following stage brings a further reduction, down to 0.0106 for the final policy, which corresponds to 0.013 on the Kaggle public leaderboard, against 0.019 for the first entity-token policy submitted. The largest single gain comes from the 24-hour horizon trained with the command filter in the loop (from 0.0133 to 0.0106), whose effect on the individual scenarios is shown in Figure 3.

As can be observed in Figure 3, the final policy is better in 23 of the 30 scenarios, with the largest reductions in the cold climates (Fairbanks 1 from 0.089 to 0.068, Fairbanks 8 from 0.046 to 0.027), while in the remaining scenarios the differences are within a few percent. Figure 4 shows how this is achieved during the first week of Fairbanks 1, when the outdoor air drops below $-35\,^{\circ}\mathrm{C}$: the final policy delivers more heat in the second half of each working day, thereby keeping the coldest zones closer to the heating setpoint, at the price of an 11% higher gas consumption, and its mean step reward over the week improves from -0.0650 to -0.0548. Over the 30 scenarios the comfort term is more than halved (from 0.0065 to 0.0026), whereas the energy and carbon terms grow only slightly (from 0.0041 to 0.0043 and from 0.0033 to 0.0037, respectively).




Figure 4: First week of Fairbanks 1 (official building 1): outdoor air temperature, 10th percentile of the zone temperatures and natural gas power of the filtered policy on world model v10 and of the final policy.

Table 2: World-model diagnostics after 24 hours (temperature mean absolute error and bias, ratio of predicted to true comfort and energy terms) and 14-day score of the policies trained on each model.

World Model	Replay MAE [K]	Closed-Loop MAE [K]	Closed-Loop Bias [K]	Comfort Pred./True	Energy Pred./True	Policy (Horizon) 14-Day Score [-]
v8	1.38	1.13	+0.43	0.96	0.95	Entity-Token (6–12 h): 0.0155
v9	1.50	1.35	+1.07	0.92	1.09	–
v10	0.87	0.87	−0.18	1.22	1.22	Filter (6–12 h): 0.0139
v11	0.89	0.82	+0.06	1.00	1.10	Filter (6–12 h): 0.0133
						Filter In Training (24 h): **0.0106**
v12	0.78	0.79	−0.01	1.07	1.20	Filter In Training (24 h): 0.0121

4.3 World-Model Quality and Policy Quality

The world models were diagnosed on 45 clean episodes driven by a fixed policy, 30 on the official scenarios and 15 on unseen benchmark buildings, from 1080 start states, both by replaying the logged actions and in closed loop with the policy acting inside the model. Table 2 relates these diagnostics to the policies trained on each model.

As reported in Table 2, the long memory of v10 reduced the 24-hour error by about 35% with respect to v9, and the on-policy round of v11 removed both the temperature bias and the overestimation of discomfort (from 1.22 to 1.00). World model v12 has the lowest error of all, yet the same training recipe yields a worse policy on it than on v11 (0.0121 against 0.0106), better in only 7 of the 30 scenarios; v12 overestimates the comfort term by 7% and the energy term by 20%, and its policy spends more energy than needed, especially in the warm climates. This can primarily be attributed to the fact that the DPC gradient follows the predicted reward rather than the predicted temperature, so that a systematic bias on the reward terms steers the policy, whereas a random temperature error largely averages out.

4.4 Long Horizon And Command Filter

The step from 0.0133 to 0.0106 in Figure 2 combines the 24-hour horizon with the command filter applied inside the training rollouts, and the two elements are effective only together and only on an accurate world model. On world model v11, training with the filter but with the shorter 6 to 12-hour horizon yields 0.0182, since the filtered commands respond more slowly and the short rollouts do not reveal the benefit of acting earlier, whereas the long horizon lets the policy learn to anticipate occupancy and cold nights, as in Figure 4, while the filter keeps it from exploiting high-frequency errors of the model. On the older world model v9, whose closed-loop error after 24 hours is 1.35 K (Table 2), the same long horizon instead degraded the 7-day score from 0.0195 to 0.0328, since the policy exploited errors accumulated over the horizon. Each improvement of the world model has therefore made a longer horizon usable, and the horizon has in turn produced the largest single improvement of the policy.

5 Conclusion

This work has shown that a single policy for unseen buildings can be obtained without deep reinforcement learning and without imitation, by representing the building as a set of entities, learning a world model of its physics and differentiating the competition reward through closed-loop rollouts of that model. The resulting policy reduces the score of the shipped PID baseline by 82% on the official scenarios and reaches 0.013 on the Kaggle public leaderboard. The experiments indicate that the main driver of performance is the world model, and in particular its calibration on the reward terms and its accuracy over the planning horizon, since each improvement of the world model made a longer horizon or a weaker regularization usable. The current results rest on a single training seed per configuration, and the remaining gap to the best entries of the leaderboard is concentrated in the coldest climates. The next steps are the measurement of the variance between training seeds, ensembles of world models to make the policy robust to the errors of any single model, and planning at deployment, in which the actions of the policy are refined online by a short search inside the world model.

Acknowledgments and Disclosure of Funding

This work was carried out within the CREALab project, funded by the Italian Ministry of the Environment and Energy Security (MASE) under the Mission Innovation 2.0 program (project code MI_FAE_00326).

References

[1] Brandon Amos, Ivan Jimenez, Jacob Sacks, Byron Boots, and J Zico Kolter. Differentiable MPC for end-to-end planning and control. In *Advances in Neural Information Processing Systems*, volume 31, 2018.

[2] David Blum, Javier Arroyo, Sen Huang, Ján Drgoňa, Filip Jorissen, Harald Taxt Walnum, Yan Chen, Kyle Benne, Draguna Vrabie, Michael Wetter, and Lieve Helsen. Building optimization testing framework (BOPTEST) for simulation-based benchmarking of control strategies in buildings. *Journal of Building Performance Simulation*, 14(5):586–610, 2021.

[3] Bingqing Chen, Zicheng Cai, and Mario Bergés. Gnu-RL: A precocial reinforcement learning solution for building HVAC control using a differentiable MPC policy. In *Proceedings of the 6th ACM International Conference on Systems for Energy-Efficient Buildings, Cities, and Transportation*, pages 316–325, 2019.

[4] Ján Drgoňa, Javier Arroyo, Iago Cupeiro Figueroa, David Blum, Krzysztof Arendt, Donghun Kim, Enric Perarnau Ollé, Juraj Oravec, Michael Wetter, Draguna L Vrabie, and Lieve Helsen. All you need to know about model predictive control for buildings. *Annual Reviews in Control*, 50:190–232, 2020.

[5] Ján Drgoňa, Karol Kiš, Aaron Tuor, Draguna Vrabie, and Martin Klaučo. Differentiable predictive control: Deep learning alternative to explicit model predictive control for unknown nonlinear systems. *Journal of Process Control*, 116:80–92, 2022.

[6] Judah Goldfeder, Victoria Dean, Zixin Jiang, Xuezheng Wang, Hod Lipson, John Sipple, et al. The smart buildings control suite: A diverse open source benchmark to evaluate and scale hvac control policies for sustainability. *arXiv preprint arXiv:2410.03756*, 2024.

[7] Judah Goldfeder, Ayush Rai, Philippe M Wyder, Na Li, Victoria Dean, Donna Vakalis, Jiong Lin, Bing Dong, Michael Rossetti, Nathan Kutz, et al. The smart buildings challenge: Learning foundation models for real-world optimization at scale. *arXiv preprint arXiv:2610.18511*, 2026.

[8] David Ha and Jürgen Schmidhuber. World models. *arXiv preprint arXiv:1803.10122*, 2018.

[9] Danijar Hafner, Timothy Lillicrap, Jimmy Ba, and Mohammad Norouzi. Dream to control: Learning behaviors by latent imagination. In *International Conference on Learning Representations*, 2020.

[10] Michael Janner, Justin Fu, Marvin Zhang, and Sergey Levine. When to trust your model: Model-based policy optimization. In *Advances in Neural Information Processing Systems*, volume 32, 2019.

[11] Giuseppe Pinto, Zhe Wang, Abhishek Roy, Tianzhen Hong, and Alfonso Capozzoli. Transfer learning for smart buildings: A critical review of algorithms, applications, and future perspectives. *Advances in Applied Energy*, 5:100084, 2022.

[12] Ashish Vaswani, Noam Shazeer, Niki Parmar, Jakob Uszkoreit, Llion Jones, Aidan N Gomez, Łukasz Kaiser, and Illia Polosukhin. Attention is all you need. In *Advances in Neural Information Processing Systems*, volume 30, 2017.

[13] Zhe Wang and Tianzhen Hong. Reinforcement learning for building controls: The opportunities and challenges. *Applied Energy*, 269:115036, 2020.

[14] Tianshu Wei, Yanzhi Wang, and Qi Zhu. Deep reinforcement learning for building HVAC control. In *Proceedings of the 54th Annual Design Automation Conference*, pages 1–6, 2017.

[15] Jie Xu, Viktor Makoviychuk, Yashraj Narang, Fabio Ramos, Wojciech Matusik, Animesh Garg, and Miles Macklin. Accelerated policy learning with parallel differentiable simulation. In *International Conference on Learning Representations*, 2022.

[16] Chengxuan Ying, Tianle Cai, Shengjie Luo, Shuxin Zheng, Guolin Ke, Di He, Yanming Shen, and Tie-Yan Liu. Do transformers really perform badly for graph representation? In *Advances in Neural Information Processing Systems*, volume 34, pages 28877–28888, 2021.