



Water Well And Pump Record



Completion is required under authority of Part 127 Act 368 PA 1978.

Failure to comply is a misdemeanor.

Import ID: 01257510001

Tax No:	Permit No:	County: Alcona		Township: Curtis	
Well ID: 010000000007 Elevation: 845 ft. Latitude: 44.5787191955 Longitude: -83.8127483927 Method of Collection: GPS Differential (DGPS)		Town/Range: 25N 05E	Section: 10	Well Status: Active	WSSN: 2015701
		Source ID/Well No: 001			
		Distance and Direction from Road Intersection: 2019001;001			
		Well Owner: ALCONA PARK			
		Well Address: MI		Owner Address: 2550 S AuSable Road GLENNIE, MI	

Drilling Method: Auger/Bored	Pump Installed: Yes	Pump Installation Only: No
Well Depth: 45.00 ft.	Pump Installation Date:	HP:
Well Type: Replacement	Manufacturer: Unknown	Pump Type: Unknown
Date Completed: 5/3/1984	Model Number:	Pump Capacity:
Casing Type: Unknown	Drop Pipe Length:	Pump Voltage:
Height: 1.20 ft. above grade	Drop Pipe Diameter:	Drilling Record ID:
Casing Joint: Threaded & coupled	Draw Down Seal Used: No	
Casing Fitting: None	Pressure Tank Installed: No	
Diameter: 2.00 in. to 45.00 ft. depth	Pressure Relief Valve Installed: No	
Borehole:		

Static Water Level: 8.00 ft. Below Grade	Formation Description	Thickness	Depth to Bottom
Well Yield Test:	Sand	9.00	9.00
Yield Test Method: Unknown	Sand Wet/Moist	36.00	45.00
Pumping level 8.00 ft. after 1.00 hrs. at 12 GPM			

Screen Installed: Yes	Filter Packed: No
Screen Diameter: 1.25 in.	Blank: 0.00 ft. Above
Screen Material Type: Unknown	
Screen Installation Type: Unknown	
Slot	Length
8.00	4.00 ft.
Set Between	
41.00 ft. and 45.00 ft.	
Fittings: None	

Well Grouted: Yes	Grouting Method: Unknown	Geology Remarks:
Grouting Material	Bags	
Other	0.00	
Additives	Depth	
None	0.00 ft. to 0.00 ft.	

Wellhead Completion: Other, 12+ inches above grade	Drilling Machine Operator Name: GEORGE TAIT
	Employment: Unknown
Nearest Source of Possible Contamination:	
Type	Distance
Septic tank	100 ft.
Direction	
Southwest	

Abandoned Well Plugged: No	Contractor Type: Unknown	Reg No: 74-1873
Reason Not Plugged:	Business Name:	
	Business Address:	

Water Well Contractor's Certification	
This well was drilled under my supervision and this report is true to the best of my knowledge and belief.	
Signature of Registered Contractor	Date

General Remarks:
Other Remarks: Grouting Material 1: Listed as other in Wellkey, Wellhead Completion: 12 inch Above Grade