



Water Well And Pump Record

Completion is required under authority of Part 127 Act 368 PA 1978.



Import ID:

Failure to comply is a misdemeanor.

Tax No:	Permit No: 01-01-97	County: Alcona		Township: Curtis	
Well ID: 010000000008 Elevation: 845 ft. Latitude: 44.5787331 Longitude: -83.8127353 Method of Collection: GPS Differential (DGPS)		Town/Range: 25N 05E	Section: 10	Well Status: Active	WSSN: 2019001
		Source ID/Well No: 001			
		Distance and Direction from Road Intersection: East Well			
		Well Owner: ALCONA PARK			
		Well Address: 2550 Ausable Glennie, MI 48737		Owner Address: 2550 AUSABLE RD GLENNIE, MI 48737	

Drilling Method: Rotary	Well Use: Type II public	Pump Installed: Yes	Pump Installation Only: No
Well Depth: 68.00 ft.	Date Completed: 9/12/1997	Pump Installation Date:	HP: 1.50
Well Type: New	Height:	Manufacturer: Goulds	Pump Type: Submersible
Casing Type: PVC plastic		Model Number: 356S15	Pump Capacity: 41 GPM
Casing Joint: Unknown		Drop Pipe Length: 51.00 ft.	Pump Voltage:
Casing Fitting: None		Drop Pipe Diameter:	Drilling Record ID:
		Draw Down Seal Used: No	
Diameter: 5.00 in. to 58.00 ft. depth		Pressure Tank Installed: No	
		Pressure Relief Valve Installed: No	
Borehole: 8.75 in. to 50.00 ft. depth			

Static Water Level: 16.00 ft. Below Grade	Formation Description	Thickness	Depth to Bottom
Well Yield Test: Pumping level 35.00 ft. after 1.00 hrs. at 50 GPM			
Yield Test Method: Unknown	Sand & Gravel W/Cobbles	9.00	9.00
	Clay	7.00	16.00
	Sand	11.00	27.00
	Clay	19.00	46.00
	Sand Fine	22.00	68.00

Screen Installed: Yes	Filter Packed: No	Geology Remarks:
Screen Diameter: 5.00 in.	Blank: 0.00 ft. Above	
Screen Material Type: Unknown		
Screen Installation Type: Unknown		
Slot	Length	
10.00	10.00 ft.	
Set Between		
	58.00 ft. and 68.00 ft.	
Fittings: None		

Well Grouted: Yes	Grouting Method: Unknown
--------------------------	---------------------------------

Grouting Material	Bags	Additives	Depth
Bentonite slurry	0.00	None	0.00 ft. to 50.00 ft.

Wellhead Completion: 12+ inches above grade
--

Nearest Source of Possible Contamination:
--

Type	Distance	Direction
Septic tank	250 ft.	Southwest

Contractor Type: Water Well Drilling Contractor	Reg No: 35-2137
--	------------------------

Business Name: Webb Well Drill

Business Address:

Water Well Contractor's Certification
--

This well was drilled under my supervision and this report is true to the best of my knowledge and belief.
--

Signature of Registered Contractor	Date
---	-------------

General Remarks:

Other Remarks:
