

Inspection Report IR-1042

Equipment Tag: Pump P-101

Date: 2026-09-10

Inspector: J. Doe

Findings:

- Measured wall loss at discharge flange: 4.2 mm.
- Minor gasket seepage observed on casing.
- Pressure gauge calibration expired on 2026-07-15.

Vibration data: 8.2 mm/s RMS (Drive End).