

GridLock coordination report

Prepared: 9/27/2026, 4:32:41 AM

Filters: Distance band: Touching / crossing

Timeline emphasis: All years

Timeline emphasis does not change ranked or exported rows. Coordination opportunities and shared assets are unverified. Estimates are for discussion only; no realized savings are claimed.

At a glance

46 ranked pairs in this report; 2 cross the state line.

By distance: touching 46.

Possible savings: \$13,543,000 to \$27,791,000 across 24 pairs with an estimate. Each pair is estimated on its own and pairs can share a project, so this is a screening figure, not a budget.

Highest ranked: #1, Okatie – McIntosh 115kV Tie: Add Series Reactor / MCINTOSH 230 KV, BREAKER CONTROL RELAY UPGRADES (score 5.8).

Overlap #1

Why these projects appear together

0.0 km · Touching / crossing

- Shared named endpoint
- Approximate locations: possibly touching.
- Timing: same year. Sharing is not verified.

Pair evidence

The Okatie–McIntosh 115 kV tie line names McIntosh as an endpoint. The DESC series reactor work is at new Deerfield Switching Station, location not stated; the SERTP relay work is at the McIntosh 230 kV bus (SCRTP Planned Facilities 2026-2030 \$2M & Above, p. 41; SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 107).

Verify work locations before reviewing possible coordination; shared assets unverified. Their job types could also share a laydown yard, crew and equipment moves, bulk material buying and joint engineering and project management.

Same in-service year

Nearest mapped distance: 0.0 km

Okatie – McIntosh 115kV Tie: Add Series Reactor

Dominion Energy SC

SCRTP Planned Facilities 2026-2030 \$2M & Above, p. 41

- In service: 12/31/2028
- Plan cost: \$5,376,418

Source text

Construct Deerfield Switching Station and Install a 9% series reactor on the Okatie – McIntosh 115kV Tie Line.

This project is needed to improve system performance and to meet NERC TPL and internal DESC Planning Criteria for reliability.

Status: Planned

Location: approximate

- Shown as a mapped line.
- Construction limits are not verified.

Location sources

Straight line between Okatie and McIntosh (matched from Hand-placed from HIFLD Electric Power Transmission Lines, archived line feature (committed source file); SC RTP Planned Facilities 2026-2030, pp. 11-12: INFERRED - junction on the Jasper-Yemassee 230 kV line (HIFLD archived line feature); DESC plans to fold that line into Okatie. Verify on Dominion's Jasper-Okatie route map. / OpenStreetMap)

MCINTOSH 230 KV, BREAKER CONTROL RELAY UPGRADES

Georgia Power (inferred)

SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 107

- In service: 2028
- Plan cost: not stated

Source text

Replace existing twenty 230 kV breaker control relays with twenty high speed breaker control relays at the McIntosh 230 kV breaker and a half bus.

Protection analysis identified the project modifications are required due to the interconnection of the proposed generating facility.

Status: not stated

Location: exact

- Shown as a mapped point.
- Construction limits are not verified.

Location sources

OpenStreetMap (McIntosh Substation)

Screening savings

Possible saving (estimate): \$62,000 to \$264,000

- Only costs both job types need at this distance count; the low end keeps sharing with a public precedent.
- Team estimate, 2026-09-26: team unit costs by job type and distance.
- Not verified: the plans do not show shared work.

How we estimated this

Team unit-cost file, 2026-09-26: shareable cost items by job type and distance, priced from MISO's transmission cost guide (escalated to 2026 at 4% a year) and public land, wage and rental sources. Saving rates are team assumptions, not measured savings or evidence of a shared asset.

Team unit-cost estimate: two equipment jobs that touch could share a laydown yard, crew and equipment moves, bulk material buying and joint engineering and project management (equipment job: sized to its printed cost of \$5,376,418; equipment job: sized as one added 230 kV breaker position). The low end counts only items with public precedent; direct costs before contingency; shared savings unverified.

How this pair ranks

Score 5.8 = touching (4) × same year (1.0) × one location approximate (0.8) × crosses the state line (1.5) × savings up to \$264,000 (1.21)

- Distance counts most: savings add at most 30%, so with the rest equal a closer pair ranks higher.
- Filters hide pairs; they never change a score or rank.

How the score works

Distance band: touching 4, under 1.6 km 3, under 8 km 2, under 40 km 1. Timing: same year 1.0, 1 year apart 0.7, 2 years 0.4, 3 or more 0.1, a year unknown 0.3. Location: 1.0 for each exact project and 0.8 for each approximate one. State line: 1.5 when the projects are in different states. Savings: 1 plus up to 0.3, growing with the top of the savings range (0.15 at \$100,000, the full 0.3 from \$1,000,000).

Coordination status

Team assumptions

Team unit-cost file, 2026-09-26: shareable cost items by job type and distance, priced from MISO's transmission cost guide (escalated to 2026 at 4% a year) and public land, wage and rental sources. Saving rates are team assumptions, not measured savings or evidence of a shared asset.

Ranked overlaps

46 ranked overlaps. The CSV export has every field, including the evidence text.

Rank	Projects	Distance, timing and score	Possible saving	Sources	Status
1	Okatie – McIntosh 115kV Tie: Add Series Reactor · Dominion Energy SC · 2028 MCINTOSH 230 KV, BREAKER CONTROL RELAY UPGRADES · Georgia Power (inferred) · 2028	0.0 km · Touching / crossing Shared named endpoint 2 years to coordinate Score 5.8	\$62,000 to \$264,000 estimate	SCRTP Planned Facilities 2026-2030 \$2M & Above, p. 41 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 107	
2	Okatie – McIntosh 115kV Tie: Add Series Reactor · Dominion Energy SC · 2028 SAV: GOSHEN (SAV) – MCINTOSH 115 KV TRANSMISSION LINE, REBUILD · Georgia Power · 2028	0.0 km · Touching / crossing Shared named endpoint 2 years to coordinate Score 4.6	\$62,000 to \$191,000 estimate	SCRTP Planned Facilities 2026-2030 \$2M & Above, p. 41 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 111	
4	GTC: DRESDEN 500 KV, BUS EXPANSION · Georgia Transmission Corp. · 2026 MEAG: DRESDEN – LAGRANGE PRIMARY 230 KV, UPGRADE AND JUMPER REPLACEMENT · MEAG Power · 2026	0.0 km · Touching / crossing Shared named endpoint Coordinate now Score 4.0	No estimate: the plans do not size this pair, or these job types share nothing at this distance.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 68 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 72	

Rank	Projects	Distance, timing and score	Possible saving	Sources	Status
5	MEAG: DRESDEN – LAGRANGE PRIMARY 230 KV, UPGRADE AND JUMPER REPLACEMENT · MEAG Power · 2026 LAGRANGE – NORTH OPELIKA TS 230 KV, NEW TRANSMISSION LINE, CONSTRUCT · Georgia Power (inferred) · 2026	0.0 km · Touching / crossing Same approximate area Coordinate now Score 3.9	\$109,000 to \$351,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 72 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 72	
6	GTC: NEW TENASKA – WANSLEY 500 KV, NEW TRANSMISSION LINE, CONSTRUCT · Georgia Transmission Corp. · 2029 WANSLEY 500 KV, OVERSTRESSED BREAKER REPLACEMENTS · Georgia Power (inferred) · 2029	0.0 km · Touching / crossing Same named substation 3 years to coordinate Score 3.7	\$40,000 to \$126,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 124 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 133	
7	GTC: NEW TENASKA – WANSLEY 500 KV, NEW TRANSMISSION LINE, CONSTRUCT · Georgia Transmission Corp. · 2029 WANSLEY 500 KV, OVERSTRESSED BREAKER REPLACEMENTS · Georgia Power (inferred) · 2029	0.0 km · Touching / crossing Same named substation 3 years to coordinate Score 3.7	\$40,000 to \$126,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 124 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 133	
8	ASHLEY PARK-WANSLEY 500 KV, NEW TRANSMISSION LINE, CONSTRUCT · Georgia Power (inferred) · 2029 GTC: NEW TENASKA – WANSLEY 500 KV, NEW TRANSMISSION LINE, CONSTRUCT · Georgia Transmission Corp. · 2029	0.0 km · Touching / crossing Same named substation 3 years to coordinate Score 3.3	\$4,583,000 to \$8,030,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 114 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 124	
9	GTC: LAGRANGE – NORTH OPELIKA 230 KV, NEW TRANSMISSION LINE, CONSTRUCT · Georgia Transmission Corp. · 2026 LAGRANGE – NORTH OPELIKA TS 230 KV, NEW TRANSMISSION LINE, CONSTRUCT · Georgia Power (inferred) · 2026	0.0 km · Touching / crossing Same named substation Coordinate now Score 3.3	\$1,890,000 to \$3,312,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 68 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 72	
10	GTC: LAGRANGE – NORTH OPELIKA 230 KV, NEW TRANSMISSION LINE, CONSTRUCT · Georgia Transmission Corp. · 2026 MEAG: DRESDEN – LAGRANGE PRIMARY 230 KV, UPGRADE AND JUMPER REPLACEMENT · MEAG Power · 2026	0.0 km · Touching / crossing Same approximate area Coordinate now Score 3.2	No estimate: the plans do not size this pair, or these job types share nothing at this distance.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 68 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 72	

Rank	Projects	Distance, timing and score	Possible saving	Sources	Status
11	GRID: ARKWRIGHT – LLOYD SHOALS 115 KV TRANSMISSION LINE, REBUILD · Georgia ITS (joint) · 2027 LLOYD SHOALS 115 KV LIMITING ELEMENTS, REMOVAL · Georgia Power (inferred) · 2027	0.0 km · Touching / crossing Shared named endpoint 1 year to coordinate Score 3.2	No estimate: the plans do not size this pair, or these job types share nothing at this distance.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 82 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 92	
12	GORDON – N DUBLIN 115 KV (GORDON – ENGL MCI J) TRANSMISSION LINE, REBUILD · Georgia Power (inferred) · 2026 GTC: GORDON – SANDERSVILLE #1 115 KV TRANSMISSION LINE, REBUILD · Georgia Transmission Corp. · 2026	0.0 km · Touching / crossing Shared named endpoint Coordinate now Score 3.1	\$82,000 to \$307,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 66 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 68	
13	GTC: HICKORY LEVEL – VILLA RICA 230 KV TRANSMISSION LINE, RECONDUCTOR · Georgia Transmission Corp. · 2027 SUMMER LAKE – VILLA RICA 230 KV TRANSMISSION LINE, REBUILD · Georgia Power (inferred) · 2027	0.0 km · Touching / crossing Same named substation 1 year to coordinate Score 3.1	\$69,000 to \$198,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 85 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 94	
14	GTC: DOUGLASVILLE – VILLA RICA 230 KV TRANSMISSION LINE, REBUILD · Georgia Transmission Corp. · 2027 SUMMER LAKE – VILLA RICA 230 KV TRANSMISSION LINE, REBUILD · Georgia Power (inferred) · 2027	0.0 km · Touching / crossing Same named substation 1 year to coordinate Score 3.1	\$52,000 to \$195,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 83 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 94	
15	VILLA RICA SUBSTATION, UPGRADES · Georgia Power (inferred) · 2028 GTC: HICKORY LEVEL – VILLA RICA 230 KV TRANSMISSION LINE, RECONDUCTOR · Georgia Transmission Corp. · 2027	0.0 km · Touching / crossing Same named substation 1 year to coordinate Score 2.5	\$12,000 to \$72,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 112 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 85	
16	VILLA RICA SUBSTATION, UPGRADES · Georgia Power (inferred) · 2028 GTC: DOUGLASVILLE – VILLA RICA 230 KV TRANSMISSION LINE, REBUILD · Georgia Transmission Corp. · 2027	0.0 km · Touching / crossing Same named substation 1 year to coordinate Score 2.5	\$22,000 to \$69,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 112 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 83	

Rank	Projects	Distance, timing and score	Possible saving	Sources	Status
17	GTC: NEW TENASKA – WANSLEY 500 KV, NEW TRANSMISSION LINE, CONSTRUCT · Georgia Transmission Corp. · 2029 CAVENDER DRIVE – WANSLEY 500 KV, NEW TRANSMISSION LINE, CONSTRUCT · Georgia Power (inferred) · 2030	0.0 km · Touching / crossing Same named substation 3 years to coordinate Score 2.3	\$4,812,000 to \$8,431,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 124 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 138	
18	GTC: CLARKSBORO – WINDER PRIMARY 230 KV TRANSMISSION LINE, REBUILD · Georgia Transmission Corp. · 2029 JEFFERSON ROAD – WINDER PRIMARY 115 KV TRANSMISSION LINE, REBUILD · Georgia Power (inferred) · 2030	0.0 km · Touching / crossing Shared named endpoint 3 years to coordinate Score 2.3	\$260,000 to \$976,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 121 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 147	
19	GTC: DAWSON CROSSING – NELSON (BLACK) TRANSMISSION LINE, REBUILD · Georgia Transmission Corp. · 2029 DU: DAWSON CROSSING – NELSON (WHITE) 115 KV TRANSMISSION LINE, REBUILD · Dalton Utilities · 2030	0.0 km · Touching / crossing Same named substation 3 years to coordinate Score 2.3	\$241,000 to \$905,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 122 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 139	
20	LLOYD SHOALS – PORTERDALE PRIMARY 115 KV TRANSMISSION LINE, REBUILD · Georgia Power (inferred) · 2028 GRID: ARKWRIGHT – LLOYD SHOALS 115 KV TRANSMISSION LINE, REBUILD · Georgia ITS (joint) · 2027	0.0 km · Touching / crossing Shared named endpoint 1 year to coordinate Score 2.3	\$164,000 to \$617,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 106 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 82	
21	GTC: CLARKSBORO – WINDER PRIMARY 230 KV TRANSMISSION LINE, REBUILD · Georgia Transmission Corp. · 2029 LAWRENCEVILLE – WINDER PRIMARY 115 KV TRANSMISSION LINE, REBUILD · Georgia Power (inferred) · 2030	0.0 km · Touching / crossing Same named substation 3 years to coordinate Score 2.3	\$158,000 to \$593,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 121 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 148	
22	ARKWRIGHT, BUS AND JUMPER REPLACEMENT · Georgia Power (inferred) · 2026 GRID: ARKWRIGHT – LLOYD SHOALS 115 KV TRANSMISSION LINE, REBUILD · Georgia ITS (joint) · 2027	0.0 km · Touching / crossing Shared named endpoint Coordinate now Score 2.2	No estimate: the plans do not size this pair, or these job types share nothing at this distance.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 61 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 82	

Rank	Projects	Distance, timing and score	Possible saving	Sources	Status
25	GTC: BARNESVILLE PRIMARY – THOMASTON 230 KV TRANSMISSION LINE, REBUILD · Georgia Transmission Corp. · 2029 MEAG: BARNESVILLE PRIMARY 230/115 KV BANK B, REPLACEMENT · MEAG Power · 2030	0.0 km · Touching / crossing Shared named endpoint 3 years to coordinate Score 2.2	\$80,000 to \$262,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 120 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 149	
26	PLANT YATES 230 KV BREAKER AND HALF SUBSTATION, REBUILD · Georgia Power (inferred) · 2028 GTC: YATES – LINE CREEK (GREEN) 230 KV TRANSMISSION LINE, REBUILD · Georgia Transmission Corp. · 2030	0.0 km · Touching / crossing Nearby mapped locations 2 years to coordinate Score 2.0	\$107,000 to \$347,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 109 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 146	
27	PLANT YATES 230 KV BREAKER AND HALF SUBSTATION, REBUILD · Georgia Power (inferred) · 2028 GTC: YATES – LINE CREEK (RED) 230 KV TRANSMISSION LINE, REBUILD · Georgia Transmission Corp. · 2030	0.0 km · Touching / crossing Nearby mapped locations 2 years to coordinate Score 2.0	\$107,000 to \$347,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 109 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 147	
29	GORDON 115 KV, OVERSTRESSED BREAKER REPLACEMENT · Georgia Power (inferred) · 2028 GTC: GORDON – SANDERSVILLE #1 115 KV TRANSMISSION LINE, REBUILD · Georgia Transmission Corp. · 2026	0.0 km · Touching / crossing Shared named endpoint Coordinate now Score 1.4	\$18,000 to \$57,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 102 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 68	
30	GTC: CLARKSBORO – WINDER PRIMARY 230 KV TRANSMISSION LINE, REBUILD · Georgia Transmission Corp. · 2029 LAWRENCEVILLE – WINDER PRIMARY 230 KV TRANSMISSION LINE, REBUILD · Georgia Power (inferred) · 2027	0.0 km · Touching / crossing Same named substation 1 year to coordinate Score 1.3	\$306,000 to \$1,147,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 121 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 89	
34	UNION CITY – LINE CREEK – YATES 230 KV TRANSMISSION LINES, REBUILD · Georgia Power (inferred) · 2028 GTC: UNION CITY, LINE TRAP REPLACEMENT · Georgia Transmission Corp. · 2030	0.0 km · Touching / crossing Same named substation 2 years to coordinate Score 1.3	\$141,000 to \$464,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 112 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 146	

Rank	Projects	Distance, timing and score	Possible saving	Sources	Status
35	MEAG: DRESDEN – LAGRANGE PRIMARY 230 KV, UPGRADE AND JUMPER REPLACEMENT · MEAG Power · 2026 CORN CRIB – LAGRANGE 115 KV TRANSMISSION LINE, RECONDUCTOR · Georgia Power (inferred) · 2028	0.0 km · Touching / crossing Same approximate area Coordinate now Score 1.3	No estimate: the plans do not size this pair, or these job types share nothing at this distance.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 72 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 99	
37	GTC: BARNESVILLE – SOUTH GRIFFIN 230 KV, NEW TRANSMISSION LINE, CONSTRUCT · Georgia Transmission Corp. · 2029 BARNESVILLE AREA 115 KV, NETWORK SOLUTION · Georgia Power (inferred) · 2031	0.0 km · Touching / crossing Same named substation 3 years to coordinate Score 1.3	\$126,000 to \$404,000 estimate	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 120 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 152	
49	GTC: LAGRANGE – NORTH OPELIKA 230 KV, NEW TRANSMISSION LINE, CONSTRUCT · Georgia Transmission Corp. · 2026 CORN CRIB – LAGRANGE 115 KV TRANSMISSION LINE, RECONDUCTOR · Georgia Power (inferred) · 2028	0.0 km · Touching / crossing Same named substation Coordinate now Score 1.0	No estimate: the plans do not size this pair, or these job types share nothing at this distance.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 68 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 99	
193	GTC: DRESDEN 230 KV, BREAKER REPLACEMENTS · Georgia Transmission Corp. · 2029 MEAG: DRESDEN – LAGRANGE PRIMARY 230 KV, UPGRADE AND JUMPER REPLACEMENT · MEAG Power · 2026	0.0 km · Touching / crossing Shared named endpoint Coordinate now Score 0.40	No estimate: project timing is too far apart.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 123 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 72	
194	GTC: DRESDEN 230 KV, JUMPER REPLACEMENT · Georgia Transmission Corp. · 2031 MEAG: DRESDEN – LAGRANGE PRIMARY 230 KV, UPGRADE AND JUMPER REPLACEMENT · MEAG Power · 2026	0.0 km · Touching / crossing Shared named endpoint Coordinate now Score 0.40	No estimate: project timing is too far apart.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 154 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 72	
210	GTC: CLARKSBORO – WINDER PRIMARY 230 KV TRANSMISSION LINE, REBUILD · Georgia Transmission Corp. · 2029 WINDER PRIMARY 230 KV, BREAKER INSTALLATION · Georgia Power (inferred) · 2033	0.0 km · Touching / crossing Same named substation 3 years to coordinate Score 0.32	No estimate: project timing is too far apart.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 121 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 163	

Rank	Projects	Distance, timing and score	Possible saving	Sources	Status
211	GTC: DRESDEN – TALBOT 500 KV, NEW TRANSMISSION LINE, CONSTRUCT · Georgia Transmission Corp. · 2029 MEAG: DRESDEN – LAGRANGE PRIMARY 230 KV, UPGRADE AND JUMPER REPLACEMENT · MEAG Power · 2026	0.0 km · Touching / crossing Shared named endpoint Coordinate now Score 0.32	No estimate: project timing is too far apart.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 122 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 72	
212	GTC: NEW TENASKA – WANSLEY 500 KV, NEW TRANSMISSION LINE, CONSTRUCT · Georgia Transmission Corp. · 2029 WANSLEY LINE, PROTECTIVE RELAYING REPLACEMENT · Georgia Power (inferred) · 2026	0.0 km · Touching / crossing Same named substation Coordinate now Score 0.32	No estimate: project timing is too far apart.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 124 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 77	
213	GOLDENS CREEK – WARRENTON PRIMARY 230 KV TRANSMISSION LINE, REBUILD · Georgia Power (inferred) · 2030 MEAG: RAY PLACE RD – WARRENTON PRIMARY 115 KV TRANSMISSION LINE, RECONDUCTOR · MEAG Power · 2027	0.0 km · Touching / crossing Shared named endpoint 1 year to coordinate Score 0.32	No estimate: project timing is too far apart.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 141 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 90	
214	GTC: EAST WATKINSVILLE 230 KV, REACTOR INSTALLATION · Georgia Transmission Corp. · 2030 ATHENA – EAST WATKINSVILLE 115 KV TRANSMISSION LINE, REBUILD · Georgia Power (inferred) · 2027	0.0 km · Touching / crossing Shared named endpoint 1 year to coordinate Score 0.32	No estimate: project timing is too far apart.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 144 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 78	
215	GTC: YATES – LINE CREEK (GREEN) 230 KV TRANSMISSION LINE, REBUILD · Georgia Transmission Corp. · 2030 UNION CITY – YATES 230 KV (WHITE), SWITCH AND TRAP REPLACEMENT · Georgia Power (inferred) · 2026	0.0 km · Touching / crossing Same named substation Coordinate now Score 0.32	No estimate: project timing is too far apart.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 146 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 77	
216	GTC: YATES – LINE CREEK (GREEN) 230 KV TRANSMISSION LINE, REBUILD · Georgia Transmission Corp. · 2030 UNION CITY (WHITE) – YATES 230 KV TRANSMISSION LINE, REBUILD · Georgia Power (inferred) · 2026	0.0 km · Touching / crossing Same named substation Coordinate now Score 0.32	No estimate: project timing is too far apart.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 146 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 77	

Rank	Projects	Distance, timing and score	Possible saving	Sources	Status
217	GTC: YATES – LINE CREEK (RED) 230 KV TRANSMISSION LINE, REBUILD · Georgia Transmission Corp. · 2030 UNION CITY – YATES 230 KV (WHITE), SWITCH AND TRAP REPLACEMENT · Georgia Power (inferred) · 2026	0.0 km · Touching / crossing Same named substation Coordinate now Score 0.32	No estimate: project timing is too far apart.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 147 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 77	
218	GTC: YATES – LINE CREEK (RED) 230 KV TRANSMISSION LINE, REBUILD · Georgia Transmission Corp. · 2030 UNION CITY (WHITE) – YATES 230 KV TRANSMISSION LINE, REBUILD · Georgia Power (inferred) · 2026	0.0 km · Touching / crossing Same named substation Coordinate now Score 0.32	No estimate: project timing is too far apart.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 147 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 77	
256	GORDON – SANDERSVILLE #1 115 KV TRANSMISSION LINE (DEEPSTEP-SAND #6), REBUILD · Georgia Power (inferred) · 2030 GTC: GORDON – SANDERSVILLE #1 115 KV TRANSMISSION LINE, REBUILD · Georgia Transmission Corp. · 2026	0.0 km · Touching / crossing Shared named endpoint Coordinate now Score 0.26	No estimate: project timing is too far apart.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 142 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 68	
257	GTC: UNION CITY, LINE TRAP REPLACEMENT · Georgia Transmission Corp. · 2030 EAST POINT – UNION CITY, FIBER INSTALLATION · Georgia Power (inferred) · 2027	0.0 km · Touching / crossing Shared named endpoint 1 year to coordinate Score 0.26	No estimate: project timing is too far apart.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 146 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 80	
258	MEAG: ATHENA – WARRENTON 230 KV TRANSMISSION LINE, CONVERSION · MEAG Power · 2030 ATHENA – EAST WATKINSVILLE 115 KV TRANSMISSION LINE, REBUILD · Georgia Power (inferred) · 2027	0.0 km · Touching / crossing Shared named endpoint 1 year to coordinate Score 0.26	No estimate: project timing is too far apart.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 149 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 78	
259	BAY CREEK – CONYERS 230 KV TRANSMISSION LINE, REBUILD · Georgia Power (inferred) · 2031 GTC: CONYERS – CORNISH MOUNTAIN 115 KV LINE, UPGRADE · Georgia Transmission Corp. · 2026	0.0 km · Touching / crossing Same named substation Coordinate now Score 0.26	No estimate: project timing is too far apart.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 152 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 67	
260	BAY CREEK – CONYERS 230 KV, LIMITING ELEMENT REPLACEMENT · Georgia Power (inferred) · 2033 GTC: CONYERS – CORNISH MOUNTAIN 115 KV LINE, UPGRADE · Georgia Transmission Corp. · 2026	0.0 km · Touching / crossing Same named substation Coordinate now Score 0.26	No estimate: project timing is too far apart.	SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 160 SERTP 2025 Regional Transmission Plan (Nov 26 2025), p. 67	

Sources and attribution

SCRTP Planned Facilities 2026-2030 \$2M & Above; edition date: not stated. Project citations above identify PDF pages.

SERTP 2025 Regional Transmission Plan (Nov 26 2025); edition date: 2025-11-26. Project citations above identify PDF pages.

Independent student project; not affiliated with Dominion Energy, Georgia Power, Southern Company, GTC, MEAG or Sperry Tech.
Estimates are for discussion only.