MATPOWER

MATPOWER Reference Manual

Release 8.0b1

Ray Zimmerman

May 07, 2024

Contents

1 Introduction

The purpose of this *Reference Manual* is to provide reference documentation on each class and function in MATPOWER.

This documentation is automatically generated from the corresponding help text in the Matlab source for each function, class, property or method.

The GitHub icon in the upper right of each reference page links to the corresponding source file in the master branch on GitHub.

Currently, this manual includes *only* classes and functions that make up the new **MP-Core** and the **flexible** and **legacy** MATPOWER frameworks, but not the other legacy MATPOWER functions or the included packages MP-Opt-Model, MIPS, MP-Test, or MOST.

2 Functions

2.1 Top-Level Simulation Functions

These are top-level functions intended as user commands for running power flow (PF), continuation power flow (CPF), optimal power flow (OPF) and other custom simulation or optimization tasks.

2.1.1 run_mp

run_mp(*task_class*, *d*, *mpopt*, *varargin*)

run_mp() (page 3) - Run any MATPOWER simulation.

```
run_mp(task_class, d, mpopt)
run_mp(task_class, d, mpopt, ...)
task = run_mp(...)
```

This is **the** main function in the **flexible framework** for running MATPOWER. It creates the task object, applying any specified extensions, runs the task, and prints or saves the solution, if desired.

It is typically called from one of the wrapper functions such as *run_pf()* (page 4), *run_cpf()* (page 5), or *run_opf()* (page 5).

Inputs

- **task_class** (*function handle*) – handle to constructor of default task class for type of task to be run, e.g. *mp.task_pf* (page 18) for power flow, *mp.task_cpf* (page 20) for CPF, and *mp.task_opf* (page 21) for OPF
- **d** – data source specification, currently assumed to be a MATPOWER case name or case struct (`mpc`)
- **mpopt** (*struct*) – MATPOWER options struct

  Additional optional inputs can be provided as <*name*>, <*val*> pairs, with the following options:

  - `'print_fname'` - file name for saving pretty-printed output
  - `'soln_fname'` - file name for saving solved case

- 'mpx' - MATPOWER extension or cell array of MATPOWER extensions to apply

Output

task (*mp.task* (page 7)) – task object containing the solved run including the data, network, and mathematical model objects.

Solution results are available in the data model, and its elements, contained in the returned task object. For example:

```
task = run_opf('case9');
lam_p = task.dm.elements.bus.tab.lam_p  % nodal price
pg = task.dm.elements.gen.tab.pg        % generator active dispatch
```

See also *run_pf()* (page 4), *run_cpf()* (page 5), *run_opf()* (page 5), *mp.task* (page 7).

2.1.2 run_pf

run_pf(*varargin*)

run_pf() (page 4) - Run a power flow.

```
run_pf(d, mpopt)
run_pf(d, mpopt, ...)
task = run_pf(...)
```

This is the main function used to run power flow (PF) problems via the **flexible MATPOWER framework**.

This function is a simple wrapper around *run_mp()* (page 3), calling it with the first argument set to `@mp.task_pf`.

Inputs

- **d** – data source specification, currently assumed to be a MATPOWER case name or case struct (`mpc`)
- **mpopt** (*struct*) – MATPOWER options struct

  Additional optional inputs can be provided as *<name>, <val>* pairs, with the following options:

  - 'print_fname' - file name for saving pretty-printed output
  - 'soln_fname' - file name for saving solved case
  - 'mpx' - MATPOWER extension or cell array of MATPOWER extensions to apply

Output

task (*mp.task_pf* (page 18)) – task object containing the solved run including the data, network, and mathematical model objects.

Solution results are available in the data model, and its elements, contained in the returned task object. For example:

```
task = run_pf('case9');
va = task.dm.elements.bus.tab.va    % bus voltage angles
pg = task.dm.elements.gen.tab.pg    % generator active dispatch
```

See also *run_mp()* (page 3), *mp.task_pf* (page 18).

2.1.3 run_cpf

run_cpf(*varargin*)

run_cpf() (page 5) Run a continuation power flow.

```
run_cpf(d, mpopt)
run_cpf(d, mpopt, ...)
task = run_cpf(...)
```

This is the main function used to run continuation power flow (CPF) problems via the **flexible MATPOWER framework**.

This function is a simple wrapper around *run_mp()* (page 3), calling it with the first argument set to `@mp.task_cpf`.

Inputs

- **d** – data source specification, currently assumed to be a cell array of two MATPOWER case names or case structs (`mpc`), the first being the base case, the second the target case
- **mpopt** (*struct*) – MATPOWER options struct

  Additional optional inputs can be provided as *<name>, <val>* pairs, with the following options:

  - `'print_fname'` - file name for saving pretty-printed output
  - `'soln_fname'` - file name for saving solved case
  - `'mpx'` - MATPOWER extension or cell array of MATPOWER extensions to apply

Output

task (*mp.task_cpf* (page 20)) – task object containing the solved run including the data, network, and mathematical model objects.

Solution results are available in the data model, and its elements, contained in the returned task object. For example:

```
task = run_cpf({'case9', 'case9target'});
vm = task.dm.elements.bus.tab.vm    % bus voltage magnitudes
pg = task.dm.elements.gen.tab.pg    % generator active dispatch
```

See also *run_mp()* (page 3), *mp.task_cpf* (page 20).

2.1.4 run_opf

run_opf(*varargin*)

run_opf() (page 5) Run an optimal power flow.

```
run_opf(d, mpopt)
run_opf(d, mpopt, ...)
task = run_opf(...)
```

This is the main function used to run optimal power flow (OPF) problems via the **flexible MATPOWER framework**.

This function is a simple wrapper around *run_mp()* (page 3), calling it with the first argument set to `@mp.task_opf`.

Inputs

- **d** – data source specification, currently assumed to be a MATPOWER case name or case struct (`mpc`)
- **mpopt** (*struct*) – MATPOWER options struct

  Additional optional inputs can be provided as <*name*>, <*val*> pairs, with the following options:

  – `'print_fname'` - file name for saving pretty-printed output

  – `'soln_fname'` - file name for saving solved case

  – `'mpx'` - MATPOWER extension or cell array of MATPOWER extensions to apply

Output

task (*mp.task_opf* (page 21)) – task object containing the solved run including the data, network, and mathematical model objects.

Solution results are available in the data model, and its elements, contained in the returned task object. For example:

```
task = run_opf('case9');
lam_p = task.dm.elements.bus.tab.lam_p  % nodal price
pg = task.dm.elements.gen.tab.pg        % generator active dispatch
```

See also *run_mp()* (page 3), *mp.task_opf* (page 21).

2.2 Other Functions

2.2.1 mp_table_class

mp_table_class()

mp_table_class() (page 6) - Returns handle to constructor for `table` or *mp_table* (page 156).

Returns a handle to `table` constructor, if it is available, otherwise to *mp_table* (page 156) constructor. Useful for table-based code that is compatible with both MATLAB (using native tables) and Octave (using *mp_table* (page 156) or the `table` implementation from Tablicious, if available).

```
% Works in MATLAB or Octave, which does not (yet) natively support table().
table_class = mp_table_class();
T = table_class(var1, var2, ...);
```

See also `table`, *mp_table* (page 156).

3 Classes

3.1 Task Classes

3.1.1 Core Task Classes

mp.task

class mp.**task**

Bases: handle

mp.task (page 7) - MATPOWER task abstract base class.

Each task type (e.g. power flow, CPF, OPF) will inherit from *mp.task* (page 7).

Provides properties and methods related to the specific problem specification being solved (e.g. power flow, continuation power flow, optimal power flow, etc.). In particular, it coordinates all interactions between the 3 (data, network, mathematical) model layers.

The model objects, and indirectly their elements, as well as the solution success flag and messages from the mathematical model solver, are available in the properties of the task object.

mp.task Properties:

- *tag* (page 9) - task tag - e.g. 'PF', 'CPF', 'OPF'
- *name* (page 9) - task name - e.g. 'Power Flow', etc.
- *dmc* (page 9) - data model converter object
- *dm* (page 9) - data model object
- *nm* (page 9) - network model object
- *mm* (page 9) - mathematical model object
- *mm_opt* (page 9) - solve options for mathematical model
- *i_dm* (page 9) - iteration counter for data model loop
- *i_nm* (page 9) - iteration counter for network model loop

- *i_mm* (page 9) - iteration counter for math model loop
- *success* (page 9) - success flag, 1 - math model solved, 0 - didn't solve
- *message* (page 9) - output message
- *et* (page 9) - elapsed time (seconds) for *run()* (page 9) method

mp.task Methods:

- *run()* (page 9) - execute the task
- *next_mm()* (page 10) - controls iterations over mathematical models
- *next_nm()* (page 10) - controls iterations over network models
- *next_dm()* (page 10) - controls iterations over data models
- *run_pre()* (page 11) - called at beginning of *run()* (page 9) method
- *run_post()* (page 11) - called at end of *run()* (page 9) method
- *print_soln()* (page 11) - display pretty-printed results
- *print_soln_header()* (page 11) - display success/failure, elapsed time
- *save_soln()* (page 12) - save solved case to file
- *dm_converter_class()* (page 12) - get data model converter constructor
- *dm_converter_class_mpc2_default()* (page 12) - get default data model converter constructor
- *dm_converter_create()* (page 12) - create data model converter object
- *data_model_class()* (page 13) - get data model constructor
- *data_model_class_default()* (page 13) - get default data model constructor
- *data_model_create()* (page 13) - create data model object
- *data_model_build()* (page 14) - create and build data model object
- *data_model_build_pre()* (page 14) - called at beginning of *data_model_build()* (page 14)
- *data_model_build_post()* (page 14) - called at end of *data_model_build()* (page 14)
- *network_model_class()* (page 14) - get network model constructor
- *network_model_class_default()* (page 15) - get default network model constructor
- *network_model_create()* (page 15) - create network model object
- *network_model_build()* (page 15) - create and build network model object
- *network_model_build_pre()* (page 15) - called at beginning of *network_model_build()* (page 15)
- *network_model_build_post()* (page 16) - called at end of *network_model_build()* (page 15)
- *network_model_x_soln()* (page 16) - update network model state from math model solution
- *network_model_update()* (page 16) - update net model state/soln from math model soln
- *math_model_class()* (page 16) - get mathematical model constructor
- *math_model_class_default()* (page 17) - get default mathematical model constructor
- *math_model_create()* (page 17) - create mathematical model object
- *math_model_build()* (page 17) - create and build mathematical model object

- *math_model_opt()* (page 18) - get options struct to pass to `mm.solve()`

See the sec_task section in the *MATPOWER Developer's Manual* for more information.

See also *mp.data_model* (page 27), *mp.net_model* (page 90), *mp.math_model* (page 121), *mp.dm_converter* (page 59).

Property Summary

tag

(char array) task *tag* (page 9) - e.g. 'PF', 'CPF', 'OPF'

name

(char array) task *name* (page 9) - e.g. 'Power Flow', etc.

dmc

(*mp.dm_converter* (page 59)) data model converter object

dm

(*mp.data_model* (page 27)) data model object

nm

(*mp.net_model* (page 90)) network model object

mm

(*mp.math_model* (page 121)) mathematical model object

mm_opt

(struct) solve options for mathematical model

i_dm

(integer) iteration counter for data model loop

i_nm

(integer) iteration counter for network model loop

i_mm

(integer) iteration counter for math model loop

success

(integer) *success* (page 9) flag, 1 - math model solved, 0 - didn't solve

message

(char array) output *message* (page 9)

et

(double) elapsed time (seconds) for *run()* (page 9) method

Method Summary

run(*d*, *mpopt*, *mpx*)

Execute the task.

```
task.run(d, mpopt)
task.run(d, mpopt, mpx)
```

Inputs

- **d** – data source specification, currently assumed to be a MATPOWER case name or case struct (`mpc`)

- **mpopt** (*struct*) – MATPOWER options struct
- **mpx** (cell array of *mp.extension* (page 170)) – MATPOWER Extensions

Output

task (*mp.task* (page 7)) – task object containing the solved *run()* (page 9) including the data, network, and mathematical model objects.

Execute the task, creating the data model converter and the data, network and mathematical model objects, solving the math model and propagating the solution back to the data model.

See the sec_task section in the *MATPOWER Developer's Manual* for more information.

next_mm(*mm*, *nm*, *dm*, *mpopt*, *mpx*)

Controls iterations over mathematical models.

```
[mm, nm, dm] = task.next_mm(mm, nm, dm, mpoopt, mpx)
```

Inputs

- **mm** (*mp.math_model* (page 121)) – mathmatical model object
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct
- **mpx** (cell array of *mp.extension* (page 170)) – MATPOWER Extensions

Output

- **mm** (*mp.math_model* (page 121)) – new or updated mathmatical model object, or empty matrix
- **nm** (*mp.net_model* (page 90)) – potentially updated network model object
- **dm** (*mp.data_model* (page 27)) – potentially updated data model object

Called automatically by *run()* (page 9) method. Subclasses can override this method to return a new or updated math model object for use in the next iteration or an empty matrix (the default) if finished.

next_nm(*mm*, *nm*, *dm*, *mpopt*, *mpx*)

Controls iterations over network models.

```
[nm, dm] = task.next_nm(mm, nm, dm, mpoopt, mpx)
```

Inputs

- **mm** (*mp.math_model* (page 121)) – mathmatical model object
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct
- **mpx** (cell array of *mp.extension* (page 170)) – MATPOWER Extensions

Output

- **nm** (*mp.net_model* (page 90)) – new or updated network model object, or empty matrix
- **dm** (*mp.data_model* (page 27)) – potentially updated data model object

Called automatically by *run()* (page 9) method. Subclasses can override this method to return a new or updated network model object for use in the next iteration or an empty matrix (the default) if finished.

next_dm(*mm*, *nm*, *dm*, *mpopt*, *mpx*)

Controls iterations over data models.

```
dm = task.next_dm(mm, nm, dm, mpoopt, mpx)
```

Inputs

- **mm** (*mp.math_model* (page 121)) – mathmatical model object
- **nm** (*mp.net_model* (page 90)) – network model object

- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct
- **mpx** (cell array of *mp.extension* (page 170)) – MATPOWER Extensions

Output

dm (*mp.data_model* (page 27)) – new or updated data model object, or empty matrix

Called automatically by *run()* (page 9) method. Subclasses can override this method to return a new or updated data model object for use in the next iteration or an empty matrix (the default) if finished.

run_pre(*d*, *mpopt*)

Called at beginning of *run()* (page 9) method.

```
[d, mpopt] = task.run_pre(d, mpopt)
```

Inputs

- **d** – data source specification, currently assumed to be a MATPOWER case name or case struct (`mpc`)
- **mpopt** (*struct*) – MATPOWER options struct

Outputs

- **d** – updated value of corresponding input
- **mpopt** (*struct*) – updated value of corresponding input

Subclasses can override this method to update the input data or options before beginning the run.

run_post(*mm*, *nm*, *dm*, *mpopt*)

Called at end of *run()* (page 9) method.

```
task.run_post(mm, nm, dm, mpopt)
```

Inputs

- **mm** (*mp.math_model* (page 121)) – mathmatical model object
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Output

task (*mp.task* (page 7)) – task object

Subclasses can override this method to do any final processing after the run is complete.

print_soln(*mpopt*, *fname*)

Display the pretty-printed results.

```
task.print_soln(mpopt)
task.print_soln(mpopt, fname)
```

Inputs

- **mpopt** (*struct*) – MATPOWER options struct
- **fname** (*char array*) – file name for saving pretty-printed output

Display to standard output and/or save to a file the pretty-printed solved case.

print_soln_header(*mpopt*, *fd*)

Display solution header information.

```
task.print_soln_header(mpopt, fd)
```

Inputs

- **mpopt** (*struct*) – MATPOWER options struct

- **fd** (*integer*) – file identifier (1 for standard output)

Called by *print_soln()* (page 11) to print success/failure, elapsed time, etc. to a file identifier.

save_soln(*fname*)

Save the solved case to a file.

```
task.save_soln(fname)
```

Input
fname (*char array*) – file name for saving solved case

dm_converter_class(*d*, *mpopt*, *mpx*)

Get data model converter constructor.

```
dmc_class = task.dm_converter_class(d, mpopt, mpx)
```

Inputs
- **d** – data source specification, currently assumed to be a MATPOWER case name or case struct (`mpc`)
- **mpopt** (*struct*) – MATPOWER options struct
- **mpx** (cell array of *mp.extension* (page 170)) – MATPOWER Extensions

Output
dmc_class (*function handle*) – handle to the constructor to be used to instantiate the data model converter object

Called by *dm_converter_create()* (page 12) to determine the class to use for the data model converter object. Handles any modifications specified by MATPOWER options or extensions.

dm_converter_class_mpc2_default()

Get default data model converter constructor.

```
dmc_class = task.dm_converter_class_mpc2_default()
```

Output
dmc_class (*function handel*) – handle to default constructor to be used to instantiate the data model converter object

Called by *dm_converter_class()* (page 12) to determine the default class to use for the data model converter object when the input is a version 2 MATPOWER case struct.

dm_converter_create(*d*, *mpopt*, *mpx*)

Create data model converter object.

```
dmc = task.dm_converter_create(d, mpopt, mpx)
```

Inputs
- **d** – data source specification, currently assumed to be a MATPOWER case name or case struct (`mpc`)
- **mpopt** (*struct*) – MATPOWER options struct
- **mpx** (cell array of *mp.extension* (page 170)) – MATPOWER Extensions

Output
dmc (*mp.dm_converter* (page 59)) – data model converter object, ready to build

Called by *dm_converter_build()* (page 12) method to instantiate the data model converter object. Handles any modifications to data model converter elements specified by MATPOWER options or extensions.

dm_converter_build(*d*, *mpopt*, *mpx*)

Create and build data model converter object.

```
dmc = task.dm_converter_build(d, mpopt, mpx)
```

Inputs
- **d** – data source specification, currently assumed to be a MATPOWER case name or case struct (`mpc`)
- **mpopt** (*struct*) – MATPOWER options struct
- **mpx** (cell array of *mp.extension* (page 170)) – MATPOWER Extensions

Output
dmc (*mp.dm_converter* (page 59)) – data model converter object, ready for use

Called by *run()* (page 9) method to instantiate and build the data model converter object, including any modifications specified by MATPOWER options or extensions.

data_model_class(*d*, *mpopt*, *mpx*)

Get data model constructor.

```
dm_class = task.data_model_class(d, mpopt, mpx)
```

Inputs
- **d** – data source specification, currently assumed to be a MATPOWER case name or case struct (`mpc`)
- **mpopt** (*struct*) – MATPOWER options struct
- **mpx** (cell array of *mp.extension* (page 170)) – MATPOWER Extensions

Output
dm_class (*function handle*) – handle to the constructor to be used to instantiate the data model object

Called by *data_model_create()* (page 13) to determine the class to use for the data model object. Handles any modifications specified by MATPOWER options or extensions.

data_model_class_default()

Get default data model constructor.

```
dm_class = task.data_model_class_default()
```

Output
dm_class (*function handel*) – handle to default constructor to be used to instantiate the data model object

Called by *data_model_class()* (page 13) to determine the default class to use for the data model object.

data_model_create(*d*, *mpopt*, *mpx*)

Create data model object.

```
dm = task.data_model_create(d, mpopt, mpx)
```

Inputs
- **d** – data source specification, currently assumed to be a MATPOWER case name or case struct (`mpc`)
- **mpopt** (*struct*) – MATPOWER options struct
- **mpx** (cell array of *mp.extension* (page 170)) – MATPOWER Extensions

Output
dm (*mp.data_model* (page 27)) – data model object, ready to build

Called by *data_model_build()* (page 14) to instantiate the data model object. Handles any modifications to data model elements specified by MATPOWER options or extensions.

data_model_build(*d*, *dmc*, *mpopt*, *mpx*)

Create and build data model object.

```
dm = task.data_model_create(d, dmc, mpopt, mpx)
```

Inputs
- **d** – data source specification, currently assumed to be a MATPOWER case name or case struct (`mpc`)
- **dmc** (*mp.dm_converter* (page 59)) – data model converter object
- **mpopt** (*struct*) – MATPOWER options struct
- **mpx** (cell array of *mp.extension* (page 170)) – MATPOWER Extensions

Output
dm (*mp.data_model* (page 27)) – data model object, ready for use

Called by *run()* (page 9) method to instantiate and build the data model object, including any modifications specified by MATPOWER options or extensions.

data_model_build_pre(*dm*, *d*, *dmc*, *mpopt*)

Called at beginning of *data_model_build()* (page 14).

```
[dm, d] = task.data_model_build_pre(dm, d, dmc, mpopt)
```

Inputs
- **dm** (*mp.data_model* (page 27)) – data model object
- **d** – data source specification, currently assumed to be a MATPOWER case name or case struct (`mpc`)
- **dmc** (*mp.dm_converter* (page 59)) – data model converter object
- **mpopt** (*struct*) – MATPOWER options struct

Outputs
- **dm** (*mp.data_model* (page 27)) – updated data model object
- **d** – updated value of corresponding input

Called just *before* calling the data model's build() method. In this base class, this method does nothing.

data_model_build_post(*dm*, *dmc*, *mpopt*)

Called at end of *data_model_build()* (page 14).

```
dm = task.data_model_build_post(dm, dmc, mpopt)
```

Inputs
- **dm** (*mp.data_model* (page 27)) – data model object
- **dmc** (*mp.dm_converter* (page 59)) – data model converter object
- **mpopt** (*struct*) – MATPOWER options struct

Output
dm (*mp.data_model* (page 27)) – updated data model object

Called just *after* calling the data model's build() method. In this base class, this method does nothing.

network_model_class(*dm*, *mpopt*, *mpx*)

Get network model constructor.

```
nm_class = task.network_model_class(dm, mpopt, mpx)
```

Inputs

- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct
- **mpx** (cell array of *mp.extension* (page 170)) – MATPOWER Extensions

Output

nm_class (*function handle*) – handle to the constructor to be used to instantiate the network model object

Called by *network_model_create()* (page 15) to determine the class to use for the network model object. Handles any modifications specified by MATPOWER options or extensions.

network_model_class_default(*dm*, *mpopt*)

Get default network model constructor.

```
nm_class = task.network_model_class_default(dm, mpopt)
```

Inputs

- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Output

nm_class (*function handle*) – handle to default constructor to be used to instantiate the network model object

Called by *network_model_class()* (page 14) to determine the default class to use for the network model object.

Note: This is an abstract method that must be implemented by a subclass.

network_model_create(*dm*, *mpopt*, *mpx*)

Create network model object.

```
nm = task.network_model_create(dm, mpopt, mpx)
```

Inputs

- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct
- **mpx** (cell array of *mp.extension* (page 170)) – MATPOWER Extensions

Output

nm (*mp.net_model* (page 90)) – network model object, ready to build

Called by *network_model_build()* (page 15) to instantiate the network model object. Handles any modifications to network model elements specified by MATPOWER options or extensions.

network_model_build(*dm*, *mpopt*, *mpx*)

Create and build network model object.

```
nm = task.network_model_build(dm, mpopt, mpx)
```

Inputs

- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct
- **mpx** (cell array of *mp.extension* (page 170)) – MATPOWER Extensions

Output

nm (*mp.net_model* (page 90)) – network model object, ready for use

Called by *run()* (page 9) method to instantiate and build the network model object, including any modifications specified by MATPOWER options or extensions.

network_model_build_pre(*nm*, *dm*, *mpopt*)

Called at beginning of *network_model_build()* (page 15).

```
nm = task.network_model_build_pre(nm, dm, mpopt)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Output
nm (*mp.net_model* (page 90)) – updated network model object

Called just *before* calling the network model's build() method. In this base class, this method does nothing.

network_model_build_post(*nm*, *dm*, *mpopt*)

Called at end of *network_model_build()* (page 15).

```
nm = task.network_model_build_post(nm, dm, mpopt)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Output
nm (*mp.net_model* (page 90)) – updated network model object

Called just *after* calling the network model's build() method. In this base class, this method does nothing.

network_model_x_soln(*mm*, *nm*)

Update network model state from math model solution.

```
nm = task.network_model_x_soln(mm, nm)
```

Inputs
- **mm** (*mp.math_model* (page 121)) – mathmatical model object
- **nm** (*mp.net_model* (page 90)) – network model object

Output
nm (*mp.net_model* (page 90)) – updated network model object

Called by *network_model_update()* (page 16).

network_model_update(*mm*, *nm*)

Update network model state, solution values from math model solution.

```
nm = task.network_model_update(mm, nm)
```

Inputs
- **mm** (*mp.math_model* (page 121)) – mathmatical model object
- **nm** (*mp.net_model* (page 90)) – network model object

Output
nm (*mp.net_model* (page 90)) – updated network model object

Called by *run()* (page 9) method.

math_model_class(*nm*, *dm*, *mpopt*, *mpx*)

Get mathematical model constructor.

```
mm_class = task.math_model_class(nm, dm, mpopt, mpx)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct
- **mpx** (cell array of *mp.extension* (page 170)) – MATPOWER Extensions

Output

mm_class (*function handle*) – handle to the constructor to be used to instantiate the mathematical model object

Called by *math_model_create()* (page 17) to determine the class to use for the mathematical model object. Handles any modifications specified by MATPOWER options or extensions.

math_model_class_default(*nm*, *dm*, *mpopt*)

Get default mathematical model constructor.

```
mm_class = task.math_model_class_default(nm, dm, mpopt)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Output

mm_class (*function handle*) – handle to the constructor to be used to instantiate the mathematical model object

Called by *math_model_class()* (page 16) to determine the default class to use for the mathematical model object.

Note: This is an abstract method that must be implemented by a subclass.

math_model_create(*nm*, *dm*, *mpopt*, *mpx*)

Create mathematical model object.

```
mm = task.math_model_create(nm, dm, mpopt, mpx)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct
- **mpx** (cell array of *mp.extension* (page 170)) – MATPOWER Extensions

Output

mm (*mp.math_model* (page 121)) – mathmatical model object, ready to build

Called by *math_model_build()* (page 17) to instantiate the mathematical model object. Handles any modifications to mathematical model elements specified by MATPOWER options or extensions.

math_model_build(*nm*, *dm*, *mpopt*, *mpx*)

Create and build mathematical model object.

```
mm = task.math_model_build(nm, dm, mpopt, mpx)
```

Inputs

- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct
- **mpx** (cell array of *mp.extension* (page 170)) – MATPOWER Extensions

Output

mm (*mp.math_model* (page 121)) – mathmatical model object, ready for use

Called by *run()* (page 9) method to instantiate and build the mathematical model object, including any modifications specified by MATPOWER options or extensions.

math_model_opt(*mm*, *nm*, *dm*, *mpopt*)

Get the options struct to pass to `mm.solve()`.

```
opt = task.math_model_opt(mm, nm, dm, mpopt)
```

Inputs

- **mm** (*mp.math_model* (page 121)) – mathmatical model object
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Output

opt (*struct*) – options struct for mathematical model solve() method

Called by *run()* (page 9) method.

mp.task_pf

class mp.**task_pf**

Bases: *mp.task* (page 7)

mp.task_pf (page 18) - MATPOWER task for power flow (PF).

Provides task implementation for the power flow problem.

This includes the handling of iterative runs to enforce generator reactive power limits, if requested.

mp.task_pf Properties:

- *tag* (page 19) - task tag 'PF'
- *name* (page 19) - task name 'Power Flow'
- *dc* (page 19) - `true` if using DC network model
- *iterations* (page 19) - total number of power flow iterations
- *ref* (page 19) - current ref node indices
- *ref0* (page 19) - initial ref node indices
- *va_ref0* (page 19) - initial ref node voltage angles
- *fixed_q_idx* (page 19) - indices of fixed Q gens
- *fixed_q_qty* (page 19) - Q output of fixed Q gens

mp.task_pf Methods:

- *run_pre()* (page 19) - set dc property

- *next_dm()* (page 19) - optionally iterate to enforce generator reactive limits
- *enforce_q_lims()* (page 19) - implementation of generator reactive limits
- *network_model_class_default()* (page 19) - select default network model constructor
- *network_model_build_post()* (page 19) - initialize properties for reactive limits
- *network_model_x_soln()* (page 19) - correct the voltage angles if necessary
- *math_model_class_default()* (page 20) - select default math model constructor

See also *mp.task* (page 7).

Property Summary

tag = 'PF'

name = 'Power Flow'

dc

`true` if using DC network model (from `mpopt.model`, cached in *run_pre()* (page 19))

iterations

(integer) total number of power flow *iterations* (page 19)

ref

(integer) current *ref* (page 19) node indices

ref0

(integer) initial ref node indices

va_ref0

(double) initial ref node voltage angles

fixed_q_idx

(integer) indices of fixed Q gens

fixed_q_qty

(double) Q output of fixed Q gens

Method Summary

run_pre(*d*, *mpopt*)

Set dc property after calling superclass *run_pre()* (page 11).

next_dm(*mm*, *nm*, *dm*, *mpopt*, *mpx*)

Implement optional iterations to enforce generator reactive limits.

enforce_q_lims(*nm*, *dm*, *mpopt*)

Used by *next_dm()* (page 19) to implement enforcement of generator reactive limits.

network_model_class_default(*dm*, *mpopt*)

Implement selector for default network model constructor depending on `mpopt.model` and `mpopt.pf.v_cartesian`.

network_model_build_post(*nm*, *dm*, *mpopt*)

Initialize *mp.task_pf* (page 18) properties, if non-empty AC case with generator reactive limits enforced.

network_model_x_soln(*mm*, *nm*)

Call superclass *network_model_x_soln()* (page 16) then correct the voltage angle if the ref node has been changed.

math_model_class_default(*nm*, *dm*, *mpopt*)

Implement selector for default mathematical model constructor depending on `mpopt.model`, `mpopt.pf.v_cartesian`, and `mpopt.pf.current_balance`.

mp.task_cpf

class mp.**task_cpf**

Bases: *mp.task_pf* (page 18)

mp.task_cpf (page 20) - MATPOWER task for continuation power flow (CPF).

Provides task implementation for the continuation power flow problem.

This includes the iterative solving of the mathematical model (using warm restarts) after updating the problem data, e.g. when enforcing certain limits.

mp.task_cpf Properties:

- *warmstart* (page 20) - warm start data

mp.task_cpf Methods:

- *task_cpf()* (page 20) - constructor, inherits from *mp.task_pf* (page 18) constructor
- *run_pre()* (page 21) - call superclass *run_pre()* (page 19) for base and target inputs
- *next_mm()* (page 21) - handle warm start of continuation iterations
- *dm_converter_class()* (page 21) - select data model converter class
- *data_model_class_default()* (page 21) - select default data model constructor
- *data_model_build()* (page 21) - build base and target data models
- *network_model_build()* (page 21) - build base and target network models
- *network_model_x_soln()* (page 21) - update network model solution
- *network_model_update()* (page 21) - evaluate port injection solution
- *math_model_class_default()* (page 21) - select default math model constructor
- *math_model_opt()* (page 21) - add warmstart parameters to math model solve options

See also *mp.task* (page 7), *mp.task_pf* (page 18).

Constructor Summary

task_cpf()

Constructor, inherits from *mp.task_pf* (page 18) constructor.

Property Summary

warmstart

(struct) warm start data, with fields:
- clam - corrector parameter lambda
- plam - predictor parameter lambda

- cV - corrector complex voltage vector
- pV - predictor complex voltage vector

Method Summary

run_pre(*d*, *mpopt*)

Call superclass *run_pre()* (page 19) for base and target inputs.

next_mm(*mm*, *nm*, *dm*, *mpopt*, *mpx*)

Handle warm start of continuation iterations, after problem data update.

dm_converter_class(*d*, *mpopt*, *mpx*)

Implement selector for data model converter class based on superclass constructor.

data_model_class_default()

Implement selector for default data model constructor.

data_model_build(*d*, *dmc*, *mpopt*, *mpx*)

Call superclass `data_model_build()` for base and target models.

network_model_build(*dm*, *mpopt*, *mpx*)

Call superclass `network_model_build()` for base and target models.

network_model_x_soln(*mm*, *nm*)

Call superclass *network_model_x_soln()* (page 19) then update solution in target network model.

network_model_update(*mm*, *nm*)

Call superclass `network_model_update()` then update port injection solution by interpolating with parameter lambda.

math_model_class_default(*nm*, *dm*, *mpopt*)

Implement selector for default mathematical model constructor depending on `mpopt.pf.v_cartesian` and `mpopt.pf.current_balance`.

math_model_opt(*mm*, *nm*, *dm*, *mpopt*)

Call superclass `math_model_opt()` then add warmstart parameters, if available.

mp.task_opf

class mp.**task_opf**

Bases: *mp.task* (page 7)

mp.task_opf (page 21) - MATPOWER task for optimal power flow (OPF).

Provides task implementation for the optimal power flow problem.

mp.task_opf Properties:

- `tag` - task tag 'OPF'
- `name` - task name 'Optimal Power Flow'
- *dc* (page 22) - `true` if using DC network model

mp.task_opf Methods:

- *run_pre()* (page 22) - set `dc` property
- *print_soln_header()* (page 22) - add printout of objective function value

- *data_model_class_default()* (page 22) - select default data model constructor
- *data_model_build_post()* (page 22) - adjust bus voltage limits, if requested
- *network_model_class_default()* (page 22) - select default network model constructor
- *math_model_class_default()* (page 22) - select default math model constructor

See also *mp.task* (page 7).

Property Summary

dc

`true` if using DC network model (from `mpopt.model`, cached in *run_pre()* (page 22))

Method Summary

run_pre(*d*, *mpopt*)

Set `dc` property after calling superclass *run_pre()* (page 11), then check for unsupported AC OPF solver selection.

print_soln_header(*mpopt*, *fd*)

Call superclass *print_soln_header()* (page 11) the print out the objective function value.

data_model_class_default()

Implement selector for default data model constructor.

data_model_build_post(*dm*, *dmc*, *mpopt*)

Call superclass *data_model_build_post()* (page 14) then adjust bus voltage magnitude limits based on generator `vm_setpoint`, if requested.

network_model_class_default(*dm*, *mpopt*)

Implement selector for default network model constructor depending on `mpopt.model` and `mpopt.opf.v_cartesian`.

math_model_class_default(*nm*, *dm*, *mpopt*)

Implement selector for default mathematical model constructor depending on `mpopt.model`, `mpopt.opf.v_cartesian`, and `mpopt.opf.current_balance`.

3.1.2 Legacy Task Classes

Used by MP-Core when called by the *legacy MATPOWER framework*.

mp.task_pf_legacy

class mp.**task_pf_legacy**

Bases: *mp.task_pf* (page 18), *mp.task_shared_legacy* (page 26)

mp.task_pf_legacy (page 22) - MATPOWER task for legacy power flow (PF).

Adds functionality needed by the *legacy MATPOWER framework* to the task implementation for the power flow problem. This consists of pre-processing some input data and exporting and packaging result data.

mp.task_pf Methods:

- *run_pre()* (page 23) - pre-process inputs that are for legacy framework only

- *run_post()* (page 23) - export results back to data model source
- *legacy_post_run()* (page 23) - post-process *legacy framework* outputs

See also *mp.task_pf* (page 18), *mp.task* (page 7), *mp.task_shared_legacy* (page 26).

Method Summary

run_pre(*d*, *mpopt*)

Pre-process inputs that are for *legacy framework* only.

```
[d, mpopt] = task.run_pre(d, mpopt)
```

Inputs
- **d** – data source specification, currently assumed to be a MATPOWER case name or case struct (`mpc`)
- **mpopt** (*struct*) – MATPOWER options struct

Outputs
- **d** – updated value of corresponding input
- **mpopt** (*struct*) – updated value of corresponding input

Call *run_pre_legacy()* (page 27) method before calling parent.

run_post(*mm*, *nm*, *dm*, *mpopt*)

Export results back to data model source.

```
task.run_post(mm, nm, dm, mpopt)
```

Inputs
- **mm** (*mp.math_model* (page 121)) – mathmatical model object
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Output
task (*mp.task* (page 7)) – task object

Calls *mp.dm_converter.export()* (page 60) and saves the result in the data model `source` property.

legacy_post_run(*mpopt*)

Post-process *legacy framework* outputs.

```
[results, success] = task.legacy_post_run(mpopt)
```

Input
mpopt (*struct*) – MATPOWER options struct

Outputs
- **results** (*struct*) – results struct for *legacy MATPOWER framework*, see Table 4.1 in legacy MATPOWER User's Manual.
- **success** (*integer*) – 1 - succeeded, 0 - failed

Extract `results` and `success` and save the task object in `results.task` before returning.

mp.task_cpf_legacy

class mp.**task_cpf_legacy**

Bases: *mp.task_cpf* (page 20), *mp.task_shared_legacy* (page 26)

mp.task_cpf (page 20) - MATPOWER task for legacy continuation power flow (CPF).

Adds functionality needed by the *legacy MATPOWER framework* to the task implementation for the continuation power flow problem. This consists of pre-processing some input data and exporting and packaging result data.

mp.task_pf Methods:

- *run_pre()* (page 24) - pre-process inputs that are for legacy framework only
- *run_post()* (page 24) - export results back to data model source
- *legacy_post_run()* (page 24) - post-process *legacy framework* outputs

See also *mp.task_cpf* (page 20), *mp.task* (page 7), *mp.task_shared_legacy* (page 26).

Method Summary

run_pre(*d*, *mpopt*)

Pre-process inputs that are for *legacy framework* only.

```
[d, mpopt] = task.run_pre(d, mpopt)
```

Inputs
- **d** – data source specification, currently assumed to be a MATPOWER case name or case struct (mpc)
- **mpopt** (*struct*) – MATPOWER options struct

Outputs
- **d** – updated value of corresponding input
- **mpopt** (*struct*) – updated value of corresponding input

Call *run_pre_legacy()* (page 27) method for both input cases before calling parent.

run_post(*mm*, *nm*, *dm*, *mpopt*)

Export results back to data model source.

```
task.run_post(mm, nm, dm, mpopt)
```

Inputs
- **mm** (*mp.math_model* (page 121)) – mathmatical model object
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Output
task (*mp.task* (page 7)) – task object

Calls *mp.dm_converter.export()* (page 60) and saves the result in the data model source property.

legacy_post_run(*mpopt*)

Post-process *legacy framework* outputs.

```
[results, success] = task.legacy_post_run(mpopt)
```

Input
mpopt (*struct*) – MATPOWER options struct

Outputs

- **results** (*struct*) – results struct for *legacy MATPOWER framework*, see Table 5.1 in legacy MATPOWER User's Manual.
- **success** (*integer*) – 1 - succeeded, 0 - failed

Extract `results` and `success` and save the task object in `results.task` before returning.

mp.task_opf_legacy

class mp.**task_opf_legacy**

Bases: *mp.task_opf* (page 21), *mp.task_shared_legacy* (page 26)

mp.task_opf (page 21) - MATPOWER task for legacy optimal power flow (OPF).

Adds functionality needed by the *legacy MATPOWER framework* to the task implementation for the optimal power flow problem. This consists of pre-processing some input data and exporting and packaging result data, as well as using some legacy specific model sub-classes.

mp.task_pf Methods:

- *run_pre()* (page 25) - pre-process inputs that are for legacy framework only
- *run_post()* (page 25) - export results back to data model source
- *dm_converter_class_mpc2_default()* (page 26) - set to *mp.dm_converter_mpc2_legacy* (page 62)
- *data_model_build_post()* (page 26) - get data model converter to do more input pre-processing
- *math_model_class_default()* (page 26) - use legacy math model subclasses
- *legacy_post_run()* (page 26) - post-process *legacy framework* outputs

See also *mp.task_opf* (page 21), *mp.task* (page 7), *mp.task_shared_legacy* (page 26).

Method Summary

run_pre(*d*, *mpopt*)

Pre-process inputs that are for *legacy framework* only.

```
[d, mpopt] = task.run_pre(d, mpopt)
```

Inputs
- **d** – data source specification, currently assumed to be a MATPOWER case name or case struct (`mpc`)
- **mpopt** (*struct*) – MATPOWER options struct

Outputs
- **d** – updated value of corresponding input
- **mpopt** (*struct*) – updated value of corresponding input

Call *run_pre_legacy()* (page 27) method before calling parent.

run_post(*mm*, *nm*, *dm*, *mpopt*)

Export results back to data model source.

```
task.run_post(mm, nm, dm, mpopt)
```

Inputs
- **mm** (*mp.math_model* (page 121)) – mathmatical model object

- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Output

task (*mp.task* (page 7)) – task object

Calls *mp.dm_converter.export()* (page 60) and saves the result in the data model `source` property.

dm_converter_class_mpc2_default()

Set to *mp.dm_converter_mpc2_legacy* (page 62).

```
dmc_class = task.dm_converter_class_mpc2_default()
```

data_model_build_post(*dm*, *dmc*, *mpopt*)

Get data model converter to do more input pre-processing after calling superclass *data_model_build_post()* (page 22).

math_model_class_default(*nm*, *dm*, *mpopt*)

Use legacy math model subclasses to support legacy costs and callbacks.

Uses math model variations that inherit from *mp.mm_shared_opf_legacy* (page 142) (compatible with the legacy *opf_model* (page 219)), in order to support legacy cost functions and callback functions that expect to find the MATPOWER case struct in `mm.mpc`.

legacy_post_run(*mpopt*)

Post-process *legacy framework* outputs.

```
[results, success, raw] = task.legacy_post_run(mpopt)
```

Input

mpopt (*struct*) – MATPOWER options struct

Outputs

- **results** (*struct*) – results struct for *legacy MATPOWER framework*, see Table 6.1 in legacy MATPOWER User's Manual.
- **success** (*integer*) – 1 - succeeded, 0 - failed
- **raw** (*struct*) – see `raw` field in Table 6.1 in legacy MATPOWER User's Manual.

Extract `results` and `success` and save the task object in `results.task` before returning. This method also creates and populates numerous other fields expected in the legacy OPF `results` struct, such as `f`, `x`, `om`, `mu`, `g`, `dg`, `raw`, `var`, `nle`, `nli`, `lin`, and `cost`. Based on code from the legacy functions *opf_execute()* (page 292), *dcopf_solver()* (page 286), and *nlpopf_solver()* (page 287).

mp.task_shared_legacy

class mp.**task_shared_legacy**

Bases: `handle`

mp.task_shared_legacy (page 26) - Shared legacy task functionality.

Provides legacy task functionality shared across different tasks (e.g. PF, CPF, OPF), specifically, the pre-processing of input data for the experimental system-wide ZIP load data.

mp.task_pf Methods:

- *run_pre_legacy()* (page 27) - handle experimental system-wide ZIP load inputs

See also *mp.task* (page 7).

Method Summary

run_pre_legacy(*d*, *mpopt*)

Handle experimental system-wide ZIP load inputs.

```
[d, mpopt] = task.run_pre_legacy(d, mpopt)
```

Inputs
- **d** – data source specification, currently assumed to be a MATPOWER case name or case struct (mpc)
- **mpopt** (*struct*) – MATPOWER options struct

Outputs
- **d** – updated value of corresponding input
- **mpopt** (*struct*) – updated value of corresponding input

Moves the legacy experimental system-wide ZIP load data from `mpopt.exp.sys_wide_zip_loads` to `d.sys_wide_zip_loads` to make it available to the data model converter (*mp.dmce_load_mpc2* (page 70)).

Called by *run_pre()* (page 11).

3.2 Data Model Classes

3.2.1 Containers

mp.data_model

class mp.**data_model**

Bases: *mp.element_container* (page 165)

mp.data_model (page 27) - Base class for MATPOWER **data model** objects.

The data model object encapsulates the input data provided by the user for the problem of interest and the output data presented back to the user upon completion. It corresponds roughly to the `mpc` (MATPOWER case) and `results` structs used throughout the legacy MATPOWER implementation, but encapsulated in an object with additional functionality. It includes tables of data for each type of element in the system.

A data model object is primarily a container for data model element (*mp.dm_element* (page 35)) objects. Concrete data model classes may be specific to the task.

By convention, data model variables are named `dm` and data model class names begin with `mp.data_model`.

mp.data_model Properties:

- *base_mva* (page 28) - system per unit MVA base
- *base_kva* (page 28) - system per unit kVA base
- *source* (page 28) - source of data, e.g. `mpc` (MATPOWER case struct)
- *userdata* (page 28) - arbitrary user data

mp.data_model Methods:

- *data_model()* (page 28) - constructor, assign default data model element classes
- *copy()* (page 29) - make duplicate of object
- *build()* (page 29) - create, add, and build element objects
- *count()* (page 29) - count instances of each element and remove if count is zero
- *initialize()* (page 29) - initialize (online/offline) status of each element
- *update_status()* (page 29) - update (online/offline) status based on connectivity, etc
- *build_params()* (page 30) - extract/convert/calculate parameters for online elements
- *online()* (page 30) - get number of online elements of named type
- *display()* (page 30) - display the data model object
- *pretty_print()* (page 30) - pretty print data model to console or file
- *pp_flags()* (page 31) - from options, build flags to control pretty printed output
- *pp_section_label()* (page 31) - construct section header lines for output
- *pp_section_list()* (page 31) - return list of section tags
- *pp_have_section()* (page 32) - return true if section exists for object
- *pp_section()* (page 32) - pretty print the given section
- *pp_get_headers()* (page 32) - construct pretty printed lines for section headers
- *pp_get_headers_cnt()* (page 32) - construct pretty printed lines for **cnt** section headers
- *pp_get_headers_ext()* (page 33) - construct pretty printed lines for **ext** section headers
- *pp_data()* (page 33) - pretty print the data for the given section
- *set_bus_v_lims_via_vg()* (page 33) - set gen bus voltage limits based on gen voltage setpoints

See the sec_data_model section in the *MATPOWER Developer's Manual* for more information.

See also *mp.task* (page 7), *mp.net_model* (page 90), *mp.math_model* (page 121), *mp.dm_converter* (page 59).

Constructor Summary

`data_model()`

Constructor, assign default data model element classes.

```
dm = mp.data_model()
```

Property Summary

`base_mva`

(double) system per unit MVA base, for balanced single-phase systems/sections, must be provided if system includes any `'bus'` elements

`base_kva`

(double) system per unit kVA base, for unbalanced 3-phase systems/sections, must be provided if system includes any `'bus3p'` elements

`source`

source (page 28) of data, e.g. `mpc` (MATPOWER case struct)

userdata = struct()

(struct) arbitrary user data

Method Summary

copy()

Create a duplicate of the data model object, calling the *copy()* (page 40) method on each element.

```
new_dm = dm.copy()
```

build(*d*, *dmc*)

Create and add data model element objects.

```
dm.build(d, dmc)
```

Inputs

- **d** – data source, type depends on the implementing subclass (e.g. MATPOWER case struct for *mp.dm_converter_mpc2* (page 61))
- **dmc** (*mp.dm_converter* (page 59)) – data model converter

Create the data model element objects by instantiating each class in the *element_classes* (page 165) property and adding the resulting object to the *elements* (page 165) property. Then proceed through the following additional *build()* (page 29) stages for each element.

- Import
- Count
- Initialize
- Update status
- Build parameters

See the sec_building_data_model section in the *MATPOWER Developer's Manual* for more information.

count()

Count instances of each element and remove if *count()* (page 29) is zero.

```
dm.count()
```

Call each element's *count()* (page 40) method to determine the number of instances of that element in the data, and remove the element type from *elements* (page 165) if the count is 0.

Called by *build()* (page 29) to perform its **count** stage. See the sec_building_data_model section in the *MATPOWER Developer's Manual* for more information.

initialize()

Initialize (online/offline) status of each element.

```
dm.initialize()
```

Call each element's *initialize()* (page 40) method to *initialize()* (page 29) statuses and create ID to row index mappings.

Called by *build()* (page 29) to perform its **initialize** stage. See the sec_building_data_model section in the *MATPOWER Developer's Manual* for more information.

update_status()

Update (online/offline) status based on connectivity, etc.

```
dm.update_status()
```

Call each element's *update_status()* (page 41) method to update statuses based on connectivity or other criteria and define element properties containing number and row indices of online elements, indices of offline elements, and mapping of row indices to indices in online and offline element lists.

Called by *build()* (page 29) to perform its **update status** stage. See the sec_building_data_model section in the *MATPOWER Developer's Manual* for more information.

build_params()

Extract/convert/calculate parameters for online elements.

```
dm.build_params()
```

Call each element's *build_params()* (page 41) method to build parameters as necessary for online elements from the original data tables (e.g. p.u. conversion, initial state, etc.) and store them in element-specific properties.

Called by *build()* (page 29) to perform its **build parameters** stage. See the sec_building_data_model section in the *MATPOWER Developer's Manual* more information.

online(*name*)

Get number of online elements of named type.

```
n = dm.online(name)
```

Input
name (*char array*) – name of element type (e.g. `'bus'`, `'gen'`) as returned by the element's *name()* (page 37) method
Output
n (*integer*) – number of online elements

display()

Display the data model object.

This method is called automatically when omitting a semicolon on a line that retuns an object of this class.

Displays the details of the data model elements.

pretty_print(*mpopt*, *fd*)

Pretty print data model to console or file.

```
dm.pretty_print(mpopt)
dm.pretty_print(mpopt, fd)
[dm, out] = dm.pretty_print(mpopt, fd)
```

Inputs
- **mpopt** (*struct*) – MATPOWER options struct
- **fd** (*integer*) – *(optional, default = 1)* file identifier to use for printing, (1 for standard output, 2 for standard error)

Outputs
- **dm** (*mp.data_model* (page 27)) – the data model object
- **out** (*struct*) – struct of output control flags

Displays the model parameters to a pretty-printed text format. The result can be output either to the console or to a file.

The output is organized into sections and each element type controls its own output for each section. The default sections are:
- **cnt** - counts, number of online, offline, and total elements of this type

- **sum** - summary, e.g. total amount of capacity, load, line loss, etc.
- **ext** - extremes, e.g. min and max voltages, nodal prices, etc.
- **det** - details, table of detailed data, e.g. voltages, prices for buses, dispatch, limits for generators, etc.

`pp_flags`(*mpopt*)

From options, build flags to control pretty printed output.

```
[out, add] = dm.pp_flags(mpopt)
```

Input

mpopt (*struct*) – MATPOWER options struct

Outputs

- **out** (*struct*) – struct of output control flags

```
out
  .all    (-1, 0 or 1)
  .any    (0 or 1)
  .sec
    .cnt
      .all    (-1, 0 or 1)
      .any    (0 or 1)
    .sum    (same as cnt)
    .ext    (same as cnt)
    .det
      .all    (-1, 0 or 1)
      .any    (0 or 1)
      .elm
        .<name>    (0 or 1)
```

where <name> is the name of the corresponding element type.

- **add** (*struct*) – additional data for subclasses to use

```
add
  .s0
    .<name> = 0
  .s1
    .<name> = 1
  .suppress    (-1, 0 or 1)
  .names    (cell array of element names)
  .ne       (number of element names)
```

See also *pretty_print()* (page 30).

`pp_section_label`(*label*, *blank_line*)

Construct pretty printed lines for section label.

```
h = dm.pp_section_label(label, blank_line)
```

Inputs

- **label** (*char array*) – label for the section header
- **blank_line** (*boolean*) – include a blank line before the section label if true

Output

h (*cell array of char arrays*) – individual lines of section label

See also *pretty_print()* (page 30).

pp_section_list(*out*)

Return list of section tags.

```
sections = dm.pp_section_list(out)
```

Input
out (*struct*) – struct of output control flags (see *pp_flags()* (page 31) for details)
Output
sections (*cell array of char arrays*) – e.g. `{'cnt', 'sum', 'ext', 'det'}`

See also *pretty_print()* (page 30).

pp_have_section(*section*, *mpopt*)

Return true if section exists for object with given options.

```
TorF = dm.pp_have_section(section, mpopt)
```

Inputs
- **section** (*char array*) – e.g. `'cnt'`, `'sum'`, `'ext'`, or `'det'`
- **mpopt** (*struct*) – MATPOWER options struct

Output
TorF (*boolean*) – true if section exists

See also *pretty_print()* (page 30).

pp_section(*section*, *out_s*, *mpopt*, *fd*)

Pretty print the given section.

```
dm.pp_section(section, out_s, mpopt, fd)
```

Inputs
- **section** (*char array*) – e.g. `'cnt'`, `'sum'`, `'ext'`, or `'det'`
- **out_s** (*struct*) – output control flags for the section, `out_s = out.sec.(section)`
- **mpopt** (*struct*) – MATPOWER options struct
- **fd** (*integer*) – *(optional, default = 1)* file identifier to use for printing, (1 for standard output, 2 for standard error)

See also *pretty_print()* (page 30).

pp_get_headers(*section*, *out_s*, *mpopt*)

Construct pretty printed lines for section headers.

```
h = dm.pp_get_headers(section, out_s, mpopt)
```

Inputs
- **section** (*char array*) – e.g. `'cnt'`, `'sum'`, `'ext'`, or `'det'`
- **out_s** (*struct*) – output control flags for the section, `out_s = out.sec.(section)`
- **mpopt** (*struct*) – MATPOWER options struct

Output
h (*cell array of char arrays*) – individual lines of section headers

See also *pretty_print()* (page 30).

pp_get_headers_cnt(*out_s*, *mpopt*)

Construct pretty printed lines for **cnt** section headers.

```
h = dm.pp_get_headers_cnt(out_s, mpopt)
```

Inputs
- **out_s** (*struct*) – output control flags for the section, `out_s = out.sec.(section)`
- **mpopt** (*struct*) – MATPOWER options struct

Output
h (*cell array of char arrays*) – individual lines of **cnt** section headers

See also *pretty_print()* (page 30), *pp_get_headers()* (page 32).

`pp_get_headers_ext`(*out_s*, *mpopt*)

Construct pretty printed lines for **ext** section headers.

```
h = dm.pp_get_headers_cnt(out_s, mpopt)
```

Inputs
- **out_s** (*struct*) – output control flags for the section, `out_s = out.sec.(section)`
- **mpopt** (*struct*) – MATPOWER options struct

Output
h (*cell array of char arrays*) – individual lines of **ext** section headers

See also *pretty_print()* (page 30), *pp_get_headers()* (page 32).

`pp_get_headers_other`(*section*, *out_s*, *mpopt*)

Construct pretty printed lines for other section headers.

Returns nothing in base class, but subclasses can implement other section types (e.g. `'lim'` for OPF).

```
h = dm.pp_get_headers_other(section, out_s, mpopt)
```

Inputs
- **section** (*char array*) – e.g. `'cnt'`, `'sum'`, `'ext'`, or `'det'`
- **out_s** (*struct*) – output control flags for the section, `out_s = out.sec.(section)`
- **mpopt** (*struct*) – MATPOWER options struct

Output
h (*cell array of char arrays*) – individual lines of **ext** section headers

See also *pretty_print()* (page 30), *pp_get_headers()* (page 32).

`pp_data`(*section*, *out_s*, *mpopt*, *fd*)

Pretty print the data for the given section.

```
dm.pp_data(section, out_s, mpopt, fd)
```

Inputs
- **section** (*char array*) – e.g. `'cnt'`, `'sum'`, `'ext'`, or `'det'`
- **out_s** (*struct*) – output control flags for the section, `out_s = out.sec.(section)`
- **mpopt** (*struct*) – MATPOWER options struct
- **fd** (*integer*) – *(optional, default = 1)* file identifier to use for printing, (1 for standard output, 2 for standard error)

See also *pretty_print()* (page 30), *pp_section()* (page 32).

`set_bus_v_lims_via_vg`(*use_vg*)

Set gen bus voltage limits based on gen voltage setpoints.

```
dm.set_bus_v_lims_via_vg(use_vg)
```

Input
use_vg (*double*) – 1 if voltage setpoint should be used, 0 for original bus voltage bounds, or fractional value between 0 and 1 for bounds interpolated between the two.

mp.data_model_cpf

class mp.**data_model_cpf**

Bases: *mp.data_model* (page 27)

mp.data_model_cpf (page 34) - MATPOWER **data model** for CPF tasks.

The purpose of this class is to include CPF-specific subclasses for the load and shunt elements, which need to be able to provide versions of their model parameters that are parameterized by the continuation parameter λ.

data_model_cpf Methods:

- *data_model_cpf()* (page 34) - constructor, assign default data model element classes

See also *mp.data_model* (page 27).

Constructor Summary

data_model_cpf()

Constructor, assign default data model element classes.

Create an empty data model object and assign the default data model element classes, which are the same as those defined by the base class, except for loads and shunts.

```
dm = mp.data_model_cpf()
```

mp.data_model_opf

class mp.**data_model_opf**

Bases: *mp.data_model* (page 27)

mp.data_model_opf (page 34) - MATPOWER **data model** for OPF tasks.

The purpose of this class is to include OPF-specific subclasses for its elements and to handle pretty-printing output for **lim** sections.

mp.data_model_opf Methods:

- *data_model_opf()* (page 34) - constructor, assign default data model element classes
- *pp_flags()* (page 35) - add flags for **lim** sections
- *pp_section_list()* (page 35) - append `'lim'` tag for **lim** sections to default list
- *pp_get_headers_other()* (page 35) - construct headers for **lim** section headers

See also *mp.data_model* (page 27).

Constructor Summary

data_model_opf()

Constructor, assign default data model element classes.

Create an empty data model object and assign the default data model element classes, each specific to OPF.

```
dm = mp.data_model_opf()
```

Method Summary

pp_flags(*mpopt*)

Add flags for **lim** sections.

See *mp.data_model.pp_flags()* (page 31).

pp_section_list(*out*)

Append 'lim' tag for **lim** section to default list.

See *mp.data_model.pp_section_list()* (page 31).

pp_get_headers_other(*section*, *out_s*, *mpopt*)

Construct pretty printed lines for **lim** section headers.

See *mp.data_model.pp_get_headers_other()* (page 33).

3.2.2 Elements

mp.dm_element

class mp.**dm_element**

Bases: handle

mp.dm_element (page 35) - Abstract base class for MATPOWER **data model element** objects.

A data model element object encapsulates all of the input and output data for a particular element type. All data model element classes inherit from *mp.dm_element* (page 35) and each element type typically implements its own subclass. A given data model element object contains the data for all instances of that element type, stored in one or more table data structures.

Defines the following columns in the main data table, which are inherited by all subclasses:

Name	Type	Description
uid	*integer*	unique ID
name	*char array*	element name
status	*boolean*	true = online, false = offline
source_uid	*undefined*	intended for any info required to link back to element instance in source data

By convention, data model element variables are named dme and data model element class names begin with mp.dme.

In addition to being containers for the data itself, data model elements are responsible for handling the on/off status of each element, preparation of parameters needed by network and mathematical models, definition of connections with other elements, defining solution data to be updated when exporting, and pretty-printing of data to the console or file.

Elements that create nodes (e.g. buses) are called **junction** elements. Elements that define ports (e.g. generators, branches, loads) can connect the ports of a particular instance to the nodes of a particular instance of a junction element by specifying two pieces of information for each port:

- the **type** of junction element it connects to
- the **index** of the specific junction element

mp.dm_element Properties:

- *tab* (page 37) - main data table
- *nr* (page 37) - total number of rows in table
- *n* (page 37) - number of online elements
- *ID2i* (page 37) - max(ID) x 1 vector, maps IDs to row indices
- *on* (page 37) - `n` x 1 vector of row indices of online elements
- *off* (page 37) - (`nr`-`n`) x 1 vector of row indices of offline elements
- *i2on* (page 37) - `nr` x 1 vector mapping row index to index in `on`/`off` respectively

mp.dm_element Methods:

- *name()* (page 37) - get name of element type, e.g. `'bus'`, `'gen'`
- *label()* (page 38) - get singular label for element type, e.g. `'Bus'`, `'Generator'`
- *labels()* (page 38) - get plural label for element type, e.g. `'Buses'`, `'Generators'`
- *cxn_type()* (page 38) - type(s) of junction element(s) to which this element connects
- *cxn_idx_prop()* (page 38) - name(s) of property(ies) containing indices of junction elements
- *cxn_type_prop()* (page 39) - name(s) of property(ies) containing types of junction elements
- *table_exists()* (page 39) - check for existence of data in main data table
- *main_table_var_names()* (page 39) - names of variables (columns) in main data table
- *export_vars()* (page 39) - names of variables to be exported by DMCE to data source
- *export_vars_offline_val()* (page 40) - values of export variables for offline elements
- *dm_converter_element()* (page 40) - get corresponding data model converter element
- *copy()* (page 40) - create a duplicate of the data model element object
- *count()* (page 40) - determine number of instances of this element in the data
- *initialize()* (page 40) - initialize (online/offline) status of each element
- *ID()* (page 41) - return unique ID's for all or indexed rows
- *init_status()* (page 41) - initialize `status` column
- *update_status()* (page 41) - update (online/offline) status based on connectivity, etc
- *build_params()* (page 41) - extract/convert/calculate parameters for online elements
- *rebuild()* (page 42) - rebuild object, calling *count()* (page 40), *initialize()* (page 40), *build_params()* (page 41)
- *display()* (page 42) - display the data model element object
- *pretty_print()* (page 42) - pretty-print data model element to console or file
- *pp_have_section()* (page 42) - true if pretty-printing for element has specified section

- *pp_rows()* (page 43) - indices of rows to include in pretty-printed output
- *pp_get_headers()* (page 43) - get pretty-printed headers for this element/section
- *pp_get_footers()* (page 43) - get pretty-printed footers for this element/section
- *pp_data()* (page 43) - pretty-print the data for this element/section
- *pp_have_section_cnt()* (page 43) - true if pretty-printing for element has **counts** section
- *pp_data_cnt()* (page 44) - pretty-print the **counts** data for this element
- *pp_have_section_sum()* (page 44) - true if pretty-printing for element has **summary** section
- *pp_data_sum()* (page 44) - pretty-print the **summary** data for this element
- *pp_have_section_ext()* (page 44) - true if pretty-printing for element has **extremes** section
- *pp_data_ext()* (page 44) - pretty-print the **extremes** data for this element
- *pp_have_section_det()* (page 44) - true if pretty-printing for element has **details** section
- *pp_get_title_det()* (page 44) - get title of **details** section for this element
- *pp_get_headers_det()* (page 45) - get pretty-printed **details** headers for this element
- *pp_get_footers_det()* (page 45) - get pretty-printed **details** footers for this element
- *pp_data_det()* (page 45) - pretty-print the **details** data for this element
- *pp_data_row_det()* (page 45) - get pretty-printed row of **details** data for this element

See the sec_dm_element section in the *MATPOWER Developer's Manual* for more information.

See also *mp.data_model* (page 27).

Property Summary

`tab`
: *(table)* main data table

`nr`
: *(integer)* total number of rows in table

`n`
: *(integer)* number of online elements

`ID2i`
: *(integer)* max(ID) x 1 vector, maps IDs to row indices

`on`
: *(integer)* `n` x 1 vector of row indices of online elements

`off`
: *(integer)* (`nr`-`n`) x 1 vector of row indices of offline elements

`i2on`
: *(integer)* `nr` x 1 vector mapping row index to index in `on`/`off` respectively

Method Summary

`name()`

Get name of element type, e.g. `'bus'`, `'gen'`.

```
name = dme.name()
```

Output
name (*char array*) – name of element type, must be a valid struct field name

Implementation provided by an element type specific subclass.

`label()`

Get singular label for element type, e.g. `'Bus'`, `'Generator'`.

```
label = dme.label()
```

Output
label (*char array*) – user-visible label for element type, when singular

Implementation provided by an element type specific subclass.

`labels()`

Get plural label for element type, e.g. `'Buses'`, `'Generators'`.

```
label = dme.labels()
```

Output
label (*char array*) – user-visible label for element type, when plural

Implementation provided by an element type specific subclass.

`cxn_type()`

Type(s) of junction element(s) to which this element connects.

```
name = dme.cxn_type()
```

Output
name (*char array or cell array of char arrays*) – name(s) of type(s) of junction elements, i.e. node-creating elements (e.g. `'bus'`), to which this element connects

Assuming an element with *nc* connections, there are three options for the return value:

1. Single char array with one type that applies to all connections, *cxn_idx_prop()* (page 38) returns *empty*.
2. Cell array with *nc* elements, one for each connection, *cxn_idx_prop()* (page 38) returns *empty*.
3. Cell array of valid junction element types, *cxn_idx_prop()* (page 38) return value *not empty*.

See the sec_dm_element_cxn section in the *MATPOWER Developer's Manual* for more information.

Implementation provided by an element type specific subclass.

See also *cxn_idx_prop()* (page 38), *cxn_type_prop()* (page 39).

`cxn_idx_prop()`

Name(s) of property(ies) containing indices of junction elements.

```
name = dme.cxn_idx_prop()
```

Output
name (*char array or cell array of char arrays*) – name(s) of property(ies) containing indices of junction elements that define connections (e.g. `{'fbus', 'tbus'}`)

See the sec_dm_element_cxn section in the *MATPOWER Developer's Manual* for more information.

Implementation provided by an element type specific subclass.

See also *cxn_type()* (page 38), *cxn_type_prop()* (page 39).

cxn_type_prop()

Name(s) of property(ies) containing types of junction elements.

```
name = dme.cxn_type_prop()
```

Output

name (*char array or cell array of char arrays*) – name(s) of properties containing type of junction elements for each connection

Note: If not empty, dimension must match *cxn_idx_prop()* (page 38)

This is only used if the junction element type can vary by individual element, e.g. some elements of this type connect to one kind of bus, some to another kind. Otherwise, it returns an empty string and the junction element types for the connections are determined solely by *cxn_type()* (page 38).

See the sec_dm_element_cxn section in the *MATPOWER Developer's Manual* for more information.

Implementation provided by an element type specific subclass.

See also *cxn_type()* (page 38), *cxn_idx_prop()* (page 38).

table_exists()

Check for existence of data in main data table.

```
TorF = dme.table_exists()
```

Output

TorF (*boolean*) – true if main data table is not empty

main_table_var_names()

Names of variables (columns) in main data table.

```
names = dme.main_table_var_names()
```

Output

names (*cell array of char arrays*) – names of variables (columns) in main table

This base class includes the following variables `{'uid', 'name', 'status', 'source_uid'}` which are common to all element types and should therefore be included in all subclasses. That is, subclass methods should append their additional fields to those returned by this parent method. For example, a subclass method would like something like the following:

```
function names = main_table_var_names(obj)
    names = horzcat( main_table_var_names@mp.dm_element(obj), ...
    {'subclass_var1', 'subclass_var2'} );
end
```

export_vars()

Names of variables to be exported by DMCE to data source.

```
vars = dme.export_vars()
```

Output

vars (*cell array of char arrays*) – names of variables to export

Return the names of the variables the data model converter element needs to export to the data source. This is typically the list of variables updated by the solution process, e.g. bus voltages, line flows, etc.

export_vars_offline_val()

Values of export variables for offline elements.

```
s = dme.export_vars_offline_val()
```

Output
s (*struct*) – keys are export variable names, values are the corresponding values to assign to these variables for offline elements.

Returns a struct defining the values of export variables for offline elements. Called by *mp.mm_element.data_model_update()* (page 145) to define how to set export variables for offline elements.

Export variables not found in the struct are not modified.

For example, `s = struct('va', 0, 'vm', 1)` would assign the value 0 to the `va` variable and 1 to the `vm` variable for any offline elements.

See also *export_vars()* (page 39).

dm_converter_element(*dmc*, *name*)

Get corresponding data model converter element.

```
dmce = dme.dm_converter_element(dmc)
dmce = dme.dm_converter_element(dmc, name)
```

Inputs
- **dmc** (*mp.dm_converter* (page 59)) – data model converter object
- **name** (*char array*) – *(optional)* name of element type *(default is name of this object)*

Output
dmce (*mp.dmc_element* (page 62)) – data model converter element object

copy()

Create a duplicate of the data model element object.

```
new_dme = dme.copy()
```

Output
new_dme (*mp.dm_element* (page 35)) – *copy()* (page 40) of data model element object

count(*dm*)

Determine number of instances of this element in the data.

Store the count in the `nr` property.

```
nr = dme.count(dm);
```

Input
dm (*mp.data_model* (page 27)) – data model

Output
nr (*integer*) – number of instances (rows of data)

Called for each element by the *count()* (page 29) method of *mp.data_model* (page 27) during the **count** stage of a data model build.

See the sec_building_data_model section in the *MATPOWER Developer's Manual* for more information.

`initialize`(*dm*)

Initialize a newly created data model element object.

```
dme.initialize(dm)
```

Input
dm (*mp.data_model* (page 27)) – data model

Initialize the (online/offline) status of each element and create a mapping of ID to row index in the `ID2i` element property, then call *init_status()* (page 41).

Called for each element by the *initialize()* (page 29) method of *mp.data_model* (page 27) during the **initialize** stage of a data model build.

See the sec_building_data_model section in the *MATPOWER Developer's Manual* for more information.

`ID`(*idx*)

Return unique ID's for all or indexed rows.

```
uid = dme.ID()
uid = dme.ID(idx)
```

Input
idx (*integer*) – *(optional)* row index vector

Return an *nr* x 1 vector of unique IDs for all rows, i.e. a map of row index to unique ID or, if a row index vector is provided just the ID's of the indexed rows.

`init_status`(*dm*)

Initialize `status` column.

```
dme.init_status(dm)
```

Input
dm (*mp.data_model* (page 27)) – data model

Called by *initialize()* (page 40). Does nothing in the base class.

`update_status`(*dm*)

Update (online/offline) status based on connectivity, etc.

```
dme.update_status(dm)
```

Input
dm (*mp.data_model* (page 27)) – data model

Update status of each element based on connectivity or other criteria and define element properties containing number and row indices of online elements (`n` and `on`), indices of offline elements (`off`), and mapping (`i2on`) of row indices to corresponding entries in `on` or `off`.

Called for each element by the *update_status()* (page 29) method of *mp.data_model* (page 27) during the **update status** stage of a data model build.

See the sec_building_data_model section in the *MATPOWER Developer's Manual* for more information.

`build_params`(*dm*)

Extract/convert/calculate parameters for online elements.

```
dme.build_params(dm)
```

Input
dm (*mp.data_model* (page 27)) – data model

Extract/convert/calculate parameters as necessary for online elements from the original data tables (e.g. p.u. conversion, initial state, etc.) and store them in element-specific properties.

Called for each element by the *build_params()* (page 30) method of *mp.data_model* (page 27) during the **build parameters** stage of a data model build.

See the sec_building_data_model section in the *MATPOWER Developer's Manual* for more information.

Does nothing in the base class.

`rebuild`(*dm*)

Rebuild object, calling *count()* (page 40), *initialize()* (page 40), *build_params()* (page 41).

```
dme.rebuild(dm)
```

Input
dm (*mp.data_model* (page 27)) – data model

Typically used after modifying data in the main table.

`display`()

Display the data model element object.

This method is called automatically when omitting a semicolon on a line that retuns an object of this class.

Displays the details of the elements, including total number of rows, number of online elements, and the main data table.

`pretty_print`(*dm*, *section*, *out_e*, *mpopt*, *fd*, *pp_args*)

Pretty print data model element to console or file.

```
dme.pretty_print(dm, section, out_e, mpopt, fd, pp_args)
```

Inputs
- **dm** (*mp.data_model* (page 27)) – data model
- **section** (*char array*) – section identifier, e.g. `'cnt'`, `'sum'`, `'ext'`, or `'det'`, for **counts**, **summary**, **extremes**, or **details** sections, respectively
- **out_e** (*boolean*) – output control flag for this element/section
- **mpopt** (*struct*) – MATPOWER options struct
- **fd** (*integer*) – *(optional, default = 1)* file identifier to use for printing, (1 for standard output, 2 for standard error)
- **pp_args** (*struct*) – arbitrary struct of additional pretty printing arguments passed to all sub-methods, allowing a single sub-method to be used for multiple output portions (e.g. for active and reactive power) by passing in a different argument; by convention, arguments for a `branch` element, for example, are passed in `pp_args.branch`, etc.

`pp_have_section`(*section*, *mpopt*, *pp_args*)

True if pretty-printing for element has specified section.

```
TorF = dme.pp_have_section(section, mpopt, pp_args)
```

Inputs
see *pretty_print()* (page 42) for details
Output
TorF (*boolean*) – true if output includes specified section

Implementation handled by section-specific *pp_have_section* methods or *pp_have_section_other()* (page 58).

See also *pp_have_section_cnt()* (page 43), *pp_have_section_sum()* (page 44), *pp_have_section_ext()* (page 44), *pp_have_section_det()* (page 44).

pp_rows(*dm*, *section*, *out_e*, *mpopt*, *pp_args*)

Indices of rows to include in pretty-printed output.

```
rows = dme.pp_rows(dm, section, out_e, mpopt, pp_args)
```

Inputs
see *pretty_print()* (page 42) for details

Output
rows (*integer*) – index vector of rows to be included in output
- 0 = no rows
- -1 = all rows

Includes all rows by default.

pp_get_headers(*dm*, *section*, *out_e*, *mpopt*, *pp_args*)

Get pretty-printed headers for this element/section.

```
h = dme.pp_get_headers(dm, section, out_e, mpopt, pp_args)
```

Inputs
see *pretty_print()* (page 42) for details

Output
h (*cell array of char arrays*) – lines of pretty printed header output for this element/section

Empty by default for counts, summary and extremes sections, and handled by *pp_get_headers_det()* (page 45) for details section.

pp_get_footers(*dm*, *section*, *out_e*, *mpopt*, *pp_args*)

Get pretty-printed footers for this element/section.

```
f = dme.pp_get_footers(dm, section, out_e, mpopt, pp_args)
```

Inputs
see *pretty_print()* (page 42) for details

Output
f (*cell array of char arrays*) – lines of pretty printed footer output for this element/section

Empty by default for counts, summary and extremes sections, and handled by *pp_get_headers_det()* (page 45) for details section.

pp_data(*dm*, *section*, *rows*, *out_e*, *mpopt*, *fd*, *pp_args*)

Pretty-print the data for this element/section.

```
dme.pp_data(dm, section, rows, out_e, mpopt, fd, pp_args)
```

Inputs
- **rows** (*integer*) – indices of rows to include, from *pp_rows()* (page 43)
- **...** – see *pretty_print()* (page 42) for details of other inputs

Implementation handled by section-specific *pp_data* methods or *pp_data_other()* (page 58).

See also *pp_data_cnt()* (page 44), *pp_data_sum()* (page 44), *pp_data_ext()* (page 44), *pp_data_det()* (page 45).

pp_have_section_cnt(*mpopt*, *pp_args*)

True if pretty-printing for element has **counts** section.

```
TorF = dme.pp_have_section_cnt(mpopt, pp_args)
```

Default is **true**.

See also *pp_have_section()* (page 42).

pp_data_cnt(*dm*, *rows*, *out_e*, *mpopt*, *fd*, *pp_args*)

Pretty-print the **counts** data for this element.

```
dme.pp_data_cnt(dm, rows, out_e, mpopt, fd, pp_args)
```

See also *pp_data()* (page 43).

pp_have_section_sum(*mpopt*, *pp_args*)

True if pretty-printing for element has **summary** section.

```
TorF = dme.pp_have_section_sum(mpopt, pp_args)
```

Default is **false**.

See also *pp_have_section()* (page 42).

pp_data_sum(*dm*, *rows*, *out_e*, *mpopt*, *fd*, *pp_args*)

Pretty-print the **summary** data for this element.

```
dme.pp_data_sum(dm, rows, out_e, mpopt, fd, pp_args)
```

Does nothing by default.

See also *pp_data()* (page 43).

pp_have_section_ext(*mpopt*, *pp_args*)

True if pretty-printing for element has **extremes** section.

```
TorF = dme.pp_have_section_ext(mpopt, pp_args)
```

Default is **false**.

See also *pp_have_section()* (page 42).

pp_data_ext(*dm*, *rows*, *out_e*, *mpopt*, *fd*, *pp_args*)

Pretty-print the **extremes** data for this element.

```
dme.pp_data_ext(dm, rows, out_e, mpopt, fd, pp_args)
```

Does nothing by default.

See also *pp_data()* (page 43).

pp_have_section_det(*mpopt*, *pp_args*)

True if pretty-printing for element has **details** section.

```
TorF = dme.pp_have_section_det(mpopt, pp_args)
```

Default is **false**.

See also *pp_have_section()* (page 42).

pp_get_title_det(*mpopt*, *pp_args*)

Get title of **details** section for this element.

```
str = dme.pp_get_title_det(mpopt, pp_args)
```

Inputs
see *pretty_print()* (page 42) for details
Output
str (*char array*) – title of details section, e.g. `'Bus Data'`, `'Generator Data'`, etc.

Called by *pp_get_headers_det()* (page 45) to insert title into detail section header.

pp_get_headers_det(*dm*, *out_e*, *mpopt*, *pp_args*)

Get pretty-printed **details** headers for this element.

```
h = dme.pp_get_headers_det(dm, out_e, mpopt, pp_args)
```

See also *pp_get_headers()* (page 43).

pp_get_footers_det(*dm*, *out_e*, *mpopt*, *pp_args*)

Get pretty-printed **details** footers for this element.

```
f = dme.pp_get_footers_det(dm, out_e, mpopt, pp_args)
```

Empty by default.

See also *pp_get_footers()* (page 43).

pp_data_det(*dm*, *rows*, *out_e*, *mpopt*, *fd*, *pp_args*)

Pretty-print the **details** data for this element.

```
dme.pp_data_det(dm, rows, out_e, mpopt, fd, pp_args)
```

Calls *pp_data_row_det()* (page 45) for each row.

See also *pp_data()* (page 43), *pp_data_row_det()* (page 45).

pp_data_row_det(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

Get pretty-printed row of **details** data for this element.

```
str = dme.pp_data_row_det(dm, k, out_e, mpopt, fd, pp_args)
```

Inputs
- **k** (*integer*) – index of row to print
- **...** – see *pretty_print()* (page 42) for details of other inputs

Output
str (*char array*) – row of data *(without newline)*

Called by *pp_data_det()* (page 45) for each row.

mp.dme_branch

class mp.**dme_branch**

Bases: *mp.dm_element* (page 35)

mp.dme_branch (page 46) - Data model element for branch.

Implements the data element model for branch elements, including transmission lines and transformers.

Adds the following columns in the main data table, found in the `tab` property:

Name	Type	Description
bus_fr	*integer*	bus ID (`uid`) of "from" bus
bus_to	*integer*	bus ID (`uid`) of "to" bus
r	*double*	per unit series resistance
x	*double*	per unit series reactance
g_fr	*double*	per unit shunt conductance at "from" end
b_fr	*double*	per unit shunt susceptance at "from" end
g_to	*double*	per unit shunt conductance at "to" end
b_to	*double*	per unit shunt susceptance at "to" end
sm_ub_a	*double*	long term apparent power rating (MVA)
sm_ub_b	*double*	short term apparent power rating (MVA)
sm_ub_c	*double*	emergency apparent power rating (MVA)
cm_ub_a	*double*	long term current magnitude rating (MVA equivalent at 1 p.u. voltage)
cm_ub_b	*double*	short term current magnitude rating (MVA equivalent at 1 p.u. voltage)
cm_ub_c	*double*	emergency current magnitude rating (MVA equivalent at 1 p.u. voltage)
vad_lb	*double*	voltage angle difference lower bound
vad_ub	*double*	voltage angle difference upper bound
tm	*double*	transformer off-nominal turns ratio
ta	*double*	transformer phase-shift angle (degrees)
pl_fr	*double*	active power injection at "from" end
ql_fr	*double*	reactive power injection at "from" end
pl_to	*double*	active power injection at "to" end
ql_to	*double*	reactive power injection at "to" end

Property Summary

fbus

bus index vector for "from" port (port 1) (all branches)

tbus

bus index vector for "to" port (port 2) (all branches)

r

series resistance (p.u.) for branches that are on

x

series reactance (p.u.) for branches that are on

g_fr

shunt conductance (p.u.) at "from" end for branches that are on

g_to

shunt conductance (p.u.) at "to" end for branches that are on

b_fr
shunt susceptance (p.u.) at "from" end for branches that are on

b_to
shunt susceptance (p.u.) at "to" end for branches that are on

tm
transformer off-nominal turns ratio for branches that are on

ta
xformer phase-shift angle (radians) for branches that are on

rate_a
long term flow limit (p.u.) for branches that are on

Method Summary

name()

label()

labels()

cxn_type()

cxn_idx_prop()

main_table_var_names()

export_vars()

export_vars_offline_val()

initialize(*dm*)

update_status(*dm*)

build_params(*dm*)

pp_data_cnt(*dm*, *rows*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_have_section_sum(*mpopt*, *pp_args*)

pp_data_sum(*dm*, *rows*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_get_headers_det(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_have_section_det(*mpopt*, *pp_args*)

pp_data_row_det(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

mp.dme_branch_opf

class mp.**dme_branch_opf**

Bases: *mp.dme_branch* (page 46), *mp.dme_shared_opf* (page 58)

mp.dme_branch_opf (page 48) - Data model element for branch for OPF.

To parent class *mp.dme_branch* (page 46), adds shadow prices on flow and angle difference limits, and pretty-printing for **lim** sections.

Adds the following columns in the main data table, found in the `tab` property:

Name	Type	Description
mu_flow_fr_ub	*double*	shadow price on flow constraint at "from" end *(u/MVA)*[1]
mu_flow_to_ub	*double*	shadow price on flow constraint at "to" end *(u/MVA)*[1]
mu_vad_lb	*double*	shadow price on lower bound of voltage angle difference constraint *(u/degree)*[1]
mu_vad_ub	*double*	shadow price on upper bound of voltage angle difference constraint *(u/degree)*[1]

Method Summary

main_table_var_names()

export_vars()

export_vars_offline_val()

pretty_print(*dm*, *section*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_have_section_lim(*mpopt*, *pp_args*)

pp_binding_rows_lim(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_get_title_lim(*mpopt*, *pp_args*)

pp_get_headers_lim(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_data_row_lim(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

[1] Here *u* denotes the units of the objective function, e.g. USD.

mp.dme_bus

class mp.**dme_bus**

Bases: *mp.dm_element* (page 35)

mp.dme_bus (page 49) - Data model element for bus.

Implements the data element model for bus elements.

Adds the following columns in the main data table, found in the `tab` property:

Name	Type	Description
`base_kv`	*double*	base voltage *(kV)*
`type`	*integer*	bus type (1 = PQ, 2 = PV, 3 = ref, 4 = isolated)
`area`	*integer*	area number
`zone`	*integer*	loss zone
`vm_lb`	*double*	voltage magnitude lower bound *(p.u.)*
`vm_ub`	*double*	voltage magnitude upper bound *(p.u.)*
`va`	*double*	voltage angle *(degrees)*
`vm`	*double*	voltage magnitude *(p.u.)*

Property Summary

type

node *type* (page 49) vector for buses that are on

vm_start

initial voltage magnitudes (p.u.) for buses that are on

va_start

initial voltage angles (radians) for buses that are on

vm_lb

voltage magnitude lower bounds for buses that are on

vm_ub

voltage magnitude upper bounds for buses that are on

vm_control

true if voltage is controlled, for buses that are on

Method Summary

name()

label()

labels()

main_table_var_names()

export_vars()

export_vars_offline_val()

init_status(*dm*)

update_status(*dm*)

build_params(*dm*)

pp_data_cnt(*dm*, *rows*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_have_section_ext(*mpopt*, *pp_args*)

pp_data_ext(*dm*, *rows*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_have_section_det(*mpopt*, *pp_args*)

pp_get_headers_det(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_data_row_det(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

set_bus_type_ref(*dm*, *idx*)

set_bus_type_pv(*dm*, *idx*)

set_bus_type_pq(*dm*, *idx*)

mp.dme_bus_opf

class mp.**dme_bus_opf**

Bases: *mp.dme_bus* (page 49), *mp.dme_shared_opf* (page 58)

mp.dme_bus_opf (page 50) - Data model element for bus for OPF.

To parent class *mp.dme_bus* (page 49), adds shadow prices on power balance and voltage magnitude limits, and pretty-printing for **lim** sections.

Adds the following columns in the main data table, found in the `tab` property:

Name	Type	Description
lam_p	*double*	active power nodal price, i.e. shadow price on active power balance constraint *(u/MW)*[1]
lam_q	*double*	reactive power nodal price, i.e. shadow price on reactive power balance constraint *(u/MVAr)*[1]
mu_vm_ll	*double*	shadow price on voltage magnitude lower bound *(u/p.u.)*[1]
mu_vm_ul	*double*	shadow price on voltage magnitude upper bound *(u/p.u.)*[1]

Method Summary

main_table_var_names()

export_vars()

export_vars_offline_val()

[1] Here *u* denotes the units of the objective function, e.g. USD.

pp_data_ext(*dm*, *rows*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_get_headers_det(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_data_row_det(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_have_section_lim(*mpopt*, *pp_args*)

pp_binding_rows_lim(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_get_headers_lim(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_data_row_lim(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

mp.dme_gen

class mp.**dme_gen**

Bases: *mp.dm_element* (page 35)

mp.dme_gen (page 51) - Data model element for generator.

Implements the data element model for generator elements.

Adds the following columns in the main data table, found in the `tab` property:

Name	Type	Description
`bus`	*integer*	bus ID (`uid`)
`vm_setpoint`	*double*	voltage magnitude setpoint *(p.u.)*
`pg_lb`	*double*	active power output lower bound *(MW)*
`pg_ub`	*double*	active power output upper bound *(MW)*
`qg_lb`	*double*	reactive power output lower bound *(MVAr)*
`qg_ub`	*double*	reactive power output upper bound *(MVAr)*
`pg`	*double*	active power output *(MW)*
`qg`	*double*	reactive power output *(MVAr)*
`startup_cost_cold`	*double*	cold startup cost *(USD)*
`pc1`	*double*	lower active power output of PQ capability curve *(MW)*
`pc2`	*double*	upper active power output of PQ capability curve *(MW)*
`qc1_lb`	*double*	lower bound on reactive power output at `pc1` *(MVAr)*
`qc1_ub`	*double*	upper bound on reactive power output at `pc1` *(MVAr)*
`qc2_lb`	*double*	lower bound on reactive power output at `pc2` *(MVAr)*
`qc2_ub`	*double*	upper bound on reactive power output at `pc2` *(MVAr)*

Property Summary

bus

bus (page 51) index vector (all gens)

bus_on

vector of indices into online buses for gens that are on

pg_start

initial active power (p.u.) for gens that are on

qg_start
: initial reactive power (p.u.) for gens that are on

vm_setpoint
: generator voltage setpoint for gens that are on

pg_lb
: active power lower bound (p.u.) for gens that are on

pg_ub
: active power upper bound (p.u.) for gens that are on

qg_lb
: reactive power lower bound (p.u.) for gens that are on

qg_ub
: reactive power upper bound (p.u.) for gens that are on

Method Summary

name()

label()

labels()

cxn_type()

cxn_idx_prop()

main_table_var_names()

export_vars()

export_vars_offline_val()

have_cost()

initialize(*dm*)

update_status(*dm*)

apply_vm_setpoint(*dm*)

build_params(*dm*)

violated_q_lims(*dm*, *mpopt*)

isload(*idx*)

pp_have_section_sum(*mpopt*, *pp_args*)

pp_data_sum(*dm*, *rows*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_have_section_det(*mpopt*, *pp_args*)

pp_get_headers_det(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_get_footers_det(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_data_row_det(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

mp.dme_gen_opf

class mp.**dme_gen_opf**

Bases: *mp.dme_gen* (page 51), *mp.dme_shared_opf* (page 58)

mp.dme_gen_opf (page 53) - Data model element for generator for OPF.

To parent class *mp.dme_gen* (page 51), adds costs, shadow prices on active and reactive generation limits, and pretty-printing for **lim** sections.

Adds the following columns in the main data table, found in the `tab` property:

Name	Type	Description
`cost_pg`	*mp.cost_table*	active power cost *(u/MW)*[1]
`cost_qg`	*mp.cost_table*	reactive power cost *(u/MVAr)*[1]
`mu_pg_lb`	*double*	shadow price on active power output lower bound *(u/MW)*[1]
`mu_pg_ub`	*double*	shadow price on active power output upper bound *(u/MW)*[1]
`mu_qg_lb`	*double*	shadow price on reactive power output lower bound *(u/MVAr)*[1]
`mu_qg_ub`	*double*	shadow price on reactive power output upper bound *(u/MVAr)*[1]

The cost tables `cost_pg` and `cost_qg` are defined as tables with the following columns:

See also *mp.cost_table* (page 161).

Method Summary

main_table_var_names()

export_vars()

export_vars_offline_val()

have_cost()

build_cost_params(*dm*, *dc*)

max_pwl_gencost()

pretty_print(*dm*, *section*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_have_section_lim(*mpopt*, *pp_args*)

pp_binding_rows_lim(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_get_headers_lim(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_data_row_lim(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

[1] Here *u* denotes the units of the objective function, e.g. USD.

mp.dme_load

class mp.**dme_load**

Bases: *mp.dm_element* (page 35)

mp.dme_load (page 54) - Data model element for load.

Implements the data element model for load elements, using a ZIP load model.

Adds the following columns in the main data table, found in the `tab` property:

Name	Type	Description
`bus`	*integer*	bus ID (`uid`)
`pd`	*double*	p_p, active constant power demand *(MW)*
`qd`	*double*	q_p, reactive constant power demand *(MVAr)*
`pd_i`	*double*	p_i, active nominal[1] constant current demand *(MW)*
`qd_i`	*double*	q_i, reactive nominal[1] constant current demand *(MVAr)*
`pd_z`	*double*	p_z, active nominal[1] constant impedance demand *(MW)*
`qd_z`	*double*	q_z, reactive nominal[1] constant impedance demand *(MVAr)*
`p`	*double*	p, total active demand *(MW)*
`q`	*double*	q, total reactive demand *(MVAr)*

Implements a ZIP load model, where each load has three components, and total demand for the load *i* is given by

$$\begin{aligned} \mathrm{s} &= \mathrm{s}_p + \mathrm{s}_i|\mathrm{v}| + \mathrm{s}_z|\mathrm{v}|^2 \\ p + jq &= (p_p + jq_p) + (p_i + jq_i)|\mathrm{v}| + (p_z + jq_z)|\mathrm{v}|^2 \end{aligned} \tag{3.1}$$

Property Summary

bus

bus (page 54) index vector (all loads)

pd

active power demand (p.u.) for constant power loads that are on

qd

reactive power demand (p.u.) for constant power loads that are on

pd_i

active power demand (p.u.) for constant current loads that are on

qd_i

reactive power demand (p.u.) for constant current loads that are on

pd_z

active power demand (p.u.) for constant impedance loads that are on

qd_z

reactive power demand (p.u.) for constant impedance loads that are on

Method Summary

name()

[1] *Nominal* means for a voltage of 1 p.u.

label()

labels()

cxn_type()

cxn_idx_prop()

main_table_var_names()

count(*dm*)

update_status(*dm*)

build_params(*dm*)

pp_have_section_sum(*mpopt*, *pp_args*)

pp_data_sum(*dm*, *rows*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_have_section_det(*mpopt*, *pp_args*)

pp_get_headers_det(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_get_footers_det(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_data_row_det(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

mp.dme_load_cpf

class mp.**dme_load_cpf**

Bases: *mp.dme_load* (page 54)

mp.dme_load_cpf (page 55) - Data model element for load for CPF.

To parent class *mp.dme_load* (page 54), adds method for adjusting model parameters based on value of continuation parameter λ, and overrides export_vars to export these updated parameter values.

Method Summary

export_vars()

parameterized(*dm*, *dmb*, *dmt*, *lam*)

mp.dme_load_opf

class mp.**dme_load_opf**

Bases: *mp.dme_load* (page 54), *mp.dme_shared_opf* (page 58)

mp.dme_load_opf (page 55) - Data model element for load for OPF.

To parent class *mp.dme_load* (page 54), adds pretty-printing for **lim** sections.

mp.dme_shunt_cpf

class mp.**dme_shunt_cpf**

Bases: *mp.dme_shunt* (page 56)

mp.dme_shunt_cpf (page 56) - Data model element for shunt for CPF.

To parent class *mp.dme_shunt* (page 56), adds method for adjusting model parameters based on value of continuation parameter λ, and overrides *export_vars()* (page 56) to export these updated parameter values.

Method Summary

export_vars()

parameterized(*dm*, *dmb*, *dmt*, *lam*)

mp.dme_shunt

class mp.**dme_shunt**

Bases: *mp.dm_element* (page 35)

mp.dme_shunt (page 56) - Data model element for shunt.

Implements the data element model for shunt elements.

Adds the following columns in the main data table, found in the `tab` property:

Name	Type	Description
`bus`	*integer*	bus ID (`uid`)
`gs`	*double*	g_s, shunt conductance, specified as nominal[1] active power demand *(MW)*
`bs`	*double*	b_s, shunt susceptance, specified as nominal[1] reactive power injection *(MVAr)*
`p`	*double*	p, total active power absorbed *(MW)*
`q`	*double*	q, total reactive power absorbed *(MVAr)*

Property Summary

bus

bus (page 56) index vector (all shunts)

gs

shunt conductance (p.u. active power demanded at

[1] *Nominal* means for a voltage of 1 p.u.

bs

V = 1.0 p.u.) for shunts that are on

Method Summary

name()

label()

labels()

cxn_type()

cxn_idx_prop()

main_table_var_names()

count(*dm*)

update_status(*dm*)

build_params(*dm*)

pp_have_section_sum(*mpopt*, *pp_args*)

pp_data_sum(*dm*, *rows*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_have_section_det(*mpopt*, *pp_args*)

pp_get_headers_det(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_get_footers_det(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_data_row_det(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

mp.dme_shunt_opf

class mp.**dme_shunt_opf**

Bases: *mp.dme_shunt* (page 56), *mp.dme_shared_opf* (page 58)

mp.dme_shunt_opf (page 57) - Data model element for shunt for OPF.

To parent class *mp.dme_shunt* (page 56), adds pretty-printing for **lim** sections.

3.2.3 Element Mixins

mp.dme_shared_opf

class mp.**dme_shared_opf**

Bases: handle

mp.dme_shared_opf (page 58) - Mixin class for OPF **data model element** objects.

For all elements of *mp.data_model_opf* (page 34), adds shared functionality for pretty-printing of **lim** sections.

Property Summary

ctol

constraint violation tolerance

ptol

shadow price tolerance

Method Summary

pp_set_tols_lim(*mpopt*)

pp_have_section_other(*section*, *mpopt*, *pp_args*)

pp_rows_other(*dm*, *section*, *out_e*, *mpopt*, *pp_args*)

pp_get_headers_other(*dm*, *section*, *out_e*, *mpopt*, *pp_args*)

pp_get_footers_other(*dm*, *section*, *out_e*, *mpopt*, *pp_args*)

pp_data_other(*dm*, *section*, *rows*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_have_section_lim(*mpopt*, *pp_args*)

pp_rows_lim(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_binding_rows_lim(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_get_title_lim(*mpopt*, *pp_args*)

pp_get_headers_lim(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_get_footers_lim(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_data_lim(*dm*, *rows*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_data_row_lim(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

3.3 Data Model Converter Classes

3.3.1 Containers

mp.dm_converter

class mp.**dm_converter**

Bases: *mp.element_container* (page 165)

mp.dm_converter (page 59) - Abstract base class for MATPOWER **data model converter** objects.

A data model converter provides the ability to convert data between a data model and a specific data source or format, such as the PSS/E RAW format or version 2 of the MATPOWER case format. It is used, for example, during the import stage of the data model build process.

A data model converter object is primarily a container for data model converter element (*mp.dmc_element* (page 62)) objects. Concrete data model converter classes are specific to the type or format of the data source.

By convention, data model converter variables are named `dmc` and data model converter class names begin with `mp.dm_converter`.

mp.dm_converter Methods:

- *format_tag()* (page 59) - return char array identifier for data source/format
- *copy()* (page 59) - make duplicate of object
- *build()* (page 59) - create and add element objects
- *import()* (page 59) - import data from a data source into a data model
- *export()* (page 60) - export data from a data model to a data source
- *init_export()* (page 60) - initialize a data source for export
- *save()* (page 60) - save data source to a file
- *display()* (page 60) - display the data model converter object

See the sec_dm_converter section in the *MATPOWER Developer's Manual* for more information.

See also *mp.data_model* (page 27), *mp.task* (page 7).

Method Summary

format_tag()

Return a short char array identifier for data source/format.

```
tag = dmc.format_tag()
```

E.g. the subclass for the MATPOWER case format returns `'mpc2'`.

Note: This is an abstract method that must be implemented by a subclass.

copy()

Create a duplicate of the data model converter object, calling the `copy()` method on each element.

```
new_dmc = dmc.copy()
```

build()

Create and add data model converter element objects.

```
dmc.build()
```

Create the data model converter element objects by instantiating each class in the *element_classes* (page 165) property and adding the resulting object to the *elements* (page 165) property.

import(*dm*, *d*)

Import data from a data source into a data model.

```
dm = dmc.import(dm, d)
```

Inputs
- **dm** (*mp.data_model* (page 27)) – data model
- **d** – data source, type depends on the implementing subclass (e.g. MATPOWER case struct for *mp.dm_converter_mpc2* (page 61))

Output
dm (*mp.data_model* (page 27)) – updated data model

Calls the *import()* (page 59) method for each data model converter element and its corresponding data model element.

export(*dm*, *d*)

Export data from a data model to a data source.

```
d = dmc.export(dm, d)
```

Inputs
- **dm** (*mp.data_model* (page 27)) – data model
- **d** – data source, type depends on the implementing subclass (e.g. MATPOWER case struct for *mp.dm_converter_mpc2* (page 61))

Output
d – updated data source

Calls the *export()* (page 60) method for each data model converter element and its corresponding data model element.

init_export(*dm*)

Initialize a data source for export.

```
d = dmc.export(dm)
```

Input
dm (*mp.data_model* (page 27)) – data model

Output
d – new empty data source, type depends on the implementing subclass (e.g. MATPOWER case struct for *mp.dm_converter_mpc2* (page 61))

Creates a new data source of the appropriate type in preparation for calling *export()* (page 60).

save(*fname*, *d*)

Save data source to a file.

```
fname_out = dmc.save(fname, d)
```

Inputs
- **fname** (*char array*)
- **d** – data source, type depends on the implementing subclass (e.g. MATPOWER case struct for *mp.dm_converter_mpc2* (page 61))

Output
fname_out (*char array*) – final file name after saving, possibly modified from input (e.g. extension added)

Note: This is an abstract method that must be implemented by a subclass.

display()

Display the data model converter object.

This method is called automatically when omitting a semicolon on a line that retuns an object of this class.

Displays the details of the data model converter elements.

mp.dm_converter_mpc2

class mp.**dm_converter_mpc2**

Bases: *mp.dm_converter* (page 59)

mp.dm_converter_mpc2 (page 61) - MATPOWER **data model converter** for MATPOWER case v2.

This class implements importing/exporting of data models for version 2 of the classic MATPOWER case format. That is, the *data source* **d** for this class is expected to be a MATPOWER case struct.

mp.dm_converter_mpc2 Methods:

- *dm_converter_mpc2()* (page 61) - constructor
- *format_tag()* (page 61) - return char array identifier for data source/format (`'mpc2'`)
- *import()* (page 61) - import data from a MATPOWER case struct into a data model
- `export()` - export data from a data model to a MATPOWER case struct
- *save()* (page 61) - save MATPOWER case struct to a file

See also *mp.dm_converter* (page 59).

Constructor Summary

dm_converter_mpc2()

Specify the element classes for handling MATPOWER case format.

Method Summary

format_tag()

Return identifier tag `'mpc2'` for version 2 MATPOWER case format.

import(*dm*, *d*)

Import data from a version 2 MATPOWER case struct into a data model.

init_export(*dm*)

Initialize a MATPOWER case struct for export.

save(*fname*, *d*)

Save a MATPOWER case struct to a file.

mp.dm_converter_mpc2_legacy

class mp.**dm_converter_mpc2_legacy**

Bases: *mp.dm_converter_mpc2* (page 61)

mp.dm_converter_mpc2_legacy (page 62) - Legacy MATPOWER **data model converter** for MATPOWER case v2.

Adds to *mp.dm_converter_mpc2* (page 61) the ability to handle legacy user customization.

mp.dm_converter_mpc2_legacy Methods:

- *legacy_user_mod_inputs()* (page 62) - pre-process legacy inputs for use-defined customization
- *legacy_user_nln_constraints()* (page 62) - pre-process legacy inputs for user-defined nonlinear constraints

See also *mp.dm_converter* (page 59), *mp.dm_converter_mpc2* (page 61), *mp.task_opf_legacy* (page 25).

Method Summary

legacy_user_mod_inputs(*dm*, *mpopt*, *dc*)

Handle pre-processing of inputs related to legacy user-defined variables, costs, and constraints. This includes optional `mpc` fields `A`, `l`, `u`, `N`, `fparm`, `H1`, `Cw`, `z0`, `zl`, `zu` and `user_constraints`.

legacy_user_nln_constraints(*dm*, *mpopt*)

Handle pre-processing of inputs related to legacy user-defined non-linear constraints, specifically optional `mpc` fields `user_constraints.nle` and `user_constraints.nli`.

Called by *legacy_user_mod_inputs()* (page 62) method.

3.3.2 Elements

mp.dmc_element

class mp.**dmc_element**

Bases: `handle`

mp.dmc_element (page 62)- Abstract base class for **data model converter element** objects.

A data model converter element object implements the functionality needed to import and export a particular element type from and to a given data format. All data model converter element classes inherit from *mp.dmc_element* (page 62) and each element type typically implements its own subclass.

By convention, data model converter element variables are named `dmce` and data model converter element class names begin with `mp.dmce`.

Typically, much of the import/export functionality for a particular concrete subclass can be defined simply by implementing the *table_var_map()* (page 65) method.

mp.dmc_element Methods:

- *name()* (page 63) - get name of element type, e.g. `'bus'`, `'gen'`
- *data_model_element()* (page 63) - get corresponding data model element
- *data_field()* (page 63) - get name of field in data source corresponding to default data table

- *data_subs()* (page 64) - get subscript reference struct for accessing data source
- *data_exists()* (page 64) - check if default field exists in data source
- *get_import_spec()* (page 64) - get import specification
- *get_export_spec()* (page 64) - get export specification
- *get_import_size()* (page 65) - get dimensions of data to be imported
- *get_export_size()* (page 65) - get dimensions of data to be exported
- *table_var_map()* (page 65) - get variable map for import/export
- *import()* (page 65) - import data from data source into data model element
- *import_table_values()* (page 66) - import table values for given import specification
- *get_input_table_values()* (page 66) - get values to insert in data model element table
- *import_col()* (page 66) - extract and optionally modify values from data source column
- *export()* (page 67) - export data from data model element to data source
- *export_table_values()* (page 67) - export table values for given import specification
- *init_export_data()* (page 67) - initialize data source for export from data model element
- *default_export_data_table()* (page 68) - create default (empty) data table for data source
- *default_export_data_nrows()* (page 68) - get number of rows *default_export_data_table()* (page 68)
- *export_col()* (page 68) - export a variable (table column) to the data source

See the sec_dmc_element section in the *MATPOWER Developer's Manual* for more information.

See also *mp.dm_converter* (page 59).

Method Summary

name()

Get name of element type, e.g. `'bus'`, `'gen'`.

```
name = dmce.name()
```

Output

name (*char array*) – name of element type, must be a valid struct field name

Implementation provided by an element type specific subclass.

data_model_element(*dm*, *name*)

Get the corresponding data model element.

```
dme = dmce.data_model_element(dm)
dme = dmce.data_model_element(dm, name)
```

Inputs

- **dm** (*mp.data_model* (page 27)) – data model object
- **name** (*char array*) – *(optional)* name of element type *(default is name of this object)*

Output

dme (*mp.dm_element* (page 35)) – data model element object

`data_field()`

Get name of field in data source corresponding to default data table.

```
df = dmce.data_field()
```

Output
df (*char array*) – field name

`data_subs()`

Get subscript reference struct for accessing data source.

```
s = dmce.data_subs()
```

Output
s (*struct*) – same as the `s` input argument to the built-in `subsref()`, to access this element's data in data source, with fields:
- `type` – character vector or string containing `'()'`, `'{}'`, or `'.'` specifying the subscript type
- `subs` – cell array, character vector, or string containing the actual subscripts

The default implementation in this base class uses the return value of the *data_field()* (page 63) method to access a field of the data source struct. That is:

```
s = struct('type', '.', 'subs', dmce.data_field());
```

`data_exists(d)`

Check if default field exists in data source.

```
TorF = dmce.data_exists(d)
```

Input
d – data source, type depends on the implementing subclass (e.g. MATPOWER case struct for *mp.dm_converter_mpc2* (page 61))
Output
TorF (*boolean*) – true if field exists

Check if value returned by *data_field()* (page 63) exists as a field in `d`.

`get_import_spec(dme, d)`

Get import specification.

```
spec = dmce.get_import_spec(dme, d)
```

Inputs
- **dme** (*mp.dm_element* (page 35)) – data model element object
- **d** – data source, type depends on the implementing subclass (e.g. MATPOWER case struct for *mp.dm_converter_mpc2* (page 61))

Output
spec (*struct*) – import specification, with keys:
- `'subs'` - subscript reference struct for accessing data source, as returned by *data_subs()* (page 64)
- `'nr'`, `'nc'`, `'r'` - number of rows, number of columns, row index vector, as returned by *get_import_size()* (page 65)
- `'vmap'` - variable map, as returned by *table_var_map()* (page 65)

See also *get_export_spec()* (page 64).

get_export_spec(*dme*, *d*)

Get export specification.

```
spec = dmce.get_export_spec(dme, d)
```

Inputs
- **dme** (*mp.dm_element* (page 35)) – data model element object
- **d** – data source, type depends on the implementing subclass (e.g. MATPOWER case struct for *mp.dm_converter_mpc2* (page 61))

Output
spec (*struct*) – export specification, see *get_import_spec()* (page 64)

See also *get_import_spec()* (page 64).

get_import_size(*d*)

Get dimensions of data to be imported.

```
[nr, nc, r] = dmce.get_import_size(d)
```

Input
d – data source, type depends on the implementing subclass (e.g. MATPOWER case struct for *mp.dm_converter_mpc2* (page 61))

Outputs
- **nr** (*integer*) – number of rows of data
- **nc** (*integer*) – number of columns of data
- **r** (*integer*) – optional index vector *(empty by default)* of rows in data source field that correspond to data to be imported

get_export_size(*dme*)

Get dimensions of data to be exported.

```
[nr, nc, r] = dmce.get_export_size(dme)
```

Input
dme (*mp.dm_element* (page 35)) – data model element object

Outputs
- **nr** (*integer*) – number of rows of data
- **nc** (*integer*) – number of columns of data
- **r** (*integer*) – optional index vector *(empty by default)* of rows in main table of `dme` that correspond to data to be exported

table_var_map(*dme*, *d*)

Get variable map for import/export.

```
vmap = dmce.table_var_map(dme, d)
```

Inputs
- **dme** (*mp.dm_element* (page 35)) – data model element object
- **d** – data source, type depends on the implementing subclass (e.g. MATPOWER case struct for *mp.dm_converter_mpc2* (page 61))

Output
vmap (*struct*) – variable map, see `tab_var_map` in the *MATPOWER Developer's Manual* for details

This method initializes each entry to `{'col', []}` by default, so subclasses only need to assign `vmap.(vn){2}` for columns that map directly from a column of the data source.

import(*dme*, *d*, *var_names*, *ridx*)

Import data from data source into data model element.

```
dme = dmce.import(dme, d, var_names, ridx)
```

Inputs
- **dme** (*mp.dm_element* (page 35)) – data model element object
- **d** – data source, type depends on the implementing subclass (e.g. MATPOWER case struct for *mp.dm_converter_mpc2* (page 61))
- **var_names** (*cell array*) – *(optional)* list of names of variables (columns of main table) to import *(default is all variables)*
- **ridx** (*integer*) – *(optional)* vector of row indices of data to import *(default is all rows)*

Output

dme (*mp.dm_element* (page 35)) – updated data model element object

See also *export()* (page 67).

import_table_values(*dme*, *d*, *spec*, *var_names*, *ridx*)

Import table values for given import specification.

```
dme = dmce.import_table_values(dme, d, spec, var_names, ridx)
```

Inputs
- **dme** (*mp.dm_element* (page 35)) – data model element object
- **d** – data source, type depends on the implementing subclass (e.g. MATPOWER case struct for *mp.dm_converter_mpc2* (page 61))
- **spec** (*struct*) – import specification, see *get_import_spec()* (page 64)
- **var_names** (*cell array*) – *(optional)* list of names of variables (columns of main table) to import *(default is all variables)*
- **ridx** (*integer*) – *(optional)* vector of row indices of data to import *(default is all rows)*

Output

dme (*mp.dm_element* (page 35)) – updated data model element object

Called by *import()* (page 65).

get_input_table_values(*d*, *spec*, *var_names*, *ridx*)

Get values to insert in data model element table.

```
vals = dmce.get_input_table_values(d, spec, var_names, ridx)
```

Inputs
- **d** – data source, type depends on the implementing subclass (e.g. MATPOWER case struct for *mp.dm_converter_mpc2* (page 61))
- **spec** (*struct*) – import specification, see *get_import_spec()* (page 64)
- **var_names** (*cell array*) – *(optional)* list of names of variables (columns of main table) to import *(default is all variables)*
- **ridx** (*integer*) – *(optional)* vector of row indices of data to import *(default is all rows)*

Output

vals (*cell array*) – values to assign to table columns in data model element

Called by *import_table_values()* (page 66).

import_col(*d*, *spec*, *vn*, *c*, *sf*)

Extract and optionally modify values from data source column.

```
vals = dmce.import_col(d, spec, vn, c, sf)
```

Inputs
- **d** – data source, type depends on the implementing subclass (e.g. MATPOWER case struct for *mp.dm_converter_mpc2* (page 61))
- **spec** (*struct*) – import specification, see *get_import_spec()* (page 64)
- **vn** (*char array*) – variable name
- **c** (*integer*) – column index for data in data source
- **sf** (*double or function handle*) – *(optional)* scale factor, function is called as *sf(dmce, vn)*

Output
vals (*cell array*) – values to assign to table columns in data model element

Called by *get_input_table_values()* (page 66).

export(*dme*, *d*, *var_names*, *ridx*)

Export data from data model element to data source.

```
d = dmce.export(dme, d, var_names, ridx)
```

Inputs
- **dme** (*mp.dm_element* (page 35)) – data model element object
- **d** – data source, type depends on the implementing subclass (e.g. MATPOWER case struct for *mp.dm_converter_mpc2* (page 61))
- **var_names** (*cell array*) – *(optional)* list of names of variables (columns of main table) to export *(default is all variables)*
- **ridx** (*integer*) – *(optional)* vector of row indices of data to export *(default is all rows)*

Output
d – updated data source

See also *import()* (page 65).

export_table_values(*dme*, *d*, *spec*, *var_names*, *ridx*)

Export table values for given import specification.

```
d = dmce.export_table_values(dme, d, spec, var_names, ridx)
```

Inputs
- **dme** (*mp.dm_element* (page 35)) – data model element object
- **d** – data source, type depends on the implementing subclass (e.g. MATPOWER case struct for *mp.dm_converter_mpc2* (page 61))
- **spec** (*struct*) – export specification, see *get_export_spec()* (page 64)
- **var_names** (*cell array*) – *(optional)* list of names of variables (columns of main table) to export *(default is all variables)*
- **ridx** (*integer*) – *(optional)* vector of row indices of data to export *(default is all rows)*

Output
d – updated data source

Called by *export()* (page 67).

init_export_data(*dme*, *d*, *spec*)

Initialize data source for export from data model element.

```
d = dmce.init_export_data(dme, d, spec)
```

Inputs
- **dme** (*mp.dm_element* (page 35)) – data model element object
- **d** – data source, type depends on the implementing subclass (e.g. MATPOWER case struct for *mp.dm_converter_mpc2* (page 61))
- **spec** (*struct*) – export specification, see *get_export_spec()* (page 64)

Output
d – updated data source

Called by *export_table_values()* (page 67).

default_export_data_table(*spec*)

Create default (empty) data table for data source.

```
dt = dmce.default_export_data_table(spec)
```

Input
spec (*struct*) – export specification, see *get_export_spec()* (page 64)
Output
dt – data table for data source, type depends on implementing subclass

Called by *init_export_data()* (page 67).

default_export_data_nrows(*spec*)

Get number of rows for *default_export_data_table()* (page 68).

```
nr = default_export_data_nrows(spec)
```

Input
spec (*struct*) – export specification, see *get_export_spec()* (page 64)
Output
nr (*integer*) – number of rows

Called by *default_export_data_table()* (page 68).

export_col(*dme*, *d*, *spec*, *vn*, *ridx*, *c*, *sf*)

Export a variable (table column) to the data source.

```
d = dmce.export_col(dme, d, spec, vn, ridx, c, sf)
```

Inputs
- **dme** (*mp.dm_element* (page 35)) – data model element object
- **d** – data source, type depends on the implementing subclass (e.g. MATPOWER case struct for *mp.dm_converter_mpc2* (page 61))
- **spec** (*struct*) – export specification, see *get_export_spec()* (page 64)
- **vn** (*char array*) – variable name
- **ridx** (*integer*) – *(optional)* vector of row indices of data to export *(default is all rows)*
- **c** (*integer*) – column index for data in data source
- **sf** (*double or function handle*) – *(optional)* scale factor, function is called as *sf(dmce, vn)*

Output
d – updated data source

Called by *export_table_values()* (page 67).

mp.dmce_branch_mpc2

class mp.**dmce_branch_mpc2**

Bases: *mp.dmc_element* (page 62)

mp.dmce_branch_mpc2 (page 69) - Data model converter element for branch for MATPOWER case v2.

Method Summary

name()

data_field()

table_var_map(*dme*, *mpc*)

default_export_data_table(*spec*)

mp.dmce_bus_mpc2

class mp.**dmce_bus_mpc2**

Bases: *mp.dmc_element* (page 62)

mp.dmce_bus_mpc2 (page 69) - Data model converter element for bus for MATPOWER case v2.

Method Summary

name()

data_field()

table_var_map(*dme*, *mpc*)

init_export_data(*dme*, *d*, *spec*)

default_export_data_table(*spec*)

bus_name_import(*mpc*, *spec*, *vn*, *c*)

bus_name_export(*dme*, *mpc*, *spec*, *vn*, *ridx*, *c*)

bus_status_import(*mpc*, *spec*, *vn*, *c*)

mp.dmce_gen_mpc2

class mp.**dmce_gen_mpc2**

Bases: *mp.dmc_element* (page 62)

mp.dmce_gen_mpc2 (page 69) - Data model converter element for generator for MATPOWER case v2.

Property Summary

pwl1

indices of single-block piecewise linear costs, all gens *(automatically converted to linear cost)*

Method Summary

name()

data_field()

table_var_map(*dme*, *mpc*)

default_export_data_table(*spec*)

start_cost_import(*mpc*, *spec*, *vn*)

start_cost_export(*dme*, *mpc*, *spec*, *vn*, *ridx*)

gen_cost_import(*mpc*, *spec*, *vn*, *p_or_q*)

gen_cost_export(*dme*, *mpc*, *spec*, *vn*, *p_or_q*, *ridx*)

static gencost2cost_table(*gencost*)

static cost_table2gencost(*gencost0*, *cost*, *ridx*)

mp.dmce_load_mpc2

class mp.**dmce_load_mpc2**

Bases: *mp.dmc_element* (page 62)

mp.dmce_load_mpc2 (page 70) - Data model converter element for load for MATPOWER case v2.

Property Summary

bus

Method Summary

name()

data_field()

get_import_size(*mpc*)

get_export_size(*dme*)

table_var_map(*dme*, *mpc*)

scale_factor_fcn(*vn*, *zip_sf*)

sys_wide_zip_loads(*mpc*)

mp.dmce_shunt_mpc2

class mp.**dmce_shunt_mpc2**

Bases: *mp.dmc_element* (page 62)

mp.dmce_shunt_mpc2 (page 71) - Data model converter element for shunt for MATPOWER case v2.

Property Summary

bus

Method Summary

name()

data_field()

get_import_size(*mpc*)

get_export_size(*dme*)

table_var_map(*dme*, *mpc*)

3.4 Network Model Classes

3.4.1 Containers

mp.form

class mp.**form**

Bases: handle

mp.form (page 71) - Abstract base class for MATPOWER **formulation**.

Used as a mix-in class for all **network model element** classes. That is, each concrete network model element class must inherit, at least indirectly, from both *mp.nm_element* (page 107) and *mp.form* (page 71).

mp.form (page 71) provides properties and methods that are specific to the network model formulation (e.g. DC version, AC polar power version, etc.).

For more details, see the sec_net_model_formulations section in the *MATPOWER Developer's Manual* and the derivations in *MATPOWER Technical Note 5*.

mp.form Properties:
subclasses provide properties for model parameters

mp.form Methods:

- *form_name()* (page 72) - get char array w/name of formulation
- *form_tag()* (page 72) - get char array w/short label of formulation
- *model_params()* (page 72) - get cell array of names of model parameters
- *model_vvars()* (page 72) - get cell array of names of voltage state variables
- *model_zvars()* (page 72) - get cell array of names of non-voltage state variables

- *get_params()* (page 73) - get network model element parameters
- *find_form_class()* (page 73) - get name of network element object's formulation subclass

See also *mp.nm_element* (page 107).

Method Summary

`form_name()`

Get user-readable name of formulation, e.g. `'DC'`, `'AC-cartesian'`, `'AC-polar'`.

```
name  = nme.form_name()
```

Output
name (*char array*) – name of formulation

Note: This is an abstract method that must be implemented by a subclass.

`form_tag()`

Get short label of formulation, e.g. `'dc'`, `'acc'`, `'acp'`.

```
tag  = nme.form_tag()
```

Output
tag (*char array*) – short label of formulation

Note: This is an abstract method that must be implemented by a subclass.

`model_params()`

Get cell array of names of model parameters.

```
params  = nme.model_params()
```

Output
params (*cell array of char arrays*) – names of object properies for model parameters

Note: This is an abstract method that must be implemented by a subclass.

`model_vvars()`

Get cell array of names of voltage state variables.

```
vtypes = nme.model_vvars()
```

Output
vtypes (*cell array of char arrays*) – names of network object properties for voltage state variables

The network model object, which inherits from `mp_idx_manager`, uses these values as set types for tracking its voltage state variables.

Note: This is an abstract method that must be implemented by a subclass.

`model_zvars()`

Get cell array of names of non-voltage state variables.

```
vtypes = nme.model_zvars()
```

Output
vtypes (*cell array of char arrays*) – names of network object properties for voltage state variables

The network model object, which inherits from `mp_idx_manager`, uses these values as set types for tracking its non-voltage state variables.

Note: This is an abstract method that must be implemented by a subclass.

`get_params`(*idx*, *names*)

Get network model element parameters.

```
[p1, p2, ..., pN] = nme.get_params(idx)
pA = nme.get_params(idx, nameA)
[pA, pB, ...] = nme.get_params(idx, {nameA, nameB, ...})
```

Inputs
- **idx** (*integer*) – *(optional)* vector of indices of ports of interest, if empty or missing, returns parameters corresponding to all ports
- **names** (*char array or cell array of char arrays*) – *(optional)* name(s) of parameters to return

Outputs
- **p1, p2, ..., pN** – full set of parameters in canonical order
- **pA, pB** – parameters specified by `names`

If a particular parameter in the object is empty, this method returns a sparse zero matrix or vector of the appropriate size.

`find_form_class`()

Get name of network element object's formulation subclass.

```
form_class = nme.find_form_class()
```

Output
form_class (*char array*)

Selects from this netork model elements parent classes, the *mp.form* (page 71) subclass, that is not a subclass of *mp.nm_element* (page 107), with the longest inheritance path back to *mp.form* (page 71).

mp.form_ac

`class mp.form_ac`

Bases: *mp.form* (page 71)

mp.form_ac (page 73) - Abstract base class for MATPOWER AC **formulations**.

Used as a mix-in class for all **network model element** classes with an AC network model formulation. That is, each concrete network model element class with an AC formulation must inherit, at least indirectly, from both *mp.nm_element* (page 107) and *mp.form_ac* (page 73).

mp.form_ac (page 73) defines the complex port injections as functions of the state variables $\mathbf{x}$, that is, the complex voltages $\mathbf{v}$ and non-voltage states $\mathbf{z}$. They are defined in terms of 3 components, the linear current injection and linear power injection components,

$$\begin{aligned}\mathbf{i}^{lin}(\mathbf{x}) &= \begin{bmatrix} \underline{\mathbf{Y}} & \underline{\mathbf{L}} \end{bmatrix}\mathbf{x} + \underline{\mathbf{i}} \\ &= \underline{\mathbf{Y}}\mathbf{v} + \underline{\mathbf{L}}\mathbf{z} + \underline{\mathbf{i}}\end{aligned} \tag{3.2}$$

$$\begin{aligned}\mathbf{s}^{lin}(\mathbf{x}) &= \begin{bmatrix} \underline{\mathbf{M}} & \underline{\mathbf{N}} \end{bmatrix}\mathbf{x} + \underline{\mathbf{s}} \\ &= \underline{\mathbf{M}}\mathbf{v} + \underline{\mathbf{N}}\mathbf{z} + \underline{\mathbf{s}},\end{aligned} \tag{3.3}$$

and an arbitrary nonlinear injection component represented by $\mathbf{s}^{nln}(\mathbf{x})$ or $\mathbf{i}^{nln}(\mathbf{x})$. The full complex power and current port injection functions implemented by *mp.form_ac* (page 73), are respectively

$$\begin{aligned}\mathbf{g}^S(\mathbf{x}) &= \left[\diagup\mathbf{v}\diagdown\right]\left(\mathbf{i}^{lin}(\mathbf{x})\right)^* + \mathbf{s}^{lin}(\mathbf{x}) + \mathbf{s}^{nln}(\mathbf{x}) \\ &= \left[\diagup\mathbf{v}\diagdown\right]\left(\underline{\mathbf{Y}}\mathbf{v} + \underline{\mathbf{L}}\mathbf{z} + \underline{\mathbf{i}}\right)^* + \underline{\mathbf{M}}\mathbf{v} + \underline{\mathbf{N}}\mathbf{z} + \underline{\mathbf{s}} + \mathbf{s}^{nln}(\mathbf{x})\end{aligned} \tag{3.4}$$

$$\begin{aligned}\mathbf{g}^I(\mathbf{x}) &= \mathbf{i}^{lin}(\mathbf{x}) + \left[\diagup\mathbf{s}^{lin}(\mathbf{x})\diagdown\right]^*\boldsymbol{\Lambda}^* + \mathbf{i}^{nln}(\mathbf{x}) \\ &= \underline{\mathbf{Y}}\mathbf{v} + \underline{\mathbf{L}}\mathbf{z} + \underline{\mathbf{i}} + \left[\diagup\underline{\mathbf{M}}\mathbf{v} + \underline{\mathbf{N}}\mathbf{z} + \underline{\mathbf{s}}\diagdown\right]^*\boldsymbol{\Lambda}^* + \mathbf{i}^{nln}(\mathbf{x})\end{aligned} \tag{3.5}$$

where $\underline{\mathbf{Y}}$, $\underline{\mathbf{L}}$, $\underline{\mathbf{M}}$, $\underline{\mathbf{N}}$, $\underline{\mathbf{i}}$, and $\underline{\mathbf{s}}$, along with $\mathbf{s}^{nln}(\mathbf{x})$ or $\mathbf{i}^{nln}(\mathbf{x})$, are the model parameters.

For more details, see the sec_nm_formulations_ac section in the *MATPOWER Developer's Manual* and the derivations in *MATPOWER Technical Note 5*.

mp.form_dc Properties:

- *Y* (page 75) - $n_p n_k \times n_n$ matrix $\underline{\mathbf{Y}}$ of model parameters
- *L* (page 75) - $n_p n_k \times n_{\mathbf{z}}$ matrix $\underline{\mathbf{L}}$ of model parameters
- *M* (page 75) - $n_p n_k \times n_n$ matrix $\underline{\mathbf{M}}$ of model parameters
- *N* (page 75) - $n_p n_k \times n_{\mathbf{z}}$ matrix $\underline{\mathbf{N}}$ of model parameters
- *i* (page 75) - $n_p n_k \times 1$ vector $\underline{\mathbf{i}}$ of model parameters
- *s* (page 75) - $n_p n_k \times 1$ vector $\underline{\mathbf{s}}$ of model parameters
- `params_ncols` - specify number of columns for each parameter
- *inln* (page 75) - function to compute $\mathbf{i}^{nln}(\mathbf{x})$
- *snln* (page 75) - function to compute $\mathbf{s}^{nln}(\mathbf{x})$
- *inln_hess* (page 75) - function to compute Hessian of $\mathbf{i}^{nln}(\mathbf{x})$
- *snln_hess* (page 75) - function to compute Hessian of $\mathbf{s}^{nln}(\mathbf{x})$

mp.form_dc Methods:

- *model_params()* (page 76) - get network model element parameters (`{'Y', 'L', 'M', 'N', 'i', 's'}`)
- *model_zvars()* (page 76) - get cell array of names of non-voltage state variables (`{'zr', 'zi'}`)
- *port_inj_current()* (page 76) - compute port current injections from network state
- *port_inj_power()* (page 76) - compute port power injections from network state
- *port_inj_current_hess()* (page 77) - compute Hessian of port current injections
- *port_inj_power_hess()* (page 78) - compute Hessian of port power injections
- *port_inj_current_jac()* (page 78) - abstract method to compute voltage-related Jacobian terms
- *port_inj_current_hess_v()* (page 78) - abstract method to compute voltage-related Hessian terms
- *port_inj_current_hess_vz()* (page 78) - abstract method to compute voltage-related Hessian terms
- *port_inj_power_jac()* (page 78) - abstract method to compute voltage-related Jacobian terms
- *port_inj_power_hess_v()* (page 78) - abstract method to compute voltage-related Hessian terms
- *port_inj_power_hess_vz()* (page 79) - abstract method to compute voltage-related Hessian terms

- *port_apparent_power_lim_fcn()* (page 79) - compute port squared apparent power injection constraints
- *port_active_power_lim_fcn()* (page 79) - compute port active power injection constraints
- *port_active_power2_lim_fcn()* (page 79) - compute port squared active power injection constraints
- *port_current_lim_fcn()* (page 80) - compute port squared current injection constraints
- *port_apparent_power_lim_hess()* (page 80) - compute port squared apparent power injection Hessian
- *port_active_power_lim_hess()* (page 81) - compute port active power injection Hessian
- *port_active_power2_lim_hess()* (page 81) - compute port squared active power injection Hessian
- *port_current_lim_hess()* (page 81) - compute port squared current injection Hessian
- *aux_data_va_vm()* (page 82) - abstract method to return voltage angles/magnitudes from auxiliary data

See also *mp.form* (page 71), *mp.form_acc* (page 82), *mp.form_acp* (page 86), *mp.form_dc* (page 88), *mp.nm_element* (page 107).

Property Summary

Y = []

(double) $n_p n_k \times n_n$ matrix $\underline{\mathbf{Y}}$ of model parameter coefficients for $\mathbf{v}$

L = []

(double) $n_p n_k \times n_{\mathbf{z}}$ matrix $\underline{\mathbf{L}}$ of model parameter coefficients for $\mathbf{z}$

M = []

(double) $n_p n_k \times n_n$ matrix $\underline{\mathbf{M}}$ of model parameter coefficients for $\mathbf{v}$

N = []

(double) $n_p n_k \times n_{\mathbf{z}}$ matrix $\underline{\mathbf{N}}$ of model parameter coefficients for $\mathbf{z}$

i = []

(double) $n_p n_k \times 1$ vector $\underline{\mathbf{i}}$ of model parameters

s = []

(double) $n_p n_k \times 1$ vector $\underline{\mathbf{s}}$ of model parameters

param_ncols = struct('Y',2,'L',3,'M',2,'N',3,'i',1,'s',1)

(struct) specify number of columns for each parameter, where

- 1 => single column (i.e. a vector)
- 2 => n_p columns
- 3 => $n_{\mathbf{z}}$ columns

inln = ''

(function handle) function to compute $\mathbf{i}^{nln}(\mathbf{x})$

snln = ''

(function handle) function to compute $\mathbf{s}^{nln}(\mathbf{x})$

inln_hess = ''

(function handle) function to compute Hessian of $\mathbf{i}^{nln}(\mathbf{x})$

snln_hess = ''

(function handle) function to compute Hessian of $\mathbf{s}^{nln}(\mathbf{x})$

Method Summary

model_params()

Get cell array of names of model parameters, i.e. `{'Y', 'L', 'M', 'N', 'i', 's'}`.

See *mp.form.model_params()* (page 72).

model_zvars()

Get cell array of names of non-voltage state variables, i.e. `{'zr', 'zi'}`.

See *mp.form.model_zvars()* (page 72).

port_inj_current(*x_*, *sysx*, *idx*)

Compute port complex current injections from network state.

```
I = nme.port_inj_current(x_, sysx)
I = nme.port_inj_current(x_, sysx, idx)
[I, Iv1, Iv2] = nme.port_inj_current(...)
[I, Iv1, Iv2, Izr, Izi] = nme.port_inj_current(...)
```

Compute the complex current injections for all or a selected subset of ports and, optionally, the components of the Jacobian, that is, the sparse matrices of partial derivatives with respect to each real component of the state. The voltage portion, which depends on the formulation (polar vs cartesian), is delegated to the `port_inj_current_jac()` method implemented by the appropriate subclass.

The state can be provided as a stacked aggregate of the state variables (port voltages and non-voltage states) for the full collection of network model elements of this type, or as the combined state for the entire network.

Inputs

- **x_** (*complex double*) – state vector $\mathbf{x}$
- **sysx** (*0 or 1*) – which state is provided in **x_**
  - 0 – class aggregate state
  - 1 – *(default)* full system state
- **idx** (*integer*) – *(optional)* vector of indices of ports of interest, if empty or missing, returns results corresponding to all ports

Outputs

- **I** (*complex double*) – vector of port complex current injections, $\mathbf{g}^I(\mathbf{x})$
- **Iv1** (*complex double*) – Jacobian of port complex current injections w.r.t 1st voltage component, $\mathbf{g}^I_{\boldsymbol{\theta}}$ (polar) or $\mathbf{g}^I_{\boldsymbol{u}}$ (cartesian)
- **Iv2** (*complex double*) – Jacobian of port complex current injections w.r.t 2nd voltage component, $\mathbf{g}^I_{\boldsymbol{\nu}}$ (polar) or $\mathbf{g}^I_{\boldsymbol{w}}$ (cartesian)
- **Izr** (*complex double*) – Jacobian of port complex current injections w.r.t real part of non-voltage state, $\mathbf{g}^I_{\boldsymbol{z}_r}$
- **Izi** (*complex double*) – Jacobian of port complex current injections w.r.t imaginary part of non-voltage state, $\mathbf{g}^I_{\boldsymbol{z}_i}$

For details on the derivations of the formulas used, see *MATPOWER Technical Note 5*.

See also *port_inj_power()* (page 76).

port_inj_power(*x_*, *sysx*, *idx*)

Compute port complex power injections from network state.

```
S = nme.port_inj_power(x_, sysx)
S = nme.port_inj_power(x_, sysx, idx)
```

(continues on next page)

(continued from previous page)

```
[S, Sv1, Sv2] = nme.port_inj_power(...)
[S, Sv1, Sv2, Szr, Szi] = nme.port_inj_power(...)
```

Compute the complex power injections for all or a selected subset of ports and, optionally, the components of the Jacobian, that is, the sparse matrices of partial derivatives with respect to each real component of the state. The voltage portion, which depends on the formulation (polar vs cartesian), is delegated to the `port_inj_power_jac()` method implemented by the appropriate subclass.

The state can be provided as a stacked aggregate of the state variables (port voltages and non-voltage states) for the full collection of network model elements of this type, or as the combined state for the entire network.

Inputs

- **x_** (*complex double*) – state vector $\mathbf{x}$
- **sysx** (*0 or 1*) – which state is provided in **x_**
  - 0 – class aggregate state
  - 1 – *(default)* full system state
- **idx** (*integer*) – *(optional)* vector of indices of ports of interest, if empty or missing, returns results corresponding to all ports

Outputs

- **S** (*complex double*) – vector of port complex power injections, $\mathbf{g}^S(\mathbf{x})$
- **Sv1** (*complex double*) – Jacobian of port complex power injections w.r.t 1st voltage component, $\mathbf{g}^S_{\boldsymbol{\theta}}$ (polar) or $\mathbf{g}^S_{\boldsymbol{u}}$ (cartesian)
- **Sv2** (*complex double*) – Jacobian of port complex power injections w.r.t 2nd voltage component, $\mathbf{g}^S_{\boldsymbol{v}}$ (polar) or $\mathbf{g}^S_{\boldsymbol{w}}$ (cartesian)
- **Szr** (*complex double*) – Jacobian of port complex power injections w.r.t real part of non-voltage state, $\mathbf{g}^S_{\boldsymbol{z}_r}$
- **Szi** (*complex double*) – Jacobian of port complex power injections w.r.t imaginary part of non-voltage state, $\mathbf{g}^S_{\boldsymbol{z}_i}$.

For details on the derivations of the formulas used, see *MATPOWER Technical Note 5*.

See also *port_inj_current()* (page 76).

port_inj_current_hess(*x_*, *lam*, *sysx*, *idx*)

Compute Hessian of port current injections from network state.

```
H = nme.port_inj_current_hess(x_, lam)
H = nme.port_inj_current_hess(x_, lam, sysx)
H = nme.port_inj_current_hess(x_, lam, sysx, idx)
```

Compute a sparse Hessian matrix for all or a selected subset of ports. Rather than a full, 3-dimensional Hessian, it computes the Jacobian of the vector obtained by muliplying the transpose of the port current injection Jacobian by a vector $\boldsymbol{\lambda}$.

Inputs

- **x_** (*complex double*) – state vector $\mathbf{x}$
- **lam** (*double*) – vector $\boldsymbol{\lambda}$ of multipliers, one for each port
- **sysx** (*0 or 1*) – which state is provided in **x_**
  - 0 – class aggregate state
  - 1 – *(default)* full system state
- **idx** (*integer*) – *(optional)* vector of indices of ports of interest, if empty or missing, returns results corresponding to all ports

Outputs

H (*complex double*) – sparse Hessian matrix of port complex current injections corresponding to specified $\boldsymbol{\lambda}$, namely $\mathbf{g}^I_{\mathbf{xx}}(\boldsymbol{\lambda})$

For details on the derivations of the formulas used, see *MATPOWER Technical Note 5*.

See also port_inj_current() (page 76).

port_inj_power_hess(*x_*, *lam*, *sysx*, *idx*)

Compute Hessian of port power injections from network state.

```
H = nme.port_inj_power_hess(x_, lam)
H = nme.port_inj_power_hess(x_, lam, sysx)
H = nme.port_inj_power_hess(x_, lam, sysx, idx)
```

Compute a sparse Hessian matrix for all or a selected subset of ports. Rather than a full, 3-dimensional Hessian, it computes the Jacobian of the vector obtained by muliplying the transpose of the port power injection Jacobian by a vector $\boldsymbol{\lambda}$.

Inputs

- **x_** (*complex double*) – state vector $\mathbf{x}$
- **lam** (*double*) – vector $\boldsymbol{\lambda}$ of multipliers, one for each port
- **sysx** (*0 or 1*) – which state is provided in **x_**
  - 0 – class aggregate state
  - 1 – *(default)* full system state
- **idx** (*integer*) – *(optional)* vector of indices of ports of interest, if empty or missing, returns results corresponding to all ports

Outputs

H (*complex double*) – sparse Hessian matrix of port complex power injections corresponding to specified $\boldsymbol{\lambda}$, namely $\mathbf{g}_{\mathbf{xx}}^{S}(\boldsymbol{\lambda})$

For details on the derivations of the formulas used, see *MATPOWER Technical Note 5*.

See also port_inj_power() (page 76).

port_inj_current_jac(*n*, *v_*, *Y*, *M*, *invdiagvic*, *diagSlincJ*)

Abstract method to compute voltage-related Jacobian terms.

Called by port_inj_current() (page 76) to compute voltage-related Jacobian terms. See mp.form_acc.port_inj_current_jac() (page 83) and mp.form_acp.port_inj_current_jac() (page 87) for details.

port_inj_current_hess_v(*x_*, *lam*, *v_*, *z_*, *diaginvic*, *Y*, *M*, *diagSlincJ*, *dlamJ*)

Abstract method to compute voltage-related Hessian terms.

Called by port_inj_current_hess() (page 77) to compute voltage-related Hessian terms. See mp.form_acc.port_inj_current_hess_v() (page 83) and mp.form_acp.port_inj_current_hess_v() (page 87) for details.

port_inj_current_hess_vz(*x_*, *lam*, *v_*, *z_*, *diaginvic*, *N*, *dlamJ*)

Abstract method to compute voltage-related Hessian terms.

Called by port_inj_current_hess() (page 77) to compute voltage/non-voltage-related Hessian terms. See mp.form_acc.port_inj_current_hess_vz() (page 83) and mp.form_acp.port_inj_current_hess_vz() (page 87) for details.

port_inj_power_jac(*n*, *v_*, *Y*, *M*, *diagv*, *diagvi*, *diagIlincJ*)

Abstract method to compute voltage-related Jacobian terms.

Called by port_inj_power() (page 76) to compute voltage-related Jacobian terms. See mp.form_acc.port_inj_power_jac() (page 84) and mp.form_acp.port_inj_power_jac() (page 87) for details.

port_inj_power_hess_v(*x_*, *lam*, *v_*, *z_*, *diagvi*, *Y*, *M*, *diagIlincJ*, *dlamJ*)

Abstract method to compute voltage-related Hessian terms.

Called by *port_inj_power_hess()* (page 78) to compute voltage-related Hessian terms. See *mp.form_acc.port_inj_power_hess_v()* (page 84) and *mp.form_acp.port_inj_power_hess_v()* (page 87) for details.

port_inj_power_hess_vz(*x_*, *lam*, *v_*, *z_*, *diagvi*, *L*, *dlamJ*)

Abstract method to compute voltage-related Hessian terms.

Called by *port_inj_power_hess()* (page 78) to compute voltage/non-voltage-related Hessian terms. See *mp.form_acc.port_inj_power_hess_vz()* (page 84) and *mp.form_acp.port_inj_power_hess_vz()* (page 88) for details.

port_apparent_power_lim_fcn(*x_*, *nm*, *idx*, *hmax*)

Compute port squared apparent power injection constraints.

```
h = nme.port_apparent_power_lim_fcn(x_, nm, idx, hmax)
[h, dh] = nme.port_apparent_power_lim_fcn(x_, nm, idx, hmax)
```

Compute constraint function and optionally the Jacobian for the limit on port squared apparent power injections based on complex outputs of *port_inj_power()* (page 76).

Inputs

- **x_** (*complex double*) – state vector $\mathbf{x}$
- **nm** (*mp.net_model* (page 90)) – network model object
- **idx** (*integer*) – *(optional)* vector of indices of ports of interest, if empty or missing, returns results corresponding to all ports
- **hmax** (*double*) – vector of squared apparent power limits

Outputs

- **h** (*double*) – constraint function, $\boldsymbol{h}^{\text{flow}}(\boldsymbol{x})$
- **dh** (*double*) – constraint Jacobian, $\boldsymbol{h}_{\boldsymbol{x}}^{\text{flow}}$

For details on the derivations of the formulas used, see *MATPOWER Technical Note 5*.

See also *port_inj_power()* (page 76).

port_active_power_lim_fcn(*x_*, *nm*, *idx*, *hmax*)

Compute port active power injection constraints.

```
h = nme.port_active_power_lim_fcn(x_, nm, idx, hmax)
[h, dh] = nme.port_active_power_lim_fcn(x_, nm, idx, hmax)
```

Compute constraint function and optionally the Jacobian for the limit on port active power injections based on complex outputs of *port_inj_power()* (page 76).

Inputs

- **x_** (*complex double*) – state vector $\mathbf{x}$
- **nm** (*mp.net_model* (page 90)) – network model object
- **idx** (*integer*) – *(optional)* vector of indices of ports of interest, if empty or missing, returns results corresponding to all ports
- **hmax** (*double*) – vector of active power limits

Outputs

- **h** (*double*) – constraint function, $\boldsymbol{h}^{\text{flow}}(\boldsymbol{x})$
- **dh** (*double*) – constraint Jacobian, $\boldsymbol{h}_{\boldsymbol{x}}^{\text{flow}}$

For details on the derivations of the formulas used, see *MATPOWER Technical Note 5*.

See also *port_inj_power()* (page 76).

port_active_power2_lim_fcn(*x_*, *nm*, *idx*, *hmax*)

Compute port squared active power injection constraints.

```
h = nme.port_active_power2_lim_fcn(x_, nm, idx, hmax)
[h, dh] = nme.port_active_power2_lim_fcn(x_, nm, idx, hmax)
```

Compute constraint function and optionally the Jacobian for the limit on port squared active power injections based on complex outputs of *port_inj_power()* (page 76).

Inputs

- **x_** (*complex double*) – state vector $\mathbf{x}$
- **nm** (*mp.net_model* (page 90)) – network model object
- **idx** (*integer*) – *(optional)* vector of indices of ports of interest, if empty or missing, returns results corresponding to all ports
- **hmax** (*double*) – vector of squared active power limits

Outputs

- **h** (*double*) – constraint function, $\boldsymbol{h}^{\text{flow}}(\boldsymbol{x})$
- **dh** (*double*) – constraint Jacobian, $\boldsymbol{h}_{\boldsymbol{x}}^{\text{flow}}$

For details on the derivations of the formulas used, see *MATPOWER Technical Note 5*.

See also *port_inj_power()* (page 76).

port_current_lim_fcn(*x_*, *nm*, *idx*, *hmax*)

Compute port squared current injection constraints.

```
h = nme.port_current_lim_fcn(x_, nm, idx, hmax)
[h, dh] = nme.port_current_lim_fcn(x_, nm, idx, hmax)
```

Compute constraint function and optionally the Jacobian for the limit on port squared current injections based on complex outputs of *port_inj_current()* (page 76).

Inputs

- **x_** (*complex double*) – state vector $\mathbf{x}$
- **nm** (*mp.net_model* (page 90)) – network model object
- **idx** (*integer*) – *(optional)* vector of indices of ports of interest, if empty or missing, returns results corresponding to all ports
- **hmax** (*double*) – vector of squared current limits

Outputs

- **h** (*double*) – constraint function, $\boldsymbol{h}^{\text{flow}}(\boldsymbol{x})$
- **dh** (*double*) – constraint Jacobian, $\boldsymbol{h}_{\boldsymbol{x}}^{\text{flow}}$

For details on the derivations of the formulas used, see *MATPOWER Technical Note 5*.

See also *port_inj_current()* (page 76).

port_apparent_power_lim_hess(*x_*, *lam*, *nm*, *idx*)

Compute port squared apparent power injection Hessian.

```
d2H = nme.port_apparent_power_lim_hess(x_, lam, nm, idx)
```

Compute a sparse Hessian matrix for all or a selected subset of ports. Rather than a full, 3-dimensional Hessian, it computes the Jacobian of the vector obtained by muliplying the transpose of the constraint Jacobian by a vector $\boldsymbol{\mu}$. Results are based on the complex outputs of *port_inj_power()* (page 76) and *port_inj_power_hess()* (page 78).

Inputs

- **x_** (*complex double*) – state vector $\mathbf{x}$
- **lam** (*double*) – vector $\boldsymbol{\mu}$ of multipliers, one for each port
- **nm** (*mp.net_model* (page 90)) – network model object
- **idx** (*integer*) – *(optional)* vector of indices of ports of interest, if empty or missing, returns results corresponding to all ports

Output

d2H (*double*) – sparse constraint Hessian matrix, $\boldsymbol{h}_{\boldsymbol{xx}}^{\text{flow}}(\boldsymbol{\mu})$

For details on the derivations of the formulas used, see *MATPOWER Technical Note 5*.

See also `port_inj_power()` (page 76), `port_inj_power_hess()` (page 78).

port_active_power_lim_hess(*x_*, *lam*, *nm*, *idx*)

Compute port active power injection Hessian.

```
d2H = nme.port_active_power_lim_hess(x_, lam, nm, idx)
```

Compute a sparse Hessian matrix for all or a selected subset of ports. Rather than a full, 3-dimensional Hessian, it computes the Jacobian of the vector obtained by muliplying the transpose of the constraint Jacobian by a vector $\boldsymbol{\mu}$. Results are based on the complex outputs of `port_inj_power()` (page 76) and `port_inj_power_hess()` (page 78).

Inputs

- **x_** (*complex double*) – state vector $\mathbf{x}$
- **lam** (*double*) – vector $\boldsymbol{\mu}$ of multipliers, one for each port
- **nm** (`mp.net_model` (page 90)) – network model object
- **idx** (*integer*) – *(optional)* vector of indices of ports of interest, if empty or missing, returns results corresponding to all ports

Output

d2H (*double*) – sparse constraint Hessian matrix, $\boldsymbol{h}_{\boldsymbol{xx}}^{\text{flow}}(\boldsymbol{\mu})$

For details on the derivations of the formulas used, see *MATPOWER Technical Note 5*.

See also `port_inj_power()` (page 76), `port_inj_power_hess()` (page 78).

port_active_power2_lim_hess(*x_*, *lam*, *nm*, *idx*)

Compute port squared active power injection Hessian.

```
d2H = nme.port_active_power2_lim_hess(x_, lam, nm, idx)
```

Compute a sparse Hessian matrix for all or a selected subset of ports. Rather than a full, 3-dimensional Hessian, it computes the Jacobian of the vector obtained by muliplying the transpose of the constraint Jacobian by a vector $\boldsymbol{\mu}$. Results are based on the complex outputs of `port_inj_power()` (page 76) and `port_inj_power_hess()` (page 78).

Inputs

- **x_** (*complex double*) – state vector $\mathbf{x}$
- **lam** (*double*) – vector $\boldsymbol{\mu}$ of multipliers, one for each port
- **nm** (`mp.net_model` (page 90)) – network model object
- **idx** (*integer*) – *(optional)* vector of indices of ports of interest, if empty or missing, returns results corresponding to all ports

Output

d2H (*double*) – sparse constraint Hessian matrix, $\boldsymbol{h}_{\boldsymbol{xx}}^{\text{flow}}(\boldsymbol{\mu})$

For details on the derivations of the formulas used, see *MATPOWER Technical Note 5*.

See also `port_inj_power()` (page 76), `port_inj_power_hess()` (page 78).

port_current_lim_hess(*x_*, *lam*, *nm*, *idx*)

Compute port squared current injection Hessian.

```
d2H = nme.port_current_lim_hess(x_, lam, nm, idx)
```

Compute a sparse Hessian matrix for all or a selected subset of ports. Rather than a full, 3-dimensional Hessian, it computes the Jacobian of the vector obtained by muliplying the transpose of the constraint Jacobian by a vector $\boldsymbol{\mu}$. Results are based on the complex outputs of `port_inj_current()` (page 76) and `port_inj_current_hess()` (page 77).

Inputs
- **x_** (*complex double*) – state vector $\mathbf{x}$
- **lam** (*double*) – vector $\boldsymbol{\mu}$ of multipliers, one for each port
- **nm** (*mp.net_model* (page 90)) – network model object
- **idx** (*integer*) – *(optional)* vector of indices of ports of interest, if empty or missing, returns results corresponding to all ports

Output

d2H (*double*) – sparse constraint Hessian matrix, $\boldsymbol{h}_{\boldsymbol{xx}}^{\text{flow}}(\boldsymbol{\mu})$

For details on the derivations of the formulas used, see *MATPOWER Technical Note 5*.

See also *port_inj_current()* (page 76), *port_inj_current_hess()* (page 77).

aux_data_va_vm(*ad*)

Abstract method to return voltage angles/magnitudes from auxiliary data.

```
[va, vm] = nme.aux_data_va_vm(ad)
```

Input

ad (*struct*) – struct of auxiliary data

Outputs
- **va** (*double*) – vector of voltage angles corresponding to voltage information stored in auxiliary data
- **vm** (*double*) – vector of voltage magnitudes corresponding to voltage information stored in auxiliary data

Implemented by *mp.form_acc.aux_data_va_vm()* (page 84) and *mp.form_acp.aux_data_va_vm()* (page 88).

mp.form_acc

class mp.**form_acc**

Bases: *mp.form_ac* (page 73)

mp.form_acc (page 82) - Base class for MATPOWER AC cartesian **formulations**.

Used as a mix-in class for all **network model element** classes with an AC network model formulation with a **cartesian** repesentation for voltages. That is, each concrete network model element class with an AC cartesian formulation must inherit, at least indirectly, from both *mp.nm_element* (page 107) and *mp.form_acc* (page 82).

Provides implementation of evaluation of voltage-related Jacobian and Hessian terms needed by some *mp.form_ac* (page 73) methods.

mp.form_dc Methods:

- *form_name()* (page 83) - get char array w/name of formulation (`'AC-cartesian'`)
- *form_tag()* (page 83) - get char array w/short label of formulation (`'acc'`)
- *model_vvars()* (page 83) - get cell array of names of voltage state variables (`{'vr', 'vi'}`)
- *port_inj_current_jac()* (page 83) - compute voltage-related terms of current injection Jacobian
- *port_inj_current_hess_v()* (page 83) - compute voltage-related terms of current injection Hessian
- *port_inj_current_hess_vz()* (page 83) - compute voltage/non-voltage-related terms of current injection Hessian

- *port_inj_power_jac()* (page 84) - compute voltage-related terms of power injection Jacobian
- *port_inj_power_hess_v()* (page 84) - compute voltage-related terms of power injection Hessian
- *port_inj_power_hess_vz()* (page 84) - compute voltage/non-voltage-related terms of power injection Hessian
- *aux_data_va_vm()* (page 84) - return voltage angles/magnitudes from auxiliary data
- *va_fcn()* (page 84) - compute voltage angle constraints and Jacobian
- *va_hess()* (page 85) - compute voltage angle Hessian
- *vm2_fcn()* (page 85) - compute squared voltage magnitude constraints and Jacobian
- *vm2_hess()* (page 85) - compute squared voltage magnitude Hessian

For more details, see the sec_nm_formulations_ac section in the *MATPOWER Developer's Manual* and the derivations in *MATPOWER Technical Note 5*.

See also *mp.form* (page 71), *mp.form_ac* (page 73), *mp.form_acp* (page 86), *mp.nm_element* (page 107).

Method Summary

form_name()

Get user-readable name of formulation, i.e. `'AC-cartesian'`.

See *mp.form.form_name()* (page 72).

form_tag()

Get short label of formulation, i.e. `'acc'`.

See *mp.form.form_tag()* (page 72).

model_vvars()

Get cell array of names of voltage state variables, i.e. `{'vr', 'vi'}`.

See *mp.form.model_vvars()* (page 72).

port_inj_current_jac(*n*, *v_*, *Y*, *M*, *invdiagvic*, *diagSlincJ*)

Compute voltage-related terms of current injection Jacobian.

```
[Iu, Iw] = nme.port_inj_current_jac(n, v_, Y, M, invdiagvic, diagSlincJ)
```

Called by *mp.form_ac.port_inj_current()* (page 76) to compute voltage-related Jacobian terms.

port_inj_current_hess_v(*x_*, *lam*, *v_*, *z_*, *diaginvic*, *Y*, *M*, *diagSlincJ*, *dlamJ*)

Compute voltage-related terms of current injection Hessian.

```
[Iuu, Iuw, Iww] = nme.port_inj_current_hess_v(x_, lam)
[Iuu, Iuw, Iww] = nme.port_inj_current_hess_v(x_, lam, sysx)
[Iuu, Iuw, Iww] = nme.port_inj_current_hess_v(x_, lam, sysx, idx)
[...] = nme.port_inj_current_hess_vz(x_, lam, v_, z_, diaginvic, Y, M,␣
↪diagSlincJ, dlamJ)
```

Called by *mp.form_ac.port_inj_current_hess()* (page 77) to compute voltage-related Hessian terms.

port_inj_current_hess_vz(*x_*, *lam*, *v_*, *z_*, *diaginvic*, *N*, *dlamJ*)

Compute voltage/non-voltage-related terms of current injection Hessian.

```
[Iuzr, Iuzi, Iwzr, Iwzi] = nme.port_inj_current_hess_vz(x_, lam)
[...] = nme.port_inj_current_hess_vz(x_, lam, sysx)
[...] = nme.port_inj_current_hess_vz(x_, lam, sysx, idx)
[...] = nme.port_inj_current_hess_vz(x_, lam, v_, z_, diaginvic, N, dlamJ)
```

Called by *mp.form_ac.port_inj_current_hess()* (page 77) to compute voltage/non-voltage-related Hessian terms.

port_inj_power_jac(*n*, *v_*, *Y*, *M*, *diagv*, *diagvi*, *diagIlincJ*)

Compute voltage-related terms of power injection Jacobian.

```
[Su, Sw] = nme.port_inj_power_jac(...)
```

Called by *mp.form_ac.port_inj_power()* (page 76) to compute voltage-related Jacobian terms.

port_inj_power_hess_v(*x_*, *lam*, *v_*, *z_*, *diagvi*, *Y*, *M*, *diagIlincJ*, *dlamJ*)

Compute voltage-related terms of power injection Hessian.

```
[Suu, Suw, Sww] = nme.port_inj_power_hess_v(x_, lam)
[Suu, Suw, Sww] = nme.port_inj_power_hess_v(x_, lam, sysx)
[Suu, Suw, Sww] = nme.port_inj_power_hess_v(x_, lam, sysx, idx)
[...] = nme.port_inj_power_hess_v(x_, lam, v_, z_, diagvi, Y, M, diagIlincJ,
↪ dlamJ)
```

Called by *mp.form_ac.port_inj_power_hess()* (page 78) to compute voltage-related Hessian terms.

port_inj_power_hess_vz(*x_*, *lam*, *v_*, *z_*, *diagvi*, *L*, *dlamJ*)

Compute voltage/non-voltage-related terms of power injection Hessian.

```
[Suzr, Suzi, Swzr, Swzi] = nme.port_inj_power_hess_vz(x_, lam)
[...] = nme.port_inj_power_hess_vz(x_, lam, sysx)
[...] = nme.port_inj_power_hess_vz(x_, lam, sysx, idx)
[...] = nme.port_inj_power_hess_vz(x_, lam, v_, z_, diagvi, L, dlamJ)
```

Called by *mp.form_ac.port_inj_power_hess()* (page 78) to compute voltage/non-voltage-related Hessian terms.

aux_data_va_vm(*ad*)

Return voltage angles/magnitudes from auxiliary data.

```
[va, vm] = nme.aux_data_va_vm(ad)
```

Connverts from cartesian voltage data stored in `ad.vr` and `ad.vi`.

Input

ad (*struct*) – struct of auxiliary data

Outputs

- **va** (*double*) – vector of voltage angles corresponding to voltage information stored in auxiliary data
- **vm** (*double*) – vector of voltage magnitudes corresponding to voltage information stored in auxiliary data

va_fcn(*xx*, *idx*, *lim*)

Compute voltage angle constraints and Jacobian.

```
g = nme.va_fcn(xx, idx, lim)
[g, dg] = nme.va_fcn(xx, idx, lim)
```

Compute constraint function and optionally the Jacobian for voltage angle limits.

Inputs

- **xx** (*1 x 2 cell array*) – real part of complex voltage in `xx{1}`, imaginary part in `xx{2}`
- **idx** (*integer*) – index of subset of voltages of interest to include in constraint; if empty, include all
- **lim** (*double or cell array of double*) – constraint bound(s), can be a vector, for equality constraints or an upper bound, or a cell array with `{va_lb, va_ub}` for dual-bound constraints

Outputs

- **g** (*double*) – constraint function, $\boldsymbol{g}(\boldsymbol{x})$
- **dg** (*double*) – constraint Jacobian, $\boldsymbol{g}_{\boldsymbol{x}}$

va_hess(*xx*, *lam*, *idx*)

Compute voltage angle Hessian.

```
d2G = nme.va_hess(xx, lam, idx)
```

Compute a sparse Hessian matrix for all or a selected subset of voltages. Rather than a full, 3-dimensional Hessian, it computes the Jacobian of the vector obtained by muliplying the transpose of the constraint Jacobian by a vector $\boldsymbol{\lambda}$.

Inputs

- **xx** (*1 x 2 cell array*) – real part of complex voltage in `xx{1}`, imaginary part in `xx{2}`
- **lam** (*double*) – vector $\boldsymbol{\lambda}$ of multipliers, one for each constraint
- **idx** (*integer*) – index of subset of voltages of interest to include in constraint; if empty, include all

Output

d2G (*double*) – sparse constraint Hessian, $\boldsymbol{g}_{\boldsymbol{xx}}(\boldsymbol{\lambda})$

vm2_fcn(*xx*, *idx*, *lim*)

Compute squared voltage magnitude constraints and Jacobian.

```
g = nme.vm2_fcn(xx, idx, lim)
[g, dg] = nme.vm2_fcn(xx, idx, lim)
```

Compute constraint function and optionally the Jacobian for squared voltage magnitude limits.

Inputs

- **xx** (*1 x 2 cell array*) – real part of complex voltage in `xx{1}`, imaginary part in `xx{2}`
- **idx** (*integer*) – index of subset of voltages of interest to include in constraint; if empty, include all
- **lim** (*double or cell array of double*) – constraint bound(s), can be a vector, for equality constraints or an upper bound, or a cell array with `{vm2_lb, vm2_ub}` for dual-bound constraints

Outputs

- **g** (*double*) – constraint function, $\boldsymbol{g}(\boldsymbol{x})$
- **dg** (*double*) – constraint Jacobian, $\boldsymbol{g}_{\boldsymbol{x}}$

vm2_hess(*xx*, *lam*, *idx*)

Compute squared voltage magnitude Hessian.

```
d2G = nme.vm2_hess(xx, lam, idx)
```

Compute a sparse Hessian matrix for all or a selected subset of voltages. Rather than a full, 3-dimensional Hessian, it computes the Jacobian of the vector obtained by muliplying the transpose of the constraint Jacobian by a vector $\boldsymbol{\lambda}$.

Inputs

- **xx** (*1 x 2 cell array*) – real part of complex voltage in `xx{1}`, imaginary part in `xx{2}`
- **lam** (*double*) – vector $\boldsymbol{\lambda}$ of multipliers, one for each constraint
- **idx** (*integer*) – index of subset of voltages of interest to include in constraint; if empty, include all

Output

d2G (*double*) – sparse constraint Hessian, $\boldsymbol{g_{xx}}(\boldsymbol{\lambda})$

mp.form_acp

class mp.**form_acp**

Bases: *mp.form_ac* (page 73)

mp.form_acp (page 86) - Base class for MATPOWER AC polar **formulations**.

Used as a mix-in class for all **network model element** classes with an AC network model formulation with a **polar** repesentation for voltages. That is, each concrete network model element class with an AC polar formulation must inherit, at least indirectly, from both *mp.nm_element* (page 107) and *mp.form_acp* (page 86).

Provides implementation of evaluation of voltage-related Jacobian and Hessian terms needed by some *mp.form_ac* (page 73) methods.

mp.form_dc Methods:

- *form_name()* (page 86) - get char array w/name of formulation (`'AC-polar'`)
- *form_tag()* (page 87) - get char array w/short label of formulation (`'acp'`)
- *model_vvars()* (page 87) - get cell array of names of voltage state variables (`{'va', 'vm'}`)
- *port_inj_current_jac()* (page 87) - compute voltage-related terms of current injection Jacobian
- *port_inj_current_hess_v()* (page 87) - compute voltage-related terms of current injection Hessian
- *port_inj_current_hess_vz()* (page 87) - compute voltage/non-voltage-related terms of current injection Hessian
- *port_inj_power_jac()* (page 87) - compute voltage-related terms of power injection Jacobian
- *port_inj_power_hess_v()* (page 87) - compute voltage-related terms of power injection Hessian
- *port_inj_power_hess_vz()* (page 88) - compute voltage/non-voltage-related terms of power injection Hessian
- *aux_data_va_vm()* (page 88) - return voltage angles/magnitudes from auxiliary data

For more details, see the sec_nm_formulations_ac section in the *MATPOWER Developer's Manual* and the derivations in *MATPOWER Technical Note 5*.

See also *mp.form* (page 71), *mp.form_ac* (page 73), *mp.form_acc* (page 82), *mp.nm_element* (page 107).

Method Summary

form_name()

Get user-readable name of formulation, i.e. `'AC-polar'`.

See *mp.form.form_name()* (page 72).

form_tag()

Get short label of formulation, i.e. `'acp'`.

See *mp.form.form_tag()* (page 72).

model_vvars()

Get cell array of names of voltage state variables, i.e. `{'va', 'vm'}`.

See *mp.form.model_vvars()* (page 72).

port_inj_current_jac(*n*, *v_*, *Y*, *M*, *invdiagvic*, *diagSlincJ*)

Compute voltage-related terms of current injection Jacobian.

```
[Iva, Ivm] = nme.port_inj_current_jac(n, v_, Y, M, invdiagvic, diagSlincJ)
```

Called by *mp.form_ac.port_inj_current()* (page 76) to compute voltage-related Jacobian terms.

port_inj_current_hess_v(*x_*, *lam*, *v_*, *z_*, *diaginvic*, *Y*, *M*, *diagSlincJ*, *dlamJ*)

Compute voltage-related terms of current injection Hessian.

```
[Ivava, Ivavm, Ivmvm] = nme.port_inj_current_hess_v(x_, lam)
[Ivava, Ivavm, Ivmvm] = nme.port_inj_current_hess_v(x_, lam, sysx)
[Ivava, Ivavm, Ivmvm] = nme.port_inj_current_hess_v(x_, lam, sysx, idx)
[...] = nme.port_inj_current_hess_vz(x_, lam, v_, z_, diaginvic, Y, M,␣
↪diagSlincJ, dlamJ)
```

Called by *mp.form_ac.port_inj_current_hess()* (page 77) to compute voltage-related Hessian terms.

port_inj_current_hess_vz(*x_*, *lam*, *v_*, *z_*, *diaginvic*, *N*, *dlamJ*)

Compute voltage/non-voltage-related terms of current injection Hessian.

```
[Ivazr, Ivazi, Ivmzr, Ivmzi] = nme.port_inj_current_hess_vz(x_, lam)
[...] = nme.port_inj_current_hess_vz(x_, lam, sysx)
[...] = nme.port_inj_current_hess_vz(x_, lam, sysx, idx)
[...] = nme.port_inj_current_hess_vz(x_, lam, v_, z_, diaginvic, N, dlamJ)
```

Called by *mp.form_ac.port_inj_current_hess()* (page 77) to compute voltage/non-voltage-related Hessian terms.

port_inj_power_jac(*n*, *v_*, *Y*, *M*, *diagv*, *diagvi*, *diagIlincJ*)

Compute voltage-related terms of power injection Jacobian.

```
[Sva, Svm] = nme.port_inj_power_jac(...)
```

Called by *mp.form_ac.port_inj_power()* (page 76) to compute voltage-related Jacobian terms.

port_inj_power_hess_v(*x_*, *lam*, *v_*, *z_*, *diagvi*, *Y*, *M*, *diagIlincJ*, *dlamJ*)

Compute voltage-related terms of power injection Hessian.

```
[Svava, Svavm, Svmvm] = nme.port_inj_power_hess_v(x_, lam)
[Svava, Svavm, Svmvm] = nme.port_inj_power_hess_v(x_, lam, sysx)
[Svava, Svavm, Svmvm] = nme.port_inj_power_hess_v(x_, lam, sysx, idx)
[...] = nme.port_inj_power_hess_v(x_, lam, v_, z_, diagvi, Y, M, diagIlincJ,
↪ dlamJ)
```

Called by *mp.form_ac.port_inj_power_hess()* (page 78) to compute voltage-related Hessian terms.

port_inj_power_hess_vz(*x_*, *lam*, *v_*, *z_*, *diagvi*, *L*, *dlamJ*)

Compute voltage/non-voltage-related terms of power injection Hessian.

```
[Svazr, Svazi, Svmzr, Svmzi] = nme.port_inj_power_hess_vz(x_, lam)
[...] = nme.port_inj_power_hess_vz(x_, lam, sysx)
[...] = nme.port_inj_power_hess_vz(x_, lam, sysx, idx)
[...] = nme.port_inj_power_hess_vz(x_, lam, v_, z_, diagvi, L, dlamJ)
```

Called by *mp.form_ac.port_inj_power_hess()* (page 78) to compute voltage/non-voltage-related Hessian terms.

aux_data_va_vm(*ad*)

Return voltage angles/magnitudes from auxiliary data.

```
[va, vm] = nme.aux_data_va_vm(ad)
```

Simply returns voltage data stored in `ad.va` and `ad.vm`.

Input

ad (*struct*) – struct of auxiliary data

Outputs

- **va** (*double*) – vector of voltage angles corresponding to voltage information stored in auxiliary data
- **vm** (*double*) – vector of voltage magnitudes corresponding to voltage information stored in auxiliary data

mp.form_dc

class mp.**form_dc**

Bases: *mp.form* (page 71)

mp.form_dc (page 88) - Base class for MATPOWER DC **formulations**.

Used as a mix-in class for all **network model element** classes with a DC network model formulation. That is, each concrete network model element class with a DC formulation must inherit, at least indirectly, from both *mp.nm_element* (page 107) and *mp.form_dc* (page 88).

mp.form_dc (page 88) defines the port active power injection as a linear function of the state variables $\boldsymbol{x}$, that is, the voltage angles $\boldsymbol{\theta}$ and non-voltage states $\boldsymbol{z}$, as

$$\begin{aligned} \boldsymbol{g}^P(\boldsymbol{x}) &= \begin{bmatrix} \underline{\boldsymbol{B}} & \underline{\boldsymbol{K}} \end{bmatrix} \boldsymbol{x} + \underline{\boldsymbol{p}} \\ &= \underline{\boldsymbol{B}}\boldsymbol{\theta} + \underline{\boldsymbol{K}}\boldsymbol{z} + \underline{\boldsymbol{p}}, \end{aligned} \tag{3.6}$$

where $\underline{\boldsymbol{B}}$, $\underline{\boldsymbol{K}}$, and $\underline{\boldsymbol{p}}$ are the model parameters.

For more details, see the sec_nm_formulations_dc section in the *MATPOWER Developer's Manual* and the derivations in *MATPOWER Technical Note 5*.

mp.form_dc Properties:

- *B* (page 89) - $n_p n_k \times n_n$ matrix $\underline{\boldsymbol{B}}$ of model parameters
- *K* (page 89) - $n_p n_k \times n_z$ matrix $\underline{\boldsymbol{K}}$ of model parameters
- *p* (page 89) - $n_p n_k \times 1$ vector $\underline{\boldsymbol{p}}$ of model parameters
- `params_ncols` - specify number of columns for each parameter

mp.form_dc Methods:

- *form_name()* (page 89) - get char array w/name of formulation (`'DC'`)
- *form_tag()* (page 89) - get char array w/short label of formulation (`'dc'`)
- *model_params()* (page 89) - get network model element parameters (`{'B', 'K', 'p'}`)
- *model_vvars()* (page 89) - get cell array of names of voltage state variables (`{'va'}`)
- *model_zvars()* (page 90) - get cell array of names of non-voltage state variables (`{'z'}`)
- *port_inj_power()* (page 90) - compute port power injections from network state

See also *mp.form* (page 71), *mp.form_ac* (page 73), *mp.nm_element* (page 107).

Property Summary

`B = []`

(double) $n_p n_k \times n_n$ matrix $\underline{\boldsymbol{B}}$ of model parameter coefficients for $\boldsymbol{\theta}$

`K = []`

(double) $n_p n_k \times n_z$ matrix $\underline{\boldsymbol{K}}$ of model parameter coefficients for $\boldsymbol{z}$

`p = []`

(double) $n_p n_k \times 1$ vector $\underline{\boldsymbol{p}}$ of model parameters

`param_ncols = struct('B',2,'K',3,'p',1)`

(struct) specify number of columns for each parameter, where
- 1 => single column (i.e. a vector)
- 2 => n_p columns
- 3 => n_z columns

Method Summary

`form_name()`

Get user-readable name of formulation, i.e. `'DC'`.

See *mp.form.form_name()* (page 72).

`form_tag()`

Get short label of formulation, i.e. `'dc'`.

See *mp.form.form_tag()* (page 72).

`model_params()`

Get cell array of names of model parameters, i.e. `{'B', 'K', 'p'}`.

See *mp.form.model_params()* (page 72).

model_vvars()

Get cell array of names of voltage state variables, i.e. `{'va'}`.

See *mp.form.model_vvars()* (page 72).

model_zvars()

Get cell array of names of non-voltage state variables, i.e. `{'z'}`.

See *mp.form.model_zvars()* (page 72).

port_inj_power(*x*, *sysx*, *idx*)

Compute port power injections from network state.

```
P = nme.port_inj_power(x, sysx, idx)
```

Compute the active power injections for all or a selected subset of ports.

The state can be provided as a stacked aggregate of the state variables (port voltages and non-voltage states) for the full collection of network model elements of this type, or as the combined state for the entire network.

Inputs

- **x** (*double*) – state vector $\boldsymbol{x}$
- **sysx** (*0 or 1*) – which state is provided in **x**
  - 0 – class aggregate state
  - 1 – *(default)* full system state
- **idx** (*integer*) – *(optional)* vector of indices of ports of interest, if empty or missing, returns injections corresponding to all ports

Outputs

P (*double*) – vector of port power injections, $\boldsymbol{g}^P(\boldsymbol{x})$

mp.net_model

class mp.**net_model**

Bases: *mp.nm_element* (page 107), *mp.element_container* (page 165), `mp_idx_manager`

mp.net_model (page 90) - Abstract base class for MATPOWER **network model** objects.

The network model defines the states of and connections between network elements, as well as the parameters and functions defining the relationships between states and port injections. A given network model implements a specific network model **formulation**, and defines sets of **nodes**, **ports**, and **states**.

A network model object is primarily a container for network model element (*mp.nm_element* (page 107)) objects and *is itself* a network model element. All network model classes inherit from *mp.net_model* (page 90) and therefore also from *mp.element_container* (page 165), `mp_idx_manager`, and *mp.nm_element* (page 107). Concrete network model classes are also formulation-specific, inheriting from a corresponding subclass of *mp.form* (page 71).

By convention, network model variables are named `nm` and network model class class names begin with `mp.net_model`.

mp.net_model Properties:

- *the_np* (page 92) - total number of ports
- *the_nz* (page 92) - total number of non-voltage states
- *nv* (page 92) - total number of (real) voltage variables

- *node* (page 92) - `mp_idx_manager` data for nodes
- *port* (page 92) - `mp_idx_manager` data for ports
- *state* (page 92) - `mp_idx_manager` data for non-voltage states

mp.net_model Methods:

- *name()* (page 92) - return name of this network element type (`'network'`)
- *np()* (page 92) - return number of ports for this network element
- *nz()* (page 92) - return number of *(possibly complex)* non-voltage states for this network element
- *build()* (page 92) - create, add, and build network model element objects
- *add_nodes()* (page 92) - elements add nodes, then add corresponding voltage variables
- *add_states()* (page 93) - elements add states, then add corresponding state variables
- *build_params()* (page 93) - build incidence matrices, parameters, add ports for each element
- *stack_matrix_params()* (page 93) - form network matrix parameter by stacking corresponding element parameters
- *stack_vector_params()* (page 93) - form network vector parameter by stacking corresponding element parameters
- *add_vvars()* (page 94) - add voltage variable(s) for each network node
- *add_zvars()* (page 94) - add non-voltage state variable(s) for each network state
- *def_set_types()* (page 94) - define node, state, and port set types for `mp_idx_manager`
- *init_set_types()* (page 94) - initialize structures for tracking/indexing nodes, states, ports
- *display()* (page 94) - display the network model object
- *add_node()* (page 95) - add named set of nodes
- *add_port()* (page 95) - add named set of ports
- *add_state()* (page 95) - add named set of states
- *set_type_idx_map()* (page 95) - map node/port/state index back to named set & index within set
- *set_type_label()* (page 96) - create a user-readable label to identify a node, port, or state
- *add_var()* (page 96) - add a set of variables to the model
- *params_var()* (page 97) - return initial value, bounds, and variable type for variables
- *get_node_idx()* (page 98) - get index information for named node set
- *get_port_idx()* (page 98) - get index information for named port set
- *get_state_idx()* (page 98) - get index information for named state set
- *node_types()* (page 98) - get node type information
- *ensure_ref_node()* (page 99) -
- *set_node_type_ref()* (page 99) - make the specified node a reference node
- *set_node_type_pv()* (page 100) - make the specified node a PV node
- *set_node_type_pq()* (page 100) - make the specified node a PQ node

See the sec_net_model section in the *MATPOWER Developer's Manual* for more information.

See also *mp.form* (page 71), *mp.nm_element* (page 107), *mp.task* (page 7), *mp.data_model* (page 27), *mp.math_model* (page 121).

Property Summary

the_np = 0

(integer) total number of ports

the_nz = 0

(integer) total number of non-voltage states

nv = 0

(integer) total number of (real) voltage variables

node = []

(struct) `mp_idx_manager` data for nodes

port = []

(struct) `mp_idx_manager` data for ports

state = []

(struct) `mp_idx_manager` data for non-voltage states

Method Summary

name()

Return the name of this network element type (`'network'`).

```
name = nm.name()
```

np()

Return the number of ports for this network element.

```
np = nm.np()
```

nz()

Return the number of *(possibly complex)* non-voltage states for this network element.

```
nz = nm.nz()
```

build(*dm*)

Create, add, and *build()* (page 92) network model element objects.

```
nm.build(dm)
```

Input
dm (*mp.data_model* (page 27)) – data model object

Create and add network model element objects, add nodes and states, and build the parameters for all elements.

See also *add_nodes()* (page 92), *add_states()* (page 93), *build_params()* (page 93).

add_nodes(*nm*, *dm*)

Elements add nodes, then add corresponding voltage variables.

```
nm.add_nodes(nm, dm)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object

Each element can add its nodes, then the network model itself can add additional nodes, and finally corresponding voltage variables are added for each node.

See also *add_vvars()* (page 94), *add_states()* (page 93).

add_states(*nm*, *dm*)

Elements add states, then add corresponding state variables.

```
nm.add_states(nm, dm)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object

Each element can add its states, then corresponding non-voltage state variables are added for each state.

See also *add_zvars()* (page 94), *add_nodes()* (page 92).

build_params(*nm*, *dm*)

Build incidence matrices and parameters, and add ports for each element.

```
nm.build_params(nm, dm)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object

For each element, build connection and state variable incidence matrices and element parameters, and add ports. Then construct the full network connection and state variable incidence matrices.

stack_matrix_params(*name*, *vnotz*)

Form network matrix parameter by stacking corresponding element parameters.

```
M = nm.stack_matrix_params(name, vnotz)
```

Inputs
- **name** (*char array*) – name of the parameter of interest
- **vnotz** (*boolean*) – true if columns of parameter correspond to voltage variables, false otherwise

Output

M (*double*) – matrix parameter of interest for the full network

A given matrix parameter (e.g. `Y`) for the full network is formed by stacking the corresponding matrix parameters for each element along the matrix block diagonal.

stack_vector_params(*name*)

Form network vector parameter by stacking corresponding element parameters.

```
v = nm.stack_vector_params(name)
```

Input
name (*char array*) – name of the parameter of interest
Output
v (*double*) – vector parameter of interest for the full network

A given vector parameter (e.g. `s`) for the full network is formed by vertically stacking the corresponding vector parameters for each element.

`add_vvars`(*nm*, *dm*, *idx*)

Add voltage variable(s) for each network node.

```
nm.add_vvars(nm, dm)
nm.add_vvars(nm, dm, idx)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **idx** (*integer*) – index for name and indexed variables *(currently unused here)*

Also updates the `nv` property.

See also *add_zvars()* (page 94), *add_nodes()* (page 92).

`add_zvars`(*nm*, *dm*, *idx*)

Add non-voltage state variable(s) for each network state.

```
nm.add_zvars(nm, dm)
nm.add_zvars(nm, dm, idx)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **idx** (*cell array*) – indices for named and indexed variables *(currently unused here)*

See also *add_vvars()* (page 94), *add_states()* (page 93).

`def_set_types`()

Define node, state, and port set types for `mp_idx_manager`.

```
nm.def_set_types()
```

Define the following set types:
- `'node'` - NODES
- `'state'` - STATES
- `'port'` - PORTS

See also `mp_idx_manager`.

`init_set_types`()

Initialize structures for tracking/indexing nodes, states, ports.

```
nm.init_set_types()
```

See also `mp_idx_manager`.

`display`()

Display the network model object.

This method is called automatically when omitting a semicolon on a line that retuns an object of this class.

Displays the details of the nodes, ports, states, voltage variables, non-voltage state variables, and network model elements.

See also `mp_idx_manager`.

add_node(*name*, *idx*, *N*)

Add named set of nodes.

```
nm.add_node(name, N)
nm.add_node(name, idx, N)
```

Inputs

- **name** (*char array*) – name for set of nodes
- **idx** (*cell array*) – indices for named, indexed set of nodes
- **N** (*integer*) – number of nodes in set

See also `mp_idx_manager.add_named_set()`.

add_port(*name*, *idx*, *N*)

Add named set of ports.

```
nm.add_port(name, N)
nm.add_port(name, idx, N)
```

Inputs

- **name** (*char array*) – name for set of ports
- **idx** (*cell array*) – indices for named, indexed set of ports
- **N** (*integer*) – number of ports in set

See also `mp_idx_manager.add_named_set()`.

add_state(*name*, *idx*, *N*)

Add named set of states.

```
nm.add_state(name, N)
nm.add_state(name, idx, N)
```

Inputs

- **name** (*char array*) – name for set of states
- **idx** (*cell array*) – indices for named, indexed set of states
- **N** (*integer*) – number of states in set

See also `mp_idx_manager.add_named_set()`.

set_type_idx_map(*set_type*, *idxs*, *dm*, *group_by_name*)

Map node/port/state index back to named set & index within set.

```
s = obj.set_type_idx_map(set_type)
s = obj.set_type_idx_map(set_type, idxs)
s = obj.set_type_idx_map(set_type, idxs, dm)
s = obj.set_type_idx_map(set_type, idxs, dm, group_by_name)
```

Inputs

- **set_type** (*char array*) – `'node'`, `'port'`, or `'state'`
- **idxs** (*integer*) – vector of indices, defaults to `[1:ns]'`, where `ns` is the full dimension of the set corresponding to the all elements for the specified set type (i.e. node, port, or state)
- **dm** (*mp.data_model* (page 27)) – data model object

- **group_by_name** (*boolean*) – if true, results are consolidated, with a single entry in `s` for each unique name/idx pair, where the `i` and `j` fields are vectors

Output

s (*struct*) – index map of same dimensions as `idxs`, unless `group_by_name` is true, in which case it is 1 dimensional

Returns a struct of same dimensions as `idxs` specifying, for each index, the corresponding named set and element within the named set for the specified `set_type`. The return struct has the following fields:

- `name` : name of corresponding set
- `idx` : cell array of indices for the name, if named set is indexed
- `i` : index of element within the set
- `e` : external index (i.e. corresponding row in data model)
- `ID` : external ID (i.e. corresponding element ID in data model)
- `j` : (only if `group_by_name` == 1), corresponding index of set type, equal to a particular element of `idxs`

Examples:

```
s = nm.set_type_idx_map('node', 87, dm));
s = nm.set_type_idx_map('port', [38; 49; 93], dm));
s = nm.set_type_idx_map('state'));
s = nm.set_type_idx_map('node', [], dm, 1));
```

set_type_label(*set_type*, *idxs*, *dm*)

Create a user-readable label to identify a node, port, or state.

```
label = nm.set_type_label(set_type, idxs)
label = nm.set_type_label(set_type, idxs, dm)
```

Inputs

- **set_type** (*char array*) – `'node'`, `'port'`, or `'state'`
- **idxs** (*integer*) – vector of indices
- **dm** (*mp.data_model* (page 27)) – data model object

Output

label (*cell array*) – same dimensions as `idxs`, where each entry is a char array

Example:

```
labels = nm.set_type_label('port', [1;6;15;20], dm)

labels =

  4×1 cell array

    {'gen 1'      }
    {'load 3'     }
    {'branch(1) 9'}
    {'branch(2) 5'}
```

add_var(*vtype*, *name*, *idx*, *varargin*)

Add a set of variables to the model.

```
nm.add_var(vtype, name, N, v0, vl, vu, vt)
nm.add_var(vtype, name, N, v0, vl, vu)
nm.add_var(vtype, name, N, v0, vl)
```

(continues on next page)

(continued from previous page)

```
nm.add_var(vtype, name, N, v0)
nm.add_var(vtype, name, N)
nm.add_var(vtype, name, idx_list, N, v0, vl, vu, vt)
nm.add_var(vtype, name, idx_list, N, v0, vl, vu)
nm.add_var(vtype, name, idx_list, N, v0, vl)
nm.add_var(vtype, name, idx_list, N, v0)
nm.add_var(vtype, name, idx_list, N)
```

Inputs

- **vtype** (*char array*) – variable type, must be a valid struct field name
- **name** (*char array*) – name of variable set
- **idx_list** (*cell array*) – optional index list
- **N** (*integer*) – number of variables in the set
- **v0** (*double*) – N x 1 col vector, initial value of variables, default is `0`
- **vl** (*double*) – N x 1 col vector, lower bounds, default is `-Inf`
- **vu** (*double*) – N x 1 col vector, upper bounds, default is `Inf`
- **vt** (*char*) – scalar or 1 x N row vector, variable type, default is `'C'`, valid element values are:
  - `'C'` - continuous
  - `'I'` - integer
  - `'B'` - binary

Essentially identical to the `add_var()` method from `opt_model` of MP-Opt-Model, with the addition of a variable type (`vtype`).

See also `opt_model.add_var()`.

params_var(*vtype*, *name*, *idx*)

Return initial value, bounds, and variable type for variables.

```
[v0, vl, vu] = nm.params_var(vtype)
[v0, vl, vu] = nm.params_var(vtype, name)
[v0, vl, vu] = nm.params_var(vtype, name, idx_list)
[v0, vl, vu, vt] = nm.params_var(...)
```

Inputs

- **vtype** (*char array*) – variable type, must be a valid struct field name
- **name** (*char array*) – name of variable set
- **idx_list** (*cell array*) – optional index list

Outputs

- **v0** (*double*) – N x 1 col vector, initial value of variables
- **vl** (*double*) – N x 1 col vector, lower bounds
- **vu** (*double*) – N x 1 col vector, upper bounds
- **vt** (*char*) – scalar or 1 x N row vector, variable type, valid element values are:
  - `'C'` - continuous
  - `'I'` - integer
  - `'B'` - binary

Essentially identical to the `params_var()` method from `opt_model` of MP-Opt-Model, with the addition of a variable type (`vtype`).

Returns the initial value `v0`, lower bound `vl` and upper bound `vu` for the full variable vector, or for a specific named or named and indexed variable set. Optionally also returns a corresponding char vector `vt` of variable types, where `'C'`, `'I'` and `'B'` represent continuous, integer, and binary variables, respectively.

Examples:

```
[vr0, vrmin, vrmax] = obj.params_var('vr');
[pg0, pg_lb, pg_ub] = obj.params_var('zr', 'pg');
[zij0, zij_lb, zij_ub, ztype] = obj.params_var('zi', 'z', {i, j});
```

See also `opt_model.params_var()`.

get_node_idx(*name*)

Get index information for named node set.

```
[i1 iN] = nm.get_node_idx(name)
nidx = nm.get_node_idx(name)
```

Input

name (*char array*) – name of node set

Outputs

- **i1** (*integer*) – index of first node for `name`
- **iN** (*integer*) – index of last node for `name`
- **nidx** (*integer or cell array*) – indices of nodes for `name`, equal to either `[i1:iN]'` or `{[i1(1):iN(1)]', ..., [i1(n):iN(n)]'}`

get_port_idx(*name*)

Get index information for named port set.

```
[i1 iN] = nm.get_port_idx(name)
pidx = nm.get_port_idx(name)
```

Input

name (*char array*) – name of port set

Outputs

- **i1** (*integer*) – index of first port for `name`
- **iN** (*integer*) – index of last port for `name`
- **pidx** (*integer or cell array*) – indices of ports for `name`, equal to either `[i1:iN]'` or `{[i1(1):iN(1)]', ..., [i1(n):iN(n)]'}`

get_state_idx(*name*)

Get index information for named state set.

```
[i1 iN] = nm.get_state_idx(name)
sidx = nm.get_state_idx(name)
```

Input

name (*char array*) – name of state set

Outputs

- **i1** (*integer*) – index of first state for `name`
- **iN** (*integer*) – index of last state for `name`
- **sidx** (*integer or cell array*) – indices of states for `name`, equal to either `[i1:iN]'` or `{[i1(1):iN(1)]', ..., [i1(n):iN(n)]'}`

node_types(*nm*, *dm*, *idx*, *skip_ensure_ref*)

Get node type information.

```
ntv           = nm.node_types(nm, dm)
[ntv, by_elm] = nm.node_types(nm, dm)
```

(continues on next page)

(continued from previous page)

```
[ref, pv, pq]         = nm.node_types(nm, dm)
[ref, pv, pq, by_elm] = nm.node_types(nm, dm)
... = nm.node_types(nm, dm, idx)
... = nm.node_types(nm, dm, idx, skip_ensure_ref)
```

Inputs

- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **idx** (*integer*) – index *(not used in base method)*
- **skip_ensure_ref** (*boolean*) – unless true, if there is no reference node, the first PV node will be converted to a new reference

Outputs

- **ntv** (*integer*) – node type vector, valid element values are:
  - *mp.NODE_TYPE.REF* (page 169)
  - *mp.NODE_TYPE.PV* (page 169)
  - *mp.NODE_TYPE.PQ* (page 169)
- **ref** (*integer*) – vector of indices of reference nodes
- **pv** (*integer*) – vector of indices of PV nodes
- **pq** (*integer*) – vector of indices of PQ nodes
- **by_elm** (*struct*) – `by_elm(k)` is struct for k-th node-creating element type, with fields:
  - `'name'` - name of corresponding node-creating element type
  - `'ntv'` - node type vector (if `by_elm` is 2nd output arg)
  - `'ref'/'pv'/'pq'` - index vectors into elements of corresponding node-creating element type (if `by_elm` is 4th output arg)

See also *mp.NODE_TYPE* (page 169), *ensure_ref_node()* (page 99).

ensure_ref_node(*dm*, *ref*, *pv*, *pq*)

Ensure there is at least one reference node.

```
[ref, pv, pq] = nm.ensure_ref_node(dm, ref, pv, pq)
ntv = nm.ensure_ref_node(dm, ntv)
```

Inputs

- **dm** (*mp.data_model* (page 27)) – data model object
- **ref** (*integer*) – vector of indices of reference nodes
- **pv** (*integer*) – vector of indices of PV nodes
- **pq** (*integer*) – vector of indices of PQ nodes
- **ntv** (*integer*) – node type vector, valid element values are:
  - *mp.NODE_TYPE.REF* (page 169)
  - *mp.NODE_TYPE.PV* (page 169)
  - *mp.NODE_TYPE.PQ* (page 169)

Outputs

- **ref** (*integer*) – updated vector of indices of reference nodes
- **pv** (*integer*) – updated vector of indices of PV nodes
- **pq** (*integer*) – updated vector of indices of PQ nodes
- **ntv** (*integer*) – updated node type vector

set_node_type_ref(*dm*, *idx*)

Make the specified node a reference node.

```
nm.set_node_type_ref(dm, idx)
```

Inputs

- **dm** (*mp.data_model* (page 27)) – data model object
- **idx** (*integer*) – index of node to modify, this is the internal network model element index

Set the specified node to type *mp.NODE_TYPE.REF* (page 169).

set_node_type_pv(*dm*, *idx*)

Make the specified node a PV node.

```
nm.set_node_type_pv(dm, idx)
```

Inputs
- **dm** (*mp.data_model* (page 27)) – data model object
- **idx** (*integer*) – index of node to modify, this is the internal network model element index

Set the specified node to type *mp.NODE_TYPE.PV* (page 169).

set_node_type_pq(*dm*, *idx*)

Make the specified node a PQ node.

```
nm.set_node_type_pq(dm, idx)
```

Inputs
- **dm** (*mp.data_model* (page 27)) – data model object
- **idx** (*integer*) – index of node to modify, this is the internal network model element index

Set the specified node to type *mp.NODE_TYPE.PQ* (page 169).

mp.net_model_ac

class mp.**net_model_ac**

Bases: *mp.net_model* (page 90)

mp.net_model_ac (page 100) - Abstract base class for MATPOWER AC **network model** objects.

Explicitly a subclass of *mp.net_model* (page 90) and implicitly assumed to be a subclass of *mp.form_ac* (page 73) as well.

mp.net_model_ac Properties:

- `zr` - vector of real part of complex non-voltage states, z_r
- `zi` - vector of imaginary part of complex non-voltage states, z_i

mp.net_model_ac Methods:

- *def_set_types()* (page 101) - add non-voltage state variable set types for `mp_idx_manager`
- *build_params()* (page 101) - build incidence matrices, parameters, add ports for each element
- *port_inj_nln()* (page 101) - compute general nonlinear port injection functions and Jacobians
- *port_inj_nln_hess()* (page 102) - compute general nonlinear port injection Hessian
- *nodal_complex_current_balance()* (page 102) - compute nodal complex current balance constraints
- *nodal_complex_power_balance()* (page 102) - compute nodal complex power balance constraints
- *nodal_complex_current_balance_hess()* (page 103) - compute nodal complex current balance Hessian

- *nodal_complex_power_balance_hess()* (page 103) - compute nodal complex power balance Hessian
- *port_inj_soln()* (page 103) - compute the network port power injections at the solution
- *get_va()* (page 103) - get node voltage angle vector

See also *mp.net_model* (page 90), *mp.form* (page 71), *mp.form_ac* (page 73), *mp.nm_element* (page 107).

Method Summary

def_set_types()

Add non-voltage state variable set types for mp_idx_manager.

```
nm.def_set_types()
```

Add the following set types:
- 'zr' - NON-VOLTAGE VARS REAL (zr)
- 'zi' - NON-VOLTAGE VARS IMAG (zi)

See also *mp.net_model.def_set_types()* (page 94), mp_idx_manager.

build_params(*nm*, *dm*)

Build incidence matrices and parameters, and add ports for each element.

```
nm.build_params(nm, dm)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object

Call the parent method to do most() of the work, then build the aggregate network model parameters and add the general nonlinear function terms, $\mathbf{s}^{nln}(\mathbf{x})$ or $\mathbf{i}^{nln}(\mathbf{x})$, for any elements that define them.

port_inj_nln(*si*, *x_*, *sysx*, *idx*)

Compute general nonlinear port injection functions and Jacobians

```
g = nm.port_inj_nln(si, x_, sysx, idx)
[g, gv1, gv2] = nm.port_inj_nln(si, x_, sysx, idx)
[g, gv1, gv2, gzr, gzi] = nm.port_inj_nln(si, x_, sysx, idx)
```

Compute and assemble the functions, and optionally Jacobians, for the general nonlinear injection functions $\mathbf{s}^{nln}(\mathbf{x})$ and $\mathbf{i}^{nln}(\mathbf{x})$ for the full aggregate network model, for all or a selected subset of ports.

Inputs
- **si** ('S' or 'I') – select power or current injection function:
  - 'S' for complex power $\mathbf{s}^{nln}(\mathbf{x})$
  - 'I' for complex current $\mathbf{i}^{nln}(\mathbf{x})$
- **x_** (*complex double*) – state vector $\mathbf{x}$
- **sysx** (*0 or 1*) – which state is provided in x_
  - 0 – class aggregate state
  - 1 – *(default)* full system state
- **idx** (*integer*) – *(optional)* vector of indices of ports of interest, if empty or missing, returns results corresponding to all ports

Outputs
- **g** (*complex double*) – nonlinear injection function, $\mathbf{s}^{nln}(\mathbf{x})$ (or $\mathbf{i}^{nln}(\mathbf{x})$)
- **gv1** (*complex double*) – Jacobian w.r.t. 1st voltage variable, $\mathbf{s}^{nln}_{\boldsymbol{\theta}}$ or $\mathbf{s}^{nln}_{\boldsymbol{u}}$ (or $\mathbf{i}^{nln}_{\boldsymbol{\theta}}$ or $\mathbf{i}^{nln}_{\boldsymbol{u}}$)
- **gv2** (*complex double*) – Jacobian w.r.t. 2nd voltage variable, $\mathbf{s}^{nln}_{\boldsymbol{\nu}}$ or $\mathbf{s}^{nln}_{\boldsymbol{w}}$ (or $\mathbf{i}^{nln}_{\boldsymbol{\nu}}$ or $\mathbf{i}^{nln}_{\boldsymbol{w}}$)

- **gzr** (*complex double*) – Jacobian w.r.t. real non-voltage variable, $\mathbf{s}_{z_r}^{nln}$ (or $\mathbf{i}_{z_r}^{nln}$)
- **gzi** (*complex double*) – Jacobian w.r.t. imaginary non-voltage variable, $\mathbf{s}_{z_i}^{nln}$ (or $\mathbf{i}_{z_i}^{nln}$)

See also *port_inj_nln_hess()* (page 102).

port_inj_nln_hess(*si*, *x_*, *lam*, *sysx*, *idx*)

Compute general nonlinear port injection Hessian.

```
H = nm.port_inj_nln_hess(si, x_, lam)
H = nm.port_inj_nln_hess(si, x_, lam, sysx)
H = nm.port_inj_nln_hess(si, x_, lam, sysx, idx)
```

Compute and assemble the Hessian for the general nonlinear injection functions $\mathbf{s}^{nln}(\mathbf{x})$ and $\mathbf{i}^{nln}(\mathbf{x})$ for the full aggregate network model, for all or a selected subset of ports. Rather than a full, 3-dimensional Hessian, it computes the Jacobian of the vector obtained by muliplying the transpose of the corresponding Jacobian by a vector $\boldsymbol{\lambda}$.

Inputs

- **si** (`'S'` or `'I'`) – select power or current injection function:
  - `'S'` for complex power $\mathbf{s}^{nln}(\mathbf{x})$
  - `'I'` for complex current $\mathbf{i}^{nln}(\mathbf{x})$
- **x_** (*complex double*) – state vector $\mathbf{x}$
- **lam** (*double*) – vector $\boldsymbol{\lambda}$ of multipliers, one for each port
- **sysx** (*0 or 1*) – which state is provided in `x_`
  - 0 – class aggregate state
  - 1 – *(default)* full system state
- **idx** (*integer*) – *(optional)* vector of indices of ports of interest, if empty or missing, returns results corresponding to all ports

Output

H (*complex double*) – sparse Hessian matrix, $\mathbf{s}_{\boldsymbol{xx}}^{nln}(\boldsymbol{\lambda})$ or $\mathbf{i}_{\boldsymbol{xx}}^{nln}(\boldsymbol{\lambda})$

See also *port_inj_nln()* (page 101).

nodal_complex_current_balance(*x_*)

Compute nodal complex current balance constraints.

```
G = nm.nodal_complex_current_balance(x_)
[G, Gv1, Gv2, Gzr, Gzi] = nm.nodal_complex_current_balance(x_)
```

Compute constraint function and optionally the Jacobian for the complex current balance equality constraints based on outputs of *mp.form_ac.port_inj_current()* (page 76) and the node incidence matrix.

Input

x_ (*complex double*) – state vector $\mathbf{x}$ (full system state)

Outputs

- **G** (*complex double*) – nodal complex current balance constraint function, $\mathbf{g}^{\text{kcl}}(\boldsymbol{x})$
- **Gv1** (*complex double*) – Jacobian w.r.t. 1st voltage variable, $\mathbf{g}_{\boldsymbol{\theta}}^{\text{kcl}}$ or $\mathbf{g}_{\boldsymbol{u}}^{\text{kcl}}$
- **Gv2** (*complex double*) – Jacobian w.r.t. 2nd voltage variable, $\mathbf{g}_{\boldsymbol{\nu}}^{\text{kcl}}$ or $\mathbf{g}_{\boldsymbol{w}}^{\text{kcl}}$
- **Gzr** (*complex double*) – Jacobian w.r.t. real non-voltage variable, $\mathbf{g}_{z_r}^{\text{kcl}}$
- **Gzi** (*complex double*) – Jacobian w.r.t. imaginary non-voltage variable, $\mathbf{g}_{z_i}^{\text{kcl}}$

See also *mp.form_ac.port_inj_current()* (page 76), *nodal_complex_current_balance_hess()* (page 103).

nodal_complex_power_balance(*x_*)

Compute nodal complex power balance constraints.

```
G = nm.nodal_complex_power_balance(x_)
[G, Gv1, Gv2, Gzr, Gzi] = nm.nodal_complex_power_balance(x_)
```

Compute constraint function and optionally the Jacobian for the complex power balance equality constraints based on outputs of *mp.form_ac.port_inj_power()* (page 76) and the node incidence matrix.

Input

x_ (*complex double*) – state vector $\mathbf{x}$ (full system state)

Outputs

- **G** (*complex double*) – nodal complex power balance constraint function, $\mathbf{g}^{\text{kcl}}(\boldsymbol{x})$
- **Gv1** (*complex double*) – Jacobian w.r.t. 1st voltage variable, $\mathbf{g}^{\text{kcl}}_{\boldsymbol{\theta}}$ or $\mathbf{g}^{\text{kcl}}_{\boldsymbol{u}}$
- **Gv2** (*complex double*) – Jacobian w.r.t. 2nd voltage variable, $\mathbf{g}^{\text{kcl}}_{\boldsymbol{\nu}}$ or $\mathbf{g}^{\text{kcl}}_{\boldsymbol{w}}$
- **Gzr** (*complex double*) – Jacobian w.r.t. real non-voltage variable, $\mathbf{g}^{\text{kcl}}_{z_r}$
- **Gzi** (*complex double*) – Jacobian w.r.t. imaginary non-voltage variable, $\mathbf{g}^{\text{kcl}}_{z_i}$

See also *mp.form_ac.port_inj_power()* (page 76), *nodal_complex_power_balance_hess()* (page 103).

nodal_complex_current_balance_hess(*x_*, *lam*)

Compute nodal complex current balance Hessian.

```
d2G = nm.nodal_complex_current_balance_hess(x_, lam)
```

Compute the Hessian of the nodal complex current balance constraint. Rather than a full, 3-dimensional Hessian, it computes the Jacobian of the vector obtained by muliplying the transpose of the constraint Jacobian by a vector $\boldsymbol{\lambda}$. Based on *mp.form_ac.port_inj_current_hess()* (page 77).

Inputs

- **x_** (*complex double*) – state vector $\mathbf{x}$ (full system state)
- **lam** (*double*) – vector $\boldsymbol{\lambda}$ of multipliers, one for each node

Output

d2G (*complex double*) – sparse Hessian matrix, $\mathbf{g}^{\text{kcl}}_{\boldsymbol{xx}}(\boldsymbol{\lambda})$

See also *mp.form_ac.port_inj_current_hess()* (page 77), *nodal_complex_current_balance()* (page 102).

nodal_complex_power_balance_hess(*x_*, *lam*)

Compute nodal complex power balance Hessian.

```
d2G = nm.nodal_complex_power_balance_hess(x_, lam)
```

Compute the Hessian of the nodal complex power balance constraint. Rather than a full, 3-dimensional Hessian, it computes the Jacobian of the vector obtained by muliplying the transpose of the constraint Jacobian by a vector $\boldsymbol{\lambda}$. Based on *mp.form_ac.port_inj_power_hess()* (page 78).

Inputs

- **x_** (*complex double*) – state vector $\mathbf{x}$ (full system state)
- **lam** (*double*) – vector $\boldsymbol{\lambda}$ of multipliers, one for each node

Output

d2G (*complex double*) – sparse Hessian matrix, $\mathbf{g}^{\text{kcl}}_{\boldsymbol{xx}}(\boldsymbol{\lambda})$

See also *mp.form_ac.port_inj_power_hess()* (page 78), *nodal_complex_power_balance()* (page 102).

port_inj_soln()

Compute the network port power injections at the solution.

```
nm.port_inj_soln()
```

Takes the solved network state, computes the port power injections, and saves them in `nm.soln.gs_`.

get_va(*idx*)

Get node voltage angle vector.

```
va = nm.get_va()
va = nm.get_va(idx)
```

Get vector of node voltage angles for all or a selected subset of nodes. Values come from the solution if available, otherwise from the provided initial voltages.

Input

idx (*integer*) – index of subset of voltages of interest; if missing or empty, include all

Output

va (*double*) – vector of voltage angles

mp.net_model_acc

class mp.**net_model_acc**

Bases: *mp.net_model_ac* (page 100), *mp.form_acc* (page 82)

mp.net_model_acc (page 104) - Concrete class for MATPOWER AC cartesian **network model** objects.

This network model class and all of its network model element classes are specific to the AC cartesian formulation and therefore inherit from *mp.form_acc* (page 82).

mp.net_model_acc Properties:

- `vr` - vector of real part of complex voltage state variables, u
- `vi` - vector of imaginary part of complex voltage state variables, w

mp.net_model_acc Methods:

- *net_model_acc()* (page 104) - constructor, assign default network model element classes
- *def_set_types()* (page 104) - add voltage state variable set types for `mp_idx_manager`
- *initial_voltage_angle()* (page 105) - get vector of initial node voltage angles

See also *mp.net_model_ac* (page 100), *mp.net_model* (page 90), *mp.form_acc* (page 82), *mp.form_ac* (page 73), *mp.form* (page 71), *mp.nm_element* (page 107).

Constructor Summary

net_model_acc()

Constructor, assign default network model element classes.

```
nm = net_model_acc()
```

This network model class and all of its network model element classes are specific to the AC cartesian formulation and therefore inherit from *mp.form_acc* (page 82).

Method Summary

def_set_types()

Add voltage state variable set types for `mp_idx_manager`.

```
nm.def_set_types()
```

Add the following set types:

- `'vr'` - REAL VOLTAGE VARS (vr)
- `'vi'` - IMAG VOLTAGE VARS (vi)

See also *mp.net_model_ac.def_set_types()* (page 101), *mp.net_model.def_set_types()* (page 94), mp_idx_manager.

initial_voltage_angle(*idx*)

Get vector of initial node voltage angles.

```
va = nm.initial_voltage_angle()
va = nm.initial_voltage_angle(idx)
```

Get vector of initial node voltage angles for all or a selected subset of nodes.

Input

idx (*integer*) – index of subset of voltages of interest; if missing or empty, include all

Output

va (*double*) – vector of initial voltage angles

mp.net_model_acp

class mp.**net_model_acp**

Bases: *mp.net_model_ac* (page 100), *mp.form_acp* (page 86)

mp.net_model_acp (page 105) - Concrete class for MATPOWER AC polar **network model** objects.

This network model class and all of its network model element classes are specific to the AC polar formulation and therefore inherit from *mp.form_acp* (page 86).

mp.net_model_acp Properties:

- va - vector of angles of complex voltage state variables, θ
- vm - vector of magnitudes of complex voltage state variables, ν

mp.net_model_acp Methods:

- *net_model_acp()* (page 105) - constructor, assign default network model element classes
- *def_set_types()* (page 105) - add voltage state variable set types for mp_idx_manager
- *initial_voltage_angle()* (page 106) - get vector of initial node voltage angles

See also *mp.net_model_ac* (page 100), *mp.net_model* (page 90), *mp.form_acp* (page 86), *mp.form_ac* (page 73), *mp.form* (page 71), *mp.nm_element* (page 107).

Constructor Summary

net_model_acp()

Constructor, assign default network model element classes.

```
nm = net_model_acp()
```

This network model class and all of its network model element classes are specific to the AC polar formulation and therefore inherit from *mp.form_acp* (page 86).

Method Summary

def_set_types()

Add voltage state variable set types for mp_idx_manager.

```
nm.def_set_types()
```

Add the following set types:
- 'va' - VOLTAGE ANG VARS (va)
- 'vm' - VOLTAGE MAG VARS (vm)

See also *mp.net_model_ac.def_set_types()* (page 101), *mp.net_model.def_set_types()* (page 94), mp_idx_manager.

initial_voltage_angle(*idx*)

Get vector of initial node voltage angles.

```
va = nm.initial_voltage_angle()
va = nm.initial_voltage_angle(idx)
```

Get vector of initial node voltage angles for all or a selected subset of nodes.

Input

idx (*integer*) – index of subset of voltages of interest; if missing or empty, include all

Output

va (*double*) – vector of initial voltage angles

mp.net_model_dc

class mp.**net_model_dc**

Bases: *mp.net_model* (page 90), *mp.form_dc* (page 88)

mp.net_model_dc (page 106) - Concrete class for MATPOWER DC **network model** objects.

This network model class and all of its network model element classes are specific to the DC formulation and therefore inherit from *mp.form_dc* (page 88).

mp.net_model_dc Properties:

- *va* (page 107) - vector of voltage states (voltage angles $\boldsymbol{\theta}$)
- *z* (page 107) - vector of non-voltage states $\boldsymbol{z}$

mp.net_model_dc Methods:

- *net_model_dc()* (page 106) - constructor, assign default network model element classes
- *def_set_types()* (page 107) - add voltage and non-voltage variable set types for mp_idx_manager
- *build_params()* (page 107) - build incidence matrices, parameters, add ports for each element
- *port_inj_soln()* (page 107) - compute the network port injections at the solution

See also *mp.net_model* (page 90), *mp.form_dc* (page 88), *mp.form* (page 71), *mp.nm_element* (page 107).

Constructor Summary

net_model_dc()

Constructor, assign default network model element classes.

```
nm = net_model_dc()
```

This network model class and all of its network model element classes are specific to the DC formulation and therefore inherit from *mp.form_dc* (page 88).

Property Summary

`va = []`

(double) vector of voltage states (voltage angles θ)

`z = []`

(double) vector of non-voltage states z

Method Summary

`def_set_types()`

Add voltage and non-voltage variable set types for `mp_idx_manager`.

```
nm.def_set_types()
```

Add the following set types:
- `'va'` - VOLTAGE VARS (va)
- `'z'` - NON-VOLTAGE VARS (z)

See also *mp.net_model.def_set_types()* (page 94), `mp_idx_manager`.

`build_params(nm, dm)`

Build incidence matrices and parameters, and add ports for each element.

```
nm.build_params(nm, dm)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object

Call the parent method to do `most()` of the work, then build the aggregate network model parameters.

`port_inj_soln()`

Compute the network port injections at the solution.

```
nm.port_inj_soln()
```

Takes the solved network state, computes the port power injections, and saves them in `nm.soln.gp`.

3.4.2 Elements

mp.nm_element

`class mp.nm_element`

Bases: `handle`

mp.nm_element (page 107) - Abstract base class for MATPOWER **network model element** objects.

A network model element object encapsulates all of the network model parameters for a particular element type. All network model element classes inherit from *mp.nm_element* (page 107) and also, like the container, from a formulation-specific subclass of *mp.form* (page 71). Each element type typically implements its own subclasses, which are further subclassed per formulation. A given network model element object contains the aggregate network model parameters for all online instances of that element type, stored in the set of matrices and vectors that correspond to the formulation.

By convention, network model element variables are named `nme` and network model element class names begin with `mp.nme`.

mp.mm_element Properties:

- *nk* (page 108) - number of elements of this type
- *C* (page 108) - stacked sparse element-node incidence matrices
- *D* (page 109) - stacked sparse incidence matrices for z-variables
- *soln* (page 109) - struct for storing solved states, quantities

mp.mm_element Methods:

- *name()* (page 109) - get name of element type, e.g. `'bus'`, `'gen'`
- *np()* (page 109) - number of ports per element of this type
- *nn()* (page 109) - number of nodes per element, created by this element type
- *nz()* (page 109) - number of non-voltage state variables per element of this type
- *data_model_element()* (page 109) - get the corresponding data model element
- *math_model_element()* (page 110) - get the corresponding math model element
- *count()* (page 110) - get number of online elements in `dm`, set `nk`
- *add_nodes()* (page 110) - add nodes to network model
- *add_states()* (page 110) - add non-voltage states to network model
- *add_vvars()* (page 110) - add real-valued voltage variables to network object
- *add_zvars()* (page 111) - add real-valued non-voltage state variables to network object
- *build_params()* (page 111) - build model parameters from data model
- *get_nv_()* (page 111) - get number of *(possibly complex)* voltage variables
- *x2vz()* (page 111) - get port voltages and non-voltage states from combined state vector
- *node_indices()* (page 112) - construct node indices from data model element connection info
- *incidence_matrix()* (page 112) - construct stacked incidence matrix from set of index vectors
- *node_types()* (page 113) - get node type information
- *set_node_type_ref()* (page 113) - make the specified node a reference node
- *set_node_type_pv()* (page 113) - make the specified node a PV node
- *set_node_type_pq()* (page 114) - make the specified node a PQ node
- *display()* (page 114) - display the network model element object

See the sec_nm_element section in the *MATPOWER Developer's Manual* for more information.

See also *mp.net_model* (page 90).

Property Summary

`nk = 0`

(integer) number of elements of this type

`C = []`

(sparse integer matrix) stacked element-node incidence matrices, where `C(i,kk)` is 1 if port *j* of element *k* is connected to node *i*, and `kk = k + (j-1)*np`

`D = []`

(sparse integer matrix) stacked incidence matrices for *z*-variables (non-voltage state variables), where `D(i,kk)` is 1 if *z*-variable *j* of element *k* is the *i*-th system *z*-variable and `kk = k + (j-1)*nz`

`soln`

(struct) for storing solved states, quantities

Method Summary

`name()`

Get name of element type, e.g. `'bus'`, `'gen'`.

```
name = nme.name()
```

Output
name (*char array*) – name of element type, must be a valid struct field name

Implementation provided by an element type specific subclass.

`np()`

Number of ports per element of this type.

```
np = nme.np()
```

Output
np (*integer*) – number of ports per element of this type

`nn()`

Number of nodes per element, created by this element type.

```
nn = nme.nn()
```

Output
nn (*integer*) – number of ports per element of this type

`nz()`

Number of non-voltage state variables per element of this type.

```
nz = nme.nz()
```

Output
nz (*integer*) – number of non-voltage state variables per element of this type

`data_model_element(dm, name)`

Get the corresponding data model element.

```
dme = nme.data_model_element(dm)
dme = nme.data_model_element(dm, name)
```

Inputs
- **dm** (*mp.data_model* (page 27)) – data model object
- **name** (*char array*) – *(optional)* name of element type *(default is name of this object)*

Output
dme (*mp.dm_element* (page 35)) – data model element object

`math_model_element`(*mm*, *name*)

Get the corresponding math model element.

```
mme = nme.math_model_element(mm)
mme = nme.math_model_element(mm, name)
```

Inputs
- **mm** (*mp.math_model* (page 121)) – math model object
- **name** (*char array*) – *(optional)* name of element type *(default is name of this object)*

Output
mme (*mp.mm_element* (page 143)) – math model element object

`count`(*dm*)

Get number of online elements of this type in `dm`, set `nk`.

```
nk = nme.count(dm)
```

Input
dm (*mp.data_model* (page 27)) – data model object

Output
nk (*integer*) – number of online elements of this type

`add_nodes`(*nm*, *dm*)

Add nodes to network model for this element.

```
nme.add_nodes(nm, dm)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object

Add nodes to the network model object, based on value *nn* returned by *nn()* (page 109). Calls the network model's *add_node()* (page 95) *nn* times.

`add_states`(*nm*, *dm*)

Add non-voltage states to network model for this element.

```
nme.add_states(nm, dm)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object

Add non-voltage states to the network model object, based on value *nz* returned by *nz()* (page 109). Calls the network model's *add_state()* (page 95) *nz* times.

`add_vvars`(*nm*, *dm*, *idx*)

Add real-valued voltage variables to network object.

```
nme.add_vvars(nm, dm, idx)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object

Add real-valued voltage variables (*v*-variables) to the network model object, for each port. Implementation depends on the specific formulation (i.e. subclass of *mp.form* (page 71)).

For example, consider an element with *np* ports and an AC formulation with polar voltage representation. The actual port voltages are complex, but this method would call the network model's *add_var()* (page 96) twice for each port, once for the voltage angle variables and once for the voltage magnitude variables.

Implemented by a formulation-specific subclass.

add_zvars(*nm*, *dm*, *idx*)

Add real-valued non-voltage state variables to network object.

```
nme.add_zvars(nm, dm, idx)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **idx** (*cell array*) – indices for named and indexed variables

Add real-valued non-voltage state variables (z-variables) to the network model object. Implementation depends on the specific formulation (i.e. subclass of *mp.form* (page 71)).

For example, consider an element with *nz* z-variables and a formulation in which these are complex. This method would call the network model's *add_var()* (page 96) twice for each complex z-variable, once for the variables representing the real part and once for the imaginary part.

Implemented by a formulation-specific subclass.

build_params(*nm*, *dm*)

Build model parameters from data model.

```
nme.build_params(nm, dm)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object

Construction of incidence matrices `C` and `D` are handled in this base class. Building of the formulation-specific model parameters must be implemented by a formulation-specific subclass. The subclass should call its parent in order to construct the incidence matrices.

See also *incidence_matrix()* (page 112), *node_indices()* (page 112).

get_nv_(*sysx*)

Get number of *(possibly complex)* voltage variables.

```
nv_ = nme.get_nv_(sysx)
```

Input

sysx (*boolean*) – if true the state `x_` refers to the full *(possibly complex)* system state *(all node voltages and system non-voltage states)*, otherwise it is the state vector for this specific element type *(port voltages and element non-voltage states)*

Output

nv_ (*integer*) – number of *(possibly complex)* voltage variables in the state variable `x_`, whose meaning depends on the `sysx` input

x2vz(*x_*, *sysx*, *idx*)

Get port voltages and non-voltage states from combined state vector.

```
[v_, z_, vi_] = nme.x2vz(x_, sysx, idx)
```

Inputs
- **x_** (*double*) – *possibly complex* state vector
- **sysx** (*boolean*) – if true the state `x_` refers to the full *(possibly complex)* system state *(all node voltages and system non-voltage states)*, otherwise it is the state vector for this specific element type *(port voltages and element non-voltage states)*
- **idx** (*integer*) – vector of port indices of interest

Outputs
- **v_** (*double*) – vector of *(possibly complex)* port voltages
- **z_** (*double*) – vector of *(possibly complex)* non-voltage state variables
- **vi_** (*double*) – vector of *(possibly complex)* port voltages for selected ports only, as indexed by `idx`

This method extracts voltage and non-voltage states from a combined state vector, optionally with voltages for specific ports only.

Note, that this method can operate on multiple state vectors simultaneously, by specifying `x_` as a matrix. In this case, each output will have the same number of columns, one for each column of the input `x_`.

node_indices(*nm*, *dm*, *cxn_type*, *cxn_idx_prop*, *cxn_type_prop*)

Construct node indices from data model element connection info.

```
nidxs = nme.node_indices(nm, dm)
nidxs = nme.node_indices(nm, dm, cxn_type, cxn_idx_prop)
nidxs = nme.node_indices(nm, dm, cxn_type, cxn_idx_prop, cxn_type_prop)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **cxn_type** (*char array or cell array of char arrays*) – name(s) of type(s) of junction elements, i.e. node-creating elements (e.g. `'bus'`), to which this element connects; see *mp.dm_element.cxn_type()* (page 38) for more info
- **cxn_idx_prop** (*char array or cell array of char arrays*) – name(s) of property(ies) containing indices of junction elements that define connections (e.g. `{'fbus', 'tbus'}`); see *mp.dm_element.cxn_idx_prop()* (page 38) for more info
- **cxn_type_prop** (*char array or cell array of char arrays*) – name(s) of properties containing type of junction elements for each connection, defaults to `''` if `cxn_type` and `cxn_type_prop` are provided, but not `cxn_type_prop`; see *mp.dm_element.cxn_type_prop()* (page 39) for more info

Output
nidxs (*cell array*) – 1 x *np* cell array of node index vectors for each port

This method constructs the node index vectors for each port. That is, element *p* of `nidxs` is the vector of indices of the nodes to which port *p* of these elements are connected. These node indices can be used to construct the element-node incidence matrices that form `C`.

By default, the connection information is obtained from the corresponding data model element, as described in the sec_dm_element_cxn section in the *MATPOWER Developer's Manual*.

See also *incidence_matrix()* (page 112), *mp.dm_element.cxn_type()* (page 38), *mp.dm_element.cxn_idx_prop()* (page 38), *mp.dm_element.cxn_type_prop()* (page 39).

incidence_matrix(*m*, *varargin*)

Construct stacked incidence matrix from set of index vectors.

```
CD = nme.incidence_matrix(m, idx1, idx2, ...)
```

Inputs
- **m** (*integer*) – total number of nodes or states
- **idx1** (*integer*) – index vector for nodes corresponding to this element's first port, or state variables corresponding to this element's first non-voltage state
- **idx2** (*integer*) – same as `idx1` for second port or non-voltage state, and so on

Output

CD (*sparse matrix*) – stacked incidence matrix (`C` for ports, `D` for states)

Forms an *m* x *n* incidence matrix for each input index vector `idx`, where *n* is the dimension of `idx`, and column `j` of the corresponding incidence matrix consists of all zeros with a 1 in row `idx(j)`.

These incidence matrices are then stacked horizontally to form a single matrix return value.

node_types(*nm*, *dm*, *idx*)

Get node type information.

```
ntv           = nme.node_types(nm, dm)
[ref, pv, pq] = nme.node_types(nm, dm)
          ... = nme.node_types(nm, dm, idx)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **idx** (*integer*) – index *(not used in base method)*

Outputs
- **ntv** (*integer*) – node type vector, valid element values are:
  - *mp.NODE_TYPE.REF* (page 169)
  - *mp.NODE_TYPE.PV* (page 169)
  - *mp.NODE_TYPE.PQ* (page 169)
- **ref** (*integer*) – vector of indices of reference nodes
- **pv** (*integer*) – vector of indices of PV nodes
- **pq** (*integer*) – vector of indices of PQ nodes

See also *mp.NODE_TYPE* (page 169).

set_node_type_ref(*dm*, *idx*)

Make the specified node a reference node.

```
nme.set_node_type_ref(dm, idx)
```

Inputs
- **dm** (*mp.data_model* (page 27)) – data model object
- **idx** (*integer*) – index of node to modify, this is the internal network model element index

Set the specified node to type *mp.NODE_TYPE.REF* (page 169).

Implementation provided by node-creating subclass.

set_node_type_pv(*dm*, *idx*)

Make the specified node a PV node.

```
nme.set_node_type_pv(dm, idx)
```

Inputs
- **dm** (*mp.data_model* (page 27)) – data model object
- **idx** (*integer*) – index of node to modify, this is the internal network model element index

Set the specified node to type *mp.NODE_TYPE.PV* (page 169).

Implementation provided by node-creating subclass.

set_node_type_pq(*dm*, *idx*)

Make the specified node a PQ node.

```
nme.set_node_type_pq(dm, idx)
```

Inputs

- **dm** (*mp.data_model* (page 27)) – data model object
- **idx** (*integer*) – index of node to modify, this is the internal network model element index

Set the specified node to type *mp.NODE_TYPE.PQ* (page 169).

Implementation provided by node-creating subclass.

display()

Display the network model element object.

This method is called automatically when omitting a semicolon on a line that retuns an object of this class.

Displays the details of the elements, including total number of elements, nodes per element, ports per element, non-voltage state per element, formulation name, tag, and class, and names and dimensions of the model parameters.

mp.nme_branch

class mp.**nme_branch**

Bases: *mp.nm_element* (page 107)

mp.nme_branch (page 114) - Network model element abstract base class for branch.

Implements the network model element for branch elements, including transmission lines and transformers, with 2 ports per branch.

Method Summary

name()

np()

mp.nme_branch_ac

class mp.**nme_branch_ac**

Bases: *mp.nme_branch* (page 114)

mp.nme_branch_ac (page 114) - Network model element abstract base class for branch for AC formulations.

Implements building of the admittance parameter $\underline{\mathbf{Y}}$ for branches.

Method Summary

build_params(*nm*, *dm*)

Builds the admittance parameter $\underline{\mathbf{Y}}$ for branches.

mp.nme_branch_acc

class mp.**nme_branch_acc**

Bases: *mp.nme_branch_ac* (page 114), *mp.form_acc* (page 82)

mp.nme_branch_acc (page 115) - Network model element for branch for AC cartesian voltage formulations.

Implements functions for the voltage angle difference limits and their derivatives and inherits from *mp.form_acc* (page 82).

Method Summary

ang_diff_fcn(*xx*, *Aang*, *lang*, *uang*)

ang_diff_hess(*xx*, *lambda*, *Aang*)

mp.nme_branch_acp

class mp.**nme_branch_acp**

Bases: *mp.nme_branch_ac* (page 114), *mp.form_acp* (page 86)

mp.nme_branch_acp (page 115) - Network model element for branch for AC polar voltage formulations.

Inherits from *mp.form_acp* (page 86).

mp.nme_branch_dc

class mp.**nme_branch_dc**

Bases: *mp.nme_branch* (page 114), *mp.form_dc* (page 88)

mp.nme_branch_dc (page 115) - Network model element for branch for DC formulations.

Implements building of the branch parameters $\underline{\boldsymbol{B}}$ and $\underline{\boldsymbol{p}}$, and inherits from *mp.form_dc* (page 88).

Method Summary

build_params(*nm*, *dm*)

mp.nme_bus

class mp.**nme_bus**

Bases: *mp.nm_element* (page 107)

mp.nme_bus (page 116) - Network model element abstract base class for bus.

Implements the network model element for bus elements, with 1 node per bus.

Implements node type methods.

Method Summary

name()

nn()

node_types(*nm*, *dm*, *idx*)

set_node_type_ref(*nm*, *dm*, *idx*)

set_node_type_pv(*nm*, *dm*, *idx*)

set_node_type_pq(*nm*, *dm*, *idx*)

mp.nme_bus_acc

class mp.**nme_bus_acc**

Bases: *mp.nme_bus* (page 116), *mp.form_acc* (page 82)

mp.nme_bus_acc (page 116) - Network model element for bus for AC cartesian voltage formulations.

Adds voltage variables `Vr` and `Vi` to the network model and inherits from *mp.form_acc* (page 82).

Method Summary

add_vvars(*nm*, *dm*, *idx*)

mp.nme_bus_acp

class mp.**nme_bus_acp**

Bases: *mp.nme_bus* (page 116), *mp.form_acp* (page 86)

mp.nme_bus_acp (page 116) - Network model element for bus for AC cartesian polar formulations.

Adds voltage variables `Va` and `Vm` to the network model and inherits from *mp.form_acp* (page 86).

Method Summary

add_vvars(*nm*, *dm*, *idx*)

mp.nme_bus_dc

class mp.**nme_bus_dc**

Bases: *mp.nme_bus* (page 116), *mp.form_dc* (page 88)

mp.nme_bus_dc (page 117) - Network model element for bus for DC formulations.

Adds voltage variable `Va` to the network model and inherits from *mp.form_dc* (page 88).

Method Summary

add_vvars(*nm*, *dm*, *idx*)

mp.nme_gen

class mp.**nme_gen**

Bases: *mp.nm_element* (page 107)

mp.nme_gen (page 117) - Network model element abstract base class for generator.

Implements the network model element for generator elements, with 1 port and 1 non-voltage state per generator.

Method Summary

name()

np()

nz()

mp.nme_gen_ac

class mp.**nme_gen_ac**

Bases: *mp.nme_gen* (page 117)

mp.nme_gen_ac (page 117) - Network model element abstract base class for generator for AC formulations.

Adds non-voltage state variables `Pg` and `Qg` to the network model and builds the parameter $\underline{\mathbf{N}}$.

Method Summary

add_zvars(*nm*, *dm*, *idx*)

build_params(*nm*, *dm*)

mp.nme_gen_acc

class mp.**nme_gen_acc**

Bases: *mp.nme_gen_ac* (page 117), *mp.form_acc* (page 82)

mp.nme_gen_acc (page 118) - Network model element for generator for AC cartesian voltage formulations.

Inherits from *mp.form_acc* (page 82).

mp.nme_gen_acp

class mp.**nme_gen_acp**

Bases: *mp.nme_gen_ac* (page 117), *mp.form_acp* (page 86)

mp.nme_gen_acp (page 118) - Network model element for generator for AC polar voltage formulations.

Inherits from *mp.form_acp* (page 86).

mp.nme_gen_dc

class mp.**nme_gen_dc**

Bases: *mp.nme_gen* (page 117), *mp.form_dc* (page 88)

mp.nme_gen_dc (page 118) - Network model element for generator for DC formulations.

Adds non-voltage state variable Pg to the network model, builds the parameter $\underline{\boldsymbol{K}}$, and inherits from *mp.form_dc* (page 88).

Method Summary

add_zvars(*nm*, *dm*, *idx*)

build_params(*nm*, *dm*)

mp.nme_load

class mp.**nme_load**

Bases: *mp.nm_element* (page 107)

mp.nme_load (page 118) - Network model element abstract base class for load.

Implements the network model element for load elements, with 1 port per load.

Method Summary

name()

np()

mp.nme_load_ac

class mp.**nme_load_ac**

Bases: *mp.nme_load* (page 118)

mp.nme_load_ac (page 119) - Network model element abstract base class for load for AC formulations.

Builds the parameters $\underline{\mathbf{s}}$ and $\underline{\mathbf{Y}}$ and nonlinear functions $\mathbf{s}^{nln}(\mathbf{x})$ and $\mathbf{i}^{nln}(\mathbf{x})$.

Method Summary

build_params(*nm*, *dm*)

port_inj_current_nln(*Sd*, *x_*, *sysx*, *idx*)

port_inj_power_nln(*Sd*, *x_*, *sysx*, *idx*)

mp.nme_load_acc

class mp.**nme_load_acc**

Bases: *mp.nme_load_ac* (page 119), *mp.form_acc* (page 82)

mp.nme_load_acc (page 119) - Network model element for load for AC cartesian voltage formulations.

Inherits from *mp.form_acc* (page 82).

mp.nme_load_acp

class mp.**nme_load_acp**

Bases: *mp.nme_load_ac* (page 119), *mp.form_acp* (page 86)

mp.nme_load_acp (page 119) - Network model element for load for AC polar voltage formulations.

Inherits from *mp.form_acp* (page 86).

mp.nme_load_dc

class mp.**nme_load_dc**

Bases: *mp.nme_load* (page 118), *mp.form_dc* (page 88)

mp.nme_load_dc (page 119) - Network model element for load for DC formulations.

Builds the parameter $\underline{\boldsymbol{p}}$ and inherits from *mp.form_dc* (page 88).

Method Summary

build_params(*nm*, *dm*)

mp.nme_shunt

class mp.**nme_shunt**

Bases: *mp.nm_element* (page 107)

mp.nme_shunt (page 120) - Network model element abstract base class for shunt.

Implements the network model element for shunt elements, with 1 port per shunt.

Method Summary

name()

np()

mp.nme_shunt_ac

class mp.**nme_shunt_ac**

Bases: *mp.nme_shunt* (page 120)

mp.nme_shunt_ac (page 120) - Network model element abstract base class for shunt for AC formulations.

Builds the parameter $\underline{\mathbf{Y}}$.

Method Summary

build_params(*nm*, *dm*)

mp.nme_shunt_acc

class mp.**nme_shunt_acc**

Bases: *mp.nme_shunt_ac* (page 120), *mp.form_acc* (page 82)

mp.nme_shunt_acc (page 120) - Network model element for shunt for AC cartesian voltage formulations.

Inherits from *mp.form_acc* (page 82).

mp.nme_shunt_acp

class mp.**nme_shunt_acp**

Bases: *mp.nme_shunt_ac* (page 120), *mp.form_acp* (page 86)

mp.nme_shunt_acp (page 120) - Network model element for shunt for AC polar voltage formulations.

Inherits from *mp.form_acp* (page 86).

mp.nme_shunt_dc

class mp.**nme_shunt_dc**

Bases: *mp.nme_shunt* (page 120), *mp.form_dc* (page 88)

mp.nme_shunt_dc (page 121) - Network model element for shunt for DC formulations.

Builds the parameter ***p*** and inherits from *mp.form_dc* (page 88).

Method Summary

build_params(*nm*, *dm*)

3.5 Mathematical Model Classes

3.5.1 Containers

mp.math_model

class mp.**math_model**

Bases: *mp.element_container* (page 165), opt_model

mp.math_model (page 121) - Abstract base class for MATPOWER **mathematical model** objects.

The mathematical model, or math model, formulates and defines the mathematical problem to be solved. That is, it determines the variables, constraints, and objective that define the problem. This takes on different forms depending on the task *(e.g. power flow, optimal power flow, etc.)* and the formulation *(e.g. DC, AC-polar-power, etc.)*.

A math model object is a container for math model element (*mp.mm_element* (page 143)) objects and it is also an MP-Opt-Model (opt_model) object. All math model classes inherit from *mp.math_model* (page 121) and therefore also from *mp.element_container* (page 165), opt_model, and mp_idx_manager. Concrete math model classes are task and formulation specific. They also sometimes inherit from abstract mix-in classes that are shared across tasks or formulations.

By convention, math model variables are named mm and math model class names begin with mp.math_model.

mp.math_model Properties:

- *aux_data* (page 122) - auxiliary data relevant to the model

mp.math_model Methods:

- *task_tag()* (page 122) - returns task tag, e.g. 'PF', 'OPF'
- *task_name()* (page 122) - returns task name, e.g. 'Power Flow', 'Optimal Power Flow'
- *form_tag()* (page 122) - returns network formulation tag, e.g. 'dc', 'acps'
- *form_name()* (page 122) - returns network formulation name, e.g. 'DC', 'AC-polar-power'
- *build()* (page 122) - create, add, and build math model element objects
- *display()* (page 123) - display the math model object
- *add_aux_data()* (page 123) - builds auxiliary data and adds it to the model

- *build_base_aux_data()* (page 123) - builds base auxiliary data, including node types & variable initial values
- *add_vars()* (page 123) - add variables to the model
- *add_system_vars()* (page 123) - add system variables to the model
- *add_constraints()* (page 124) - add constraints to the model
- *add_system_constraints()* (page 124) - add system constraints to the model
- *add_node_balance_constraints()* (page 124) - add node balance constraints to the model
- *add_costs()* (page 124) - add costs to the model
- *add_system_costs()* (page 125) - add system costs to the model
- *solve_opts()* (page 125) - return an options struct to pass to the solver
- *update_nm_vars()* (page 125) - update network model variables from math model solution
- *data_model_update()* (page 126) - update data model from math model solution
- *network_model_x_soln()* (page 126) - convert solved state from math model to network model solution

See the sec_math_model section in the *MATPOWER Developer's Manual* for more information.

See also *mp.task* (page 7), *mp.data_model* (page 27), *mp.net_model* (page 90).

Property Summary

aux_data

(struct) auxiliary data relevant to the model, e.g. can be passed to model constraint functions

Method Summary

task_tag()

Returns task tag, e.g. `'PF'`, `'OPF'`.

```
tag = mm.task_tag()
```

task_name()

Returns task name, e.g. `'Power Flow'`, `'Optimal Power Flow'`.

```
name = mm.task_name()
```

form_tag()

Returns network formulation tag, e.g. `'dc'`, `'acps'`.

```
tag = mm.form_tag()
```

form_name()

Returns network formulation name, e.g. `'DC'`, `'AC-polar-power'`.

```
name = mm.form_name()
```

build(*nm*, *dm*, *mpopt*)

Create, add, and *build()* (page 122) math model element objects.

```
mm.build(nm, dm, mpopt);
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Create and add network model objects, create and add auxiliary data, and add variables, constraints, and costs.

display()

Display the math model object.

This method is called automatically when omitting a semicolon on a line that retuns an object of this class.

Displays the details of the variables, constraints, costs, and math model elements.

See also `mp_idx_manager`.

add_aux_data(*nm*, *dm*, *mpopt*)

Builds auxiliary data and adds it to the model.

```
mm.add_aux_data(nm, dm, mpopt)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Calls the build_aux_data() method and assigns the result to the `aux_data` property. The base build_aux_data() method, which simply calls *build_base_aux_data()* (page 123), is defined in *mp.mm_shared_pfcpf* (page 138) (and in *mp.math_model_opf* (page 131)) allowing it to be shared across math models for different tasks (PF and CPF).

build_base_aux_data(*nm*, *dm*, *mpopt*)

Builds base auxiliary data, including node types & variable initial values.

```
ad = mm.build_base_aux_data(nm, dm, mpopt)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Output
ad (*struct*) – struct of auxiliary data

add_vars(*nm*, *dm*, *mpopt*)

Add variables to the model.

```
mm.add_vars(nm, dm, mpopt)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Adds system variables, then calls the *add_vars()* (page 144) method for each math model element.

add_system_vars(*nm*, *dm*, *mpopt*)

Add system variables to the model.

```
mm.add_system_vars(nm, dm, mpopt)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Variables which correspond to a specific math model element should be added by that element's *add_vars()* (page 144) method. Other variables can be added by *add_system_vars()* (page 123). In this base class this method does nothing.

add_constraints(*nm*, *dm*, *mpopt*)

Add constraints to the model.

```
mm.add_constraints(nm, dm, mpopt)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Adds system constraints, then calls the *add_constraints()* (page 144) method for each math model element.

add_system_constraints(*nm*, *dm*, *mpopt*)

Add system constraints to the model.

```
mm.add_system_constraints(nm, dm, mpopt)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Constraints which correspond to a specific math model element should be added by that element's *add_constraints()* (page 144) method. Other constraints can be added by *add_system_constraints()* (page 124). In this base class, it simply calls *add_node_balance_constraints()* (page 124).

add_node_balance_constraints(*nm*, *dm*, *mpopt*)

Add node balance constraints to the model.

```
mm.add_node_balance_constraints(nm, dm, mpopt)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

In this base class this method does nothing.

add_costs(*nm*, *dm*, *mpopt*)

Add costs to the model.

```
mm.add_costs(nm, dm, mpopt)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Adds system costs, then calls the *add_costs()* (page 145) method for each math model element.

add_system_costs(*nm*, *dm*, *mpopt*)

Add system costs to the model.

```
mm.add_system_costs(nm, dm, mpopt)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Costs which correspond to a specific math model element should be added by that element's *add_costs()* (page 145) method. Other variables can be added by *add_system_costs()* (page 125). In this base class this method does nothing.

solve_opts(*nm*, *dm*, *mpopt*)

Return an options struct to pass to the solver.

```
opt = mm.solve_opts(nm, dm, mpopt)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Output
opt (*struct*) – options struct for solver

In this base class, returns an empty struct.

update_nm_vars(*mmx*, *nm*)

Update network model variables from math model solution.

```
nm_vars = mm.update_nm_vars(mmx, nm)
```

Inputs
- **mmx** (*double*) – vector of math model variable `x`
- **nm** (*mp.net_model* (page 90)) – network model object

Output
nm_vars (*struct*) – updated network model variables

Returns a struct with the network model variables as fields. The `mm.aux_data.var_map` cell array is used to track mappings of math model variables back to network model variables. Each entry is itself a 7-element cell array of the form

```
{nm_var_type, nm_i1, nm_iN, nm_idx, mm_i1, mm_iN, mm_idx}
```

where
- `nm_var_type` - network model variable type (e.g. `va`, `vm`, `zr`, `zi`)
- `nm_i1` - starting index for network model variable type
- `nm_iN` - ending index for network model variable type

- nm_idx - vector of indices for network model variable type
- mm_i1 - starting index for math model variable
- mm_iN - ending index for math model variable
- mm_idx - vector of indices for math model variable

Uses either i1:iN (if i1 is not empty) or idx as the indices, unless both are empty, in which case it uses ':'.

data_model_update(*nm*, *dm*, *mpopt*)

Update data model from math model solution.

```
dm = mm.data_model_update(nm, dm, mpopt)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Output
dm (*mp.data_model* (page 27)) – updated data model object

Calls the *data_model_update()* (page 145) method for each math model element.

network_model_x_soln(*nm*)

Convert solved state from math model to network model solution.

```
nm = mm.network_model_x_soln(nm)
```

Input
nm (*mp.net_model* (page 90)) – network model object

Output
nm (*mp.net_model* (page 90)) – updated network model object

Calls convert_x_m2n() to which is defined in a subclass of in *mp.mm_shared_pfcpf* (page 138) (and of *mp.math_model_opf* (page 131)) allowing it to be shared across math models for different tasks (PF and CPF).

mp.math_model_pf

class mp.**math_model_pf**

Bases: *mp.math_model* (page 121)

mp.math_model_pf (page 126) - Abstract base class for power flow (PF) **math model** objects.

Implements setting up of solver options from MATPOWER options struct.

Method Summary

task_tag()

task_name()

add_costs(*nm*, *dm*, *mpopt*)

add_system_vars(*nm*, *dm*, *mpopt*)

solve_opts(*nm*, *dm*, *mpopt*)

mp.math_model_pf_ac

class mp.**math_model_pf_ac**

Bases: *mp.math_model_pf* (page 126)

mp.math_model_pf_ac (page 127) - Power flow (PF) **math model** for AC formulations.

Provides AC-specific and PF-specific subclasses for elements.

Constructor Summary

math_model_pf_ac()

mp.math_model_pf_acci

class mp.**math_model_pf_acci**

Bases: *mp.math_model_pf_ac* (page 127), *mp.mm_shared_pfcpf_acci* (page 140)

mp.math_model_pf_acci (page 127) - Power flow (PF) **math model** for AC-cartesian-current formulation.

Implements formulation-specific node balance constraints and inherits from formulation-specific class for shared PF/CPF code.

Method Summary

form_tag()

form_name()

add_node_balance_constraints(*nm*, *dm*, *mpopt*)

mp.math_model_pf_accs

class mp.**math_model_pf_accs**

Bases: *mp.math_model_pf_ac* (page 127), *mp.mm_shared_pfcpf_accs* (page 140)

mp.math_model_pf_accs (page 127) - Power flow (PF) **math model** for AC-cartesian-power formulation.

Implements formulation-specific node balance constraints and inherits from formulation-specific class for shared PF/CPF code.

Method Summary

form_tag()

form_name()

add_node_balance_constraints(*nm*, *dm*, *mpopt*)

mp.math_model_pf_acpi

class mp.**math_model_pf_acpi**

Bases: *mp.math_model_pf_ac* (page 127), *mp.mm_shared_pfcpf_acpi* (page 141)

mp.math_model_pf_acpi (page 128) - Power flow (PF) **math model** for AC-polar-current formulation.

Implements formulation-specific node balance constraints and inherits from formulation-specific class for shared PF/CPF code.

Method Summary

form_tag()

form_name()

add_node_balance_constraints(*nm*, *dm*, *mpopt*)

mp.math_model_pf_acps

class mp.**math_model_pf_acps**

Bases: *mp.math_model_pf_ac* (page 127), *mp.mm_shared_pfcpf_acps* (page 141)

mp.math_model_pf_acps (page 128) - Power flow (PF) **math model** for AC-polar-power formulation.

Implements formulation-specific node balance constraints and inherits from formulation-specific class for shared PF/CPF code.

Also includes implementations of methods specific to fast-decoupled power flow.

Method Summary

form_tag()

form_name()

add_node_balance_constraints(*nm*, *dm*, *mpopt*)

gs_x_update(*x*, *f*, *nm*, *dm*, *mpopt*)

zg_x_update(*x*, *f*, *nm*, *dm*, *mpopt*)

fd_jac_approx(*nm*, *dm*, *mpopt*)

fdpf_B_matrix_models(*dm*, *alg*)

mp.math_model_pf_dc

class mp.**math_model_pf_dc**

Bases: *mp.math_model_pf* (page 126), *mp.mm_shared_pfcpf_dc* (page 141)

mp.math_model_pf_dc (page 129) - Power flow (PF) **math model** for DC formulation.

Provides formulation-specific and PF-specific subclasses for elements and implements formulation-specific node balance constraints.

Overrides the default *solve_opts()* (page 129) method.

Constructor Summary

math_model_pf_dc()

Method Summary

form_tag()

form_name()

add_node_balance_constraints(*nm*, *dm*, *mpopt*)

solve_opts(*nm*, *dm*, *mpopt*)

mp.math_model_cpf_acc

class mp.**math_model_cpf_acc**

Bases: mp.math_model_cpf

mp.math_model_cpf_acc (page 129) - Abstract base class for AC cartesian CPF **math model** objects.

Provides formulation-specific and CPF-specific subclasses for elements.

Constructor Summary

math_model_cpf_acc()

Constructor, assign default network model element classes.

```
mm = math_model_cpf_acc()
```

mp.math_model_cpf_acci

class mp.**math_model_cpf_acci**

Bases: *mp.math_model_cpf_acc* (page 129), *mp.mm_shared_pfcpf_acci* (page 140)

mp.math_model_cpf_acci (page 129) - CPF **math model** for AC-cartesian-current formulation.

Implements formulation-specific and CPF-specific node balance constraint.

Method Summary

form_tag()

form_name()

add_node_balance_constraints(*nm*, *dm*, *mpopt*)

mp.math_model_cpf_accs

class mp.**math_model_cpf_accs**

Bases: *mp.math_model_cpf_acc* (page 129), *mp.mm_shared_pfcpf_accs* (page 140)

mp.math_model_cpf_accs (page 130) - CPF **math model** for AC-cartesian-power formulation.

Implements formulation-specific and CPF-specific node balance constraint.

Method Summary

form_tag()

form_name()

add_node_balance_constraints(*nm*, *dm*, *mpopt*)

mp.math_model_cpf_acp

class mp.**math_model_cpf_acp**

Bases: mp.math_model_cpf

mp.math_model_cpf_acp (page 130) - Abstract base class for AC polar CPF **math model** objects.

Provides formulation-specific and CPF-specific subclasses for elements and implementations of event and callback functions for handling voltage limits.

Constructor Summary

math_model_cpf_acp()

Constructor, assign default network model element classes.

```
mm = math_model_cpf_acp()
```

Method Summary

event_vlim(*cx*, *opt*, *nm*, *dm*, *mpopt*)

callback_vlim(*k*, *nx*, *cx*, *px*, *s*, *opt*, *nm*, *dm*, *mpopt*)

mp.math_model_cpf_acpi

class mp.**math_model_cpf_acpi**

Bases: *mp.math_model_cpf_acp* (page 130), *mp.mm_shared_pfcpf_acpi* (page 141)

mp.math_model_cpf_acpi (page 131) - CPF **math model** for AC-polar-current formulation.

Implements formulation-specific and CPF-specific node balance constraint.

Method Summary

form_tag()

form_name()

add_node_balance_constraints(*nm*, *dm*, *mpopt*)

mp.math_model_cpf_acps

class mp.**math_model_cpf_acps**

Bases: *mp.math_model_cpf_acp* (page 130), *mp.mm_shared_pfcpf_acps* (page 141)

mp.math_model_cpf_acps (page 131) - CPF **math model** for AC-polar-power formulation.

Implements formulation-specific and CPF-specific node balance constraint.

Provides methods for warm-starting solver with updated data.

Method Summary

form_tag()

form_name()

add_node_balance_constraints(*nm*, *dm*, *mpopt*)

expand_z_warmstart(*nm*, *ad*, *varargin*)

solve_opts_warmstart(*opt*, *ws*, *nm*)

mp.math_model_opf

class mp.**math_model_opf**

Bases: *mp.math_model* (page 121)

mp.math_model_opf (page 131) - Abstract base class for optimal power flow (OPF) **math model** objects.

Provide implementations for adding system variables to the mathematical model and creating an interior starting point.

Method Summary

task_tag()

task_name()

build_aux_data(*nm*, *dm*, *mpopt*)

add_system_vars(*nm*, *dm*, *mpopt*)

interior_x0(*mm*, *nm*, *dm*, *x0*)

interior_va(*nm*, *dm*)

mp.math_model_opf_ac

class mp.**math_model_opf_ac**

Bases: *mp.math_model_opf* (page 131)

mp.math_model_opf_ac (page 132) - Abstract base class for AC OPF **math model** objects.

Provide implementation of nodal current and power balance functions and their derivatives, and setup of solver options.

Method Summary

nodal_current_balance_fcn(*x*, *nm*)

nodal_power_balance_fcn(*x*, *nm*)

nodal_current_balance_hess(*x*, *lam*, *nm*)

nodal_power_balance_hess(*x*, *lam*, *nm*)

solve_opts(*nm*, *dm*, *mpopt*)

mp.math_model_opf_acc

class mp.**math_model_opf_acc**

Bases: *mp.math_model_opf_ac* (page 132)

mp.math_model_opf_acc (page 132) - Abstract base class for AC cartesian OPF **math model** objects.

Provides formulation-specific and OPF-specific subclasses for elements.

Implements *convert_x_m2n()* (page 132) to convert from math model state to network model state.

Constructor Summary

math_model_opf_acc()

Method Summary

convert_x_m2n(*mmx*, *nm*)

interior_va(*nm*, *dm*)

mp.math_model_opf_acci

class mp.**math_model_opf_acci**

Bases: *mp.math_model_opf_acc* (page 132)

mp.math_model_opf_acci (page 133) - OPF **math model** for AC-cartesian-current formulation.

Implements formulation-specific and OPF-specific node balance constraint and node balance price methods.

Method Summary

form_tag()

form_name()

add_node_balance_constraints(*nm*, *dm*, *mpopt*)

node_power_balance_prices(*nm*)

mp.math_model_opf_acci_legacy

class mp.**math_model_opf_acci_legacy**

Bases: *mp.math_model_opf_acci* (page 133), *mp.mm_shared_opf_legacy* (page 142)

mp.math_model_opf_acci_legacy (page 133) - OPF **math model** for AC-cartesian-current formulation w/legacy extensions.

Provides formluation-specific methods for handling legacy user customization of OPF problem.

Constructor Summary

math_model_opf_acci_legacy()

Method Summary

add_named_set(*varargin*)

def_set_types()

init_set_types()

build(*nm*, *dm*, *mpopt*)

add_vars(*nm*, *dm*, *mpopt*)

add_system_costs(*nm*, *dm*, *mpopt*)

add_system_constraints(*nm*, *dm*, *mpopt*)

legacy_user_var_names()

mp.math_model_opf_accs

class mp.**math_model_opf_accs**

Bases: *mp.math_model_opf_acc* (page 132)

mp.math_model_opf_accs (page 134) - OPF **math model** for AC-cartesian-power formulation.

Implements formulation-specific and OPF-specific node balance constraint and node balance price methods.

Method Summary

form_tag()

form_name()

add_node_balance_constraints(*nm*, *dm*, *mpopt*)

node_power_balance_prices(*nm*)

mp.math_model_opf_accs_legacy

class mp.**math_model_opf_accs_legacy**

Bases: *mp.math_model_opf_accs* (page 134), *mp.mm_shared_opf_legacy* (page 142)

mp.math_model_opf_accs_legacy (page 134) - OPF **math model** for AC-cartesian-power formulation w/legacy extensions.

Provides formluation-specific methods for handling legacy user customization of OPF problem.

Constructor Summary

math_model_opf_accs_legacy()

Method Summary

add_named_set(*varargin*)

def_set_types()

init_set_types()

build(*nm*, *dm*, *mpopt*)

add_vars(*nm*, *dm*, *mpopt*)

add_system_costs(*nm*, *dm*, *mpopt*)

add_system_constraints(*nm*, *dm*, *mpopt*)

legacy_user_var_names()

mp.math_model_opf_acp

class mp.**math_model_opf_acp**

Bases: *mp.math_model_opf_ac* (page 132)

mp.math_model_opf_acp (page 135) - Abstract base class for AC polar OPF **math model** objects.

Provides formulation-specific and OPF-specific subclasses for elements.

Implements *convert_x_m2n()* (page 135) to convert from math model state to network model state.

Constructor Summary

math_model_opf_acp()

Method Summary

convert_x_m2n(*mmx*, *nm*)

mp.math_model_opf_acpi

class mp.**math_model_opf_acpi**

Bases: *mp.math_model_opf_acp* (page 135)

mp.math_model_opf_acpi (page 135) - OPF **math model** for AC-polar-current formulation.

Implements formulation-specific and OPF-specific node balance constraint and node balance price methods.

Method Summary

form_tag()

form_name()

add_node_balance_constraints(*nm*, *dm*, *mpopt*)

node_power_balance_prices(*nm*)

mp.math_model_opf_acpi_legacy

class mp.**math_model_opf_acpi_legacy**

Bases: *mp.math_model_opf_acpi* (page 135), *mp.mm_shared_opf_legacy* (page 142)

mp.math_model_opf_acpi_legacy (page 135) - OPF **math model** for AC-polar-current formulation w/legacy extensions.

Provides formluation-specific methods for handling legacy user customization of OPF problem.

Constructor Summary

math_model_opf_acpi_legacy()

Method Summary

add_named_set(*varargin*)

def_set_types()

init_set_types()

build(*nm*, *dm*, *mpopt*)

add_vars(*nm*, *dm*, *mpopt*)

add_system_costs(*nm*, *dm*, *mpopt*)

add_system_constraints(*nm*, *dm*, *mpopt*)

legacy_user_var_names()

mp.math_model_opf_acps

class mp.**math_model_opf_acps**

Bases: *mp.math_model_opf_acp* (page 135)

mp.math_model_opf_acps (page 136) - OPF **math model** for AC-polar-power formulation.

Implements formulation-specific and OPF-specific node balance constraint and node balance price methods.

Method Summary

form_tag()

form_name()

add_node_balance_constraints(*nm*, *dm*, *mpopt*)

node_power_balance_prices(*nm*)

mp.math_model_opf_acps_legacy

class mp.**math_model_opf_acps_legacy**

Bases: *mp.math_model_opf_acps* (page 136), *mp.mm_shared_opf_legacy* (page 142)

mp.math_model_opf_acps_legacy (page 136) - OPF **math model** for AC-polar-power formulation w/legacy extensions.

Provides formluation-specific methods for handling legacy user customization of OPF problem.

Constructor Summary

math_model_opf_acps_legacy()

Method Summary

add_named_set(*varargin*)

def_set_types()

init_set_types()

build(*nm*, *dm*, *mpopt*)

add_vars(*nm*, *dm*, *mpopt*)

add_system_costs(*nm*, *dm*, *mpopt*)

add_system_constraints(*nm*, *dm*, *mpopt*)

legacy_user_var_names()

mp.math_model_opf_dc

class mp.**math_model_opf_dc**

Bases: *mp.math_model_opf* (page 131)

mp.math_model_opf_dc (page 137) - Optimal Power flow (OPF) **math model** for DC formulation.

Provides formulation-specific and OPF-specific subclasses for elements.

Provides implementation of nodal balance constraint method and setup of solver options.

Implements *convert_x_m2n()* (page 137) to convert from math model state to network model state.

Constructor Summary

math_model_opf_dc()

Method Summary

form_tag()

form_name()

convert_x_m2n(*mmx*, *nm*)

add_node_balance_constraints(*nm*, *dm*, *mpopt*)

solve_opts(*nm*, *dm*, *mpopt*)

mp.math_model_opf_dc_legacy

class mp.**math_model_opf_dc_legacy**

Bases: *mp.math_model_opf_dc* (page 137), *mp.mm_shared_opf_legacy* (page 142)

mp.math_model_opf_dc (page 137) - OPF **math model** for DC formulation w/legacy extensions.

Provides formluation-specific methods for handling legacy user customization of OPF problem.

Constructor Summary

math_model_opf_dc_legacy(*mpc*)

Method Summary

add_named_set(*varargin*)

def_set_types()

init_set_types()

build(*nm*, *dm*, *mpopt*)

add_vars(*nm*, *dm*, *mpopt*)

add_system_costs(*nm*, *dm*, *mpopt*)

add_system_constraints(*nm*, *dm*, *mpopt*)

legacy_user_var_names()

3.5.2 Container Mixins

mp.mm_shared_pfcpf

class mp.**mm_shared_pfcpf**

Bases: handle

mp.mm_shared_pfcpf (page 138) - Mixin class for PF/CPF **math model** objects.

An abstract mixin class inherited by all power flow (PF) and continuation power flow (CPF) **math model** objects.

Method Summary

build_aux_data(*nm*, *dm*, *mpopt*)

mp.mm_shared_pfcpf_ac

class mp.**mm_shared_pfcpf_ac**

Bases: *mp.mm_shared_pfcpf* (page 138)

mp.mm_shared_pfcpf_ac (page 138) - Mixin class for AC PF/CPF **math model** objects.

An abstract mixin class inherited by all AC power flow (PF) and continuation power flow (CPF) **math model** objects.

Method Summary

add_system_varset_pf(*nm*, *vvar*, *typ*)

update_z(*nm*, *v_*, *z_*, *ad*, *Sinj*, *idx*)

update_z() (page 138) - Update/allocate active/reactive injections at slack/PV nodes.

Update/allocate slack know active power injections and slack/PV node reactive power injections.

mp.mm_shared_pfcpf_ac_i

class mp.**mm_shared_pfcpf_ac_i**

Bases: handle

mp.mm_shared_pfcpf_ac_i (page 139) - Mixin class for AC-current PF/CPF **math model** objects.

An abstract mixin class inherited by all AC power flow (PF) and continuation power flow (CPF) **math model** objects that use a current balance formuation.

Code shared between AC cartesian and polar formulations with current balance belongs in this class.

Method Summary

build_aux_data_i(*nm*, *ad*)

mp.mm_shared_pfcpf_acc

class mp.**mm_shared_pfcpf_acc**

Bases: *mp.mm_shared_pfcpf_ac* (page 138)

mp.mm_shared_pfcpf_acc (page 139) - Mixin class for AC cartesian PF/CPF **math model** objects.

An abstract mixin class inherited by all AC power flow (PF) and continuation power flow (CPF) **math model** objects that use a cartesian voltage formuation.

Method Summary

convert_x_m2n(*mmx*, *nm*, *only_v*)

convert_x_m2n() (page 139) - Convert math model state to network model state.

```
x = mm.pf_convert(mmx, nm)
[v, z] = mm.pf_convert(mmx, nm)
[v, z, x] = mm.pf_convert(mmx, nm,)
 ... = mm.pf_convert(mmx, nm, only_v)
```

mp.mm_shared_pfcpf_acci

class mp.**mm_shared_pfcpf_acci**

Bases: *mp.mm_shared_pfcpf_acc* (page 139), *mp.mm_shared_pfcpf_ac_i* (page 139)

mp.mm_shared_pfcpf_acci (page 140) - Mixin class for AC-cartesian-current PF/CPF **math model** objects.

An abstract mixin class inherited by AC power flow (PF) and continuation power flow (CPF) **math model** objects that use a cartesian voltage and current balance formuation.

Method Summary

build_aux_data(*nm*, *dm*, *mpopt*)

add_system_vars_pf(*nm*, *dm*, *mpopt*)

node_balance_equations(*x*, *nm*)

mp.mm_shared_pfcpf_accs

class mp.**mm_shared_pfcpf_accs**

Bases: *mp.mm_shared_pfcpf_acc* (page 139)

mp.mm_shared_pfcpf_accs (page 140) - Mixin class for AC-cartesian-power PF/CPF **math model** objects.

An abstract mixin class inherited by AC power flow (PF) and continuation power flow (CPF) **math model** objects that use a cartesian voltage and power balance formuation.

Method Summary

add_system_vars_pf(*nm*, *dm*, *mpopt*)

node_balance_equations(*x*, *nm*)

mp.mm_shared_pfcpf_acp

class mp.**mm_shared_pfcpf_acp**

Bases: *mp.mm_shared_pfcpf_ac* (page 138)

mp.mm_shared_pfcpf_acp (page 140) - Mixin class for AC polar PF/CPF **math model** objects.

An abstract mixin class inherited by all AC power flow (PF) and continuation power flow (CPF) **math model** objects that use a polar voltage formuation.

Method Summary

convert_x_m2n(*mmx*, *nm*, *only_v*)

convert_x_m2n() (page 140) - Convert math model state to network model state.

```
x = mm.pf_convert(mmx, nm)
[v, z] = mm.pf_convert(mmx, nm)
[v, z, x] = mm.pf_convert(mmx, nm)
... = mm.pf_convert(mmx, nm, only_v)
```

mp.mm_shared_pfcpf_acpi

class mp.**mm_shared_pfcpf_acpi**

Bases: *mp.mm_shared_pfcpf_acp* (page 140), *mp.mm_shared_pfcpf_ac_i* (page 139)

mp.mm_shared_pfcpf_acpi (page 141) - Mixin class for AC-polar-current PF/CPF **math model** objects.

An abstract mixin class inherited by AC power flow (PF) and continuation power flow (CPF) **math model** objects that use a polar voltage and current balance formuation.

Method Summary

build_aux_data(*nm*, *dm*, *mpopt*)

add_system_vars_pf(*nm*, *dm*, *mpopt*)

node_balance_equations(*x*, *nm*)

mp.mm_shared_pfcpf_acps

class mp.**mm_shared_pfcpf_acps**

Bases: *mp.mm_shared_pfcpf_acp* (page 140)

mp.mm_shared_pfcpf_acps (page 141) - Mixin class for AC-polar-power PF/CPF **math model** objects.

An abstract mixin class inherited by AC power flow (PF) and continuation power flow (CPF) **math model** objects that use a polar voltage and power balance formuation.

Method Summary

build_aux_data(*nm*, *dm*, *mpopt*)

add_system_vars_pf(*nm*, *dm*, *mpopt*)

node_balance_equations(*x*, *nm*, *fdpf*)

mp.mm_shared_pfcpf_dc

class mp.**mm_shared_pfcpf_dc**

Bases: *mp.mm_shared_pfcpf* (page 138)

mp.mm_shared_pfcpf_dc (page 141) - Mixin class for DC power flow (PF) **math model** objects.

An abstract mixin class inherited by DC power flow (PF) **math model** objects.

Method Summary

build_aux_data(*nm*, *dm*, *mpopt*)

add_system_vars_pf(*nm*, *dm*, *mpopt*)

convert_x_m2n(*mmx*, *nm*, *only_v*)

convert_x_m2n() (page 142) - Convert math model state to network model state.

```
x = mm.pf_convert(mmx, nm)
[v, z] = mm.pf_convert(mmx, nm)
[v, z, x] = mm.pf_convert(mmx, nm)
... = mm.pf_convert(mmx, nm, only_v)
```

update_z(*nm*, *v*, *z*, *ad*)

update_z() (page 142) - Update/allocate slack node active power injections.

mp.mm_shared_opf_legacy

class mp.**mm_shared_opf_legacy**

Bases: handle

mp.mm_shared_opf_legacy (page 142) - Mixin class for legacy optimal power flow (OPF) **math model** objects.

An abstract mixin class inherited by optimal power flow (OPF) **math model** objects that need to handle legacy user customization mechanisms.

Method Summary

def_set_types_legacy()

init_set_types_legacy()

get_mpc(*om*)

build_legacy(*nm*, *dm*, *mpopt*)

add_legacy_user_vars(*nm*, *dm*, *mpopt*)

add_legacy_user_costs(*nm*, *dm*, *dc*)

add_legacy_user_constraints(*nm*, *dm*, *mpopt*)

add_legacy_user_constraints_ac(*nm*, *dm*, *mpopt*)

add_legacy_cost(*om*, *name*, *idx*, *varargin*)

add_legacy_cost() (page 142) - Add a set of user costs to the model

```
mm.add_legacy_cost(name, cp)
mm.add_legacy_cost(name, idx, varsets)
mm.add_legacy_cost(name, idx_list, cp)
mm.add_legacy_cost(name, idx_list, cp, varsets)
```

eval_legacy_cost(*om*, *x*, *name*, *idx*)

eval_legacy_cost() (page 142) - Evaluate individual or full set of legacy user costs.

```
f = mm.eval_legacy_cost(x ...)
[f, df] = mm.eval_legacy_cost(x ...)
[f, df, d2f] = mm.eval_legacy_cost(x ...)
[f, df, d2f] = mm.eval_legacy_cost(x, name)
[f, df, d2f] = mm.eval_legacy_cost(x, name, idx_list)
```

params_legacy_cost(*om*, *name*, *idx*)

params_legacy_cost() (page 143) - Return cost parameters for legacy user-defined costs.

```
cp = mm.params_legacy_cost()
cp = mm.params_legacy_cost(name)
cp = mm.params_legacy_cost(name, idx)
[cp, vs] = mm.params_legacy_cost(...)
[cp, vs, i1, iN] = mm.params_legacy_cost(...)
```

3.5.3 Elements

mp.mm_element

class mp.**mm_element**

Bases: handle

mp.mm_element (page 143) - Abstract base class for MATPOWER **mathematical model element** objects.

A math model element object typically does not contain any data, but only the methods that are used to build the math model and update the corresponding data model element once the math model has been solved.

All math model element classes inherit from *mp.mm_element* (page 143). Each element type typically implements its own subclasses, which are further subclassed where necessary per task and formulation, as with the container class.

By convention, math model element variables are named mme and math model element class names begin with mp.mme.

mp.mm_element Methods:

- *name()* (page 144) - get name of element type, e.g. 'bus', 'gen'
- *data_model_element()* (page 144) - get corresponding data model element
- *network_model_element()* (page 144) - get corresponding network model element
- *add_vars()* (page 144) - add math model variables for this element
- *add_constraints()* (page 144) - add math model constraints for this element
- *add_costs()* (page 145) - add math model costs for this element
- *data_model_update()* (page 145) - update the corresponding data model element
- *data_model_update_off()* (page 145) - update offline elements in corresponding data model element
- *data_model_update_on()* (page 145) - update online elements in corresponding data model element

See the sec_mm_element section in the *MATPOWER Developer's Manual* for more information.

See also *mp.math_model* (page 121).

Method Summary

name()

Get name of element type, e.g. `'bus'`, `'gen'`.

```
name = mme.name()
```

Output
name (*char array*) – name of element type, must be a valid struct field name

Implementation provided by an element type specific subclass.

data_model_element(*dm*, *name*)

Get corresponding data model element.

```
dme = mme.data_model_element(dm)
dme = mme.data_model_element(dm, name)
```

Inputs
- **dm** (*mp.data_model* (page 27)) – data model object
- **name** (*char array*) – *(optional)* name of element type *(default is name of this object)*

Output
dme (*mp.dm_element* (page 35)) – data model element object

network_model_element(*nm*, *name*)

Get corresponding network model element.

```
nme = mme.network_model_element(nm)
nme = mme.network_model_element(nm, name)
```

Inputs
- **nm** (*mp.net_model* (page 90)) – network model object
- **name** (*char array*) – *(optional)* name of element type *(default is name of this object)*

Output
nme (*mp.nm_element* (page 107)) – network model element object

add_vars(*mm*, *nm*, *dm*, *mpopt*)

Add math model variables for this element.

```
mme.add_vars(mm, nm, dm, mpopt)
```

Inputs
- **mm** (*mp.math_model* (page 121)) – mathmatical model object
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Implementation provided by a subclass.

add_constraints(*mm*, *nm*, *dm*, *mpopt*)

Add math model constraints for this element.

```
mme.add_constraints(obj, mm, nm, dm, mpopt)
```

Inputs
- **mm** (*mp.math_model* (page 121)) – mathmatical model object
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Implementation provided by a subclass.

add_costs(*mm*, *nm*, *dm*, *mpopt*)

Add math model costs for this element.

```
mme.add_costs(obj, mm, nm, dm, mpopt)
```

Inputs
- **mm** (*mp.math_model* (page 121)) – mathmatical model object
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Implementation provided by a subclass.

data_model_update(*mm*, *nm*, *dm*, *mpopt*)

Update the corresponding data model element.

```
mme.data_model_update(mm, nm, dm, mpopt)
```

Inputs
- **mm** (*mp.math_model* (page 121)) – mathmatical model object
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Call *data_model_update_off()* (page 145) then *data_model_update_on()* (page 145) to update the data model for this element based on the math model solution.

See also *data_model_update_off()* (page 145), *data_model_update_on()* (page 145).

data_model_update_off(*mm*, *nm*, *dm*, *mpopt*)

Update offline elements in the corresponding data model element.

```
mme.data_model_update_off(mm, nm, dm, mpopt)
```

Inputs
- **mm** (*mp.math_model* (page 121)) – mathmatical model object
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Set export variables for offline elements based on specs returned by *mp.dm_element.export_vars_offline_val()* (page 40).

See also *data_model_update()* (page 145), *data_model_update_on()* (page 145).

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

Update online elements in the corresponding data model element.

```
mme.data_model_update_on(mm, nm, dm, mpopt)
```

Inputs

- **mm** (*mp.math_model* (page 121)) – mathmatical model object
- **nm** (*mp.net_model* (page 90)) – network model object
- **dm** (*mp.data_model* (page 27)) – data model object
- **mpopt** (*struct*) – MATPOWER options struct

Extract the math model solution relevant to this particular element and update the corresponding data model element for online elements accordingly.

Implementation provided by a subclass.

See also *data_model_update()* (page 145), *data_model_update_off()* (page 145).

mp.mme_branch

class mp.**mme_branch**

Bases: *mp.mm_element* (page 143)

mp.mme_branch (page 146) - Math model element abstract base class for branch.

Abstract math model element base class for branch elements, including transmission lines and transformers.

Method Summary

name()

mp.mme_branch_pf_ac

class mp.**mme_branch_pf_ac**

Bases: *mp.mme_branch* (page 146)

mp.mme_branch_pf_ac (page 146) - Math model element for branch for AC power flow.

Math model element class for branch elements, including transmission lines and transformers, for AC power flow problems.

Implements updating the output data in the corresponding data model element for in-service branches from the math model solution.

Method Summary

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_branch_pf_dc

class mp.**mme_branch_pf_dc**

Bases: *mp.mme_branch* (page 146)

mp.mme_branch_pf_dc (page 147) - Math model element for branch for DC power flow.

Math model element class for branch elements, including transmission lines and transformers, for DC power flow problems.

Implements updating the output data in the corresponding data model element for in-service branches from the math model solution.

Method Summary

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_branch_opf

class mp.**mme_branch_opf**

Bases: *mp.mme_branch* (page 146)

mp.mme_branch_opf (page 147) - Math model element abstract base class for branch for OPF.

Math model element abstract base class for branch elements, including transmission lines and transformers, for OPF problems.

Implements methods to prepare data required for angle difference limit constraints and to extract shadow prices for these constraints from the math model solution.

Method Summary

ang_diff_params(*dm*, *ignore*)

ang_diff_prices(*mm*, *nme*)

mp.mme_branch_opf_ac

class mp.**mme_branch_opf_ac**

Bases: *mp.mme_branch_opf* (page 147)

mp.mme_branch_opf_ac (page 147) - Math model element abstract base class for branch for AC OPF.

Math model element abstract base class for branch elements, including transmission lines and transformers, for AC OPF problems.

Implements methods for adding of branch flow constraints and for updating the output data in the corresponding data model element for in-service branches from the math model solution.

Method Summary

add_constraints(*mm*, *nm*, *dm*, *mpopt*)

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_branch_opf_acc

class mp.**mme_branch_opf_acc**

Bases: *mp.mme_branch_opf_ac* (page 147)

mp.mme_branch_opf_acc (page 148) - Math model element for branch for AC cartesian voltage OPF.

Math model element class for branch elements, including transmission lines and transformers, for AC cartesian voltage OPF problems.

Implements method for adding branch angle difference constraints and overrides method to extract shadow prices for these constraints from the math model solution.

Method Summary

add_constraints(*mm*, *nm*, *dm*, *mpopt*)

ang_diff_prices(*mm*, *nme*)

mp.mme_branch_opf_acp

class mp.**mme_branch_opf_acp**

Bases: *mp.mme_branch_opf_ac* (page 147)

mp.mme_branch_opf_acp (page 148) - Math model element for branch for AC polar voltage OPF.

Math model element class for branch elements, including transmission lines and transformers, for AC polar voltage OPF problems.

Implements method for adding branch angle difference constraints.

Method Summary

add_constraints(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_branch_opf_dc

class mp.**mme_branch_opf_dc**

Bases: *mp.mme_branch_opf* (page 147)

mp.mme_branch_opf_dc (page 148) - Math model element for branch for DC OPF.

Math model element class for branch elements, including transmission lines and transformers, for DC OPF problems.

Implements methods for adding of branch flow and angle difference constraints and for updating the output data in the corresponding data model element for in-service branches from the math model solution.

Method Summary

add_constraints(*mm*, *nm*, *dm*, *mpopt*)

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_bus

class mp.**mme_bus**

Bases: *mp.mm_element* (page 143)

mp.mme_bus (page 149) - Math model element abstract base class for bus.

Abstract math model element base class for bus elements.

Method Summary

name()

mp.mme_bus_pf_ac

class mp.**mme_bus_pf_ac**

Bases: *mp.mme_bus* (page 149)

mp.mme_bus_pf_ac (page 149) - Math model element for bus for AC power flow.

Math model element class for bus elements for AC power flow problems.

Implements method for updating the output data in the corresponding data model element for in-service buses from the math model solution.

Method Summary

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_bus_pf_dc

class mp.**mme_bus_pf_dc**

Bases: *mp.mme_bus* (page 149)

mp.mme_bus_pf_dc (page 149) - Math model element for bus for DC power flow.

Math model element class for bus elements for DC power flow problems.

Implements method for updating the output data in the corresponding data model element for in-service buses from the math model solution.

Method Summary

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_bus_opf_ac

class mp.**mme_bus_opf_ac**

Bases: *mp.mme_bus* (page 149)

mp.mme_bus_opf_ac (page 150) - Math model element abstract base class for bus for AC OPF.

Abstract math model element class for bus elements for AC OPF problems.

Implements method for forming an interior initial point for voltage magnitudes.

Method Summary

interior_vm(*mm*, *nm*, *dm*)

return vm equal to avg of clipped limits

mp.mme_bus_opf_acc

class mp.**mme_bus_opf_acc**

Bases: *mp.mme_bus_opf_ac* (page 150)

mp.mme_bus_opf_acc (page 150) - Math model element for bus for AC cartesian voltage OPF.

Math model element class for bus elements for AC cartesian voltage OPF problems.

Implements methods for adding constraints for reference voltage angle, fixed voltage magnitudes and voltage magnitude limits, for forming an interior initial point and for updating the output data in the corresponding data model element for in-service buses from the math model solution.

Method Summary

add_constraints(*mm*, *nm*, *dm*, *mpopt*)

interior_x0(*mm*, *nm*, *dm*, *x0*)

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_bus_opf_acp

class mp.**mme_bus_opf_acp**

Bases: *mp.mme_bus_opf_ac* (page 150)

mp.mme_bus_opf_acp (page 150) - Math model element for bus for AC polar voltage OPF.

Math model element class for bus elements for AC polar voltage OPF problems.

Implements methods for forming an interior initial point and for updating the output data in the corresponding data model element for in-service buses from the math model solution.

Method Summary

interior_x0(*mm*, *nm*, *dm*, *x0*)

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_bus_opf_dc

class mp.**mme_bus_opf_dc**

Bases: *mp.mme_bus* (page 149)

mp.mme_bus_opf_dc (page 151) - Math model element for bus for DC OPF.

Math model element class for bus elements for DC OPF problems.

Implements methods for forming an interior initial point and for updating the output data in the corresponding data model element for in-service buses from the math model solution.

Method Summary

interior_x0(*mm*, *nm*, *dm*, *x0*)

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_gen

class mp.**mme_gen**

Bases: *mp.mm_element* (page 143)

mp.mme_gen (page 151) - Math model element abstract base class for generator.

Abstract math model element base class for generator elements.

Method Summary

name()

mp.mme_gen_pf_ac

class mp.**mme_gen_pf_ac**

Bases: *mp.mme_gen* (page 151)

mp.mme_gen_pf_ac (page 151) - Math model element for generator for AC power flow.

Math model element class for generator elements for AC power flow problems.

Implements method for updating the output data in the corresponding data model element for in-service generators from the math model solution.

Method Summary

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_gen_pf_dc

class mp.**mme_gen_pf_dc**

Bases: *mp.mme_gen* (page 151)

mp.mme_gen_pf_dc (page 152) - Math model element for generator for DC power flow.

Math model element class for generator elements for DC power flow problems.

Implements method for updating the output data in the corresponding data model element for in-service generators from the math model solution.

Method Summary

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_gen_opf

class mp.**mme_gen_opf**

Bases: *mp.mme_gen* (page 151)

mp.mme_gen_opf (page 152) - Math model element abstract base class for generator for OPF.

Math model element abstract base class for generator elements for OPF problems.

Implements methods to add costs, including piecewise linear cost variables, and to form an interior initial point for cost variables.

Property Summary

cost

struct for *cost* (page 152) parameters with fields:

- `poly_p` - polynomial costs for active power, struct returned by *mp.cost_table.poly_params()* (page 162), with fields:
  - `have_quad_cost`
  - `i0`, `i1`, `i2`, `i3`
  - `k`, `c`, `Q`
- `poly_q` - polynomial costs for reactive power *(same struct as* `poly_p` *)*
- `pwl` - piecewise linear costs for actve & reactive struct returned by *mp.cost_table.pwl_params()* (page 163), with fields:
  - `n`, `i`, `A`, `b`

Method Summary

add_vars(*mm*, *nm*, *dm*, *mpopt*)

add_costs(*mm*, *nm*, *dm*, *mpopt*)

interior_x0(*mm*, *nm*, *dm*, *x0*)

mp.mme_gen_opf_ac

class mp.**mme_gen_opf_ac**

Bases: *mp.mme_gen_opf* (page 152)

mp.mme_gen_opf_ac (page 153) - Math model element for generator for AC OPF.

Math model element class for generator elements for AC OPF problems.

Implements methods for buliding and adding PQ capability constraints, dispatchable load power factor constraints, polynomial costs, and for updating the output data in the corresponding data model element for in-service generators from the math model solution.

Method Summary

add_constraints(*mm*, *nm*, *dm*, *mpopt*)

add_costs(*mm*, *nm*, *dm*, *mpopt*)

pq_capability_constraint(*dme*, *base_mva*)

from legacy *makeApq()* (page 288)

has_pq_cap(*gen*, *upper_lower*)

from legacy *hasPQcap()* (page 338)

disp_load_constant_pf_constraint(*dm*)

from legacy *makeAvl()* (page 289)

build_cost_params(*dm*)

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_gen_opf_dc

class mp.**mme_gen_opf_dc**

Bases: *mp.mme_gen_opf* (page 152)

mp.mme_gen_opf_dc (page 153) - Math model element for generator for DC OPF.

Math model element class for generator elements for DC OPF problems.

Implements methods for buliding cost parameters, adding piecewise linear cost constraints, and for updating the output data in the corresponding data model element for in-service generators from the math model solution.

Method Summary

add_constraints(*mm*, *nm*, *dm*, *mpopt*)

build_cost_params(*dm*)

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_load

class mp.**mme_load**

Bases: *mp.mm_element* (page 143)

mp.mme_load (page 154) - Math model element abstract base class for load.

Abstract math model element base class for load elements.

Method Summary

name()

mp.mme_load_pf_ac

class mp.**mme_load_pf_ac**

Bases: *mp.mme_load* (page 154)

mp.mme_load_pf_ac (page 154) - Math model element for load for AC power flow.

Math model element class for load elements for AC power flow problems.

Implements method for updating the output data in the corresponding data model element for in-service loads from the math model solution.

Method Summary

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_load_pf_dc

class mp.**mme_load_pf_dc**

Bases: *mp.mme_load* (page 154)

mp.mme_load_pf_dc (page 154) - Math model element for load for DC power flow.

Math model element class for load elements for DC power flow problems.

Implements method for updating the output data in the corresponding data model element for in-service loads from the math model solution.

Method Summary

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_load_cpf

class mp.**mme_load_cpf**

Bases: *mp.mme_load_pf_ac* (page 154)

mp.mme_load_cpf (page 155) - Math model element for load for CPF.

Math model element class for load elements for AC CPF problems.

Implements method for updating the output data in the corresponding data model element for in-service loads from the math model solution.

Method Summary

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_shunt

class mp.**mme_shunt**

Bases: *mp.mm_element* (page 143)

mp.mme_shunt (page 155) - Math model element abstract base class for shunt.

Abstract math model element base class for shunt elements.

Method Summary

name()

mp.mme_shunt_pf_ac

class mp.**mme_shunt_pf_ac**

Bases: *mp.mme_shunt* (page 155)

mp.mme_shunt_pf_ac (page 155) - Math model element for shunt for AC power flow.

Math model element class for shunt elements for AC power flow problems.

Implements method for updating the output data in the corresponding data model element for in-service shunts from the math model solution.

Method Summary

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_shunt_pf_dc

class mp.**mme_shunt_pf_dc**

Bases: *mp.mme_shunt* (page 155)

mp.mme_shunt_pf_dc (page 156) - Math model element for shunt for DC power flow.

Math model element class for shunt elements for DC power flow problems.

Implements method for updating the output data in the corresponding data model element for in-service shunts from the math model solution.

Method Summary

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_shunt_cpf

class mp.**mme_shunt_cpf**

Bases: *mp.mme_shunt_pf_ac* (page 155)

mp.mme_shunt_cpf (page 156) - Math model element for shunt for CPF.

Math model element class for shunt elements for AC CPF problems.

Implements method for updating the output data in the corresponding data model element for in-service shunts from the math model solution.

Method Summary

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

3.6 Miscellaneous Classes

3.6.1 mp_table

class **mp_table**

mp_table (page 156) - Very basic table-compatible class for Octave or older Matlab.

```
T = mp_table(var1, var2, ...);
T = mp_table(..., 'VariableNames', {name1, name2, ...});
T = mp_table(..., 'RowNames', {name1, name2, ...});
T = mp_table(..., 'DimensionNames', {name1, name2, ...});
```

Implements a very basic table array class focused the ability to store and access named variables of different types in a way that is compatible with MATLAB's built-in table class. Other features, such as table joining, etc., are not implemented.

Important: Since the dot syntax `T.<var_name>` is used to access table variables, you must use a functional syntax `<method>(T,...)`, as opposed to the object-oriented `T.<method>(...)`, to call mp_table methods.

mp_table Methods:

- *mp_table()* (page 157) - construct object
- *istable()* (page 157) - true for *mp_table* (page 156) objects
- *size()* (page 157) - dimensions of table
- *isempty()* (page 157) - true if table has no columns or no rows
- *end()* (page 158) - used to index last row or variable/column
- *subsref()* (page 158) - indexing a table to retrieve data
- *subsasgn()* (page 158) - indexing a table to assign data
- *horzcat()* (page 159) - concatenate tables horizontally
- *vertcat()* (page 159) - concatenate tables vertically
- *display()* (page 159) - display table contents

See also `table`.

Constructor Summary

mp_table(*varargin*)

Constructs the object.

```
T = mp_table(var1, var2, ...)
T = mp_table(..., 'VariableNames', {name1, name2, ...})
T = mp_table(..., 'RowNames', {name1, name2, ...})
T = mp_table(..., 'DimensionNames', {name1, name2, ...})
```

Method Summary

istable()

Returns true.

```
TorF = istable(T)
```

Unfortunately, this is not really useful until Octave implements a built-in *istable()* (page 157) that this can override.

size(*dim*)

Returns dimensions of table.

```
[m, n] = size(T)
m = size(T, 1)
n = size(T, 2)
```

isempty()

Returns `true` if the table has no columns or no rows.

```
TorF = isempty(T)
```

end(*k*, *n*)

Used to index the last row or column of the table.

```
last_var = T{:, end}
last_row = T(end, :)
```

subsref(*s*)

Called when indexing a table to retrieve data.

```
sub_T = T(i, *)
sub_T = T(i1:iN, *)
sub_T = T(:, *)
sub_T = T(*, j)
sub_T = T(*, j1:jN)
sub_T = T(*, :)
sub_T = T(*, <str>)
sub_T = T(*, <cell>)
var_<name> = T.<name>
val = T.<name>(i)
val = T.<name>(i1:iN)
val = T.<name>{i}
val = T.<name>{i1:iN}
val = T.<name>(*, :)
val = T.<name>(*, j)
var_<j> = T{:, j}
var_<str> = T{:, <str>}
val = T{i, *}
val = T{i1:iN, *}
val = T{:, *}
val = T{*, j}
val = T{*, j1:jN}
val = T{*, :}
val = T{*, <str>}
val = T{*, <cell>}
```

subsasgn(*s*, *b*)

Called when indexing a table to assign data.

```
T(i, *) = sub_T
T(i1:iN, *) = sub_T
T(:, *) = sub_T
T(*, j) = sub_T
T(*, j1:jN) = sub_T
T(*, :) = sub_T
T(*,  <str>) = sub_T
T(*,  <cell>) = sub_T
T.<name> = val
T.<name>(i) = val
T.<name>(i1:iN) = val
T.<name>{i} = val
T.<name>{i1:iN} = val
```

(continues on next page)

(continued from previous page)

```
T.<name>(*, :) = val
T.<name>(*, j) = val
T{:, j} = var_<j>
T{:, <str>} = var_<str>
T{i, *} = val
T{i1:iN, *} = val
T{:, *} = val
T{*, j} = val
T{*, j1:jN} = val
T{*, :} = val
T{*, <str>} = val
T{*, <cell>} = val
```

horzcat(*varargin*)

Concatenate tables horizontally.

```
T = [T1 T2]
```

vertcat(*varargin*)

Concatenate tables vertically.

```
T = [T1; T2]
```

display()

Display the table contents.

This method is called automatically when omitting a semicolon on a line that retuns an object of this class.

By default it displays only the first and last 10 rows if there are more than 25 rows.

Does not currently display the contents of any nested tables.

static extract_named_args(*args*)

Extracts special named constructor arguments.

```
[var_names, row_names, dim_names, args] = extract_named_args(var1, var2, ...
↪)
[...] = extract_named_args(..., 'VariableNames', {name1, name2, ...})
[...] = extract_named_args(..., 'RowNames', {name1, name2, ...})
[...] = extract_named_args(..., 'DimensionNames', {name1, name2, ...})
```

Used to extract named arguments, `'VariableNames'`, `'RowNames'`, and `'DimensionNames'`, to pass to constructor.

3.6.2 mp_table_subclass

class mp_table_subclass

mp_table_subclass (page 160) - Class that acts like a table but isn't one.

Addresses two issues with inheriting from **table** classes (`table`) or *mp_table* (page 156)).

1. In MATLAB, `table` is a sealed class, so you cannot inherit from it. You can, however, use a subclass of *mp_table* (page 156), but that can result in the next issue under Octave.
2. While nesting of tables works just fine in general, when using *mp_table* (page 156) in Octave (at least up through 8.4.0), you cannot nest a subclass of *mp_table* (page 156) inside another *mp_table* (page 156) object because of this bug: https://savannah.gnu.org/bugs/index.php?65037.

To work around these issues, your "table subclass" can inherit from **this** class. An object of this class **isn't** a `table` or *mp_table* (page 156) object, but rather it **contains** one and attempts to act like one. That is, it delegates method calls (currently only those available in *mp_table* (page 156), listed below) to the contained table object.

The class of the contained table object is either `table` or *mp_table* (page 156) and is determined by *mp_table_class()* (page 6).

Limitations

1. The Octave bug mentioned above also affects tables that inherit from *mp_table_subclass* (page 160). That is, such tables can be nested inside tables of type `table` or *mp_table* (page 156), but not inside tables that are or inherit from *mp_table_subclass* (page 160).
2. In MATLAB, when nesting an *mp_table_subclass* (page 160) object within another *mp_table_subclass* (page 160) object, one cannot use multi-level indexing directly. E.g. If `T2` is a variable in `T1` and `x` is a variable in `T2`, attempting `x = T1.T2.x` will result in an error. The indexing must be done in multiple steps `T2 = T1.T2; x = T2.x`. Note: This only applies to MATLAB, where the contained table is a `table`. It works just fine in Octave, where the contained table is an *mp_table* (page 156).

Important: Since the dot syntax `T.<var_name>` is used to access table variables, you must use a functional syntax `<method>(T,...)`, as opposed to the object-oriented `T.<method>(...)`, to call methods of this class or subclasses, as with mp_table.

---

mp.mp_table_subclass Properties:

- `tab` - *(table or mp_table)* contained table object this class emulates

mp.cost_table Methods:

- `mp_table_subclass()` - construct object
- *get_table()* (page 161) - return the table stored in `tab`
- *set_table()* (page 161) - assign a table to `tab`
- `istable()` - true for *mp_table* (page 156) objects
- `size()` - dimensions of table
- `isempty()` - true if table has no columns or no rows
- `end()` - used to index last row or variable/column
- `subsref()` - indexing a table to retrieve data

- subsasgn() - indexing a table to assign data
- horzcat() - concatenate tables horizontally
- vertcat() - concatenate tables vertically
- display() - display table contents

See also *mp_table* (page 156), *mp_table_class()* (page 6).

Method Summary

get_table()

```
T = get_table(obj)
```

set_table(*T*)

```
set_table(obj, T)
```

3.6.3 mp.cost_table

class mp.**cost_table**

Bases: *mp_table_subclass* (page 160)

mp.cost_table (page 161) - Table for (polynomial and piecewise linear) cost parameters.

```
T = cost_table(poly_n, poly_coef, pwl_n, pwl_qty, pwl_cost);
```

Important: Since the dot syntax T.<var_name> is used to access table variables, you must use a functional syntax <method>(T,...), as opposed to the object-oriented T.<method>(...), to call standard mp.cost_table methods.

Standard table subscripting syntax is not available within methods of this class (references built-in subsref() and subsasgn() rather than the versions overridden by the table class). For this reason, some method implementations are delegated to static methods in *mp.cost_table_utils* (page 164) where that syntax is available, making the code more readable.

mp.cost_table Methods:

- *cost_table()* (page 162) - construct object
- *poly_params()* (page 162) - create struct of polynomial parameters from *mp.cost_table* (page 161)
- *pwl_params()* (page 163) - create struct of piecewise linear parameters from *mp.cost_table* (page 161)
- *max_pwl_cost()* (page 163) - get maximum cost component used to specify pwl costs

An *mp.cost_table* (page 161) has the following columns:

Name	Type	Description
poly_n	*integer*	n_{poly}, number of coefficients in polynomial cost curve, $f_{\text{poly}}(x) = c_0 + c_1 x ... + c_N x^N$, where $n_{\text{poly}} = N + 1$
poly_co	*double*	matrix of coefficients c_j, of polynomial cost $f_{\text{poly}}(x)$, where c_j is found in column $j + 1$
pwl_n	*double*	n_{pwl}, number of data points $(x_1, f_1), (x_2, f_2), ..., (x_N, f_N)$ defining a piecewise linear cost curve, $f_{\text{pwl}}(x)$ where $N = n_{\text{pwl}}$
pwl_qty	*double*	matrix of *quantiy* coordinates x_j for piecwise linear cost $f_{\text{pwl}}(x)$, where x_j is found in column j
pwl_cos	*double*	matrix of *cost* coordinates f_j for piecwise linear cost $f_{\text{pwl}}(x)$, where f_j is found in column j

See also *mp.cost_table_utils* (page 164), *mp_table_subclass* (page 160).

Constructor Summary

cost_table(*varargin*)

```
T = cost_table()
T = cost_table(poly_n, poly_coef, pwl_n, pwl_qty, pwl_cost)
```

For descriptions of the inputs, see the corresponding column in the class documentation above.

Inputs
- **poly_n** (*col vector of integers*)
- **poly_coef** (*matrix of doubles*)
- **pwl_n** (*col vector of integers*)
- **pwl_qty** (*matrix of doubles*)
- **pwl_cost** (*matrix of doubles*)

Outputs

T (*mp.cost_table* (page 161)) – the cost table object

Method Summary

poly_params(*idx*, *pu_base*)

```
p = poly_params(obj, idx, pu_base)
```

Inputs
- **obj** (*mp.cost_table* (page 161)) – the cost table
- **idx** – (integer) : index vector of rows of interest, empty for all rows
- **pu_base** (*double*) – base used to scale quantities to per unit

Outputs

p (*struct*) – polynomial cost parameters, struct with fields:
- `have_quad_cost` - true if any polynmial costs have order quadratic or less
- `i0` - row indices for constant costs
- `i1` - row indices for linear costs
- `i2` - row indices for quadratic costs
- `i3` - row indices for order 3 or higher costs
- `k` - constant term for all quadratic and lower order costs
- `c` - linear term for all quadratic and lower order costs
- `Q` - quadratic term for all quadratic and lower order costs

Implementation in *mp.cost_table_utils.poly_params()* (page 164).

pwl_params(*idx*, *pu_base*, *varargin*)

```
p = pwl_params(obj, idx, pu_base)
p = pwl_params(obj, idx, pu_base, ng, dc)
```

Inputs
- **obj** (*mp.cost_table* (page 161)) – the cost table
- **idx** – (integer) : index vector of rows of interest, empty for all rows
- **pu_base** (*double*) – base used to scale quantities to per unit
- **ng** (*integer*) – number of units, default is # of rows in cost
- **dc** (*boolean*) – true if DC formulation (ng variables), otherwise AC formulation (2*ng variables), default is 1

Outputs

p (*struct*) – piecewise linear cost parameters, struct with fields:
- `n` - number of piecewise linear costs
- `i` - row indices for piecewise linear costs
- `A` - constraint coefficient matrix for CCV formulation
- `b` - constraint RHS vector for CCV formulation

Implementation in *mp.cost_table_utils.pwl_params()* (page 165).

max_pwl_cost()

```
maxc = max_pwl_cost(obj)
```

Input

obj (*mp.cost_table* (page 161)) – the cost table

Output

maxc (*double*) – maximum cost component of all breakpoints used to specify piecewise linear costs

Implementation in *mp.cost_table_utils.max_pwl_cost()* (page 165).

static poly_cost_fcn(*xx*, *x_scale*, *ccm*, *idx*)

```
f = mp.cost_table.poly_cost_fcn(xx, x_scale, ccm, idx)
[f, df] = mp.cost_table.poly_cost_fcn(...)
[f, df, d2f] = mp.cost_table.poly_cost_fcn(...)
```

Evaluates the sum of a set of polynomial cost functions $f(x) = \sum_{i \in I} f_i(x_i)$, and optionally the gradient and Hessian.

Inputs
- **xx** (*single element cell array of double*) – first element is a vector of the pre-scaled quantities x/α used to compute the costs
- **x_scale** (*double*) – scalar α used to scale the quantity value before evaluating the polynomial cost
- **ccm** (*double*) – cost coefficient matrix, element *(i,j)* is the coefficient of the *(j-1)* order term for cost *i*
- **idx** (*integer*) – index vector of subset I of rows of `xx{1}` and `ccm` of interest

Outputs
- **f** (*double*) – value of cost function $f(x)$
- **df** (*vector of double*) – (optional) gradient of cost function
- **d2f** (*matrix of double*) – (optional) Hessian of cost function

static eval_poly_fcn(*c*, *x*)

```
f = mp.cost_table.eval_poly_fcn(c, x)
```

Evaluate a vector of polynomial functions, where ...

```
f = c(:,1) + c(:,2) .* x + c(:,3) .* x^2 + ...
```

Inputs

- **c** (*matrix of double*) – coefficient matrix, element *(i,j)* is the coefficient of the *(j-1)* order term for *i*-th element of *f*
- **x** (*vector of double*) – vector of input values

Outputs

f (*vector of double*) – value of functions

static diff_poly_fcn(*c*)

```
c = mp.cost_table.diff_poly_fcn(c)
```

Compute the coefficient matrix for the derivatives of a set of polynomial functions from the coefficients of the functions.

Inputs

c (*matrix of double*) – coefficient matrix for the functions, element *(i,j)* is the coefficient of the *(j-1)* order term of the *i*-th function

Outputs

c (*matrix of double*) – coefficient matrix for the derivatives of the functions, element *(i,j)* is the coefficient of the *(j-1)* order term of the derivative of the *i*-th function

3.6.4 mp.cost_table_utils

class mp.**cost_table_utils**

mp.cost_table_utils (page 164) - Static methods for *mp.cost_table* (page 161).

Contains the implementation of some methods that would ideally belong in *mp.cost_table* (page 161).

Within classes that inherit from *mp_table_subclass* (page 160), such as *mp.cost_table* (page 161), any subscripting to access the elements of the table must be done through explicit calls to the table's `subsref()` and `subsasgn()` methods. That is, the normal table subscripting syntax will not work, so working with the table becomes extremely cumbersome.

This purpose of this class is to provide the implementation for *mp.cost_table* (page 161) methods that **do** allow access to that table via normal table subscripting syntax.

mp.cost_table_util Methods:

- *poly_params()* (page 164) - create struct of polynomial parameters from *mp.cost_table* (page 161)
- *pwl_params()* (page 165) - create struct of piecewise linear parameters from *mp.cost_table* (page 161)
- *max_pwl_cost()* (page 165) - get maximum cost component used to specify pwl costs

See also *mp.cost_table* (page 161).

Method Summary

static poly_params(*cost*, *idx*, *pu_base*)

```
p = mp.cost_table_utils.poly_params(cost, idx, pu_base)
```

Implementation for *mp.cost_table.poly_params()* (page 162). See *mp.cost_table.poly_params()* (page 162) for details.

static pwl_params(*cost*, *idx*, *pu_base*, *ng*, *dc*)

```
p = mp.cost_table_utils.pwl_params(cost, idx, pu_base)
p = mp.cost_table_utils.pwl_params(cost, idx, pu_base, ng, dc)
```

Implementation for *mp.cost_table.pwl_params()* (page 163). See *mp.cost_table.pwl_params()* (page 163) for details.

static max_pwl_cost(*cost*)

```
maxc = mp.cost_table_utils.max_pwl_cost(cost)
```

Implementation for *mp.cost_table.max_pwl_cost()* (page 163). See *mp.cost_table.max_pwl_cost()* (page 163) for details.

3.6.5 mp.element_container

class mp.**element_container**

Bases: handle

mp.element_container (page 165) - Mix-in class to handle named/ordered element object array.

Implements an element container that is used for MATPOWER model and data model converter objects. Provides the properties to store the constructors for each element and the elements themselves. Also provides a method to modify an existing set of element constructors.

mp.element_container Properties:

- *element_classes* (page 165) - cell array of element constructors
- *elements* (page 165) - a *mp.mapped_array* (page 166) to hold the element objects

mp.element_container Methods:

- *modify_element_classes()* (page 165) - modify an existing set of element constructors

See also *mp.mapped_array* (page 166).

Property Summary

element_classes

Cell array of function handles of constructors for individual elements, filled by constructor of subclass.

elements

A mapped array (*mp.mapped_array* (page 166)) to hold the element objects included inside this container object.

Method Summary

modify_element_classes(*class_list*)

Modify an existing set of element constructors.

```
obj.modify_element_classes(class_list)
```

Input

class_list (*cell array*) – list of **element class modifiers**, where each modifier is one of the following:

1. a handle to a constructor to **append** to `obj.element_classes`, *or*
2. a char array `B`, indicating to **remove** any element `E` in the list for which `isa(E(), B)` is `true`, *or*
3. a 2-element cell array `{A,B}` where `A` is a handle to a constructor to **replace** any element `E` in the list for which `isa(E(), B)` is `true`, i.e. `B` is a char array

Also accepts a single element class modifier of type 1 or 2 *(A single type 3 modifier has to be enclosed in a single-element cell array to keep it from being interpreted as a list of 2 modifiers)*.

Can be used to modify the list of element constructors in the `element_classes` property by appending, removing, or replacing entries. See `tab_element_class_modifiers` in the *MATPOWER Developer's Manual* for more information.

3.6.6 mp.mapped_array

class mp.**mapped_array**

Bases: `handle`

mp.mapped_array (page 166) - Cell array indexed by name as well as numeric index.

Currently, arrays are only 1-D.

Example usage:

```
% create a mapped array object
ma = mp.mapped_array({30, 40, 50}, {'width', 'height', 'depth'});

% treat it like a cell array
ma{3} = 60;
height = ma{2};
for i = 1:length(ma)
    disp( ma{i} );
end

% treat it like a struct
ma.width = 20;
depth = ma.depth;

% add elements
ma.add_elements({'red', '25 lbs'}, {'color', 'weight'});

% delete elements
ma.delete_elements([3 5]);
ma.delete_elements('height');
```

(continues on next page)

(continued from previous page)

```
% check for named element
ma.has_name('color');
```

mp.mapped_array Methods:

- *mapped_array()* (page 167) - constructor
- *copy()* (page 167) - create a duplicate of the mapped array object
- *length()* (page 167) - return number of elements in mapped array
- *size()* (page 167) - return dimensions of mapped array
- *add_names()* (page 168) - add or modify names of elements
- *add_elements()* (page 168) - append elements to the end of the mapped array
- *delete_elements()* (page 168) - delete elements from the mapped array
- *has_name()* (page 168) - return `true` if the name exists in the mapped array
- *name2idx()* (page 168) - return the index corresponding to a name
- *subsref()* (page 168) - called when indexing a mapped array to retrieve data
- *subsasgn()* (page 169) - called when indexing a mapped array to assign data
- *display()* (page 169) - display the mapped array structure

Constructor Summary

`mapped_array`(*varargin*)

```
obj = mp.mapped_array(vals)
obj = mp.mapped_array(vals, names)
```

Inputs

- **vals** (*cell array*) – values to be stored
- **names** (*cell array of char arrays*) – names for each element in `vals`, where a valid name is any valid variable name that is not one of the methods of this class. If names are not provided, it is equivalent to a cell array, except that names can be added later.

Method Summary

`copy`()

Create a duplicate of the mapped array object.

```
new_obj = obj.copy();
```

`length`()

Return number of elements in mapped array.

```
num_elements = obj.length();
```

`size`(*dim*)

Return dimensions of mapped array. First dimension is 1, second matches the length.

```
[m, n] = obj.size();
m = obj.size(1);
n = obj.size(2);
```

add_names(*i0*, *names*)

Add or modify names of elements.

```
obj.add_names(i0, names)
```

Inputs
- **i0** (*cell array*) – index of element corresponding to first name provided in `names`
- **names** (*char array or cell array of char arrays*) – the names to assign

Adds or overwrites the names for elements starting at the specified index.

add_elements(*vals*, *names*)

Append elements to the end of the mapped array.

```
obj.add_elements(vals);
obj.add_elements(vals, names);
```

Inputs
- **vals** – single value or cell array of values
- **names** (*char array or cell array of char arrays*) – (optional) corresponding names

The two arguments must be both cell arrays of the same dimension or a single value and single name.

See also *delete_elements()* (page 168).

delete_elements(*refs*)

Delete elements from the mapped array.

```
obj.delete_elements(idx);
obj.delete_elements(names);
```

Inputs
- **idx** (*scalar or vector integer*) – index(indices) of element(s) to delete
- **names** (*char array or cell array of char arrays*) – name(s) of element(s) to delete

See also *add_elements()* (page 168).

has_name(*name*)

Return `true` if the name exists in the mapped array.

```
TorF = obj.has_name(name);
```

Input
name (*char array*) – name to check

name2idx(*name*)

Return the numerical index in the array corrsponding to a name.

```
idx = obj.name2idx(name);
```

Input
name (*char array*) – name corresponding to desired index

subsref(*s*)

Called when indexing a table to retrieve data.

```
val = obj.<name>;
val = obj{idx};
```

subsasgn(*s*, *b*)

Called when indexing a table to assign data.

```
obj.<name> = val;
obj{idx} = val;
```

display()

Display the mapped array structure.

This method is called automatically when omitting a semicolon on a line that retuns an object of this class.

3.6.7 mp.NODE_TYPE

class mp.**NODE_TYPE**

mp.NODE_TYPE (page 169) - Defines enumerated type for node types.

mp.NODE_TYPE Properties:

- *PQ* (page 169) - PQ node (= 1)
- *PV* (page 169) - PV node (= 2)
- *REF* (page 169) - reference node (= 3)
- *NONE* (page 169) - isolated node (= 4)

mp.NODE_TYPE Methods:

- *is_valid()* (page 169) - returns true if the value is a valid node type

All properties are `Constant` properties and the class is a `Sealed` class. So the properties function as global constants which do not create an instance of the class, e.g. *mp.NODE_TYPE.REF* (page 169).

Property Summary

PQ = 1

PQ node

PV = 2

PV node

REF = 3

reference node

NONE = 4

isolated node

Method Summary

static is_valid(*val*)

Returns true if the value is a valid node type.

```
TorF = mp.NODE_TYPE.is_valid(val)
```

Input
val (*integer*) – node type value to check for validity
Output
TorF (*boolean*) – true if `val` is a valid node type

3.7 MATPOWER Extension Classes

3.7.1 Base

mp.extension

class mp.**extension**

Bases: `handle`

mp.extension (page 170) - Abstract base class for MATPOWER extensions.

This class serves as the framework for the **MATPOWER extension** API, providing a way to bundle a set of class additions and modifications together into a single named package.

By default the methods in this class do nothing, but they can be overridden to customize essentially any aspect of a MATPOWER run. The first 5 methods are used to modify the default classes used to construct the task, data model converter, data, network, and/or mathematical model objects. The last 4 methods are used to add to or modify the classes used to construct the elements for each of the container types.

By convention, MATPOWER extension objects (or cell arrays of them) are named `mpx` and MATPOWER extension class names begin with `mp.xt`.

mp.extension Methods:

- *task_class()* (page 171) - return handle to constructor for task object
- `dmc_class()` - return handle to constructor for data model converter object
- `dm_class()` - return handle to constructor for data model object
- `nm_class()` - return handle to constructor for network model object
- `mm_class()` - return handle to constructor for mathematical object
- *dmc_element_classes()* (page 172) - return element class modifiers for data model converter elements
- *dm_element_classes()* (page 172) - return element class modifiers for data model elements
- *nm_element_classes()* (page 172) - return element class modifiers for network model elements
- *mm_element_classes()* (page 172) - return element class modifiers for mathematical model elements

See the sec_customizing and sec_extensions sections in the *MATPOWER Developer's Manual* for more information, and specifically the sec_element_classes section and the tab_element_class_modifiers table for details on *element class modifiers*.

Example MATPOWER extensions:

- *mp.xt_reserves* (page 173) - adds fixed zonal reserves to OPF
- *mp.xt_3p* (page 178) - adds example prototype unbalanced three-phase elements for AC PF, CPF, and OPF

See also *mp.task* (page 7), *mp.dm_converter* (page 59), *mp.data_model* (page 27), *mp.net_model* (page 90), *mp.math_model* (page 121), *mp.dmc_element* (page 62), *mp.dm_element* (page 35), *mp.nm_element* (page 107), *mp.mm_element* (page 143).

Method Summary

`task_class`(*task_class*, *mpopt*)

Return handle to constructor for task object.

```
task_class = mpx.task_class(task_class, mpopt)
```

Inputs
- **task_class** (*function handle*) – default task constructor
- **mpopt** (*struct*) – MATPOWER options struct

Output
task_class (*function handle*) – updated task constructor

`dm_converter_class`(*dmc_class*, *fmt*, *mpopt*)

Return handle to constructor for data model converter object.

```
dmc_class = mpx.dm_converter_class(dmc_class, fmt, mpopt)
```

Inputs
- **dmc_class** (*function handle*) – default data model converter constructor
- **fmt** (*char array*) – data format tag, e.g. `'mpc2'`
- **mpopt** (*struct*) – MATPOWER options struct

Output
dmc_class (*function handle*) – updated data model converter constructor

`data_model_class`(*dm_class*, *task_tag*, *mpopt*)

Return handle to constructor for data model object.

```
dm_class = mpx.data_model_class(dm_class, task_tag, mpopt)
```

Inputs
- **dm_class** (*function handle*) – default data model constructor
- **task_tag** (*char array*) – task tag, e.g. `'PF'`, `'CPF'`, `'OPF'`
- **mpopt** (*struct*) – MATPOWER options struct

Output
dm_class (*function handle*) – updated data model constructor

`network_model_class`(*nm_class*, *task_tag*, *mpopt*)

Return handle to constructor for network model object.

```
nm_class = mpx.network_model_class(nm_class, task_tag, mpopt)
```

Inputs
- **nm_class** (*function handle*) – default network model constructor

- **task_tag** (*char array*) – task tag, e.g. `'PF'`, `'CPF'`, `'OPF'`
- **mpopt** (*struct*) – MATPOWER options struct

Output

nm_class (*function handle*) – updated network model constructor

`math_model_class`(*mm_class*, *task_tag*, *mpopt*)

Return handle to constructor for mathematical model object.

```
mm_class = mpx.math_model_class(mm_class, task_tag, mpopt)
```

Inputs

- **mm_class** (*function handle*) – default math model constructor
- **task_tag** (*char array*) – task tag, e.g. `'PF'`, `'CPF'`, `'OPF'`
- **mpopt** (*struct*) – MATPOWER options struct

Output

mm_class (*function handle*) – updated math model constructor

`dmc_element_classes`(*dmc_class*, *fmt*, *mpopt*)

Return element class modifiers for data model converter elements.

```
dmc_elements = mpx.dmc_element_classes(dmc_class, fmt, mpopt)
```

Inputs

- **dmc_class** (*function handle*) – data model converter constructor
- **fmt** (*char array*) – data format tag, e.g. `'mpc2'`
- **mpopt** (*struct*) – MATPOWER options struct

Output

dmc_elements (*cell array*) – element class modifiers (see tab_element_class_modifiers in the *MATPOWER Developer's Manual*)

`dm_element_classes`(*dm_class*, *task_tag*, *mpopt*)

Return element class modifiers for data model elements.

```
dm_elements = mpx.dm_element_classes(dm_class, task_tag, mpopt)
```

Inputs

- **dm_class** (*function handle*) – data model constructor
- **task_tag** (*char array*) – task tag, e.g. `'PF'`, `'CPF'`, `'OPF'`
- **mpopt** (*struct*) – MATPOWER options struct

Output

dm_elements (*cell array*) – element class modifiers (see tab_element_class_modifiers in the *MATPOWER Developer's Manual*)

`nm_element_classes`(*nm_class*, *task_tag*, *mpopt*)

Return element class modifiers for network model elements.

```
nm_elements = mpx.nm_element_classes(nm_class, task_tag, mpopt)
```

Inputs

- **nm_class** (*function handle*) – network model constructor
- **task_tag** (*char array*) – task tag, e.g. `'PF'`, `'CPF'`, `'OPF'`
- **mpopt** (*struct*) – MATPOWER options struct

Output

nm_elements (*cell array*) – element class modifiers (see tab_element_class_modifiers in the *MATPOWER Developer's Manual*)

mm_element_classes(*mm_class*, *task_tag*, *mpopt*)

Return element class modifiers for mathematical model elements.

```
mm_elements = mpx.mm_element_classes(mm_class, task_tag, mpopt)
```

Inputs
- **mm_class** (*function handle*) – mathematical model constructor
- **task_tag** (*char array*) – task tag, e.g. 'PF', 'CPF', 'OPF'
- **mpopt** (*struct*) – MATPOWER options struct

Output

mm_elements (*cell array*) – element class modifiers (see tab_element_class_modifiers in the *MATPOWER Developer's Manual*)

3.7.2 OPF Fixed Zonal Reserves Extension

mp.xt_reserves

class mp.**xt_reserves**

Bases: *mp.extension* (page 170)

mp.xt_reserves (page 173) - MATPOWER extension for OPF with fixed zonal reserves.

For OPF problems, this extension adds two types of elements to the data and mathematical model containers, as well as the data model converter.

The 'reserve_gen' element handles all of the per-generator aspects, such as reserve cost and quantity limit parameters, reserve variables, and constraints on reserve capacity.

The 'reserve_zone' element handles the per-zone aspects, such as generator/zone mappings, zonal reserve requirement parameters and constraints, and zonal reserve prices.

mp.xt_reserves Methods:

- *dmc_element_classes()* (page 173) - add two classes to data model converter elements
- *dm_element_classes()* (page 173) - add two classes to data model elements
- *mm_element_classes()* (page 174) - add two classes to mathematical model elements

See the sec_customizing and sec_extensions sections in the *MATPOWER Developer's Manual* for more information, and specifically the sec_element_classes section and the tab_element_class_modifiers table for details on *element class modifiers*.

See also *mp.extension* (page 170).

Method Summary

dmc_element_classes(*dmc_class*, *fmt*, *mpopt*)

Add two classes to data model converter elements.

For 'mpc2' data formats, adds the classes:
- *mp.dmce_reserve_gen_mpc2* (page 174)
- *mp.dmce_reserve_zone_mpc2* (page 175)

dm_element_classes(*dm_class*, *task_tag*, *mpopt*)

Add two classes to data model elements.

For `'OPF'` tasks, adds the classes:
- *mp.dme_reserve_gen* (page 175)
- *mp.dme_reserve_zone* (page 176)

mm_element_classes(*mm_class*, *task_tag*, *mpopt*)

Add two classes to mathematical model elements.

For `'OPF'` tasks, adds the classes:
- *mp.mme_reserve_gen* (page 177)
- *mp.mme_reserve_zone* (page 178)

Other classes belonging to *mp.xt_reserves* (page 173) extension:

mp.dmce_reserve_gen_mpc2

class mp.**dmce_reserve_gen_mpc2**

Bases: *mp.dmc_element* (page 62)

mp.dmce_reserve_gen_mpc2 (page 174) - Data model converter element for reserve generator for MATPOWER case v2.

Method Summary

name()

data_field()

data_subs()

get_import_size(*mpc*)

get_export_size(*dme*)

table_var_map(*dme*, *mpc*)

import_cost(*mpc*, *spec*, *vn*)

import_qty(*mpc*, *spec*, *vn*)

import_ramp(*mpc*, *spec*, *vn*)

import(*dme*, *mpc*, *varargin*)

mp.dmce_reserve_zone_mpc2

class mp.**dmce_reserve_zone_mpc2**

Bases: *mp.dmc_element* (page 62)

mp.dmce_reserve_zone_mpc2 (page 175) - Data model converter element for reserve zone for MATPOWER case v2.

Method Summary

name()

data_field()

data_subs()

table_var_map(*dme*, *mpc*)

import_req(*mpc*, *spec*, *vn*)

import_zones(*mpc*, *spec*, *vn*)

mp.dme_reserve_gen

class mp.**dme_reserve_gen**

Bases: *mp.dm_element* (page 35), *mp.dme_shared_opf* (page 58)

mp.dme_reserve_gen (page 175) - Data model element for reserve generator.

Implements the data element model for reserve generator elements.

Adds the following columns in the main data table, found in the `tab` property:

Name	Type	Description
`gen`	*integer*	ID (`uid`) of corresponding generator
`cost`	*double*	reserve cost *(u/MW)*[1]
`qty`	*double*	available reserve quantity *(MW)*
`ramp10`	*double*	10-minute ramp rate *(MW)*
`r`	*double*	r, reserve allocation *(MW)*
`r_lb`	*double*	lower bound on reserve allocation *(MW)*
`r_ub`	*double*	upper bound on reserve allocation *(MW)*
`total_cost`	*double*	total cost of allocated reserves *(u)*[1]
`prc`	*double*	reserve price *(u/MVAr)*[1]
`mu_lb`	*double*	shadow price on r lower bound *(u/MW)*[1]
`mu_ub`	*double*	shadow price on r upper bound *(u/MW)*[1]
`mu_pg_ub`	*double*	shadow price on capacity constraint *(u/MW)*[1]

Property Summary

gen

index of online gens (for online reserve gens)

[1] Here *u* denotes the units of the objective function, e.g. USD.

r_ub

upper bound on reserve qty (p.u.) for units that are on

Method Summary

name()

label()

labels()

main_table_var_names()

export_vars()

export_vars_offline_val()

update_status(*dm*)

build_params(*dm*)

pp_have_section_sum(*mpopt*, *pp_args*)

pp_data_sum(*dm*, *rows*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_have_section_det(*mpopt*, *pp_args*)

pp_get_headers_det(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_data_row_det(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_have_section_lim(*mpopt*, *pp_args*)

pp_binding_rows_lim(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_get_headers_lim(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_data_row_lim(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_get_footers_det(*dm*, *out_e*, *mpopt*, *pp_args*)

mp.dme_reserve_zone

class mp.**dme_reserve_zone**

Bases: *mp.dm_element* (page 35), *mp.dme_shared_opf* (page 58)

mp.dme_reserve_zone (page 176) - Data model element for reserve zone.

Implements the data element model for reserve zone elements.

Adds the following columns in the main data table, found in the `tab` property:

Name	Type	Description
`req`	*double*	zonal reserve requirement *(MW)*
`zones`	*integer*	matrix defining generators included in the zone
`prc`	*double*	zonal reserve price *(u/MW)*[1]

Property Summary

zones
zone map for online *zones* (page 177) / gens

req
reserve requirement in p.u. for each active zone

Method Summary

name()

label()

labels()

main_table_var_names()

export_vars()

export_vars_offline_val()

update_status(*dm*)

build_params(*dm*)

pp_have_section_det(*mpopt*, *pp_args*)

pp_get_headers_det(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_data_row_det(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

mp.mme_reserve_gen

class mp.**mme_reserve_gen**

Bases: *mp.mm_element* (page 143)

mp.mme_reserve_gen (page 177) - Mathematical model element for reserve generator.

Math model element class for reserve generator elements.

Implements methods for adding reserve variables, costs, and per-generator reserve constraints, and for updating the output data in the corresponding data model element for in-service reserve generators from the math model solution.

Method Summary

name()

add_vars(*mm*, *nm*, *dm*, *mpopt*)

add_costs(*mm*, *nm*, *dm*, *mpopt*)

add_constraints(*mm*, *nm*, *dm*, *mpopt*)

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

[1] Here *u* denotes the units of the objective function, e.g. USD.

mp.mme_reserve_zone

class mp.**mme_reserve_zone**

Bases: *mp.mm_element* (page 143)

mp.mme_reserve_zone (page 178) - Mathematical model element for reserve zone.

Math model element class for reserve zone elements.

Implements methods for adding reserve zone constraints, and for updating the output data in the corresponding data model element for in-service reserve zones from the math model solution.

Method Summary

name()

add_constraints(*mm*, *nm*, *dm*, *mpopt*)

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

3.7.3 Three-Phase Prototype Extension

mp.xt_3p

class mp.**xt_3p**

Bases: *mp.extension* (page 170)

mp.xt_3p (page 178) - MATPOWER extension to add unbalanced three-phase elements.

For AC power flow, continuation power flow, and optimial power flow problems, adds six new element types:

- `'bus3p'` - 3-phase bus
- `'gen3p'` - 3-phase generator
- `'load3p'` - 3-phase load
- `'line3p'` - 3-phase distribution line
- `'xfmr3p'` - 3-phase transformer
- `'buslink'` - 3-phase to single phase linking element

No changes are required for the task or container classes, so only the `..._element_classes` methods are overridden.

The set of data model element classes depends on the task, with each OPF class inheriting from the corresponding class used for PF and CPF.

The set of network model element classes depends on the formulation, specifically whether cartesian or polar representations are used for voltages.

And the set of mathematical model element classes depends on both the task and the formulation.

mp.xt_3p Methods:

- *dmc_element_classes()* (page 179) - add six classes to data model converter elements
- *dm_element_classes()* (page 179) - add six classes to data model elements

- *nm_element_classes()* (page 179) - add six classes to network model elements
- *mm_element_classes()* (page 180) - add six classes to mathematical model elements

See the sec_customizing and sec_extensions sections in the *MATPOWER Developer's Manual* for more information, and specifically the sec_element_classes section and the tab_element_class_modifiers table for details on *element class modifiers*.

See also *mp.extension* (page 170).

Method Summary

dmc_element_classes(*dmc_class*, *fmt*, *mpopt*)

Add six classes to data model converter elements.

For 'mpc2' data formats, adds the classes:
- *mp.dmce_bus3p_mpc2* (page 180)
- *mp.dmce_gen3p_mpc2* (page 180)
- *mp.dmce_load3p_mpc2* (page 181)
- *mp.dmce_line3p_mpc2* (page 181)
- *mp.dmce_xfmr3p_mpc2* (page 182)
- *mp.dmce_buslink_mpc2* (page 182)

dm_element_classes(*dm_class*, *task_tag*, *mpopt*)

Add six classes to data model elements.

For 'PF' and 'CPF' tasks, adds the classes:
- *mp.dme_bus3p* (page 182)
- *mp.dme_gen3p* (page 184)
- *mp.dme_load3p* (page 185)
- *mp.dme_line3p* (page 187)
- *mp.dme_xfmr3p* (page 189)
- *mp.dme_buslink* (page 190)

For 'OPF' tasks, adds the classes:
- *mp.dme_bus3p_opf* (page 191)
- *mp.dme_gen3p_opf* (page 191)
- *mp.dme_load3p_opf* (page 192)
- *mp.dme_line3p_opf* (page 192)
- *mp.dme_xfmr3p_opf* (page 192)
- *mp.dme_buslink_opf* (page 192)

nm_element_classes(*nm_class*, *task_tag*, *mpopt*)

Add six classes to network model elements.

For *cartesian* voltage formulations, adds the classes:
- *mp.nme_bus3p_acc* (page 193)
- *mp.nme_gen3p_acc* (page 194)
- *mp.nme_load3p* (page 194)
- *mp.nme_line3p* (page 195)
- *mp.nme_xfmr3p* (page 195)
- *mp.nme_buslink_acc* (page 196)

For *polar* voltage formulations, adds the classes:
- *mp.nme_bus3p_acp* (page 193)
- *mp.nme_gen3p_acp* (page 194)
- *mp.nme_load3p* (page 194)
- *mp.nme_line3p* (page 195)
- *mp.nme_xfmr3p* (page 195)
- *mp.nme_buslink_acp* (page 196)

mm_element_classes(*mm_class*, *task_tag*, *mpopt*)

Add five classes to mathematical model elements.

For 'PF' and 'CPF' tasks, adds the classes:

- mp.mme_bus3p (page 196)
- mp.mme_gen3p (page 197)
- mp.mme_line3p (page 197)
- mp.mme_xfmr3p (page 197)
- mp.mme_buslink_pf_acc (page 198) *(cartesian)* or mp.mme_buslink_pf_acp (page 199) *(polar)*

For 'OPF' tasks, adds the classes:

- mp.mme_bus3p_opf_acc (page 199) *(cartesian)* or mp.mme_bus3p_opf_acp (page 199) *(polar)*
- mp.mme_gen3p_opf (page 200)
- mp.mme_line3p_opf (page 200)
- mp.mme_xfmr3p_opf (page 200)
- mp.mme_buslink_opf_acc (page 201) *(cartesian)* or mp.mme_buslink_opf_acp (page 201) *(polar)*

Data model converter element classes belonging to mp.xt_3p (page 178) extension:

mp.dmce_bus3p_mpc2

class mp.**dmce_bus3p_mpc2**

Bases: mp.dmc_element (page 62)

mp.dmce_bus3p_mpc2 (page 180) - Data model converter element for 3-phase bus for MATPOWER case v2.

Method Summary

name()

data_field()

table_var_map(*dme*, *mpc*)

bus_status_import(*mpc*, *spec*, *vn*, *c*)

mp.dmce_gen3p_mpc2

class mp.**dmce_gen3p_mpc2**

Bases: mp.dmc_element (page 62)

mp.dmce_gen3p_mpc2 (page 180) - Data model converter element for 3-phase generator for MATPOWER case v2.

Method Summary

name()

data_field()

table_var_map(*dme*, *mpc*)

mp.dmce_load3p_mpc2

class mp.**dmce_load3p_mpc2**

Bases: *mp.dmc_element* (page 62)

mp.dmce_load3p_mpc2 (page 181) - Data model converter element for 3-phase load for MATPOWER case v2.

Property Summary

bus

Method Summary

name()

data_field()

table_var_map(*dme*, *mpc*)

mp.dmce_line3p_mpc2

class mp.**dmce_line3p_mpc2**

Bases: *mp.dmc_element* (page 62)

mp.dmce_line3p_mpc2 (page 181) - Data model converter element for 3-phase line for MATPOWER case v2.

Method Summary

name()

data_field()

table_var_map(*dme*, *mpc*)

create_line_construction_table(*dme*, *lc*)

import(*dme*, *mpc*, *varargin*)

mp.dmce_xfmr3p_mpc2

class mp.**dmce_xfmr3p_mpc2**

Bases: *mp.dmc_element* (page 62)

mp.dmce_xfmr3p_mpc2 (page 182) - Data model converter element for 3-phase transformer for MATPOWER case v2.

Method Summary

name()

data_field()

table_var_map(*dme*, *mpc*)

mp.dmce_buslink_mpc2

class mp.**dmce_buslink_mpc2**

Bases: *mp.dmc_element* (page 62)

mp.dmce_buslink_mpc2 (page 182) - Data model converter element for 1-to-3-phase buslink for MATPOWER case v2.

Method Summary

name()

data_field()

table_var_map(*dme*, *mpc*)

Data model element classes belonging to *mp.xt_3p* (page 178) extension:

mp.dme_bus3p

class mp.**dme_bus3p**

Bases: *mp.dm_element* (page 35)

mp.dme_bus3p (page 182) - Data model element for 3-phase bus.

Implements the data element model for 3-phase bus elements.

Adds the following columns in the main data table, found in the `tab` property:

Name	Type	Description
type	*integer*	bus type (1 = PQ, 2 = PV, 3 = ref, 4 = isolated)
base_kv	*double*	base voltage *(kV)*
vm1	*double*	phase 1 voltage magnitude *(p.u.)*
vm2	*double*	phase 2 voltage magnitude *(p.u.)*
vm3	*double*	phase 3 voltage magnitude *(p.u.)*
va1	*double*	phase 1 voltage angle *(degrees)*
va2	*double*	phase 2 voltage angle *(degrees)*
va3	*double*	phase 3 voltage angle *(degrees)*

Property Summary

type

node *type* (page 183) vector for buses that are on

vm1_start

initial phase 1 voltage magnitudes (p.u.) for buses that are on

vm2_start

initial phase 2 voltage magnitudes (p.u.) for buses that are on

vm3_start

initial phase 3 voltage magnitudes (p.u.) for buses that are on

va1_start

initial phase 1 voltage angles (radians) for buses that are on

va2_start

initial phase 2 voltage angles (radians) for buses that are on

va3_start

initial phase 3 voltage angles (radians) for buses that are on

vm_control

true if voltage is controlled, for buses that are on

Method Summary

name()

label()

labels()

main_table_var_names()

init_status(*dm*)

update_status(*dm*)

build_params(*dm*)

pp_have_section_det(*mpopt*, *pp_args*)

pp_get_headers_det(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_data_row_det(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

mp.dme_gen3p

class mp.**dme_gen3p**

Bases: *mp.dm_element* (page 35)

mp.dme_gen3p (page 184) - Data model element for 3-phase generator.

Implements the data element model for 3-phase generator elements.

Adds the following columns in the main data table, found in the `tab` property:

Name	Type	Description
`bus`	*integer*	bus ID (`uid`) of 3-phase bus
`vm1_setpoint`	*double*	phase 1 voltage magnitude setpoint *(p.u.)*
`vm2_setpoint`	*double*	phase 2 voltage magnitude setpoint *(p.u.)*
`vm3_setpoint`	*double*	phase 3 voltage magnitude setpoint *(p.u.)*
`pg1`	*double*	phase 1 active power output *(kW)*
`pg2`	*double*	phase 2 active power output *(kW)*
`pg3`	*double*	phase 3 active power output *(kW)*
`qg1`	*double*	phase 1 reactive power output *(kVAr)*
`qg2`	*double*	phase 2 reactive power output *(kVAr)*
`qg3`	*double*	phase 3 reactive power output *(kVAr)*

Property Summary

bus

bus (page 184) index vector (all gens)

bus_on

vector of indices into online buses for gens that are on

pg1_start

initial phase 1 active power (p.u.) for gens that are on

pg2_start

initial phase 2 active power (p.u.) for gens that are on

pg3_start

initial phase 3 active power (p.u.) for gens that are on

qg1_start

initial phase 1 reactive power (p.u.) for gens that are on

qg2_start

initial phase 2 reactive power (p.u.) for gens that are on

qg3_start

initial phase 3 reactive power (p.u.) for gens that are on

vm1_setpoint

phase 1 generator voltage setpoint for gens that are on

vm2_setpoint
phase 2 generator voltage setpoint for gens that are on

vm3_setpoint
phase 3 generator voltage setpoint for gens that are on

Method Summary

name()

label()

labels()

cxn_type()

cxn_idx_prop()

main_table_var_names()

initialize(*dm*)

update_status(*dm*)

apply_vm_setpoint(*dm*)

build_params(*dm*)

pp_have_section_sum(*mpopt*, *pp_args*)

pp_data_sum(*dm*, *rows*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_have_section_det(*mpopt*, *pp_args*)

pp_get_headers_det(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_data_row_det(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

mp.dme_load3p

class mp.**dme_load3p**

Bases: *mp.dm_element* (page 35)

mp.dme_load3p (page 185) - Data model element for 3-phase load.

Implements the data element model for 3-phase load elements.

Adds the following columns in the main data table, found in the `tab` property:

Name	Type	Description
`bus`	*integer*	bus ID (`uid`) of 3-phase bus
`pd1`	*double*	phase 1 active power demand *(kW)*
`pd2`	*double*	phase 2 active power demand *(kW)*
`pd3`	*double*	phase 3 active power demand *(kW)*
`pf1`	*double*	phase 1 power factor
`pf2`	*double*	phase 2 power factor
`pf3`	*double*	phase 3 power factor

Property Summary

bus

bus (page 186) index vector (all loads)

pd1

phase 1 active power demand (p.u.) for loads that are on

pd2

phase 2 active power demand (p.u.) for loads that are on

pd3

phase 3 active power demand (p.u.) for loads that are on

pf1

phase 1 power factor for loads that are on

pf2

phase 2 power factor for loads that are on

pf3

phase 3 power factor for loads that are on

Method Summary

name()

label()

labels()

cxn_type()

cxn_idx_prop()

main_table_var_names()

initialize(*dm*)

update_status(*dm*)

build_params(*dm*)

pp_have_section_sum(*mpopt*, *pp_args*)

pp_data_sum(*dm*, *rows*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_have_section_det(*mpopt*, *pp_args*)

pp_get_headers_det(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_data_row_det(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

mp.dme_line3p

class mp.**dme_line3p**

Bases: *mp.dm_element* (page 35)

mp.dme_line3p (page 187) - Data model element for 3-phase line.

Implements the data element model for 3-phase distribution line elements.

Adds the following columns in the main data table, found in the `tab` property:

Name	Type	Description
`bus_fr`	*integer*	bus ID (`uid`) of "from" 3-phase bus
`bus_to`	*integer*	bus ID (`uid`) of "to" 3-phase bus
`lc`	*double*	index into line construction table
`len`	*double*	line length *(miles)*
`pl1_fr`	*double*	phase 1 active power injection at "from" end *(kW)*
`ql1_fr`	*double*	phase 1 reactive power injection at "from" end *(kVAr)*
`pl2_fr`	*double*	phase 2 active power injection at "from" end *(kW)*
`ql2_fr`	*double*	phase 2 reactive power injection at "from" end *(kVAr)*
`pl3_fr`	*double*	phase 3 active power injection at "from" end *(kW)*
`ql3_fr`	*double*	phase 3 reactive power injection at "from" end *(kVAr)*
`pl1_to`	*double*	phase 1 active power injection at "to" end *(kW)*
`ql1_to`	*double*	phase 1 reactive power injection at "to" end *(kVAr)*
`pl2_to`	*double*	phase 2 active power injection at "to" end *(kW)*
`ql2_to`	*double*	phase 2 reactive power injection at "to" end *(kVAr)*
`pl3_to`	*double*	phase 3 active power injection at "to" end *(kW)*
`ql3_to`	*double*	phase 3 reactive power injection at "to" end *(kVAr)*

The line construction table in the `lc_tab` property is defined as a table with the following columns:

Name	Type	Description
`id`	*integer*	unique line construction ID, referenced from `lc` column of main data table
`r`	*double*	6 resistence parameters for forming symmetric 3x3 series impedance matrix *(p.u. per mile)*
`x`	*double*	6 reactance parameters for forming symmetric 3x3 series impedance matrix *(p.u. per mile)*
`c`	*double*	6 susceptance parameters for forming symmetric 3x3 shunt susceptance matrix *(nF per mile)*

Property Summary

fbus

bus index vector for "from" bus (all lines)

tbus

bus index vector for "to" bus (all lines)

freq

system frequency, in Hz

lc
index into lc_tab for lines that are on

len
length for lines that are on

lc_tab
line construction table

ys
cell array of 3x3 series admittance matrices for lc rows

yc
cell array of 3x3 shunt admittance matrices for lc rows

Method Summary

name()

label()

labels()

cxn_type()

cxn_idx_prop()

main_table_var_names()

lc_table_var_names()

create_line_construction_table(*id*, *r*, *x*, *c*)

initialize(*dm*)

update_status(*dm*)

build_params(*dm*)

vec2symmat(*v*)
Make a symmetric matrix from a vector of 6 values.

symmat2vec(*M*)
Extract a vector of 6 values from a matrix assumed to be symmetric.

pretty_print(*dm*, *section*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_have_section_sum(*mpopt*, *pp_args*)

pp_data_sum(*dm*, *rows*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_have_section_det(*mpopt*, *pp_args*)

pp_get_headers_det(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_data_row_det(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

mp.dme_xfmr3p

class mp.**dme_xfmr3p**

Bases: *mp.dm_element* (page 35)

mp.dme_xfmr3p (page 189) - Data model element for 3-phase transformer.

Implements the data element model for 3-phase transformer elements.

Adds the following columns in the main data table, found in the `tab` property:

Name	Type	Description
`bus_fr`	*integer*	bus ID (`uid`) of "from" 3-phase bus
`bus_to`	*integer*	bus ID (`uid`) of "to" 3-phase bus
`r`	*double*	series resistance *(p.u.)*
`x`	*double*	series reactance *(p.u.)*
`base_kva`	*double*	transformer kVA base *(kVA)*
`base_kv`	*double*	transformer kV base *(kV)*
`pl1_fr`	*double*	phase 1 active power injection at "from" end *(kW)*
`ql1_fr`	*double*	phase 1 reactive power injection at "from" end *(kVAr)*
`pl2_fr`	*double*	phase 2 active power injection at "from" end *(kW)*
`ql2_fr`	*double*	phase 2 reactive power injection at "from" end *(kVAr)*
`pl3_fr`	*double*	phase 3 active power injection at "from" end *(kW)*
`ql3_fr`	*double*	phase 3 reactive power injection at "from" end *(kVAr)*
`pl1_to`	*double*	phase 1 active power injection at "to" end *(kW)*
`ql1_to`	*double*	phase 1 reactive power injection at "to" end *(kVAr)*
`pl2_to`	*double*	phase 2 active power injection at "to" end *(kW)*
`ql2_to`	*double*	phase 2 reactive power injection at "to" end *(kVAr)*
`pl3_to`	*double*	phase 3 active power injection at "to" end *(kW)*
`ql3_to`	*double*	phase 3 reactive power injection at "to" end *(kVAr)*

Property Summary

fbus

bus index vector for "from" bus (all transformers)

tbus

bus index vector for "to" bus (all transformers)

r

series resistance (p.u.) for transformers that are on

x

series reactance (p.u.) for transformers that are on

Method Summary

name()

label()

labels()

cxn_type()

cxn_idx_prop()

main_table_var_names()

initialize(*dm*)

update_status(*dm*)

build_params(*dm*)

pretty_print(*dm*, *section*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_have_section_sum(*mpopt*, *pp_args*)

pp_data_sum(*dm*, *rows*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_have_section_det(*mpopt*, *pp_args*)

pp_get_headers_det(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_data_row_det(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

mp.dme_buslink

class mp.**dme_buslink**

Bases: *mp.dm_element* (page 35)

mp.dme_buslink (page 190) - Data model element for 1-to-3-phase buslink.

Implements the data element model for 1-to-3-phase buslink elements.

Adds the following columns in the main data table, found in the `tab` property:

Name	Type	Description
`bus`	*integer*	bus ID (`uid`) of single phase bus
`bus3p`	*integer*	bus ID (`uid`) of 3-phase bus

Property Summary

bus

bus (page 190) index vector (all buslinks)

bus3p

bus3p (page 190) index vector (all buslinks)

pg1_start

initial phase 1 active power (p.u.) for buslinks that are on

pg2_start

initial phase 2 active power (p.u.) for buslinks that are on

pg3_start

initial phase 3 active power (p.u.) for buslinks that are on

qg1_start

initial phase 1 reactive power (p.u.) for buslinks that are on

qg2_start
initial phase 2 reactive power (p.u.) for buslinks that are on

qg3_start
initial phase 3 reactive power (p.u.) for buslinks that are on

Method Summary

name()

label()

labels()

cxn_type()

cxn_idx_prop()

main_table_var_names()

initialize(*dm*)

update_status(*dm*)

build_params(*dm*)

pp_have_section_det(*mpopt*, *pp_args*)

pp_get_headers_det(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_data_row_det(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

mp.dme_bus3p_opf

class mp.**dme_bus3p_opf**

Bases: *mp.dme_bus3p* (page 182), *mp.dme_shared_opf* (page 58)

mp.dme_bus3p_opf (page 191) - Data model element for 3-phase bus for OPF.

To parent class *mp.dme_bus3p* (page 182), adds pretty-printing for **lim** sections.

mp.dme_gen3p_opf

class mp.**dme_gen3p_opf**

Bases: *mp.dme_gen3p* (page 184), *mp.dme_shared_opf* (page 58)

mp.dme_gen3p_opf (page 191) - Data model element for 3-phase generator for OPF.

To parent class *mp.dme_gen3p* (page 184), adds pretty-printing for **lim** sections.

mp.dme_load3p_opf

class mp.**dme_load3p_opf**

Bases: *mp.dme_load3p* (page 185), *mp.dme_shared_opf* (page 58)

mp.dme_load3p_opf (page 192) - Data model element for 3-phase load for OPF.

To parent class *mp.dme_load3p* (page 185), adds pretty-printing for **lim** sections.

mp.dme_line3p_opf

class mp.**dme_line3p_opf**

Bases: *mp.dme_line3p* (page 187), *mp.dme_shared_opf* (page 58)

mp.dme_line3p_opf (page 192) - Data model element for 3-phase line for OPF.

To parent class *mp.dme_line3p* (page 187), adds pretty-printing for **lim** sections.

mp.dme_xfmr3p_opf

class mp.**dme_xfmr3p_opf**

Bases: *mp.dme_xfmr3p* (page 189), *mp.dme_shared_opf* (page 58)

mp.dme_xfmr3p_opf (page 192) - Data model element for 3-phase transformer for OPF.

To parent class *mp.dme_xfmr3p* (page 189), adds pretty-printing for **lim** sections.

mp.dme_buslink_opf

class mp.**dme_buslink_opf**

Bases: *mp.dme_buslink* (page 190), *mp.dme_shared_opf* (page 58)

mp.dme_buslink_opf (page 192) - Data model element for 1-to-3-phase buslink for OPF.

To parent class *mp.dme_buslink* (page 190), adds pretty-printing for **lim** sections.

Network model element classes belonging to *mp.xt_3p* (page 178) extension:

mp.nme_bus3p

class mp.**nme_bus3p**

Bases: *mp.nm_element* (page 107)

mp.nme_bus3p (page 192) - Network model element abstract base class for 3-phase bus.

Implements the network model element for 3-phase bus elements, with 3 nodes per 3-phase bus.

Implements *node_types()* (page 193) method.

Method Summary

name()

nn()

node_types(*nm*, *dm*, *idx*)

```
ntv = nme.node_types(nm, dm, idx)
[ref, pv, pq] = nme.node_types(nm, dm, idx)
```

Called by the *node_types()* (page 98) method of *mp.net_model* (page 90).

mp.nme_bus3p_acc

class mp.**nme_bus3p_acc**

Bases: *mp.nme_bus3p* (page 192), *mp.form_acc* (page 82)

mp.nme_bus3p_acc (page 193) - Network model element for 3-phase bus, AC cartesian voltage formulation.

Adds voltage variables `Vr3` and `Vi3` to the network model and inherits from *mp.form_acc* (page 82).

Method Summary

add_vvars(*nm*, *dm*, *idx*)

mp.nme_bus3p_acp

class mp.**nme_bus3p_acp**

Bases: *mp.nme_bus3p* (page 192), *mp.form_acp* (page 86)

mp.nme_bus3p_acp (page 193) - Network model element for 3-phase bus, AC polar voltage formulation.

Adds voltage variables `Va3` and `Vm3` to the network model and inherits from *mp.form_acp* (page 86).

Method Summary

add_vvars(*nm*, *dm*, *idx*)

mp.nme_gen3p

class mp.**nme_gen3p**

Bases: *mp.nm_element* (page 107)

mp.nme_gen3p (page 193) - Network model element abstract base class for 3-phase generator.

Implements the network model element for 3-phase generator elements, with 3 ports and 3 non-voltage states per 3-phase generator.

Adds non-voltage state variables `Pg3` and `Qg3` to the network model and builds the parameter $\underline{\mathbf{N}}$.

Method Summary

name()

np()

nz()

add_zvars(*nm*, *dm*, *idx*)

build_params(*nm*, *dm*)

mp.nme_gen3p_acc

class mp.**nme_gen3p_acc**

Bases: *mp.nme_gen3p* (page 193), *mp.form_acc* (page 82)

mp.nme_gen3p_acc (page 194) - Network model element for 3-phase generator, AC cartesian voltage formulation.

Inherits from *mp.form_acc* (page 82).

mp.nme_gen3p_acp

class mp.**nme_gen3p_acp**

Bases: *mp.nme_gen3p* (page 193), *mp.form_acp* (page 86)

mp.nme_gen3p_acp (page 194) - Network model element for 3-phase generator, AC polar voltage formulation.

Inherits from *mp.form_acp* (page 86).

mp.nme_load3p

class mp.**nme_load3p**

Bases: *mp.nm_element* (page 107), *mp.form_acp* (page 86)

mp.nme_load3p (page 194) - Network model element for 3-phase load.

Implements the network model element for 3-phase load elements, with 3 ports per 3-phase load.

Builds the parameter s and inherits from *mp.form_acp* (page 86).

Method Summary

name()

np()

build_params(*nm*, *dm*)

mp.nme_line3p

class mp.**nme_line3p**

Bases: *mp.nm_element* (page 107), *mp.form_acp* (page 86)

mp.nme_line3p (page 195) - Network model element for 3-phase line.

Implements the network model element for 3-phase line elements, with 6 ports per 3-phase line.

Implements building of the admittance parameter $\underline{\mathbf{Y}}$ for 3-phase lines and inherits from *mp.form_acp* (page 86).

Method Summary

name()

np()

build_params(*nm*, *dm*)

vec2symmat_stacked(*vv*)

mp.nme_xfmr3p

class mp.**nme_xfmr3p**

Bases: *mp.nm_element* (page 107), *mp.form_acp* (page 86)

mp.nme_xfmr3p (page 195) - Network model element for 3-phase transformer.

Implements the network model element for 3-phase transformer elements, with 6 ports per transformer.

Implements building of the admittance parameter $\underline{\mathbf{Y}}$ for 3-phase transformers and inherits from *mp.form_acp* (page 86).

Method Summary

name()

np()

build_params(*nm*, *dm*)

mp.nme_buslink

class mp.**nme_buslink**

Bases: *mp.nm_element* (page 107)

mp.nme_buslink (page 195) - Network model element abstract base class for 1-to-3-phase buslink.

Implements the network model element for 1-to-3-phase buslink elements, with 4 ports and 3 non-voltage states per buslink.

Adds non-voltage state variables `Plink` and `Qlink` to the network model, builds the parameter $\underline{\mathbf{N}}$, and constructs voltage constraints.

Method Summary

name()

np()

nz()

add_zvars(*nm*, *dm*, *idx*)

build_params(*nm*, *dm*)

voltage_constraints()

mp.nme_buslink_acc

class mp.**nme_buslink_acc**

Bases: *mp.nme_buslink* (page 195), *mp.form_acc* (page 82)

mp.nme_buslink_acc (page 196) - Network model element for 1-to-3-phase buslink, AC cartesian voltage formulation.

Inherits from *mp.form_acc* (page 82).

mp.nme_buslink_acp

class mp.**nme_buslink_acp**

Bases: *mp.nme_buslink* (page 195), *mp.form_acp* (page 86)

mp.nme_buslink_acp (page 196) - Network model element for 1-to-3-phase buslink, AC polar voltage formulation.

Inherits from *mp.form_acp* (page 86).

Mathematical model element classes belonging to *mp.xt_3p* (page 178) extension:

mp.mme_bus3p

class mp.**mme_bus3p**

Bases: *mp.mm_element* (page 143)

mp.mme_bus3p (page 196) - Math model element for 3-phase bus.

Math model element base class for 3-phase bus elements.

Implements method for updating the output data in the corresponding data model element for in-service 3-phase buses from the math model solution.

Method Summary

name()

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_gen3p

class mp.**mme_gen3p**

Bases: *mp.mm_element* (page 143)

mp.mme_gen3p (page 197) - Math model element for 3-phase generator.

Math model element base class for 3-phase generator elements.

Implements method for updating the output data in the corresponding data model element for in-service 3-phase generators from the math model solution.

Method Summary

name()

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_line3p

class mp.**mme_line3p**

Bases: *mp.mm_element* (page 143)

mp.mme_line3p (page 197) - Math model element for 3-phase line.

Math model element base class for 3-phase line elements.

Implements method for updating the output data in the corresponding data model element for in-service 3-phase lines from the math model solution.

Method Summary

name()

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_xfmr3p

class mp.**mme_xfmr3p**

Bases: *mp.mm_element* (page 143)

mp.mme_xfmr3p (page 197) - Math model element for 3-phase transformer.

Math model element base class for 3-phase transformer elements.

Implements method for updating the output data in the corresponding data model element for in-service 3-phase transformers from the math model solution.

Method Summary

name()

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_buslink

class mp.**mme_buslink**

Bases: *mp.mm_element* (page 143)

mp.mme_buslink (page 198) - Math model element abstract base class for 1-to-3-phase buslink.

Abstract math model element base class for 1-to-3-phase buslink elements.

Method Summary

name()

mp.mme_buslink_pf_ac

class mp.**mme_buslink_pf_ac**

Bases: *mp.mme_buslink* (page 198)

mp.mme_buslink_pf_ac (page 198) - Math model element abstract base class for 1-to-3-phase buslink for AC PF/CPF.

Abstract math model element base class for 1-to-3-phase buslink elements for AC power flow and CPF problems.

Implements methods for adding per-phase active and reactive power variables and for forming and adding voltage and reactive power constraints.

Method Summary

add_vars(*mm*, *nm*, *dm*, *mpopt*)

add_constraints(*mm*, *nm*, *dm*, *mpopt*)

voltage_constraints(*nme*, *ad*)

mp.mme_buslink_pf_acc

class mp.**mme_buslink_pf_acc**

Bases: *mp.mme_buslink_pf_ac* (page 198)

mp.mme_buslink_pf_acc (page 198) - Math model element for 1-to-3-phase buslink for AC cartesian voltage PF/CPF.

Math model element class for 1-to-3-phase buslink elements for AC cartesian power flow and CPF problems.

Implements methods for adding constraints to match voltages across each buslink.

Method Summary

add_constraints(*mm*, *nm*, *dm*, *mpopt*)

pf_va_fcn(*nme*, *xx*, *A*, *b*)

pf_vm_fcn(*nme*, *xx*, *A*, *b*)

mp.mme_buslink_pf_acp

class mp.**mme_buslink_pf_acp**

Bases: *mp.mme_buslink_pf_ac* (page 198)

mp.mme_buslink_pf_acp (page 199) - Math model element for 1-to-3-phase buslink for AC polar voltage PF/CPF.

Math model element class for 1-to-3-phase buslink elements for AC polar power flow and CPF problems.

Implements method for adding constraints to match voltages across each buslink.

Method Summary

add_constraints(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_bus3p_opf_acc

class mp.**mme_bus3p_opf_acc**

Bases: *mp.mme_bus3p* (page 196)

mp.mme_bus3p_opf_acc (page 199) - Math model element for 3-phase bus for AC cartesian voltage OPF.

Math model element class for 3-phase bus elements for AC cartesian voltage OPF problems.

Implements method for forming an interior initial point.

Method Summary

interior_x0(*mm*, *nm*, *dm*, *x0*)

mp.mme_bus3p_opf_acp

class mp.**mme_bus3p_opf_acp**

Bases: *mp.mme_bus3p* (page 196)

mp.mme_bus3p_opf_acp (page 199) - Math model element for 3-phase bus for AC polar voltage OPF.

Math model element class for 3-phase bus elements for AC polar voltage OPF problems.

Implements method for forming an interior initial point.

Method Summary

interior_x0(*mm*, *nm*, *dm*, *x0*)

mp.mme_gen3p_opf

class mp.**mme_gen3p_opf**

Bases: *mp.mme_gen3p* (page 197)

mp.mme_gen3p_opf (page 200) - Math model element for 3-phase generator for OPF.

Math model element class for 1-to-3-phase generator elements for OPF problems.

Implements (currently empty) method for forming an interior initial point.

Method Summary

interior_x0(*mm*, *nm*, *dm*, *x0*)

mp.mme_line3p_opf

class mp.**mme_line3p_opf**

Bases: *mp.mme_line3p* (page 197)

mp.mme_line3p_opf (page 200) - Math model element for 3-phase line for OPF.

Math model element class for 3-phase line elements for OPF problems.

Implements (currently empty) method for forming an interior initial point.

Method Summary

interior_x0(*mm*, *nm*, *dm*, *x0*)

mp.mme_xfmr3p_opf

class mp.**mme_xfmr3p_opf**

Bases: *mp.mme_xfmr3p* (page 197)

mp.mme_xfmr3p_opf (page 200) - Math model element for 3-phase transformer for OPF.

Math model element class for 3-phase transformer elements for OPF problems.

Implements (currently empty) method for forming an interior initial point.

Method Summary

interior_x0(*mm*, *nm*, *dm*, *x0*)

mp.mme_buslink_opf

class mp.**mme_buslink_opf**

Bases: *mp.mme_buslink* (page 198)

mp.mme_buslink_opf (page 201) - Math model element abstract base class for 1-to-3-phase buslink for OPF.

Abstract math model element base class for 1-to-3-phase buslink elements for OPF problems.

Implements (currently empty) method for forming an interior initial point.

Method Summary

interior_x0(*mm*, *nm*, *dm*, *x0*)

mp.mme_buslink_opf_acc

class mp.**mme_buslink_opf_acc**

Bases: *mp.mme_buslink_opf* (page 201)

mp.mme_buslink_opf_acc (page 201) - Math model element for 1-to-3-phase buslink for AC cartesian voltage OPF.

Math model element class for 1-to-3-phase buslink elements for AC cartesian OPF problems.

Implements methods for adding constraints to match voltages across each buslink.

Method Summary

add_constraints(*mm*, *nm*, *dm*, *mpopt*)

va_fcn(*nme*, *xx*, *A*, *b*)

va_hess(*nme*, *xx*, *lam*, *A*)

vm2_fcn(*nme*, *xx*, *A*, *b*)

vm2_hess(*nme*, *xx*, *lam*, *A*)

mp.mme_buslink_opf_acp

class mp.**mme_buslink_opf_acp**

Bases: *mp.mme_buslink_opf* (page 201)

mp.mme_buslink_opf_acp (page 201) - Math model element for 1-to-3-phase buslink for AC polar voltage OPF.

Math model element class for 1-to-3-phase buslink elements for AC polar OPF problems.

Implements method for adding constraints to match voltages across each buslink.

Method Summary

add_constraints(*mm*, *nm*, *dm*, *mpopt*)

3.7.4 Legacy DC Line Extension

For more details, see howto_element.

mp.xt_legacy_dcline

class mp.**xt_legacy_dcline**

Bases: *mp.extension* (page 170)

mp.xt_legacy_dcline (page 202) - MATPOWER extension to add legacy DC line elements.

For AC and DC power flow, continuation power flow, and optimial power flow problems, adds a new element type:

- `'legacy_dcline'` - legacy DC line

No changes are required for the task or container classes, so only the `..._element_classes` methods are overridden.

The set of data model element classes depends on the task, with each OPF class inheriting from the corresponding class used for PF and CPF.

The set of network model element classes depends on the formulation, specifically whether cartesian or polar representations are used for voltages.

And the set of mathematical model element classes depends on both the task and the formulation.

mp.xt_legacy_dcline Methods:

- *dmc_element_classes()* (page 202) - add a class to data model converter elements
- *dm_element_classes()* (page 202) - add a class to data model elements
- *nm_element_classes()* (page 202) - add a class to network model elements
- *mm_element_classes()* (page 203) - add a class to mathematical model elements

See the sec_customizing and sec_extensions sections in the *MATPOWER Developer's Manual* for more information, and specifically the sec_element_classes section and the tab_element_class_modifiers table for details on *element class modifiers*.

See also *mp.extension* (page 170).

Method Summary

dmc_element_classes(*dmc_class*, *fmt*, *mpopt*)

Add a class to data model converter elements.

For `'mpc2` data formats, adds the classes:
- *mp.dmce_legacy_dcline_mpc2* (page 203)

dm_element_classes(*dm_class*, *task_tag*, *mpopt*)

Add a class to data model elements.

For `'PF'` and `'CPF'` tasks, adds the class:
- *mp.dme_legacy_dcline* (page 204)

For `'OPF'` tasks, adds the class:
- *mp.dme_legacy_dcline_opf* (page 206)

nm_element_classes(*nm_class*, *task_tag*, *mpopt*)

Add a class to network model elements.

For DC formulations, adds the class:
- *mp.nme_legacy_dcline_dc* (page 208)

For AC *cartesian* voltage formulations, adds the class:
- *mp.nme_legacy_dcline_acc* (page 208)

For AC *polar* voltage formulations, adds the class:
- *mp.nme_legacy_dcline_acp* (page 208)

mm_element_classes(*mm_class*, *task_tag*, *mpopt*)

Add a class to mathematical model elements.

For 'PF' and 'CPF' tasks, adds the class:
- *mp.mme_legacy_dcline_pf_dc* (page 209) *(DC formulation)* or
- *mp.mme_legacy_dcline_pf_ac* (page 209) *(AC formulation)*

For 'OPF' tasks, adds the class:
- *mp.mme_legacy_dcline_opf_dc* (page 210) *(DC formulation)* or
- *mp.mme_legacy_dcline_opf_ac* (page 210) *(AC formulation)*

Data model converter element class belonging to *mp.xt_legacy_dcline* (page 202) extension:

mp.dmce_legacy_dcline_mpc2

class mp.**dmce_legacy_dcline_mpc2**

Bases: *mp.dmc_element* (page 62)

mp.dmce_legacy_dcline_mpc2 (page 203) - Data model converter element for legacy DC line for MATPOWER case v2.

Method Summary

name()

data_field()

table_var_map(*dme*, *mpc*)

default_export_data_table(*spec*)

dcline_cost_import(*mpc*, *spec*, *vn*)

dcline_cost_export(*dme*, *mpc*, *spec*, *vn*, *ridx*)

Data model element classes belonging to *mp.xt_legacy_dcline* (page 202) extension:

mp.dme_legacy_dcline

class mp.**dme_legacy_dcline**

Bases: *mp.dm_element* (page 35)

mp.dme_legacy_dcline (page 204) - Data model element for legacy DC line.

Implements the data element model for legacy DC line elements, with linear line losses.

$$p_{\text{loss}} = \underline{l}_0 + \underline{l}_1 p_{\text{fr}}$$

Adds the following columns in the main data table, found in the `tab` property:

Name	Type	Description
`bus_fr`	*integer*	bus ID (`uid`) of "from" bus
`bus_to`	*integer*	bus ID (`uid`) of "to" bus
`loss0`	*double*	$\underline{l}_0$, constant term of loss function (MW)
`loss1`	*double*	$\underline{l}_1$, linear coefficient of loss function (MW/MW)
`vm_setpoint_fr`	*double*	per unit "from" bus voltage magnitude setpoint
`vm_setpoint_to`	*double*	per unit "to" bus voltage magnitude setpoint
`p_fr_lb`	*double*	lower bound on MW flow at "from" port
`p_fr_ub`	*double*	upper bound on MW flow at "from" port
`q_fr_lb`	*double*	lower bound on MVAr injection into "from" bus
`q_fr_ub`	*double*	upper bound on MVAr injection into "from" bus
`q_to_lb`	*double*	lower bound on MVAr injection into "to" bus
`q_to_ub`	*double*	upper bound on MVAr injection into "to" bus
`p_fr`	*double*	MW flow at "from" end ("from" –> "to")
`q_fr`	*double*	MVAr injection into "from" bus
`p_to`	*double*	MW flow at "to" end ("from" –> "to")
`q_to`	*double*	MVAr injection into "to" bus

Property Summary

fbus

bus index vector for "from" port (port 1) (all DC lines)

tbus

bus index vector for "to" port (port 2) (all DC lines)

fbus_on

vector of "from" bus indices into online buses (in-service DC lines)

tbus_on

vector of "to" bus indices into online buses (in-service DC lines)

loss0

constant term of loss function (p.u.) (in-service DC lines)

loss1

linear coefficient of loss function (in-service DC lines)

p_fr_start

initial active power (p.u.) at "from" port (in-service DC lines)

p_to_start

initial active power (p.u.) at "to" port (in-service DC lines)

q_fr_start
initial reactive power (p.u.) at "from" port (in-service DC lines)

q_to_start
initial reactive power (p.u.) at "to" port (in-service DC lines)

vm_setpoint_fr
from bus voltage magnitude setpoint (p.u.) (in-service DC lines)

vm_setpoint_to
to bus voltage magnitude setpoint (p.u.) (in-service DC lines)

p_fr_lb
p.u. lower bound on active power flow at "from" port (in-service DC lines)

p_fr_ub
p.u. upper bound on active power flow at "from" port (in-service DC lines)

q_fr_lb
p.u. lower bound on reactive power flow at "from" port (in-service DC lines)

q_fr_ub
p.u. upper bound on reactive power flow at "from" port (in-service DC lines)

q_to_lb
p.u. lower bound on reactive power flow at "to" port (in-service DC lines)

q_to_ub
p.u. upper bound on reactive power flow at "to" port (in-service DC lines)

Method Summary

name()

label()

labels()

cxn_type()

cxn_idx_prop()

main_table_var_names()

export_vars()

export_vars_offline_val()

have_cost()

initialize(*dm*)

update_status(*dm*)

apply_vm_setpoints(*dm*)

build_params(*dm*)

pp_have_section_sum(*mpopt*, *pp_args*)

pp_data_sum(*dm*, *rows*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_get_headers_det(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_have_section_det(*mpopt*, *pp_args*)

pp_data_row_det(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

mp.dme_legacy_dcline_opf

class mp.**dme_legacy_dcline_opf**

Bases: *mp.dme_legacy_dcline* (page 204), *mp.dme_shared_opf* (page 58)

mp.dme_legacy_dcline_opf (page 206) - Data model element for legacy DC line for OPF.

To parent class *mp.dme_legacy_dcline* (page 204), adds costs, shadow prices on active and reactive flow limits, and pretty-printing for **lim** sections.

Adds the following columns in the main data table, found in the `tab` property:

Name	Type	Description
`cost_pg`	*mp.cost_table*	cost of active power flow *(u/MW)*[1]
`mu_p_fr_lb`	*double*	shadow price on MW flow lower bound at "from" end *(u/MW)*[1]
`mu_p_fr_ub`	*double*	shadow price on MW flow upper bound at "from" end *(u/MW)*[1]
`mu_q_fr_lb`	*double*	shadow price on lower bound of MVAr injection at "from" bus *(u/degree)*[1]
`mu_q_fr_ub`	*double*	shadow price on upper bound of MVAr injection at "from" bus *(u/degree)*[1]
`mu_q_to_lb`	*double*	shadow price on lower bound of MVAr injection at "to" bus *(u/degree)*[1]
`mu_q_to_ub`	*double*	shadow price on upper bound of MVAr injection at "to" bus *(u/degree)*[1]

Method Summary

main_table_var_names()

export_vars()

export_vars_offline_val()

have_cost()

build_cost_params(*dm*)

pretty_print(*dm*, *section*, *out_e*, *mpopt*, *fd*, *pp_args*)

pp_have_section_lim(*mpopt*, *pp_args*)

pp_binding_rows_lim(*dm*, *out_e*, *mpopt*, *pp_args*)

[1] Here *u* denotes the units of the objective function, e.g. USD.

pp_get_headers_lim(*dm*, *out_e*, *mpopt*, *pp_args*)

pp_data_row_lim(*dm*, *k*, *out_e*, *mpopt*, *fd*, *pp_args*)

Network model element classes belonging to *mp.xt_legacy_dcline* (page 202) extension:

mp.nme_legacy_dcline

class mp.**nme_legacy_dcline**

Bases: *mp.nm_element* (page 107)

mp.nme_legacy_dcline (page 207) - Network model element abstract base class for legacy DC line.

Implements the network model element for legacy DC line elements, with 2 ports and 2 non-voltage states per DC line.

Method Summary

name()

np()

nz()

mp.nme_legacy_dcline_ac

class mp.**nme_legacy_dcline_ac**

Bases: *mp.nme_legacy_dcline* (page 207)

mp.nme_legacy_dcline_ac (page 207) - Network model element abstract base class for legacy DC line for AC formulation.

Adds non-voltage state variables `Pdcf`, `Qdcf`, `Pdct`, and `Qdct` to the network model and builds the parameter $\underline{\mathbf{N}}$.

Method Summary

add_zvars(*nm*, *dm*, *idx*)

build_params(*nm*, *dm*)

mp.nme_legacy_dcline_acc

class mp.**nme_legacy_dcline_acc**

Bases: *mp.nme_legacy_dcline_ac* (page 207), *mp.form_acc* (page 82)

mp.nme_legacy_dcline_acc (page 208) - Network model element for legacy DC line for for AC cartesian voltage formulations.

Inherits from *mp.form_acc* (page 82).

mp.nme_legacy_dcline_acp

class mp.**nme_legacy_dcline_acp**

Bases: *mp.nme_legacy_dcline_ac* (page 207), *mp.form_acp* (page 86)

mp.nme_legacy_dcline_acp (page 208) - Network model element for legacy DC line for for AC polar voltage formulations.

Inherits from *mp.form_acp* (page 86).

mp.nme_legacy_dcline_dc

class mp.**nme_legacy_dcline_dc**

Bases: *mp.nme_legacy_dcline* (page 207), *mp.form_dc* (page 88)

mp.nme_legacy_dcline_dc (page 208) - Network model element for legacy DC line for DC formulation.

Adds non-voltage state variables `Pdcf` and `Pdct` to the network model and builds the parameter $\underline{\boldsymbol{K}}$.

Method Summary

add_zvars(*nm*, *dm*, *idx*)

build_params(*nm*, *dm*)

Mathematical model element classes belonging to *mp.xt_legacy_dcline* (page 202) extension:

mp.mme_legacy_dcline

class mp.**mme_legacy_dcline**

Bases: *mp.mm_element* (page 143)

mp.mme_legacy_dcline (page 208) - Math model element abstract base class for legacy DC line.

Abstract math model element base class for legacy DC line elements.

Method Summary

name()

mp.mme_legacy_dcline_pf_ac

class mp.**mme_legacy_dcline_pf_ac**

Bases: *mp.mme_legacy_dcline* (page 208)

mp.mme_legacy_dcline_pf_ac (page 209) - Math model element for legacy DC line for AC power flow.

Math model element class for legacy DC line elements for AC power flow problems.

Implements method for updating the output data in the corresponding data model element for in-service DC lines from the math model solution.

Method Summary

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_legacy_dcline_pf_dc

class mp.**mme_legacy_dcline_pf_dc**

Bases: *mp.mme_legacy_dcline* (page 208)

mp.mme_legacy_dcline_pf_dc (page 209) - Math model element for legacy DC line for DC power flow.

Math model element class for legacy DC line elements for DC power flow problems.

Implements method for updating the output data in the corresponding data model element for in-service DC lines from the math model solution.

Method Summary

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_legacy_dcline_opf

class mp.**mme_legacy_dcline_opf**

Bases: *mp.mme_legacy_dcline* (page 208)

mp.mme_legacy_dcline_opf (page 209) - Math model element abstract base class for legacy DC line for OPF.

Math model element abstract base class for legacy DC line elements for OPF problems.

Implements methods to add costs, including piecewise linear cost variables, and to form an interior initial point for cost variables.

Property Summary

cost

struct for *cost* (page 209) parameters with fields:
- `poly` - polynomial costs for active power, struct with fields:
  - `have_quad_cost`
  - `i0`, `i1`, `i2`, `i3`
  - `k`, `c`, `Q`

- pwl - piecewise linear costs for actve power, struct with fields:
  - n, i, A, b

Method Summary

build_cost_params(*dm*)

add_vars(*mm*, *nm*, *dm*, *mpopt*)

add_constraints(*mm*, *nm*, *dm*, *mpopt*)

add_costs(*mm*, *nm*, *dm*, *mpopt*)

interior_x0(*mm*, *nm*, *dm*, *x0*)

mp.mme_legacy_dcline_opf_ac

class mp.**mme_legacy_dcline_opf_ac**

Bases: *mp.mme_legacy_dcline_opf* (page 209)

mp.mme_legacy_dcline_opf_ac (page 210) - Math model element for legacy DC line for AC OPF.

Math model element class for legacy DC line elements for AC OPF problems.

Implements method for updating the output data in the corresponding data model element for in-service DC lines from the math model solution.

Method Summary

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

mp.mme_legacy_dcline_opf_dc

class mp.**mme_legacy_dcline_opf_dc**

Bases: *mp.mme_legacy_dcline_opf* (page 209)

mp.mme_legacy_dcline_opf_dc (page 210) - Math model element for legacy DC line for DC OPF.

Math model element class for legacy DC line elements for DC OPF problems.

Implements method for updating the output data in the corresponding data model element for in-service DC lines from the math model solution.

Method Summary

data_model_update_on(*mm*, *nm*, *dm*, *mpopt*)

3.7.5 Example User Constraint Extension

For more details, see howto_add_constraint.

mp.xt_oval_cap_curve

class mp.**xt_oval_cap_curve**

Bases: *mp.extension* (page 170)

mp.xt_oval_cap_curve (page 211) - MATPOWER extension for OPF with oval gen PQ capability curves.

For OPF problems, this extension restricts the output of each generator to lie within the half-oval-shaped region centered at (PMIN, Q0) and passing though (PMAX, Q0), (PMIN, QMIN) and (PMIN, QMAX).

mp.xt_oval_cap_curve Methods:

- *mm_element_classes()* (page 211) - replace a class in mathematical model elements

See the sec_customizing and sec_extensions sections in the *MATPOWER Developer's Manual* for more information, and specifically the sec_element_classes section and the tab_element_class_modifiers table for details on *element class modifiers*.

See also *mp.extension* (page 170), *mp.mme_gen_opf_ac_oval* (page 211).

Method Summary

mm_element_classes(*mm_class*, *task_tag*, *mpopt*)

Replace a class in mathematical model elements.

For `'OPF'` tasks, replaces mp.gen_opf_ac with mp.gen_opf_ac_oval.

Mathematical model element class belonging to *mp.xt_oval_cap_curve* (page 211) extension:

mp.mme_gen_opf_ac_oval

class mp.**mme_gen_opf_ac_oval**

Bases: *mp.mme_gen_opf_ac* (page 153)

mp.mme_gen_opf_ac_oval (page 211) - Math model element for generator for AC OPF w/oval cap curve.

Math model element class for generator elements for AC OPF problems, implementing an oval, as opposed to rectangular, PQ capability curve.

Method Summary

add_constraints(*mm*, *nm*, *dm*, *mpopt*)

Set up the nonlinear constraint for gen oval PQ capability curves.

```
mme.add_constraints(mm, nm, dm, mpopt)
```

oval_pq_capability_fcn(*xx*, *idx*, *p0*, *q0*, *a2*, *b2*)

Compute oval PQ capability constraints and Jacobian.

```
h = mme.oval_pq_capability_fcn(xx, idx, p0, q0, a2, b2)
[h, dh] = mme.oval_pq_capability_fcn(xx, idx, p0, q0, a2, b2)
```

Compute constraint function and optionally the Jacobian for oval PQ capability limits.

Inputs

- **xx** (*1 x 2 cell array*) – active power injection in `xx{1}`, reactive injection in `xx{2}`
- **idx** (*integer*) – index of subset of generators of interest to include in constraint; if empty, include all
- **p0** (*double*) – vector of horizontal (p) centers
- **q0** (*double*) – vector of vertical (q) centers
- **a2** (*double*) – vector of squares of horizontal (p) radii
- **b2** (*double*) – vector of squares of vertical (q) radii

Outputs

- **h** (*double*) – constraint function, $\boldsymbol{h}(\boldsymbol{x})$
- **dh** (*double*) – constraint Jacobian, $\boldsymbol{h}_{\boldsymbol{x}}$

Note that the oval specs `p0`, `q0`, `a2`, `b2` are assumed to have dimension corresponding to `idx`.

`oval_pq_capability_hess`(*xx*, *lam*, *idx*, *p0*, *q0*, *a2*, *b2*)

Compute oval PQ capability constraint Hessian.

```
d2H = mme.oval_pq_capability_hess(xx, lam, idx, p0, q0, a2, b2)
```

Compute a sparse Hessian matrix for oval PQ capability limits. Rather than a full, 3-dimensional Hessian, it computes the Jacobian of the vector obtained by muliplying the transpose of the constraint Jacobian by a vector $\boldsymbol{\mu}$.

Inputs

- **xx** (*1 x 2 cell array*) – active power injection in `xx{1}`, reactive injection in `xx{2}`
- **lam** (*double*) – vector $\boldsymbol{\mu}$ of multipliers
- **idx** (*integer*) – index of subset of generators of interest to include in constraint; if empty, include all
- **p0** (*double*) – vector of horizontal (p) centers
- **q0** (*double*) – vector of vertical (q) centers
- **a2** (*double*) – vector of squares of horizontal (p) radii
- **b2** (*double*) – vector of squares of vertical (q) radii

Output

d2H (*double*) – sparse constraint Hessian matrix

Note that the oval specs `p0`, `q0`, `a2`, `b2` are assumed to have dimension corresponding to `idx`.

4 Tests

4.1 MATPOWER Tests

4.1.1 test_matpower

test_matpower(*verbose*, *exit_on_fail*)

test_matpower() (page 213) - Run all MATPOWER tests.

```
test_matpower
test_matpower(verbose)
test_matpower(verbose, exit_on_fail)
success = test_matpower(...)
```

Runs all of the MATPOWER tests. If `verbose` is true *(false by default)*, it prints the details of the individual tests. If `exit_on_fail` is true *(false by default)*, it will exit MATLAB or Octave with a status of 1 unless `t_run_tests()` returns `all_ok` true.

See also `t_run_tests()`.

4.1.2 t_mp_mapped_array

t_mp_mapped_array(*quiet*)

t_mp_mapped_array() (page 213) - Tests for *mp.mapped_array* (page 166).

4.1.3 t_mp_table

t_mp_table(*quiet*)

t_mp_table() (page 214) - Tests for *mp_table* (page 156) (and `table`).

4.1.4 t_mp_data_model

t_mp_data_model(*quiet*)

t_mp_data_model() (page 214) - Tests for *mp.data_model* (page 27).

4.1.5 t_dmc_element

t_dmc_element(*quiet*)

t_dmc_element() (page 214) - Tests for *mp.dmc_element* (page 62).

4.1.6 t_mp_dm_converter_mpc2

t_mp_dm_converter_mpc2(*quiet*)

t_mp_dm_converter_mpc2() (page 214) - Tests for *mp.dm_converter_mpc2* (page 61).

4.1.7 t_nm_element

t_nm_element(*quiet*, *out_ac*)

t_nm_element() (page 214) - Tests for *mp.nm_element* (page 107).

4.1.8 t_port_inj_current_acc

t_port_inj_current_acc(*quiet*)

t_port_inj_current_acc() (page 214) - Tests of *mp.form_ac.port_inj_current()* (page 76) derivatives wrt cartesian V.

4.1.9 t_port_inj_current_acp

t_port_inj_current_acp(*quiet*)

t_port_inj_current_acp() (page 215) - Tests of *mp.form_ac.port_inj_current()* (page 76) derivatives wrt polar V.

4.1.10 t_port_inj_power_acc

t_port_inj_power_acc(*quiet*)

t_port_inj_power_acc() (page 215) - Tests of *mp.form_ac.port_inj_power()* (page 76) derivatives wrt cartesian V.

4.1.11 t_port_inj_power_acp

t_port_inj_power_acp(*quiet*)

t_port_inj_power_acp() (page 215) - Tests of *mp.form_ac.port_inj_power()* (page 76) derivatives wrt polar V.

4.1.12 t_node_test

t_node_test(*quiet*)

t_node_test() (page 215) - Tests for network model with multipe node-creating elements.

4.1.13 t_run_mp

t_run_mp(*quiet*)

t_run_mp() (page 215) - Tests for *run_mp()* (page 3) and simple creation and solve of models.

4.1.14 t_run_mp_3p

t_run_mp_3p(*quiet*)

t_run_mp_3p() (page 215) - Tests for *run_pf()* (page 4), *run_cpf()* (page 5), *run_opf()* (page 5) for 3-phase and hybrid test cases.

4.1.15 t_run_opf_default

t_run_opf_default(*quiet*)

t_run_opf_default() (page 216) - Tests for AC optimal power flow using *run_opf()* (page 5) w/default solver.

4.1.16 t_pretty_print

t_pretty_print(*quiet*)

t_pretty_print() (page 216) - Tests for pretty printed output.

4.1.17 t_mpxt_legacy_dcline

t_mpxt_legacy_dcline(*quiet*)

t_mpxt_legacy_dcline() (page 216) - Tests for legacy DC line extension in *mp.xt_legacy_dcline* (page 202).

4.1.18 t_mpxt_reserves

t_mpxt_reserves(*quiet*)

t_mpxt_reserves() (page 216) - Tests *mp.xt_reserves* (page 173) extension.

4.2 MATPOWER Test Data

4.2.1 mp_foo_table

class mp_foo_table

Bases: *mp_table_subclass* (page 160)

mp_foo_table (page 216) - Subclass of *mp_table_subclass* (page 160) for testing.

4.2.2 t_case3p_a

t_case3p_a()

t_case3p_a() (page 217) - Four bus, unbalanced 3-phase test case.

This data comes from `4Bus-YY-UnB.DSS`, a modified version (with unbalanced load) of `4Bus-YY-Bal.DSS` [1], the OpenDSS 4 bus IEEE test case with grounded-wye to grounded-wye transformer.

[1] https://sourceforge.net/p/electricdss/code/HEAD/tree/trunk/Distrib/IEEETestCases/4Bus-YY-Bal/4Bus-YY-Bal.DSS

4.2.3 t_case3p_b

t_case3p_b()

t_case3p_b() (page 217) - Six bus hybrid test case, 2 single-phase buses, 4 3-phase buses.

One bus is a hybrid PQ bus. Three phase bus solution should match *t_case3p_a()* (page 217).

4.2.4 t_case3p_c

t_case3p_c()

t_case3p_c() (page 217) - Six bus hybrid test case, 2 single-phase buses, 4 3-phase buses.

One bus is a hybrid PV bus (PV on single-phase side). Three phase bus solution should match *t_case3p_a()* (page 217).

4.2.5 t_case3p_d

t_case3p_d()

t_case3p_d() (page 217) - Six bus hybrid test case, 2 single-phase buses, 4 3-phase buses.

One bus is a hybrid PV bus (PV on 3-phase side). Three phase bus solution should match *t_case3p_a()* (page 217).

4.2.6 t_case3p_e

t_case3p_e()

t_case3p_e() (page 217) - Five bus hybrid test case, 1 single-phase bus, 4 3-phase buses.

One bus is a hybrid REF bus (REF on single-phase side). Three phase bus solution should match *t_case3p_a()* (page 217).

4.2.7 t_case3p_f

t_case3p_f()

t_case3p_f() (page 218) - 21 bus hybrid test case, 9 single-phase buses, 12 3-phase buses.

Three buses are hybrid PQ buses.

4.2.8 t_case3p_g

t_case3p_g()

t_case3p_g() (page 218) - 21 bus hybrid test case, 9 single-phase buses, 12 3-phase buses.

Three buses are hybrid buses, one REF-PQ, one PV-PQ and the other PQ-PQ. Solutions of three-phase portions should match *t_case3p_a()* (page 217).

4.2.9 t_case3p_h

t_case3p_h()

t_case3p_h() (page 218) -21 bus hybrid test case, 9 single-phase buses, 12 3-phase buses.

Same as *t_case3p_g()* (page 218), except the PV hybrid bus has the PV on the 3-phase side. Three buses are hybrid buses, one REF-PQ, one PQ-PV and the other PQ-PQ. Solutions of three-phase portions should match *t_case3p_a()* (page 217).

4.2.10 t_case9_gizmo

t_case9_gizmo()

t_case9_gizmo() (page 218) - Power flow data for 9 bus, 3 generator case, with gizmo data.

Please see caseformat for details on the case file format.

5 Legacy

This section contains reference documentation for the **legacy MATPOWER framework** (see sec_two_frameworks in the *MATPOWER Developer's Manual*) and the rest of the legacy codebase inherited from MATPOWER 7 and earlier.

5.1 Legacy Class

5.1.1 opf_model

class opf_model

Bases: opt_model

opf_model (page 219) - Legacy MATPOWER OPF model class.

```
OM = OPF_MODEL(MPC)

This class implements the OPF model object used to encapsulate
a given OPF problem formulation. It allows for access to optimization
variables, constraints and costs in named blocks, keeping track of the
ordering and indexing of the blocks as variables, constraints and costs
are added to the problem.

This class is a subclass of OPT_MODEL that adds the 'mpc'
field for storing the MATPOWER case struct used to build the object
along with the get_mpc() method.

It also adds the 'cost' field and the following three methods for
implementing the legacy user-defined OPF costs:
    add_legacy_cost
    params_legacy_cost
    eval_legacy_cost

The following is the structure of the data in the OPF model object.
```

(continues on next page)

(continued from previous page)

```
om
    <opt_model fields> - see OPT_MODEL for details
    .cost       - data for legacy user-defined costs
        .idx
            .i1 - starting row index within full N matrix
            .iN - ending row index within full N matrix
            .N  - number of rows in this cost block in full N matrix
        .N      - total number of rows in full N matrix
        .NS     - number of cost blocks
        .data   - data for each user-defined cost block
            .N  - see help for ADD_LEGACY_COST for details
            .H  -                "
            .Cw -                "
            .dd -                "
            .rr -                "
            .kk -                "
            .mm -                "
            .vs - cell array of variable sets that define xx for this
                  cost block, where the N for this block multiplies xx
        .order  - struct array of names/indices for cost blocks in the
                  order they appear in the rows of the full N matrix
            .name   - name of the block, e.g. R
            .idx    - indices for name, {2,3} => R(2,3)
    .mpc        - MATPOWER case struct used to create this model object
        .baseMVA
        .bus
        .branch
        .gen
        .gencost
        .A  (if present, must have l, u)
        .l
        .u
        .N  (if present, must have fparm, H, Cw)
        .fparm
        .H
        .Cw
```

See also `opt_model`.

Constructor Summary

opf_model(*mpc*)

Constructor.

```
om = opf_model()
om = opf_model(mpc)
```

Property Summary

cost = []

data for legacy user-defined costs

mpc = struct()

MATPOWER case struct from which om was built

Method Summary

def_set_types(*om*)

Define set types var, lin, nle, nli, qdc, nlc, cost.

init_set_types(*om*)

Initialize data structures for each set type.

set_mpc(*om*, *mpc*)

set_mpc() (page 221) - Sets the MATPOWER case struct.

```
OM.SET_MPC(MPC)
```

See also opt_model.

display(*om*)

display() (page 221) - Displays the object.

```
Called when semicolon is omitted at the command-line. Displays the details
of the variables, constraints, costs included in the model.
```

See also opt_model.

get_mpc(*om*)

get_mpc() (page 221) - Returns the MATPOWER case struct.

```
MPC = OM.GET_MPC()
```

See also opt_model.

eval_legacy_cost(*om*, *x*, *name*, *idx*)

eval_legacy_cost() (page 221) - Evaluates individual or full set of legacy user costs.

```
F = OM.EVAL_LEGACY_COST(X ...)
[F, DF] = OM.EVAL_LEGACY_COST(X ...)
[F, DF, D2F] = OM.EVAL_LEGACY_COST(X ...)
[F, DF, D2F] = OM.EVAL_LEGACY_COST(X, NAME)
[F, DF, D2F] = OM.EVAL_LEGACY_COST(X, NAME, IDX_LIST)
Evaluates an individual named set or the full set of legacy user
costs and their derivatives for a given value of the optimization vector
X, based on costs added by ADD_LEGACY_COST.

Example:
    [f, df, d2f] = om.eval_legacy_cost(x)
    [f, df, d2f] = om.eval_legacy_cost(x, name)
    [f, df, d2f] = om.eval_legacy_cost(x, name, idx)
```

See also opt_model, *add_legacy_cost()* (page 223), *params_legacy_cost()* (page 221).

params_legacy_cost(*om*, *name*, *idx*)

params_legacy_cost() (page 221) - Returns cost parameters for legacy user-defined costs.

```
CP = OM.PARAMS_LEGACY_COST()
CP = OM.PARAMS_LEGACY_COST(NAME)
CP = OM.PARAMS_LEGACY_COST(NAME, IDX_LIST)
[CP, VS] = OM.PARAMS_LEGACY_COST(...)
[CP, VS, I1, IN] = OM.PARAMS_LEGACY_COST(...)

With no input parameters, it assembles and returns the parameters
for the aggregate legacy user-defined cost from all legacy cost sets
added using ADD_LEGACY_COST. The values of these parameters are cached
for subsequent calls. The parameters are contained in the struct CP,
described below.

If a NAME is provided then it simply returns parameter struct CP for the
corresponding named set. Likewise for indexed named sets specified
by NAME and IDX_LIST.

An optional 2nd output argument VS indicates the variable sets used by
this cost set. The size of CP.N will be consistent with VS.

If NAME is provided, optional 3rd and 4th output arguments I1 and IN
indicate the starting and ending row indices of the corresponding
cost set in the full aggregate cost matrix CP.N.

Let X refer to the vector formed by combining the corresponding varsets VS,
and F_U(X, CP) be the cost at X corresponding to the cost parameters
contained in CP, where CP is a struct with the following fields:
    N      - nw x nx sparse matrix (optional, identity matrix by default)
    Cw     - nw x 1 vector
    H      - nw x nw sparse matrix (optional, all zeros by default)
    dd, mm - nw x 1 vectors (optional, all ones by default)
    rh, kk - nw x 1 vectors (optional, all zeros by default)

These parameters are used as follows to compute F_U(X, CP)

    R  = N*X - rh

            /  kk(i),  R(i) < -kk(i)
    K(i) = <   0,     -kk(i) <= R(i) <= kk(i)
            \ -kk(i),  R(i) > kk(i)

    RR = R + K

    U(i) =  /  0, -kk(i) <= R(i) <= kk(i)
            \  1, otherwise

    DDL(i) = /  1, dd(i) = 1
             \  0, otherwise

    DDQ(i) = /  1, dd(i) = 2
             \  0, otherwise

    Dl = diag(mm) * diag(U) * diag(DDL)
    Dq = diag(mm) * diag(U) * diag(DDQ)
```

(continues on next page)

(continued from previous page)

```
    w = (Dl + Dq * diag(RR)) * RR

    F_U(X, CP) = 1/2 * w'*H*w + Cw'*w
```

See also opt_model, *add_legacy_cost()* (page 223), *eval_legacy_cost()* (page 221).

add_named_set(*om*, *set_type*, *name*, *idx*, *N*, *varargin*)

add_named_set() (page 223) - Adds a named set of variables/constraints/costs to the model.

```
-----  PRIVATE METHOD  -----

This method is intended to be a private method, used internally by
the public methods ADD_VAR, ADD_LIN_CONSTRAINT, ADD_NLN_CONSTRAINT
ADD_QUAD_COST, ADD_NLN_COST and ADD_LEGACY_COST.

Variable Set
    OM.ADD_NAMED_SET('var', NAME, IDX_LIST, N, V0, VL, VU, VT);

Linear Constraint Set
    OM.ADD_NAMED_SET('lin', NAME, IDX_LIST, N, A, L, U, VARSETS);

Nonlinear Inequality Constraint Set
    OM.ADD_NAMED_SET('nle', NAME, IDX_LIST, N, FCN, HESS, COMPUTED_BY,␣
↪VARSETS);

Nonlinear Inequality Constraint Set
    OM.ADD_NAMED_SET('nli', NAME, IDX_LIST, N, FCN, HESS, COMPUTED_BY,␣
↪VARSETS);

Quadratic Cost Set
    OM.ADD_NAMED_SET('qdc', NAME, IDX_LIST, N, CP, VARSETS);

General Nonlinear Cost Set
    OM.ADD_NAMED_SET('nlc', NAME, IDX_LIST, N, FCN, VARSETS);

Legacy Cost Set
    OM.ADD_NAMED_SET('cost', NAME, IDX_LIST, N, CP, VARSETS);
```

See also opt_model, add_var, add_lin_constraint, add_nln_constraint add_quad_cost, add_nln_cost, *add_legacy_cost()* (page 223).

add_legacy_cost(*om*, *name*, *idx*, *varargin*)

add_legacy_cost() (page 223) - Adds a set of user costs to the model.

```
OM.ADD_LEGACY_COST(NAME, CP);
OM.ADD_LEGACY_COST(NAME, CP, VARSETS);
OM.ADD_LEGACY_COST(NAME, IDX_LIST, CP);
OM.ADD_LEGACY_COST(NAME, IDX_LIST, CP, VARSETS);

Adds a named block of user-defined costs to the model. Each set is
defined by the CP struct described below. All user-defined sets of
costs are combined together into a single set of cost parameters in
```

(continues on next page)

(continued from previous page)

```
a single CP struct by BULD_COST_PARAMS. This full aggregate set of
cost parameters can be retreived from the model by GET_COST_PARAMS.

Examples:
    cp1 = struct('N', N1, 'Cw', Cw1);
    cp2 = struct('N', N2, 'Cw', Cw2, 'H', H, 'dd', dd, ...
                 'rh', rh, 'kk', kk, 'mm', mm);
    om.add_legacy_cost('usr1', cp1, {'Pg', 'Qg', 'z'});
    om.add_legacy_cost('usr2', cp2, {'Vm', 'Pg', 'Qg', 'z'});

    om.init_indexed_name('c', {2, 3});
    for i = 1:2
      for j = 1:3
        om.add_legacy_cost('c', {i, j}, cp(i,j), ...);
      end
    end

Let x refer to the vector formed by combining the specified VARSETS,
and f_u(x, CP) be the cost at x corresponding to the cost parameters
contained in CP, where CP is a struct with the following fields:
    N      - nw x nx sparse matrix (optional, identity matrix by default)
    Cw     - nw x 1 vector
    H      - nw x nw sparse matrix (optional, all zeros by default)
    dd, mm - nw x 1 vectors (optional, all ones by default)
    rh, kk - nw x 1 vectors (optional, all zeros by default)

These parameters are used as follows to compute f_u(x, CP)

    R  = N*x - rh

            /  kk(i),  R(i) < -kk(i)
    K(i) = <   0,     -kk(i) <= R(i) <= kk(i)
            \ -kk(i),  R(i) > kk(i)

    RR = R + K

    U(i) =  /  0, -kk(i) <= R(i) <= kk(i)
            \  1, otherwise

    DDL(i) = /  1, dd(i) = 1
             \  0, otherwise

    DDQ(i) = /  1, dd(i) = 2
             \  0, otherwise

    Dl = diag(mm) * diag(U) * diag(DDL)
    Dq = diag(mm) * diag(U) * diag(DDQ)

    w = (Dl + Dq * diag(RR)) * RR

    f_u(x, CP) = 1/2 * w'*H*w + Cw'*w
```

See also opt_model, *params_legacy_cost()* (page 221), *eval_legacy_cost()* (page 221).

init_indexed_name(*om*, *set_type*, *name*, *dim_list*)

init_indexed_name() (page 225) - Initializes the dimensions for an indexed named set.

```
OM.INIT_INDEXED_NAME(SET_TYPE, NAME, DIM_LIST)

Initializes the dimensions for an indexed named variable, constraint
or cost set.

Variables, constraints and costs are referenced in OPT_MODEL in terms
of named sets. The specific type of named set being referenced is
given by SET_TYPE, with the following valid options:
    SET_TYPE = 'var'   => variable set
    SET_TYPE = 'lin'   => linear constraint set
    SET_TYPE = 'nle'   => nonlinear equality constraint set
    SET_TYPE = 'nli'   => nonlinear inequality constraint set
    SET_TYPE = 'qdc'   => quadratic cost set
    SET_TYPE = 'nlc'   => nonlinear cost set
    SET_TYPE = 'cost'  => legacy cost set

Indexed Named Sets

A variable, constraint or cost set can be identified by a single NAME,
such as 'Pmismatch', or by a name that is indexed by one or more indices,
such as 'Pmismatch(3,4)'. For an indexed named set, before adding the
indexed variable, constraint or cost sets themselves, the dimensions of
the indexed set must be set by calling INIT_INDEXED_NAME, where
DIM_LIST is a cell array of the dimensions.

Examples:
    %% linear constraints with indexed named set 'R(i,j)'
    om.init_indexed_name('lin', 'R', {2, 3});
    for i = 1:2
      for j = 1:3
        om.add_lin_constraint('R', {i, j}, A{i,j}, ...);
      end
    end
```

See also opt_model, add_var, add_lin_constraint, add_nln_constraint, add_quad_cost, add_nln_cost, *add_legacy_cost()* (page 223).

5.2 Legacy Functions

5.2.1 Top-Level Simulation Functions

runpf

runpf(*casedata*, *mpopt*, *fname*, *solvedcase*)

runpf() - Runs a power flow.

```
[RESULTS, SUCCESS] = RUNPF(CASEDATA, MPOPT, FNAME, SOLVEDCASE)

Runs a power flow (full AC Newton's method by default), optionally
returning a RESULTS struct and SUCCESS flag.

Inputs (all are optional):
    CASEDATA : either a MATPOWER case struct or a string containing
        the name of the file with the case data (default is 'case9')
        (see CASEFORMAT and LOADCASE)
    MPOPT : MATPOWER options struct to override default options
        can be used to specify the solution algorithm, output options
        termination tolerances, and more (see MPOPTION).
    FNAME : name of a file to which the pretty-printed output will
        be appended
    SOLVEDCASE : name of file to which the solved case will be saved
        in MATPOWER case format (M-file will be assumed unless the
        specified name ends with '.mat')

Outputs (all are optional):
    RESULTS : results struct, with the following fields:
        (all fields from the input MATPOWER case, i.e. bus, branch,
            gen, etc., but with solved voltages, power flows, etc.)
        order - info used in external <-> internal data conversion
        et - elapsed time in seconds
        success - success flag, 1 = succeeded, 0 = failed
    SUCCESS : the success flag can additionally be returned as
        a second output argument

Calling syntax options:
    results = runpf;
    results = runpf(casedata);
    results = runpf(casedata, mpopt);
    results = runpf(casedata, mpopt, fname);
    results = runpf(casedata, mpopt, fname, solvedcase);
    [results, success] = runpf(...);

    Alternatively, for compatibility with previous versions of MATPOWER,
    some of the results can be returned as individual output arguments:

    [baseMVA, bus, gen, branch, success, et] = runpf(...);

If the pf.enforce_q_lims option is set to true (default is false) then, if
any generator reactive power limit is violated after running the AC power
flow, the corresponding bus is converted to a PQ bus, with Qg at the
limit, and the case is re-run. The voltage magnitude at the bus will
deviate from the specified value in order to satisfy the reactive power
limit. If the reference bus is converted to PQ, the first remaining PV
bus will be used as the slack bus for the next iteration. This may
```

(continues on next page)

(continued from previous page)

```
result in the real power output at this generator being slightly off
from the specified values.

Examples:
    results = runpf('case30');
    results = runpf('case30', mpoption('pf.enforce_q_lims', 1));
```

See also `rundcpf()`.

runcpf

runcpf(*basecasedata*, *targetcasedata*, *mpopt*, *fname*, *solvedcase*)

`runcpf()` - Runs a full AC continuation power flow

```
[RESULTS, SUCCESS] = RUNCPF(BASECASEDATA, TARGETCASEDATA, ...
                                MPOPT, FNAME, SOLVEDCASE)

Runs a full AC continuation power flow using a normalized tangent
predictor and selected parameterization scheme, optionally
returning a RESULTS struct and SUCCESS flag. Step size can be
fixed or adaptive.

Inputs (all are optional):
    BASECASEDATA : either a MATPOWER case struct or a string containing
        the name of the file with the case data defining the base loading
        and generation (default is 'case9')
        (see CASEFORMAT and LOADCASE)
    TARGETCASEDATA : either a MATPOWER case struct or a string
        containing the name of the file with the case data defining the
        target loading and generation (default is 'case9target')
    MPOPT : MATPOWER options struct to override default options
        can be used to specify the parameterization, output options,
        termination criteria, and more (see MPOPTION).
    FNAME : name of a file to which the pretty-printed output will
        be appended
    SOLVEDCASE : name of file to which the solved case will be saved
        in MATPOWER case format (M-file will be assumed unless the
        specified name ends with '.mat')

Outputs (all are optional):
    RESULTS : results struct, with the following fields:
        (all fields from the input MATPOWER case, i.e. bus, branch,
            gen, etc., but with solved voltages, power flows, etc.)
        order - info used in external <-> internal data conversion
        et - elapsed time in seconds
        success - success flag, 1 = succeeded, 0 = failed
        cpf - CPF output struct whose content depends on any
                user callback functions, where default contains fields:
            done_msg - string with message describing cause of
                    continuation termination
```

(continues on next page)

(continued from previous page)

```
            iterations - number of continuation steps performed
            lam - (nsteps+1) row vector of lambda values from
                  correction steps
            lam_hat - (nsteps+1) row vector of lambda values from
                  prediction steps
            max_lam - maximum value of lambda in RESULTS.cpf.lam
            steps - (nsteps+1) row vector of stepsizes taken at each
                  continuation step
            V - (nb x nsteps+1) complex bus voltages from
                  correction steps
            V_hat - (nb x nsteps+1) complex bus voltages from
                  prediction steps
            events - an array of structs of size nevents with the
                following fields:
                 k - continuation step number at which event was located
                 name - name of event
                 idx - index(es) of critical elements in corresponding
                    event function, e.g. index of generator reaching VAr
                    limit
                 msg - descriptive text detailing the event
    SUCCESS : the success flag can additionally be returned as
        a second output argument

Calling syntax options:
    results = runcpf;
    results = runcpf(basecasedata, targetcasedata);
    results = runcpf(basecasedata, targetcasedata, mpopt);
    results = runcpf(basecasedata, targetcasedata, mpopt, fname);
    results = runcpf(basecasedata, targetcasedata, mpopt, fname, solvedcase)
    [results, success] = runcpf(...);

If the 'cpf.enforce_q_lims' option is set to true (default is false) then,
if any generator reaches its reactive power limits during the AC
continuation power flow,
    - the corresponding bus is converted to a PQ bus, and the problem
      is modified to eliminate further reactive transfer on this bus
    - the voltage magnitude at the bus will deviate from the specified
      setpoint to satisfy the reactive power limit,
    - if the reference bus is converted to PQ, further real power transfer
      for the bus is also eliminated, and the first remaining PV bus is
      selected as the new slack, resulting in the transfers at both
      reference buses potentially deviating from the specified values
    - if all reference and PV buses are converted to PQ, RUNCPF terminates
      with an infeasibility message.

If the 'cpf.enforce_p_lims' option is set to true (default is fals) then,
if any generator reaches its maximum active power limit during the AC
continuation power flow,
    - the problem is modified to eliminate further active transfer by
      this generator
    - if the generator was at the reference bus, it is converted to PV
      and the first remaining PV bus is selected as the new slack.
```

(continues on next page)

(continued from previous page)

```
If the 'cpf.enforce_v_lims' option is set to true (default is false)
then the continuation power flow is set to terminate if any bus voltage
magnitude exceeds its minimum or maximum limit.

If the 'cpf.enforce_flow_lims' option is set to true (default is false)
then the continuation power flow is set to terminate if any line MVA
flow exceeds its rateA limit.

Possible CPF termination modes:
    when cpf.stop_at == 'NOSE'
        - Reached steady state loading limit
        - Nose point eliminated by limit induced bifurcation
    when cpf.stop_at == 'FULL'
        - Traced full continuation curve
    when cpf.stop_at == <target_lam_val>
        - Reached desired lambda
    when cpf.enforce_p_lims == true
        - All generators at PMAX
    when cpf.enforce_q_lims == true
        - No REF or PV buses remaining
    when cpf.enforce_v_lims == true
        - Any bus voltage magnitude limit is reached
    when cpf.enforce_flow_lims == true
        - Any branch MVA flow limit is reached
    other
        - Base case power flow did not converge
        - Base and target case have identical load and generation
        - Corrector did not converge
        - Could not locate <event_name> event
        - Too many rollback steps triggered by callbacks

Examples:
    results = runcpf('case9', 'case9target');
    results = runcpf('case9', 'case9target', ...
                        mpoption('cpf.adapt_step', 1));
    results = runcpf('case9', 'case9target', ...
                        mpoption('cpf.enforce_q_lims', 1));
    results = runcpf('case9', 'case9target', ...
                        mpoption('cpf.stop_at', 'FULL'));
```

See also `mpoption()`, `runpf()`.

runopf

runopf(*casedata*, *mpopt*, *fname*, *solvedcase*)

runopf() - Runs an optimal power flow.

```
[RESULTS, SUCCESS] = RUNOPF(CASEDATA, MPOPT, FNAME, SOLVEDCASE)

Runs an optimal power flow (AC OPF by default), optionally returning
a RESULTS struct and SUCCESS flag.

Inputs (all are optional):
    CASEDATA : either a MATPOWER case struct or a string containing
        the name of the file with the case data (default is 'case9')
        (see CASEFORMAT and LOADCASE)
    MPOPT : MATPOWER options struct to override default options
        can be used to specify the solution algorithm, output options
        termination tolerances, and more (see MPOPTION).
    FNAME : name of a file to which the pretty-printed output will
        be appended
    SOLVEDCASE : name of file to which the solved case will be saved
        in MATPOWER case format (M-file will be assumed unless the
        specified name ends with '.mat')

Outputs (all are optional):
    RESULTS : results struct, with the following fields:
        (all fields from the input MATPOWER case, i.e. bus, branch,
            gen, etc., but with solved voltages, power flows, etc.)
        order - info used in external <-> internal data conversion
        et - elapsed time in seconds
        success - success flag, 1 = succeeded, 0 = failed
        (additional OPF fields, see OPF for details)
    SUCCESS : the success flag can additionally be returned as
        a second output argument

Calling syntax options:
    results = runopf;
    results = runopf(casedata);
    results = runopf(casedata, mpopt);
    results = runopf(casedata, mpopt, fname);
    results = runopf(casedata, mpopt, fname, solvedcase);
    [results, success] = runopf(...);

    Alternatively, for compatibility with previous versions of MATPOWER,
    some of the results can be returned as individual output arguments:

    [baseMVA, bus, gen, gencost, branch, f, success, et] = runopf(...);

Example:
    results = runopf('case30');
```

See also rundcopf(), runuopf().

runuopf

runuopf(*casedata*, *mpopt*, *fname*, *solvedcase*)

runuopf() - Runs an optimal power flow with unit-decommitment heuristic.

```
[RESULTS, SUCCESS] = RUNUOPF(CASEDATA, MPOPT, FNAME, SOLVEDCASE)

Runs an optimal power flow (AC OPF by default) with a heuristic which
allows it to shut down "expensive" generators, optionally returning
a RESULTS struct and SUCCESS flag.

Inputs (all are optional):
    CASEDATA : either a MATPOWER case struct or a string containing
        the name of the file with the case data (default is 'case9')
        (see CASEFORMAT and LOADCASE)
    MPOPT : MATPOWER options struct to override default options
        can be used to specify the solution algorithm, output options
        termination tolerances, and more (see MPOPTION).
    FNAME : name of a file to which the pretty-printed output will
        be appended
    SOLVEDCASE : name of file to which the solved case will be saved
        in MATPOWER case format (M-file will be assumed unless the
        specified name ends with '.mat')

Outputs (all are optional):
    RESULTS : results struct, with the following fields:
        (all fields from the input MATPOWER case, i.e. bus, branch,
            gen, etc., but with solved voltages, power flows, etc.)
        order - info used in external <-> internal data conversion
        et - elapsed time in seconds
        success - success flag, 1 = succeeded, 0 = failed
        (additional OPF fields, see OPF for details)
    SUCCESS : the success flag can additionally be returned as
        a second output argument

Calling syntax options:
    results = runuopf;
    results = runuopf(casedata);
    results = runuopf(casedata, mpopt);
    results = runuopf(casedata, mpopt, fname);
    results = runuopf(casedata, mpopt, fname, solvedcase);
    [results, success] = runuopf(...);

    Alternatively, for compatibility with previous versions of MATPOWER,
    some of the results can be returned as individual output arguments:

    [baseMVA, bus, gen, gencost, branch, f, success, et] = runuopf(...);

Example:
    results = runuopf('case30');
```

See also runopf(), runduopf().

rundcpf

rundcpf(*casedata*, *mpopt*, *fname*, *solvedcase*)

rundcpf() - Runs a DC power flow.

```
[RESULTS, SUCCESS] = RUNDCPF(CASEDATA, MPOPT, FNAME, SOLVEDCASE)

Runs a DC power flow, optionally returning a RESULTS struct and
SUCCESS flag.

Inputs (all are optional):
    CASEDATA : either a MATPOWER case struct or a string containing
        the name of the file with the case data (default is 'case9')
        (see  CASEFORMAT and LOADCASE)
    MPOPT : MATPOWER options struct to override default options
        can be used to specify the solution algorithm, output options
        termination tolerances, and more (see MPOPTION).
    FNAME : name of a file to which the pretty-printed output will
        be appended
    SOLVEDCASE : name of file to which the solved case will be saved
        in MATPOWER case format (M-file will be assumed unless the
        specified name ends with '.mat')

Outputs (all are optional):
    RESULTS : results struct, with the following fields:
        (all fields from the input MATPOWER case, i.e. bus, branch,
            gen, etc., but with solved voltages, power flows, etc.)
        order - info used in external <-> internal data conversion
        et - elapsed time in seconds
        success - success flag, 1 = succeeded, 0 = failed
    SUCCESS : the success flag can additionally be returned as
        a second output argument

Calling syntax options:
    results = rundcpf;
    results = rundcpf(casedata);
    results = rundcpf(casedata, mpopt);
    results = rundcpf(casedata, mpopt, fname);
    results = rundcpf(casedata, mpopt, fname, solvedcase);
    [results, success] = rundcpf(...);

    Alternatively, for compatibility with previous versions of MATPOWER,
    some of the results can be returned as individual output arguments:

    [baseMVA, bus, gen, branch, success, et] = rundcpf(...);

Example:
    results = rundcpf('case30');
```

See also runpf().

rundcopf

rundcopf(*casedata*, *mpopt*, *fname*, *solvedcase*)

rundcopf() - Runs a DC optimal power flow.

```
[RESULTS, SUCCESS] = RUNDCOPF(CASEDATA, MPOPT, FNAME, SOLVEDCASE)

Runs a DC optimal power flow, optionally returning a RESULTS struct
and SUCCESS flag.

Inputs (all are optional):
    CASEDATA : either a MATPOWER case struct or a string containing
        the name of the file with the case data (default is 'case9')
        (see CASEFORMAT and LOADCASE)
    MPOPT : MATPOWER options struct to override default options
        can be used to specify the solution algorithm, output options
        termination tolerances, and more (see MPOPTION).
    FNAME : name of a file to which the pretty-printed output will
        be appended
    SOLVEDCASE : name of file to which the solved case will be saved
        in MATPOWER case format (M-file will be assumed unless the
        specified name ends with '.mat')

Outputs (all are optional):
    RESULTS : results struct, with the following fields:
        (all fields from the input MATPOWER case, i.e. bus, branch,
            gen, etc., but with solved voltages, power flows, etc.)
        order - info used in external <-> internal data conversion
        et - elapsed time in seconds
        success - success flag, 1 = succeeded, 0 = failed
        (additional OPF fields, see OPF for details)
    SUCCESS : the success flag can additionally be returned as
        a second output argument

Calling syntax options:
    results = rundcopf;
    results = rundcopf(casedata);
    results = rundcopf(casedata, mpopt);
    results = rundcopf(casedata, mpopt, fname);
    results = rundcopf(casedata, mpopt, fname, solvedcase);
    [results, success] = rundcopf(...);

    Alternatively, for compatibility with previous versions of MATPOWER,
    some of the results can be returned as individual output arguments:

    [baseMVA, bus, gen, gencost, branch, f, success, et] = rundcopf(...);

Example:
    results = rundcopf('case30');
```

See also runopf(), runduopf().

runduopf

runduopf(*casedata*, *mpopt*, *fname*, *solvedcase*)

runduopf() - Runs a DC optimal power flow with unit-decommitment heuristic.

```
[RESULTS, SUCCESS] = RUNDUOPF(CASEDATA, MPOPT, FNAME, SOLVEDCASE)

Runs a DC optimal power flow with a heuristic which allows it to shut
down "expensive" generators optionally returning a RESULTS struct and
SUCCESS flag.

Inputs (all are optional):
    CASEDATA : either a MATPOWER case struct or a string containing
        the name of the file with the case data (default is 'case9')
        (see CASEFORMAT and LOADCASE)
    MPOPT : MATPOWER options struct to override default options
        can be used to specify the solution algorithm, output options
        termination tolerances, and more (see MPOPTION).
    FNAME : name of a file to which the pretty-printed output will
        be appended
    SOLVEDCASE : name of file to which the solved case will be saved
        in MATPOWER case format (M-file will be assumed unless the
        specified name ends with '.mat')

Outputs (all are optional):
    RESULTS : results struct, with the following fields:
        (all fields from the input MATPOWER case, i.e. bus, branch,
            gen, etc., but with solved voltages, power flows, etc.)
        order - info used in external <-> internal data conversion
        et - elapsed time in seconds
        success - success flag, 1 = succeeded, 0 = failed
        (additional OPF fields, see OPF for details)
    SUCCESS : the success flag can additionally be returned as
        a second output argument

Calling syntax options:
    results = runduopf;
    results = runduopf(casedata);
    results = runduopf(casedata, mpopt);
    results = runduopf(casedata, mpopt, fname);
    results = runduopf(casedata, mpopt, fname, solvedcase);
    [results, success] = runduopf(...);

    Alternatively, for compatibility with previous versions of MATPOWER,
    some of the results can be returned as individual output arguments:

    [baseMVA, bus, gen, gencost, branch, f, success, et] = runduopf(...);

Example:
    results = runduopf('case30');
```

See also rundcopf(), runuopf().

runopf_w_res

runopf_w_res(*varargin*)

runopf_w_res() (page 235) - Runs an optimal power flow with fixed zonal reserves.

```
RESULTS = RUNOPF_W_RES(CASEDATA, MPOPT, FNAME, SOLVEDCASE)
[RESULTS, SUCCESS] = RUNOPF_W_RES(CASEDATA, MPOPT, FNAME, SOLVEDCASE)

Runs an optimal power flow with the addition of reserve requirements
specified as a set of fixed zonal reserves. See RUNOPF for a
description of the input and output arguments, which are the same,
with the exception that the case file or struct CASEDATA must define
a 'reserves' field, which is a struct with the following fields:
    zones   nrz x ng, zone(i, j) = 1, if gen j belongs to zone i
                                   0, otherwise
    req     nrz x 1, zonal reserve requirement in MW
    cost    (ng or ngr) x 1, cost of reserves in $/MW
    qty     (ng or ngr) x 1, max quantity of reserves in MW (optional)
where nrz is the number of reserve zones and ngr is the number of
generators belonging to at least one reserve zone and ng is the total
number of generators.

In addition to the normal OPF output, the RESULTS struct contains a
new 'reserves' field with the following fields, in addition to those
provided in the input:
    R       - ng x 1, reserves provided by each gen in MW
    Rmin    - ng x 1, lower limit on reserves provided by each gen, (MW)
    Rmax    - ng x 1, upper limit on reserves provided by each gen, (MW)
    mu.l    - ng x 1, shadow price on reserve lower limit, ($/MW)
    mu.u    - ng x 1, shadow price on reserve upper limit, ($/MW)
    mu.Pmax - ng x 1, shadow price on Pg + R <= Pmax constraint, ($/MW)
    prc     - ng x 1, reserve price for each gen equal to maximum of the
                      shadow prices on the zonal requirement constraint
                      for each zone the generator belongs to

See T_CASE30_USERFCNS for an example case file with fixed reserves,
and TOGGLE_RESERVES for the implementation.

Calling syntax options:
    results = runopf_w_res(casedata);
    results = runopf_w_res(casedata, mpopt);
    results = runopf_w_res(casedata, mpopt, fname);
    results = runopf_w_res(casedata, mpopt, fname, solvedcase);
    [results, success] = runopf_w_res(...);

Example:
    results = runopf_w_res('t_case30_userfcns');
```

See also runopf(), *toggle_reserves()* (page 306), *t_case30_userfcns()* (page 381).

5.2.2 Input/Output Functions

caseformat

caseformat()

caseformat - Defines the MATPOWER case file format.

```
A MATPOWER case file is an M-file or MAT-file that defines or returns
a struct named mpc, referred to as a "MATPOWER case struct". The fields
of this struct are baseMVA, bus, gen, branch, and (optional) gencost. With
the exception of baseMVA, a scalar, each data variable is a matrix, where
a row corresponds to a single bus, branch, gen, etc. The format of the
data is similar to the PTI format described in
    https://labs.ece.uw.edu/pstca/formats/pti.txt
except where noted. An item marked with (+) indicates that it is included
in this data but is not part of the PTI format. An item marked with (-) is
one that is in the PTI format but is not included here. Those marked with
(2) were added for version 2 of the case file format. The columns for
each data matrix are given below.

MATPOWER Case Version Information:
There are two versions of the MATPOWER case file format. The current
version of MATPOWER uses version 2 of the MATPOWER case format
internally, and includes a 'version' field with a value of '2' to make
the version explicit. Earlier versions of MATPOWER used the version 1
case format, which defined the data matrices as individual variables,
as opposed to fields of a struct. Case files in version 1 format with
OPF data also included an (unused) 'areas' variable. While the version 1
format has now been deprecated, it is still be handled automatically by
LOADCASE and SAVECASE which are able to load and save case files in both
version 1 and version 2 formats.

See IDX_BUS, IDX_BRCH, IDX_GEN, IDX_AREA and IDX_COST regarding
constants which can be used as named column indices for the data matrices.
Also described in the first three are additional results columns that
are added to the bus, branch and gen matrices by the power flow and OPF
solvers.

The case struct also allows for additional fields to be included.
The OPF is designed to recognize fields named A, l, u, H, Cw, N,
fparm, z0, zl and zu as parameters used to directly extend the OPF
formulation (see OPF for details). Additional standard optional fields
include bus_name, gentype and genfuel. Other user-defined fields may also
be included and will be automatically loaded by the LOADCASE function
and, given an appropriate 'savecase' callback function (see
ADD_USERFCN), saved by the SAVECASE function.

Bus Data Format
    1   bus number (positive integer)
    2   bus type
```

(continues on next page)

(continued from previous page)

```
            PQ bus          = 1
            PV bus          = 2
            reference bus   = 3
            isolated bus    = 4
    3   Pd, real power demand (MW)
    4   Qd, reactive power demand (MVAr)
    5   Gs, shunt conductance (MW demanded at V = 1.0 p.u.)
    6   Bs, shunt susceptance (MVAr injected at V = 1.0 p.u.)
    7   area number, (positive integer)
    8   Vm, voltage magnitude (p.u.)
    9   Va, voltage angle (degrees)
(-)     (bus name)
    10  baseKV, base voltage (kV)
    11  zone, loss zone (positive integer)
(+) 12  maxVm, maximum voltage magnitude (p.u.)
(+) 13  minVm, minimum voltage magnitude (p.u.)

Generator Data Format
    1   bus number
(-)     (machine identifier, 0-9, A-Z)
    2   Pg, real power output (MW)
    3   Qg, reactive power output (MVAr)
    4   Qmax, maximum reactive power output (MVAr)
    5   Qmin, minimum reactive power output (MVAr)
    6   Vg, voltage magnitude setpoint (p.u.)
(-)     (remote controlled bus index)
    7   mBase, total MVA base of this machine, defaults to baseMVA
(-)     (machine impedance, p.u. on mBase)
(-)     (step up transformer impedance, p.u. on mBase)
(-)     (step up transformer off nominal turns ratio)
    8   status,  >  0 - machine in service
                 <= 0 - machine out of service
(-)     (% of total VAr's to come from this gen in order to hold V at
            remote bus controlled by several generators)
    9   Pmax, maximum real power output (MW)
    10  Pmin, minimum real power output (MW)
(2) 11  Pc1, lower real power output of PQ capability curve (MW)
(2) 12  Pc2, upper real power output of PQ capability curve (MW)
(2) 13  Qc1min, minimum reactive power output at Pc1 (MVAr)
(2) 14  Qc1max, maximum reactive power output at Pc1 (MVAr)
(2) 15  Qc2min, minimum reactive power output at Pc2 (MVAr)
(2) 16  Qc2max, maximum reactive power output at Pc2 (MVAr)
(2) 17  ramp rate for load following/AGC (MW/min)
(2) 18  ramp rate for 10 minute reserves (MW)
(2) 19  ramp rate for 30 minute reserves (MW)
(2) 20  ramp rate for reactive power (2 sec timescale) (MVAr/min)
(2) 21  APF, area participation factor

Branch Data Format
    1   f, from bus number
    2   t, to bus number
(-)     (circuit identifier)
```

(continues on next page)

(continued from previous page)

```
    3   r, resistance (p.u.)
    4   x, reactance (p.u.)
    5   b, total line charging susceptance (p.u.)
    6   rateA, MVA rating A (long term rating), set to 0 for unlimited
    7   rateB, MVA rating B (short term rating), set to 0 for unlimited
    8   rateC, MVA rating C (emergency rating), set to 0 for unlimited
    9   tap, transformer off nominal turns ratio, if non-zero
        (taps at "from" bus, impedance at "to" bus, i.e. if r = x = b = 0,
         then tap = Vf / Vt; tap = 0 used to indicate transmission
        line rather than transformer, i.e. mathematically equivalent to
        transformer with tap = 1)
    10  shift, transformer phase shift angle (degrees), positive => delay
(-)     (Gf, shunt conductance at from bus p.u.)
(-)     (Bf, shunt susceptance at from bus p.u.)
(-)     (Gt, shunt conductance at to bus p.u.)
(-)     (Bt, shunt susceptance at to bus p.u.)
    11  initial branch status, 1 - in service, 0 - out of service
(2) 12  minimum angle difference, angle(Vf) - angle(Vt) (degrees)
(2) 13  maximum angle difference, angle(Vf) - angle(Vt) (degrees)
        (The voltage angle difference is taken to be unbounded below
         if ANGMIN < -360 and unbounded above if ANGMAX > 360.
         If both parameters are zero, it is unconstrained.)

(+) Generator Cost Data Format
    NOTE: If gen has ng rows, then the first ng rows of gencost contain
    the cost for active power produced by the corresponding generators.
    If gencost has 2*ng rows then rows ng+1 to 2*ng contain the reactive
    power costs in the same format.
    1   model, 1 - piecewise linear, 2 - polynomial
    2   startup, startup cost in US dollars
    3   shutdown, shutdown cost in US dollars
    4   N (= n+1), number of data points to follow defining an n-segment
        piecewise linear cost function, or of cost coefficients defining
        an n-th order polynomial cost function
    5 and following, parameters defining total cost function f(p),
        units of f and p are $/hr and MW (or MVAr), respectively.
        (MODEL = 1) : p1, f1, p2, f2, ..., pN, fN
            where p1 < p2 < ... < pN and the cost f(p) is defined by
            the coordinates (p1,f1), (p2,f2), ..., (pN,fN) of the
            end/break-points of the piecewise linear cost function
        (MODEL = 2) : cn, ..., c1, c0
            N coefficients of an n-th order polynomial cost function,
            starting with highest order, where cost is
            f(p) = cn*p^n + ... + c1*p + c0

(+) Area Data Format (deprecated)
  (this data is not used by MATPOWER and is no longer necessary for
   version 2 case files with OPF data).
    1   i, area number
    2   price_ref_bus, reference bus for that area
```

See also `loadcase()`, `savecase()`, *idx_bus()* (page 339), *idx_brch()* (page 338), *idx_gen()* (page 344), `idx_area` *idx_cost()* (page 340).

cdf2mpc

cdf2mpc(*cdf_file_name*, *mpc_name*, *verbose*)

cdf2mpc() - Converts an IEEE CDF data file into a MATPOWER case struct.

```
MPC = CDF2MPC(CDF_FILE_NAME)
MPC = CDF2MPC(CDF_FILE_NAME, VERBOSE)
MPC = CDF2MPC(CDF_FILE_NAME, MPC_NAME)
MPC = CDF2MPC(CDF_FILE_NAME, MPC_NAME, VERBOSE)
[MPC, WARNINGS] = CDF2MPC(CDF_FILE_NAME, ...)

Converts an IEEE Common Data Format (CDF) data file into a MATPOWER case
struct.

Input:
    CDF_FILE_NAME :  name of the IEEE CDF file to be converted
    MPC_NAME      :  (optional) file name to use to save the resulting
                      MATPOWER case
    VERBOSE       :  1 (default) to display progress info, 0 otherwise

Output(s):
    MPC      : resulting MATPOWER case struct
    WARNINGS : (optional) cell array of strings containing warning
               messages (included by default in comments of MPC_NAME).

The IEEE CDF does not include some data need to run an optimal power
flow. This script creates default values for some of this data as
follows:

    Bus data:
        Vmin = 0.94 p.u.
        Vmax = 1.06 p.u.
    Gen data:
        Pmin = 0 MW
        Pmax = Pg + baseMVA
    Gen cost data:
        Quadratic costs with:
            c2 = 10 / Pg, c1 = 20, c0 = 0, if Pg is non-zero, and
            c2 = 0.01,    c1 = 40, c0 = 0, if Pg is zero
        This should yield an OPF solution "close" to the
        existing solution (assuming it is a solved case)
        with lambdas near $40/MWh. See 'help caseformat'
        for details on the cost curve format.

CDF2MPC may modify some of the data which are "infeasible" for
running optimal power flow. If so, warning information will be
printed out on screen.

Note: Since our code can not handle transformers with variable tap,
you may not expect to get exactly the same power flow solution
using converted data. This is the case when we converted ieee300.cdf.
```

loadcase

loadcase(*casefile*)

loadcase() - Load .m or .mat case files or data struct in MATPOWER format.

```
[BASEMVA, BUS, GEN, BRANCH, AREAS, GENCOST] = LOADCASE(CASEFILE)
[BASEMVA, BUS, GEN, BRANCH, GENCOST] = LOADCASE(CASEFILE)
[BASEMVA, BUS, GEN, BRANCH] = LOADCASE(CASEFILE)
MPC = LOADCASE(CASEFILE)

Returns the individual data matrices or a struct containing them as fields.

Here CASEFILE is either (1) a struct containing the fields baseMVA,
bus, gen, branch and, optionally, areas and/or gencost, or (2) a string
containing the name of the file. If CASEFILE contains the extension
'.mat' or '.m', then the explicit file is searched. If CASEFILE contains
no extension, then LOADCASE looks for a MAT-file first, then for an
M-file.  If the file does not exist or doesn't define all required
matrices, the routine aborts with an appropriate error message.

If the input data is from an M-file or MAT-file defining individual
data matrices, or from a struct with out a 'version' field whose
GEN matrix has fewer than 21 columns, then it is assumed to be a
MATPOWER case file in version 1 format, and will be converted to
version 2 format.
```

mpoption

mpoption(*varargin*)

mpoption() - Used to set and retrieve a MATPOWER options struct.

```
OPT = MPOPTION
    Returns the default options struct.

OPT = MPOPTION(OVERRIDES)
    Returns the default options struct, with some fields overridden
    by values from OVERRIDES, which can be a struct or the name of
    a function that returns a struct.

OPT = MPOPTION(NAME1, VALUE1, NAME2, VALUE2, ...)
    Same as previous, except override options are specified by NAME,
    VALUE pairs. This can be used to set any part of the options
    struct. The names can be individual fields or multi-level field
    names with embedded periods. The values can be scalars or structs.

    For backward compatibility, the NAMES and VALUES may correspond
    to old-style MATPOWER option names (elements in the old-style
    options vector) as well.
```

(continues on next page)

(continued from previous page)

```
OPT = MPOPTION(OPT0)
    Converts an old-style options vector OPT0 into the corresponding
    options struct. If OPT0 is an options struct it does nothing.

OPT = MPOPTION(OPT0, OVERRIDES)
    Applies overrides to an existing set of options, OPT0, which
    can be an old-style options vector or an options struct.

OPT = MPOPTION(OPT0, NAME1, VALUE1, NAME2, VALUE2, ...)
    Same as above except it uses the old-style options vector OPT0
    as a base instead of the old default options vector.

OPT_VECTOR = MPOPTION(OPT, [])
    Creates and returns an old-style options vector from an
    options struct OPT.

Note: The use of old-style MATPOWER options vectors and their
      names and values has been deprecated and will be removed
      in a future version of MATPOWER. Until then, all uppercase
      option names are not permitted for new top-level options.

Examples:
    mpopt = mpoption('pf.alg', 'FDXB', 'pf.tol', 1e-4);
    mpopt = mpoption(mpopt, 'opf.dc.solver', 'CPLEX', 'verbose', 2);

The currently defined options are as follows:

   name                    default     description [options]
----------------------    ---------   ----------------------------------
Model options:
   model                   'AC'        AC vs. DC power flow model
       [ 'AC' - use nonlinear AC model & corresponding algorithms/options  ]
       [ 'DC' - use linear DC model & corresponding algorithms/options     ]

Power Flow options:
   pf.alg                  'NR'        AC power flow algorithm
       [ 'NR'    - Newton's method (formulation depends on values of       ]
       [           pf.current_balance and pf.v_cartesian options)          ]
       [ 'NR-SP' - Newton's method (power mismatch, polar)                 ]
       [ 'NR-SC' - Newton's method (power mismatch, cartesian)             ]
       [ 'NR-SH' - Newton's method (power mismatch, hybrid)                ]
       [ 'NR-IP' - Newton's method (current mismatch, polar)               ]
       [ 'NR-IC' - Newton's method (current mismatch, cartesian)           ]
       [ 'NR-IH' - Newton's method (current mismatch, hybrid)              ]
       [ 'FDXB'  - Fast-Decoupled (XB version)                             ]
       [ 'FDBX'  - Fast-Decoupled (BX version)                             ]
       [ 'GS'    - Gauss-Seidel                                            ]
       [ 'ZG'    - Implicit Z-bus Gauss                                     ]
       [ 'PQSUM' - Power Summation method (radial networks only)           ]
       [ 'ISUM'  - Current Summation method (radial networks only)         ]
       [ 'YSUM'  - Admittance Summation method (radial networks only)      ]
```

(continues on next page)

(continued from previous page)

```
   pf.current_balance     0           type of nodal balance equation
       [ 0 - use complex power balance equations                          ]
       [ 1 - use complex current balance equations                        ]
   pf.v_cartesian         0           voltage representation
       [ 0 - bus voltage variables represented in polar coordinates       ]
       [ 1 - bus voltage variables represented in cartesian coordinates   ]
       [ 2 - hybrid, polar updates computed via modified cartesian Jacobian]
   pf.tol                 1e-8        termination tolerance on per unit
                                      P & Q mismatch
   pf.nr.max_it           10          maximum number of iterations for
                                      Newton's method
   pf.nr.lin_solver       ''          linear solver passed to MPLINSOLVE to
                                      solve Newton update step
       [ ''      - default to '\' for small systems, 'LU3' for larger ones ]
       [ '\'     - built-in backslash operator                            ]
       [ 'LU'    - explicit default LU decomposition and back substitution ]
       [ 'LU3'   - 3 output arg form of LU, Gilbert-Peierls algorithm with ]
       [           approximate minimum degree (AMD) reordering            ]
       [ 'LU4'   - 4 output arg form of LU, UMFPACK solver (same as 'LU')  ]
       [ 'LU5'   - 5 output arg form of LU, UMFPACK solver, w/row scaling  ]
       [       (see MPLINSOLVE for complete list of all options)          ]
   pf.fd.max_it           30          maximum number of iterations for
                                      fast decoupled method
   pf.gs.max_it           1000        maximum number of iterations for
                                      Gauss-Seidel method
   pf.zg.max_it           1000        maximum number of iterations for
                                      Implicit Z-bus Gauss method
   pf.radial.max_it       20          maximum number of iterations for
                                      radial power flow methods
   pf.radial.vcorr        0           perform voltage correction procedure
                                      in distribution power flow
       [  0 - do NOT perform voltage correction                           ]
       [  1 - perform voltage correction                                  ]
   pf.enforce_q_lims      0           enforce gen reactive power limits at
                                      expense of |V|
       [  0 - do NOT enforce limits                                       ]
       [  1 - enforce limits, simultaneous bus type conversion            ]
       [  2 - enforce limits, one-at-a-time bus type conversion           ]

Continuation Power Flow options:
   cpf.parameterization   3           choice of parameterization
       [  1 - natural                                                     ]
       [  2 - arc length                                                  ]
       [  3 - pseudo arc length                                           ]
   cpf.stop_at            'NOSE'      determines stopping criterion
       [ 'NOSE'     - stop when nose point is reached                     ]
       [ 'FULL'     - trace full nose curve                               ]
       [ <lam_stop> - stop upon reaching specified target lambda value    ]
   cpf.enforce_p_lims     0           enforce gen active power limits
       [  0 - do NOT enforce limits                                       ]
       [  1 - enforce limits, simultaneous bus type conversion            ]
   cpf.enforce_q_lims     0           enforce gen reactive power limits at
```

(continues on next page)

(continued from previous page)

```
                                    expense of |V|
      [  0 - do NOT enforce limits                                          ]
      [  1 - enforce limits, simultaneous bus type conversion               ]
   cpf.enforce_v_lims      0          enforce bus voltage magnitude limits
      [  0 - do NOT enforce limits                                          ]
      [  1 - enforce limits, termination on detection                       ]
   cpf.enforce_flow_lims   0          enforce branch flow MVA limits
      [  0 - do NOT enforce limits                                          ]
      [  1 - enforce limits, termination on detection                       ]
   cpf.step                0.05       continuation power flow step size
   cpf.adapt_step          0          toggle adaptive step size feature
      [  0 - adaptive step size disabled                                    ]
      [  1 - adaptive step size enabled                                     ]
   cpf.step_min            1e-4       minimum allowed step size
   cpf.step_max            0.2        maximum allowed step size
   cpf.adapt_step_damping  0.7        damping factor for adaptive step
                                      sizing
   cpf.adapt_step_tol      1e-3       tolerance for adaptive step sizing
   cpf.target_lam_tol      1e-5       tolerance for target lambda detection
   cpf.nose_tol            1e-5       tolerance for nose point detection (pu)
   cpf.p_lims_tol          0.01       tolerance for generator active
                                      power limit enforcement (MW)
   cpf.q_lims_tol          0.01       tolerance for generator reactive
                                      power limit enforcement (MVAR)
   cpf.v_lims_tol          1e-4       tolerance for bus voltage
                                      magnitude enforcement (p.u)
   cpf.flow_lims_tol       0.01       tolerance for line MVA flow
                                      enforcement (MVA)
   cpf.plot.level          0          control plotting of nose curve
      [  0 - do not plot nose curve                                         ]
      [  1 - plot when completed                                            ]
      [  2 - plot incrementally at each iteration                           ]
      [  3 - same as 2, with 'pause' at each iteration                      ]
   cpf.plot.bus            <empty>    index of bus whose voltage is to be
                                      plotted
   cpf.user_callback       <empty>    string containing the name of a user
                                      callback function, or struct with
                                      function name, and optional priority
                                      and/or args, or cell array of such
                                      strings and/or structs, see
                                      'help cpf_default_callback' for details

Optimal Power Flow options:
   name                    default    description [options]
----------------------    ---------   ---------------------------------
   opf.ac.solver           'DEFAULT'  AC optimal power flow solver
      [ 'DEFAULT' - choose default solver, i.e. 'MIPS'                      ]
      [ 'MIPS'    - MIPS, MATPOWER Interior Point Solver, primal/dual       ]
      [             interior point method (pure MATLAB/Octave)              ]
      [ 'FMINCON' - MATLAB Optimization Toolbox, FMINCON                    ]
      [ 'IPOPT'   - IPOPT, requires MEX interface to IPOPT solver           ]
      [             available from:                                         ]
```

(continues on next page)

(continued from previous page)

```
    [                   https://github.com/coin-or/Ipopt                ]
    [ 'KNITRO'  - Artelys Knitro, requires Artelys Knitro solver,       ]
    [             available from:https://www.artelys.com/solvers/knitro/]
    [ 'MINOPF'  - MINOPF, MINOS-based solver, requires optional         ]
    [             MEX-based MINOPF package, available from:             ]
    [                   http://www.pserc.cornell.edu/minopf/            ]
    [ 'PDIPM'   - PDIPM, primal/dual interior point method, requires    ]
    [             optional MEX-based TSPOPF package, available from:    ]
    [                   http://www.pserc.cornell.edu/tspopf/            ]
    [ 'SDPOPF'  - SDPOPF, solver based on semidefinite relaxation of    ]
    [             OPF problem, requires optional packages:              ]
    [               SDP_PF, available in extras/sdp_pf                  ]
    [               YALMIP, available from:                             ]
    [                   https://yalmip.github.io                        ]
    [               SDP solver such as SeDuMi, available from:          ]
    [                   http://sedumi.ie.lehigh.edu/                    ]
    [ 'TRALM'   - TRALM, trust region based augmented Langrangian       ]
    [             method, requires TSPOPF (see 'PDIPM')                 ]
opf.dc.solver           'DEFAULT'   DC optimal power flow solver
    [ 'DEFAULT' - choose solver based on availability in the following  ]
    [             order: 'GUROBI', 'CPLEX', 'MOSEK', 'OT',              ]
    [             'GLPK' (linear costs only), 'BPMPD', 'MIPS'           ]
    [ 'MIPS'    - MIPS, MATPOWER Interior Point Solver, primal/dual     ]
    [             interior point method (pure MATLAB/Octave)            ]
    [ 'BPMPD'   - BPMPD, requires optional MEX-based BPMPD_MEX package  ]
    [             available from: http://www.pserc.cornell.edu/bpmpd/   ]
    [ 'CLP'     - CLP, requires interface to COIN-OP LP solver          ]
    [             available from:https://github.com/coin-or/Clp         ]
    [ 'CPLEX'   - CPLEX, requires CPLEX solver available from:          ]
    [             https://www.ibm.com/analytics/cplex-optimizer         ]
    [ 'GLPK'    - GLPK, requires interface to GLPK solver               ]
    [             available from: https://www.gnu.org/software/glpk/    ]
    [             (GLPK does not work with quadratic cost functions)    ]
    [ 'GUROBI'  - GUROBI, requires Gurobi optimizer (v. 5+)             ]
    [             available from: https://www.gurobi.com/               ]
    [ 'IPOPT'   - IPOPT, requires MEX interface to IPOPT solver         ]
    [             available from:                                       ]
    [                 https://github.com/coin-or/Ipopt                  ]
    [ 'MOSEK'   - MOSEK, requires MATLAB interface to MOSEK solver      ]
    [             available from: https://www.mosek.com/                ]
    [ 'OSQP'    - OSQP, requires MATLAB interface to OSQP solver        ]
    [             available from: https://osqp.org/                     ]
    [ 'OT'      - MATLAB Optimization Toolbox, QUADPROG, LINPROG        ]
opf.current_balance     0           type of nodal balance equation
    [ 0 - use complex power balance equations                           ]
    [ 1 - use complex current balance equations                         ]
opf.v_cartesian         0           voltage representation
    [ 0 - bus voltage variables represented in polar coordinates        ]
    [ 1 - bus voltage variables represented in cartesian coordinates    ]
opf.violation           5e-6        constraint violation tolerance
opf.use_vg              0           respect gen voltage setpt     [ 0-1 ]
    [ 0 - use specified bus Vmin & Vmax, and ignore gen Vg              ]
```

(continues on next page)

(continued from previous page)

```
       [ 1 - replace specified bus Vmin & Vmax by corresponding gen Vg     ]
       [ between 0 and 1 - use a weighted average of the 2 options         ]
   opf.flow_lim            'S'         quantity limited by branch flow
                                       constraints
       [ 'S' - apparent power flow (limit in MVA)                          ]
       [ 'P' - active power flow, implemented using P   (limit in MW)      ]
       [ '2' - active power flow, implemented using P^2 (limit in MW)      ]
       [ 'I' - current magnitude (limit in MVA at 1 p.u. voltage)          ]
   opf.ignore_angle_lim    0           angle diff limits for branches
       [ 0 - include angle difference limits, if specified                 ]
       [ 1 - ignore angle difference limits even if specified              ]
   opf.softlims.default    1           behavior of OPF soft limits for
                                       which parameters are not explicitly
                                       provided
       [ 0 - do not include softlims if not explicitly specified           ]
       [ 1 - include softlims w/default values if not explicitly specified ]
   opf.start               0           strategy for initializing OPF start pt
       [   0 - default, MATPOWER decides based on solver                   ]
       [       (currently identical to 1)                                  ]
       [   1 - ignore current state in MATPOWER case (only applies to      ]
       [       fmincon, Ipopt, Knitro and MIPS, which use an interior pt   ]
       [       estimate; others use current state as with opf.start = 2)   ]
       [   2 - use current state in MATPOWER case                          ]
       [   3 - solve power flow and use resulting state                    ]
   opf.return_raw_der      0           for AC OPF, return constraint and
                                       derivative info in results.raw
                                       (in fields g, dg, df, d2f) [ 0 or 1 ]

Output options:
   name                    default     description [options]
----------------------    ---------   ---------------------------------
   verbose                 1           amount of progress info printed
       [   0 - print no progress info                                      ]
       [   1 - print a little progress info                                ]
       [   2 - print a lot of progress info                                ]
       [   3 - print all progress info                                     ]
   out.all                 -1          controls pretty-printing of results
       [  -1 - individual flags control what prints                        ]
       [   0 - do not print anything (overrides individual flags, ignored  ]
       [       for files specified as FNAME arg to runpf(), runopf(), etc.)]
       [   1 - print everything (overrides individual flags)               ]
   out.sys_sum             1           print system summary       [ 0 or 1 ]
   out.area_sum            0           print area summaries       [ 0 or 1 ]
   out.bus                 1           print bus detail           [ 0 or 1 ]
   out.branch              1           print branch detail        [ 0 or 1 ]
   out.gen                 0           print generator detail     [ 0 or 1 ]
   out.lim.all             -1          controls constraint info output
       [  -1 - individual flags control what constraint info prints        ]
       [   0 - no constraint info (overrides individual flags)             ]
       [   1 - binding constraint info (overrides individual flags)        ]
       [   2 - all constraint info (overrides individual flags)            ]
   out.lim.v               1           control voltage limit info
```

(continues on next page)

(continued from previous page)

```
       [   0 - do not print                                                ]
       [   1 - print binding constraints only                              ]
       [   2 - print all constraints                                       ]
       [   (same options for OUT_LINE_LIM, OUT_PG_LIM, OUT_QG_LIM)         ]
   out.lim.line            1           control line flow limit info
   out.lim.pg              1           control gen active power limit info
   out.lim.qg              1           control gen reactive pwr limit info
   out.force               0           print results even if success
                                       flag = 0                    [ 0 or 1 ]
   out.suppress_detail     -1          suppress all output but system summary
       [  -1 - suppress details for large systems (> 500 buses)            ]
       [   0 - do not suppress any output specified by other flags         ]
       [   1 - suppress all output except system summary section           ]
       [       (overrides individual flags, but not out.all = 1)           ]

Solver specific options:
       name                    default     description [options]
   ----------------------    ---------   ----------------------------------
   MIPS:
       mips.linsolver          ''          linear system solver
           [   '' or '\'   build-in backslash \ operator (e.g. x = A \ b)  ]
           [   'PARDISO'   PARDISO solver (if available)                    ]
       mips.feastol            0           feasibility (equality) tolerance
                                           (set to opf.violation by default)
       mips.gradtol            1e-6        gradient tolerance
       mips.comptol            1e-6        complementary condition
                                           (inequality) tolerance
       mips.costtol            1e-6        optimality tolerance
       mips.max_it             150         maximum number of iterations
       mips.step_control       0           enable step-size cntrl [ 0 or 1 ]
       mips.sc.red_it          20          maximum number of reductions per
                                           iteration with step control
       mips.xi                 0.99995     constant used in alpha updates*
       mips.sigma              0.1         centering parameter*
       mips.z0                 1           used to initialize slack variables*
       mips.alpha_min          1e-8        returns "Numerically Failed" if
                                           either alpha parameter becomes
                                           smaller than this value*
       mips.rho_min            0.95        lower bound on rho_t*
       mips.rho_max            1.05        upper bound on rho_t*
       mips.mu_threshold       1e-5        KT multipliers smaller than this
                                           value for non-binding constraints
                                           are forced to zero
       mips.max_stepsize       1e10        returns "Numerically Failed" if the
                                           2-norm of the reduced Newton step
                                           exceeds this value*
           * See the corresponding Appendix in the manual for details.

   CPLEX:
       cplex.lpmethod          0           solution algorithm for LP problems
           [   0 - automatic: let CPLEX choose                             ]
           [   1 - primal simplex                                          ]
```

(continues on next page)

(continued from previous page)

```
        [   2 - dual simplex                                            ]
        [   3 - network simplex                                         ]
        [   4 - barrier                                                 ]
        [   5 - sifting                                                 ]
        [   6 - concurrent (dual, barrier, and primal)                  ]
    cplex.qpmethod          0           solution algorithm for QP problems
        [   0 - automatic: let CPLEX choose                             ]
        [   1 - primal simplex optimizer                                ]
        [   2 - dual simplex optimizer                                  ]
        [   3 - network optimizer                                       ]
        [   4 - barrier optimizer                                       ]
    cplex.opts              <empty>     see CPLEX_OPTIONS for details
    cplex.opt_fname         <empty>     see CPLEX_OPTIONS for details
    cplex.opt               0           see CPLEX_OPTIONS for details

FMINCON:
    fmincon.alg             4           algorithm used by fmincon() for OPF
                                        for Opt Toolbox 4 and later
         [  1 - active-set (not suitable for large problems)            ]
         [  2 - interior-point, w/default 'bfgs' Hessian approx         ]
         [  3 - interior-point, w/ 'lbfgs' Hessian approx               ]
         [  4 - interior-point, w/exact user-supplied Hessian           ]
         [  5 - interior-point, w/Hessian via finite differences        ]
         [  6 - sqp (not suitable for large problems)                   ]
    fmincon.tol_x           1e-4        termination tol on x
    fmincon.tol_f           1e-4        termination tol on f
    fmincon.max_it          0           maximum number of iterations
                                                    [  0 => default ]

GUROBI:
    gurobi.method           0           solution algorithm (Method)
        [  -1 - automatic, let Gurobi decide                            ]
        [   0 - primal simplex                                          ]
        [   1 - dual simplex                                            ]
        [   2 - barrier                                                 ]
        [   3 - concurrent (LP only)                                    ]
        [   4 - deterministic concurrent (LP only)                      ]
        [   5 - deterministic concurrent simplex (LP only)              ]
    gurobi.timelimit        Inf         maximum time allowed (TimeLimit)
    gurobi.threads          0           max number of threads (Threads)
    gurobi.opts             <empty>     see GUROBI_OPTIONS for details
    gurobi.opt_fname        <empty>     see GUROBI_OPTIONS for details
    gurobi.opt              0           see GUROBI_OPTIONS for details

IPOPT:
    ipopt.opts              <empty>     see IPOPT_OPTIONS for details
    ipopt.opt_fname         <empty>     see IPOPT_OPTIONS for details
    ipopt.opt               0           see IPOPT_OPTIONS for details

KNITRO:
    knitro.tol_x            1e-4        termination tol on x
    knitro.tol_f            1e-4        termination tol on f
```

(continues on next page)

(continued from previous page)

```
    knitro.maxit            0           maximum number of iterations
                                                    [  0 => default ]
    knitro.opt_fname        <empty>     name of user-supplied native
                                        Knitro options file that overrides
                                        all other options
    knitro.opt              0           if knitro.opt_fname is empty and
                                        knitro.opt is a non-zero integer N
                                        then knitro.opt_fname is auto-
                                        generated as:
                                        'knitro_user_options_N.txt'

LINPROG:
    linprog                 <empty>     LINPROG options passed to
                                        OPTIMOPTIONS or OPTIMSET.
                                        see LINPROG in the Optimization
                                        Toolbox for details

MINOPF:
    minopf.feastol          0 (1e-3)    primal feasibility tolerance
                                        (set to opf.violation by default)
    minopf.rowtol           0 (1e-3)    row tolerance
    minopf.xtol             0 (1e-4)    x tolerance
    minopf.majdamp          0 (0.5)     major damping parameter
    minopf.mindamp          0 (2.0)     minor damping parameter
    minopf.penalty          0 (1.0)     penalty parameter
    minopf.major_it         0 (200)     major iterations
    minopf.minor_it         0 (2500)    minor iterations
    minopf.max_it           0 (2500)    iterations limit
    minopf.verbosity        -1          amount of progress info printed
        [  -1 - controlled by 'verbose' option                          ]
        [   0 - print nothing                                           ]
        [   1 - print only termination status message                   ]
        [   2 - print termination status and screen progress            ]
        [   3 - print screen progress, report file (usually fort.9)     ]
    minopf.core             0 (1200*nb + 2*(nb+ng)^2) memory allocation
    minopf.supbasic_lim     0 (2*nb + 2*ng) superbasics limit
    minopf.mult_price       0 (30)      multiple price

MOSEK:
    mosek.lp_alg            0           solution algorithm
                                            (MSK_IPAR_OPTIMIZER)
        for MOSEK 8.x ...       (see MOSEK_SYMBCON for a "better way")
        [   0 - automatic: let MOSEK choose                             ]
        [   1 - dual simplex                                            ]
        [   2 - automatic: let MOSEK choose                             ]
        [   3 - automatic simplex (MOSEK chooses which simplex method)  ]
        [   4 - interior point                                          ]
        [   6 - primal simplex                                          ]
    mosek.max_it            0 (400)     interior point max iterations
                                            (MSK_IPAR_INTPNT_MAX_ITERATIONS)
    mosek.gap_tol           0 (1e-8)    interior point relative gap tol
                                            (MSK_DPAR_INTPNT_TOL_REL_GAP)
```

(continues on next page)

(continued from previous page)

```
      mosek.max_time          0 (-1)      maximum time allowed
                                              (MSK_DPAR_OPTIMIZER_MAX_TIME)
      mosek.num_threads       0 (1)       max number of threads
                                              (MSK_IPAR_INTPNT_NUM_THREADS)
      mosek.opts              <empty>     see MOSEK_OPTIONS for details
      mosek.opt_fname         <empty>     see MOSEK_OPTIONS for details
      mosek.opt               0           see MOSEK_OPTIONS for details

   OSQP:
      osqp.opts               <empty>     see OSQP_OPTIONS for details

   QUADPROG:
      quadprog                <empty>     QUADPROG options passed to
                                          OPTIMOPTIONS or OPTIMSET.
                                          see QUADPROG in the Optimization
                                          Toolbox for details

   TSPOPF:
      pdipm.feastol           0           feasibility (equality) tolerance
                                          (set to opf.violation by default)
      pdipm.gradtol           1e-6        gradient tolerance
      pdipm.comptol           1e-6        complementary condition
                                          (inequality) tolerance
      pdipm.costtol           1e-6        optimality tolerance
      pdipm.max_it            150         maximum number of iterations
      pdipm.step_control      0           enable step-size cntrl [ 0 or 1 ]
      pdipm.sc.red_it         20          maximum number of reductions per
                                          iteration with step control
      pdipm.sc.smooth_ratio   0.04        piecewise linear curve smoothing
                                          ratio

      tralm.feastol           0           feasibility tolerance
                                          (set to opf.violation by default)
      tralm.primaltol         5e-4        primal variable tolerance
      tralm.dualtol           5e-4        dual variable tolerance
      tralm.costtol           1e-5        optimality tolerance
      tralm.major_it          40          maximum number of major iterations
      tralm.minor_it          40          maximum number of minor iterations
      tralm.smooth_ratio      0.04        piecewise linear curve smoothing
                                          ratio

Experimental Options:
   exp.use_legacy_core        0           set to 1 to bypass MP-Core and
                                          force use of legacy core code for
                                          runpf(), runcpf(), runopf().
   exp.sys_wide_zip_loads.pw  <empty>     1 x 3 vector of active load fraction
                                          to be modeled as constant power,
                                          constant current and constant
                                          impedance, respectively, where
                                          <empty> means use [1 0 0]
   exp.sys_wide_zip_loads.qw  <empty>     same for reactive power, where
                                          <empty> means use same value as
```

(continues on next page)

(continued from previous page)

```
                                                    for 'pw'
```

printpf

printpf(*baseMVA*, *bus*, *gen*, *branch*, *f*, *success*, *et*, *fd*, *mpopt*)

printpf() - Prints power flow results.

```
PRINTPF(RESULTS, FD, MPOPT)
PRINTPF(BASEMVA, BUS, GEN, BRANCH, F, SUCCESS, ET, FD, MPOPT)

Prints power flow and optimal power flow results to FD (a file
descriptor which defaults to STDOUT), with the details of what
gets printed controlled by the optional MPOPT argument, which is a
MATPOWER options struct (see MPOPTION for details).

The data can either be supplied in a single RESULTS struct, or
in the individual arguments: BASEMVA, BUS, GEN, BRANCH, F, SUCCESS
and ET, where F is the OPF objective function value, SUCCESS is
true if the solution converged and false otherwise, and ET is the
elapsed time for the computation in seconds. If F is given, it is
assumed that the output is from an OPF run, otherwise it is assumed
to be a simple power flow run.

Examples:
    mpopt = mpoptions('out.gen', 1, 'out.bus', 0, 'out.branch', 0);
    [fd, msg] = fopen(fname, 'at');
    results = runopf(mpc);
    printpf(results);
    printpf(results, fd);
    printpf(results, fd, mpopt);
    printpf(baseMVA, bus, gen, branch, f, success, et);
    printpf(baseMVA, bus, gen, branch, f, success, et, fd);
    printpf(baseMVA, bus, gen, branch, f, success, et, fd, mpopt);
    fclose(fd);
```

psse2mpc

psse2mpc(*rawfile_name*, *mpc_name*, *verbose*, *rev*)

psse2mpc() - Converts a PSS/E RAW data file into a MATPOWER case struct.

```
MPC = PSSE2MPC(RAWFILE_NAME)
MPC = PSSE2MPC(RAWFILE_NAME, VERBOSE)
MPC = PSSE2MPC(RAWFILE_NAME, VERBOSE, REV)
MPC = PSSE2MPC(RAWFILE_NAME, MPC_NAME)
MPC = PSSE2MPC(RAWFILE_NAME, MPC_NAME, VERBOSE)
MPC = PSSE2MPC(RAWFILE_NAME, MPC_NAME, VERBOSE, REV)
[MPC, WARNINGS] = PSSE2MPC(RAWFILE_NAME, ...)
```

(continues on next page)

(continued from previous page)

```
Converts a PSS/E RAW data file into a MATPOWER case struct.

Input:
    RAWFILE_NAME :  name of the PSS/E RAW file to be converted
                    (opened directly with FILEREAD)
    MPC_NAME     :  (optional) file name to use to save the resulting
                     MATPOWER case
    VERBOSE      :  1 (default) to display progress info, 0 otherwise
    REV          :  (optional) assume the input file is of this
                    PSS/E revision number, attempts to determine
                    REV from the file by default

Output(s):
    MPC      : resulting MATPOWER case struct
    WARNINGS : (optional) cell array of strings containing warning
               messages (included by default in comments of MPC_NAME).

NOTE: The data sections to be read in the PSS/E raw file includes:
      identification data; bus data; branch data; fixed shunt data;
      generator data; transformer data; switched shunt data; area data
      and hvdc line data. Other data sections are currently ignored.
```

save2psse

save2psse(*fname*, *mpc*, *rawver*)

save2psse() - Saves a MATPOWER case to PSS/E RAW format.

```
SAVE2PSSE(FNAME, MPC)

FNAME = SAVE2PSSE(FNAME, ...)

Saves a MATPOWER case struct MPC as a PSS/E RAW file. The FNAME
parameter is a string containing the name of the file to be created
or overwritten. If FNAME does not include a file extension, '.raw'
will be added. Optionally returns the, possibly updated, filename.
Currently exports to RAW format Rev 33.
```

savecase

savecase(*fname*, *varargin*)

savecase() - Saves a MATPOWER case file, given a filename and the data.

```
SAVECASE(FNAME, CASESTRUCT)
SAVECASE(FNAME, CASESTRUCT, VERSION)
SAVECASE(FNAME, BASEMVA, BUS, GEN, BRANCH)
SAVECASE(FNAME, BASEMVA, BUS, GEN, BRANCH, GENCOST)
SAVECASE(FNAME, BASEMVA, BUS, GEN, BRANCH, AREAS, GENCOST)
SAVECASE(FNAME, COMMENT, CASESTRUCT)
SAVECASE(FNAME, COMMENT, CASESTRUCT, VERSION)
SAVECASE(FNAME, COMMENT, BASEMVA, BUS, GEN, BRANCH)
SAVECASE(FNAME, COMMENT, BASEMVA, BUS, GEN, BRANCH, GENCOST)
SAVECASE(FNAME, COMMENT, BASEMVA, BUS, GEN, BRANCH, AREAS, GENCOST)

FNAME = SAVECASE(FNAME, ...)

Writes a MATPOWER case file, given a filename and data struct or list of
data matrices. The FNAME parameter is the name of the file to be created or
overwritten. If FNAME ends with '.mat' it saves the case as a MAT-file
otherwise it saves it as an M-file. Optionally returns the filename,
with extension added if necessary. The optional COMMENT argument is
either string (single line comment) or a cell array of strings which
are inserted as comments. When using a MATPOWER case struct, if the
optional VERSION argument is '1' it will modify the data matrices to
version 1 format before saving.
```

savechgtab

savechgtab(*fname*, *chgtab*, *warnings*)

savechgtab() - Save a change table to a file.

```
SAVECHGTAB(FNAME, CHGTAB)
SAVECHGTAB(FNAME, CHGTAB, WARNINGS)
FNAME = SAVECHGTAB(FNAME, ...)

Writes a CHGTAB, suitable for use with APPLY_CHANGES to a file
specified by FNAME. If FNAME ends with '.mat' it saves CHGTAB
and WARNINGS to a MAT-file as the variables 'chgtab' and 'warnings',
respectively. Otherwise, it saves an M-file function that returns
the CHGTAB, with the optional WARNINGS in comments.

Optionally returns the filename, with extension added if necessary.

Input:
    FNAME :  name of the file to be saved
    CHGTAB :  change table suitable for use with APPLY_CHANGES
    WARNINGS : optional cell array of warning messages (to be
                included in comments), such as those returned by
```

(continues on next page)

(continued from previous page)

```
                PSSECON2CHGTAB

Output(s):
    FNAME :  name of the file, with extention added if necessary
```

5.2.3 Data Conversion Functions

ext2int

ext2int(*bus*, *gen*, *branch*, *areas*)

ext2int() - Converts external to internal indexing.

```
This function has two forms, (1) the old form that operates on
and returns individual matrices and (2) the new form that operates
on and returns an entire MATPOWER case struct.

1.  [I2E, BUS, GEN, BRANCH, AREAS] = EXT2INT(BUS, GEN, BRANCH, AREAS)
    [I2E, BUS, GEN, BRANCH] = EXT2INT(BUS, GEN, BRANCH)

If the first argument is a matrix, it simply converts from (possibly
non-consecutive) external bus numbers to consecutive internal bus
numbers which start at 1. Changes are made to BUS, GEN and BRANCH,
which are returned along with a vector of indices I2E that can be
passed to INT2EXT to perform the reverse conversion, where
EXTERNAL_BUS_NUMBER = I2E(INTERNAL_BUS_NUMBER).
AREAS is completely ignored and is only included here for backward
compatibility of the API.

Examples:
    [i2e, bus, gen, branch, areas] = ext2int(bus, gen, branch, areas);
    [i2e, bus, gen, branch] = ext2int(bus, gen, branch);

2.  MPC = EXT2INT(MPC)
    MPC = EXT2INT(MPC, MPOPT)

If the input is a single MATPOWER case struct, followed optionally
by a MATOWER options struct, then all isolated buses, off-line
generators and branches are removed along with any generators or
branches connected to isolated buses. Then the buses are renumbered
consecutively, beginning at 1. Any 'ext2int' callback routines registered
in the case are also invoked automatically. All of the related indexing
information and the original data matrices are stored in an 'order'
field in the struct to be used by INT2EXT to perform the reverse
conversions. If the case is already using internal numbering it is
returned unchanged.

Examples:
    mpc = ext2int(mpc);
```

(continues on next page)

(continued from previous page)

```
    mpc = ext2int(mpc, mpopt);

The 'order' field of MPC used to store the indexing information
needed for subsequent internal to external conversion is structured
as:

    order
        state       'i' | 'e'
        ext | int
            bus
            branch
            gen
            gencost
            A
            N
        bus
            e2i
            i2e
            status
                on
                off
        gen
            e2i
            i2e
            status
                on
                off
        branch
            status
                on
                off
```

See also `int2ext()`, *e2i_field()* (page 255), *e2i_data()* (page 254).

e2i_data

e2i_data(*mpc*, *val*, *ordering*, *dim*)

e2i_data() (page 254) - Converts data from external to internal indexing.

```
VAL = E2I_DATA(MPC, VAL, ORDERING)
VAL = E2I_DATA(MPC, VAL, ORDERING, DIM)

When given a case struct that has already been converted to
internal indexing, this function can be used to convert other data
structures as well by passing in 2 or 3 extra parameters in
addition to the case struct. If the value passed in the 2nd
argument is a column vector or cell array, it will be converted
according to the ORDERING specified by the 3rd argument (described
below). If VAL is an n-dimensional matrix or cell array, then the
optional 4th argument (DIM, default = 1) can be used to specify
```

(continues on next page)

(continued from previous page)

```
which dimension to reorder. The return value in this case is the
value passed in, converted to internal indexing.

The 3rd argument, ORDERING, is used to indicate whether the data
corresponds to bus-, gen- or branch-ordered data. It can be one
of the following three strings: 'bus', 'gen' or 'branch'. For
data structures with multiple blocks of data, ordered by bus,
gen or branch, they can be converted with a single call by
specifying ORDERING as a cell array of strings.

Any extra elements, rows, columns, etc. beyond those indicated
in ORDERING, are not disturbed.

Examples:
    A_int = e2i_data(mpc, A_ext, {'bus','bus','gen','gen'}, 2);

    Converts an A matrix for user-supplied OPF constraints from
    external to internal ordering, where the columns of the A
    matrix correspond to bus voltage angles, then voltage
    magnitudes, then generator real power injections and finally
    generator reactive power injections.

    gencost_int = e2i_data(mpc, gencost_ext, {'gen','gen'}, 1);

    Converts a GENCOST matrix that has both real and reactive power
    costs (in rows 1--ng and ng+1--2*ng, respectively).
```

See also *i2e_data()* (page 257), *e2i_field()* (page 255), ext2int().

e2i_field

e2i_field(*mpc*, *field*, *ordering*, *dim*)

e2i_field() (page 255) - Converts fields of mpc from external to internal indexing.

```
This function performs several different tasks, depending on the
arguments passed.

MPC = E2I_FIELD(MPC, FIELD, ORDERING)
MPC = E2I_FIELD(MPC, FIELD, ORDERING, DIM)

When given a case struct that has already been converted to
internal indexing, this function can be used to convert other data
structures as well by passing in 2 or 3 extra parameters in
addition to the case struct.

The 2nd argument is a string or cell array of strings, specifying
a field in the case struct whose value should be converted by
a corresponding call to E2I_DATA. The field can contain either a
numeric or a cell array. The converted value is stored back in the
specified field, the original value is saved for later use and the
```

(continues on next page)

(continued from previous page)

```
updated case struct is returned. If FIELD is a cell array of strings,
they specify nested fields.

The 3rd and optional 4th arguments are simply passed along to
the call to E2I_DATA.

Examples:
    mpc = e2i_field(mpc, {'reserves', 'cost'}, 'gen');

    Reorders rows of mpc.reserves.cost to match internal generator
    ordering.

    mpc = e2i_field(mpc, {'reserves', 'zones'}, 'gen', 2);

    Reorders columns of mpc.reserves.zones to match internal
    generator ordering.
```

See also *i2e_field()* (page 258), *e2i_data()* (page 254), ext2int().

int2ext

int2ext(*i2e*, *bus*, *gen*, *branch*, *areas*)

int2ext() - Converts internal to external bus numbering.

```
This function has two forms, (1) the old form that operates on
and returns individual matrices and (2) the new form that operates
on and returns an entire MATPOWER case struct.

1.  [BUS, GEN, BRANCH, AREAS] = INT2EXT(I2E, BUS, GEN, BRANCH, AREAS)
    [BUS, GEN, BRANCH] = INT2EXT(I2E, BUS, GEN, BRANCH)

Converts from the consecutive internal bus numbers back to the originals
using the mapping provided by the I2E vector returned from EXT2INT,
where EXTERNAL_BUS_NUMBER = I2E(INTERNAL_BUS_NUMBER).
AREAS is completely ignored and is only included here for backward
compatibility of the API.

Examples:
    [bus, gen, branch, areas] = int2ext(i2e, bus, gen, branch, areas);
    [bus, gen, branch] = int2ext(i2e, bus, gen, branch);

2.  MPC = INT2EXT(MPC)
    MPC = INT2EXT(MPC, MPOPT)

If the input is a single MATPOWER case struct, followed optionally
by a MATOWER options struct, then it restores all buses, generators
and branches that were removed because of being isolated or off-line,
and reverts to the original generator ordering and original bus
numbering. This requires that the 'order' field created by EXT2INT be
in place.
```

(continues on next page)

(continued from previous page)

```
Examples:
    mpc = int2ext(mpc);
    mpc = int2ext(mpc, mpopt);
```

See also `ext2int()`, *i2e_field()* (page 258), *i2e_data()* (page 257).

i2e_data

i2e_data(*mpc*, *val*, *oldval*, *ordering*, *dim*)

i2e_data() (page 257) - Converts data from internal to external indexing.

```
VAL = I2E_DATA(MPC, VAL, OLDVAL, ORDERING)
VAL = I2E_DATA(MPC, VAL, OLDVAL, ORDERING, DIM)

For a case struct using internal indexing, this function can be
used to convert other data structures as well by passing in 3 or 4
extra parameters in addition to the case struct. If the value passed
in the 2nd argument (VAL) is a column vector or cell array, it will
be converted according to the ordering specified by the 4th argument
(ORDERING, described below). If VAL is an n-dimensional matrix or
cell array, then the optional 5th argument (DIM, default = 1) can be
used to specify which dimension to reorder. The 3rd argument (OLDVAL)
is used to initialize the return value before converting VAL to
external indexing. In particular, any data corresponding to off-line
gens or branches or isolated buses or any connected gens or branches
will be taken from OLDVAL, with VAL supplying the rest of the
returned data.

The ORDERING argument is used to indicate whether the data
corresponds to bus-, gen- or branch-ordered data. It can be one
of the following three strings: 'bus', 'gen' or 'branch'. For
data structures with multiple blocks of data, ordered by bus,
gen or branch, they can be converted with a single call by
specifying ORDERING as a cell array of strings.

Any extra elements, rows, columns, etc. beyond those indicated
in ORDERING, are not disturbed.

Examples:
    A_ext = i2e_data(mpc, A_int, A_orig, {'bus','bus','gen','gen'}, 2);

    Converts an A matrix for user-supplied OPF constraints from
    internal to external ordering, where the columns of the A
    matrix correspond to bus voltage angles, then voltage
    magnitudes, then generator real power injections and finally
    generator reactive power injections.

    gencost_ext = i2e_data(mpc, gencost_int, gencost_orig, {'gen','gen'}, 1);
```

(continues on next page)

(continued from previous page)

```
    Converts a GENCOST matrix that has both real and reactive power
    costs (in rows 1--ng and ng+1--2*ng, respectively).
```

See also *e2i_data()* (page 254), *i2e_field()* (page 258), int2ext().

i2e_field

i2e_field(*mpc*, *field*, *ordering*, *dim*)

i2e_field() (page 258) - Converts fields of mpc from internal to external bus numbering.

```
MPC = I2E_FIELD(MPC, FIELD, ORDERING)
MPC = I2E_FIELD(MPC, FIELD, ORDERING, DIM)

For a case struct using internal indexing, this function can be
used to convert other data structures as well by passing in 2 or 3
extra parameters in addition to the case struct.

The 2nd argument is a string or cell array of strings, specifying
a field in the case struct whose value should be converted by
a corresponding call to I2E_DATA. The field can contain either a
numeric or a cell array. The corresponding OLDVAL is taken from
where it was stored by EXT2INT in MPC.ORDER.EXT and the updated
case struct is returned. If FIELD is a cell array of strings,
they specify nested fields.

The 3rd and optional 4th arguments are simply passed along to
the call to I2E_DATA.

Examples:
    mpc = i2e_field(mpc, {'reserves', 'cost'}, 'gen');

    Reorders rows of mpc.reserves.cost to match external generator
    ordering.

    mpc = i2e_field(mpc, {'reserves', 'zones'}, 'gen', 2);

    Reorders columns of mpc.reserves.zones to match external
    generator ordering.
```

See also *e2i_field()* (page 255), *i2e_data()* (page 257), int2ext().

get_reorder

get_reorder(*A*, *idx*, *dim*)

get_reorder() (page 259) - Returns A with one of its dimensions indexed.

```
B = GET_REORDER(A, IDX, DIM)

Returns A(:, ..., :, IDX, :, ..., :), where DIM determines
in which dimension to place the IDX.
```

See also *set_reorder()* (page 259).

set_reorder

set_reorder(*A*, *B*, *idx*, *dim*)

set_reorder() (page 259) - Assigns B to A with one of the dimensions of A indexed.

```
A = SET_REORDER(A, B, IDX, DIM)

Returns A after doing A(:, ..., :, IDX, :, ..., :) = B
where DIM determines in which dimension to place the IDX.

If any dimension of B is smaller than the corresponding dimension
of A, the "extra" elements in A are untouched. If any dimension of
B is larger than the corresponding dimension of A, then A is padded
with zeros (if numeric) or empty matrices (if cell array) before
performing the assignment.
```

See also *get_reorder()* (page 259).

5.2.4 Power Flow Functions

calc_v_i_sum

calc_v_i_sum(*Vslack*, *nb*, *nl*, *f*, *Zb*, *Ybf*, *Ybt*, *Yd*, *Sd*, *pv*, *Pg*, *Vg*, *mpopt*)

calc_v_i_sum() (page 259) - Solves the power flow using the current summation method.

```
[V, Qpv, Sf, St, Sslack, iter, success] = calc_v_i_sum(Vslack,nb,nl,f,Zb,Ybf,Ybt,Yd,
↪Sd,pv,Pg,Vg,tol,iter_max)

Solves for bus voltages, generator reactive power, branch active and
reactive power flows and slack bus active and reactive power. The input
data consist of slack bus voltage, vector "from bus" indices, branch
impedance and shunt admittance, vector of bus shunt admittances and
load demand, as well as vectors with indicies of PV buses with their
specified voltages and active powers. It is assumed that the branches
are ordered using the principle of oriented ordering: indicies of
```

(continues on next page)

(continued from previous page)

```
sending nodes are smaller then the indicies of the receiving nodes. The
branch index is equal to the index of their receiving node. Branch
addmittances are added in Yd and treated as constant admittance bus
loads. The applied method is current summation taken from:
D. Shirmohammadi, H. W. Hong, A. Semlyen and G. X. Luo,
"A compensation-based power flow method for weakly meshed distribution
and transmission networks," IEEE Transactions on Power Systems,
vol. 3, no. 2, pp. 753-762, May 1988. https://doi.org/10.1109/59.192932
and
G. X. Luo and A. Semlyen, "Efficient load flow for large weakly meshed
networks," IEEE Transactions on Power Systems, vol. 5, no. 4,
pp. 1309-1316, Nov 1990. https://doi.org/10.1109/59.99382
```

See also *radial_pf()* (page 268).

calc_v_pq_sum

calc_v_pq_sum(*Vslack*, *nb*, *nl*, *f*, *Zb*, *Ybf*, *Ybt*, *Yd*, *Sd*, *pv*, *Pg*, *Vg*, *mpopt*)

calc_v_pq_sum() (page 260) - Solves the power flow using the power summation method.

```
[V, Qpv, Sf, St, Sslack, iter, success] = calc_v_pq_sum(Vslack,nb,nl,f,Zb,Ybf,Ybt,,
↪Yd,Sd,pv,Pg,Vg,tol,iter_max)

Solves for bus voltages, generator reactive power, branch active and
reactive power flows and slack bus active and reactive power. The input
data consist of slack bus voltage, vector "from bus" indices, branch
impedance and shunt admittance, vector of bus shunt admittances and
load demand, as well as vectors with indicies of PV buses with their
specified voltages and active powers. It is assumed that the branches
are ordered using the principle of oriented ordering: indicies of
sending nodes are smaller then the indicies of the receiving nodes. The
branch index is equal to the index of their receiving node. Branch
addmittances are added in Yd and treated as constant admittance bus
loads. The applied method is Voltage correction power flow (VCPF) taken
from:
D. Rajicic, R. Ackovski and R. Taleski, "Voltage correction power flow,"
IEEE Transactions on Power Delivery, vol. 9, no. 2, pp. 1056-1062, Apr 1994.
https://doi.org/10.1109/61.296308
```

See also *radial_pf()* (page 268).

calc_v_y_sum

calc_v_y_sum(*Vslack*, *nb*, *nl*, *f*, *Zb*, *Ybf*, *Ybt*, *Yd*, *Sd*, *pv*, *Pg*, *Vg*, *mpopt*)

calc_v_y_sum() (page 261) - Solves the power flow using the admittance summation method.

```
[V, Qpv, Sf, St, Sslack, iter, success] = calc_v_y_sum(Vslack,nb,nl,f,Zb,Ybf,Ybt,Yd,
↪Sd,pv,Pg,Vg,tol,iter_max)

Solves for bus voltages, generator reactive power, branch active and
reactive power flows and slack bus active and reactive power. The input
data consist of slack bus voltage, vector "from bus" indices, branch
impedance and shunt admittance, vector of bus shunt admittances and
load demand, as well as vectors with indicies of PV buses with their
specified voltages and active powers. It is assumed that the branches
are ordered using the principle of oriented ordering: indicies of
sending nodes are smaller then the indicies of the receiving nodes. The
branch index is equal to the index of their receiving node. Branch
addmittances are added in Yd and treated as constant admittance bus
loads. The applied method is admittance summation taken from:
Dragoslav Rajičić, Rubin Taleski, Two novel methods for radial and
weakly meshed network analysis, Electric Power Systems Research,
Volume 48, Issue 2, 15 December 1998, Pages 79-87
https://doi.org/10.1016/S0378-7796(98)00067-4
```

See also *radial_pf()* (page 268).

dcpf

dcpf(*B*, *Pbus*, *Va0*, *ref*, *pv*, *pq*)

dcpf() - Solves a DC power flow.

```
[VA, SUCCESS] = DCPF(B, PBUS, VA0, REF, PV, PQ) solves for the bus
voltage angles at all but the reference bus, given the full system
B matrix and the vector of bus real power injections, the initial
vector of bus voltage angles (in radians), and column vectors with
the lists of bus indices for the swing bus, PV buses, and PQ buses,
respectively. Returns a vector of bus voltage angles in radians.
```

See also rundcpf(), runpf().

fdpf

fdpf(*Ybus*, *Sbus*, *V0*, *Bp*, *Bpp*, *ref*, *pv*, *pq*, *mpopt*)

fdpf() - Solves the power flow using a fast decoupled method.

```
[V, CONVERGED, I] = FDPF(YBUS, SBUS, V0, BP, BPP, REF, PV, PQ, MPOPT)
solves for bus voltages given the full system admittance matrix (for
all buses), the complex bus power injection vector (for all buses),
the initial vector of complex bus voltages, the FDPF matrices B prime
and B double prime, and column vectors with the lists of bus indices
for the swing bus, PV buses, and PQ buses, respectively. The bus voltage
vector contains the set point for generator (including ref bus)
buses, and the reference angle of the swing bus, as well as an initial
guess for remaining magnitudes and angles. MPOPT is a MATPOWER options
vector which can be used to set the termination tolerance, maximum
number of iterations, and output options (see MPOPTION for details).
Uses default options if this parameter is not given. Returns the
final complex voltages, a flag which indicates whether it converged
or not, and the number of iterations performed.
```

See also runpf().

gausspf

gausspf(*Ybus*, *Sbus*, *V0*, *ref*, *pv*, *pq*, *mpopt*)

gausspf() - Solves the power flow using a Gauss-Seidel method.

```
[V, CONVERGED, I] = GAUSSPF(YBUS, SBUS, V0, REF, PV, PQ, MPOPT)
solves for bus voltages given the full system admittance matrix (for
all buses), the complex bus power injection vector (for all buses),
the initial vector of complex bus voltages, and column vectors with
the lists of bus indices for the swing bus, PV buses, and PQ buses,
respectively. The bus voltage vector contains the set point for
generator (including ref bus) buses, and the reference angle of the
swing bus, as well as an initial guess for remaining magnitudes and
angles. MPOPT is a MATPOWER options struct which can be used to
set the termination tolerance, maximum number of iterations, and
output options (see MPOPTION for details). Uses default options
if this parameter is not given. Returns the final complex voltages,
a flag which indicates whether it converged or not, and the number
of iterations performed.
```

See also runpf().

make_vcorr

make_vcorr(*DD*, *pv*, *nb*, *nl*, *f*, *Zb*)

make_vcorr() (page 263) - Voltage Correction used in distribution power flow.

```
V_corr = make_vcorr(DD,pv,nb,nl,f,Zb)

Calculates voltage corrections with current generators placed at PV
buses. Their currents are calculated with the voltage difference at PV
buses break points and loop impedances. The slack bus voltage is set to
zero. Details can be seen in
D. Rajicic, R. Ackovski and R. Taleski, "Voltage correction power flow,"
IEEE Transactions on Power Delivery, vol. 9, no. 2, pp. 1056-1062, Apr 1994.
https://doi.org/10.1109/61.296308
```

See also *radial_pf()* (page 268).

make_zpv

make_zpv(*pv*, *nb*, *nl*, *f*, *Zb*, *Yd*)

make_zpv() (page 263) - Calculates loop impedances for all PV buses.

```
Zpv = make_zpv(pv,nb,nl,f,Zb,Yd)

Loop impedance of a PV bus is defined as impedance of the path between
the bus and the slack bus. The mutual impedance between two PV buses is
the impedance of the joint part of the two path going from each of the
PV buses to the slack bus. The impedances are calculated as bus voltages
in cases when at one of the PV buses we inject current of -1 A. All
voltages are calculated with the backward-forward sweep method. The
input variables are the vector of indicies with "from" buses for each
branch, the vector of branch impedances and indicies of PV buses.
```

See also *calc_v_pq_sum()* (page 260).

newtonpf

newtonpf(*Ybus*, *Sbus*, *V0*, *ref*, *pv*, *pq*, *mpopt*)

`newtonpf()` - Solves power flow using full Newton's method (power/polar).

```
[V, CONVERGED, I] = NEWTONPF(YBUS, SBUS, V0, REF, PV, PQ, MPOPT)

Solves for bus voltages using a full Newton-Raphson method, using nodal
power balance equations and polar coordinate representation of
voltages, given the following inputs:
    YBUS  - full system admittance matrix (for all buses)
    SBUS  - handle to function that returns the complex bus power
            injection vector (for all buses), given the bus voltage
            magnitude vector (for all buses)
```

(continues on next page)

(continued from previous page)

```
    V0    - initial vector of complex bus voltages
    REF   - bus index of reference bus (voltage ang reference & gen slack)
    PV    - vector of bus indices for PV buses
    PQ    - vector of bus indices for PQ buses
    MPOPT - (optional) MATPOWER option struct, used to set the
            termination tolerance, maximum number of iterations, and
            output options (see MPOPTION for details).

The bus voltage vector contains the set point for generator
(including ref bus) buses, and the reference angle of the swing
bus, as well as an initial guess for remaining magnitudes and
angles.

Returns the final complex voltages, a flag which indicates whether it
converged or not, and the number of iterations performed.
```

See also runpf(), *newtonpf_S_cart()* (page 266), *newtonpf_I_polar()* (page 265), *newtonpf_I_cart()* (page 264).

newtonpf_I_cart

newtonpf_I_cart(*Ybus*, *Sbus*, *V0*, *ref*, *pv*, *pq*, *mpopt*)

newtonpf_I_cart() (page 264) - Solves power flow using full Newton's method (current/cartesian).

```
[V, CONVERGED, I] = NEWTONPF_I_CART(YBUS, SBUS, V0, REF, PV, PQ, MPOPT)

Solves for bus voltages using a full Newton-Raphson method, using nodal
current balance equations and cartesian coordinate representation of
voltages, given the following inputs:
    YBUS  - full system admittance matrix (for all buses)
    SBUS  - handle to function that returns the complex bus power
            injection vector (for all buses), given the bus voltage
            magnitude vector (for all buses)
    V0    - initial vector of complex bus voltages
    REF   - bus index of reference bus (voltage ang reference & gen slack)
    PV    - vector of bus indices for PV buses
    PQ    - vector of bus indices for PQ buses
    MPOPT - (optional) MATPOWER option struct, used to set the
            termination tolerance, maximum number of iterations, and
            output options (see MPOPTION for details).

The bus voltage vector contains the set point for generator
(including ref bus) buses, and the reference angle of the swing
bus, as well as an initial guess for remaining magnitudes and
angles.

Returns the final complex voltages, a flag which indicates whether it
converged or not, and the number of iterations performed.
```

See also runpf(), newtonpf(), *newtonpf_S_cart()* (page 266), *newtonpf_I_polar()* (page 265).

newtonpf_I_hybrid

newtonpf_I_hybrid(*Ybus*, *Sbus*, *V0*, *ref*, *pv*, *pq*, *mpopt*)

newtonpf_I_hybrid() (page 265) - Solves power flow using full Newton's method (current/hybrid).

```
[V, CONVERGED, I] = NEWTONPF_I_HYBRID(YBUS, SBUS, V0, REF, PV, PQ, MPOPT)

Solves for bus voltages using a full Newton-Raphson method, using nodal
current balance equations and a hybrid representation of voltages, where
a polar update is computed using a cartesian Jacobian, given the
following inputs:
    YBUS  - full system admittance matrix (for all buses)
    SBUS  - handle to function that returns the complex bus power
            injection vector (for all buses), given the bus voltage
            magnitude vector (for all buses)
    V0    - initial vector of complex bus voltages
    REF   - bus index of reference bus (voltage ang reference & gen slack)
    PV    - vector of bus indices for PV buses
    PQ    - vector of bus indices for PQ buses
    MPOPT - (optional) MATPOWER option struct, used to set the
            termination tolerance, maximum number of iterations, and
            output options (see MPOPTION for details).

The bus voltage vector contains the set point for generator
(including ref bus) buses, and the reference angle of the swing
bus, as well as an initial guess for remaining magnitudes and
angles.

Returns the final complex voltages, a flag which indicates whether it
converged or not, and the number of iterations performed.
```

See also `runpf()`, `newtonpf()`, *newtonpf_S_cart()* (page 266), *newtonpf_I_polar()* (page 265).

newtonpf_I_polar

newtonpf_I_polar(*Ybus*, *Sbus*, *V0*, *ref*, *pv*, *pq*, *mpopt*)

newtonpf_I_polar() (page 265) - Solves power flow using full Newton's method (current/cartesian).

```
[V, CONVERGED, I] = NEWTONPF_I_POLAR(YBUS, SBUS, V0, REF, PV, PQ, MPOPT)

Solves for bus voltages using a full Newton-Raphson method, using nodal
current balance equations and polar coordinate representation of
voltages, given the following inputs:
    YBUS  - full system admittance matrix (for all buses)
    SBUS  - handle to function that returns the complex bus power
            injection vector (for all buses), given the bus voltage
            magnitude vector (for all buses)
    V0    - initial vector of complex bus voltages
```

(continues on next page)

(continued from previous page)

```
    REF   - bus index of reference bus (voltage ang reference & gen slack)
    PV    - vector of bus indices for PV buses
    PQ    - vector of bus indices for PQ buses
    MPOPT - (optional) MATPOWER option struct, used to set the
            termination tolerance, maximum number of iterations, and
            output options (see MPOPTION for details).

The bus voltage vector contains the set point for generator
(including ref bus) buses, and the reference angle of the swing
bus, as well as an initial guess for remaining magnitudes and
angles.

Returns the final complex voltages, a flag which indicates whether it
converged or not, and the number of iterations performed.
```

See also runpf(), newtonpf(), *newtonpf_S_cart()* (page 266), *newtonpf_I_cart()* (page 264).

newtonpf_S_cart

newtonpf_S_cart(*Ybus*, *Sbus*, *V0*, *ref*, *pv*, *pq*, *mpopt*)

newtonpf_S_cart() (page 266) - Solves power flow using full Newton's method (power/cartesian).

```
[V, CONVERGED, I] = NEWTONPF_S_CART(YBUS, SBUS, V0, REF, PV, PQ, MPOPT)

Solves for bus voltages using a full Newton-Raphson method, using nodal
power balance equations and cartesian coordinate representation of
voltages, given the following inputs:
    YBUS  - full system admittance matrix (for all buses)
    SBUS  - handle to function that returns the complex bus power
            injection vector (for all buses), given the bus voltage
            magnitude vector (for all buses)
    V0    - initial vector of complex bus voltages
    REF   - bus index of reference bus (voltage ang reference & gen slack)
    PV    - vector of bus indices for PV buses
    PQ    - vector of bus indices for PQ buses
    MPOPT - (optional) MATPOWER option struct, used to set the
            termination tolerance, maximum number of iterations, and
            output options (see MPOPTION for details).

The bus voltage vector contains the set point for generator
(including ref bus) buses, and the reference angle of the swing
bus, as well as an initial guess for remaining magnitudes and
angles.

Returns the final complex voltages, a flag which indicates whether it
converged or not, and the number of iterations performed.
```

See also runpf(), newtonpf(), *newtonpf_I_polar()* (page 265), *newtonpf_I_cart()* (page 264).

newtonpf_S_hybrid

newtonpf_S_hybrid(*Ybus*, *Sbus*, *V0*, *ref*, *pv*, *pq*, *mpopt*)

newtonpf_S_hybrid() (page 267) - Solves power flow using full Newton's method (power/hybrid).

```
[V, CONVERGED, I] = NEWTONPF_S_HYBRID(YBUS, SBUS, V0, REF, PV, PQ, MPOPT)

Solves for bus voltages using a full Newton-Raphson method, using nodal
power balance equations and a hybrid representation of voltages, where
a polar update is computed using a cartesian Jacobian, given the
following inputs:
    YBUS  - full system admittance matrix (for all buses)
    SBUS  - handle to function that returns the complex bus power
            injection vector (for all buses), given the bus voltage
            magnitude vector (for all buses)
    V0    - initial vector of complex bus voltages
    REF   - bus index of reference bus (voltage ang reference & gen slack)
    PV    - vector of bus indices for PV buses
    PQ    - vector of bus indices for PQ buses
    MPOPT - (optional) MATPOWER option struct, used to set the
            termination tolerance, maximum number of iterations, and
            output options (see MPOPTION for details).

The bus voltage vector contains the set point for generator
(including ref bus) buses, and the reference angle of the swing
bus, as well as an initial guess for remaining magnitudes and
angles.

Returns the final complex voltages, a flag which indicates whether it
converged or not, and the number of iterations performed.
```

See also `runpf()`, `newtonpf()`, *newtonpf_I_polar()* (page 265), *newtonpf_I_cart()* (page 264).

order_radial

order_radial(*mpc*)

order_radial() (page 267) - Performs oriented ordering to buses and branches.

```
mpc = order_radial(mpc)

orders the branches by the the principle of oriented ordering:
indicies of sending nodes are smaller than the indicies of the
receiving nodes. The branch index is equal to the index of their
receiving node. The ordering is taken from:
D. Rajicic, R. Ackovski and R. Taleski, "Voltage correction power flow,"
IEEE Transactions on Power Delivery, vol. 9, no. 2, pp. 1056-1062, Apr 1994.
```

See also *radial_pf()* (page 268).

pfsoln

pfsoln(*baseMVA*, *bus0*, *gen0*, *branch0*, *Ybus*, *Yf*, *Yt*, *V*, *ref*, *pv*, *pq*, *mpopt*)

pfsoln() - Updates bus, gen, branch data structures to match power flow soln.

```
[BUS, GEN, BRANCH] = PFSOLN(BASEMVA, BUS0, GEN0, BRANCH0, ...
                            YBUS, YF, YT, V, REF, PV, PQ, MPOPT)
```

radial_pf

radial_pf(*mpc*, *mpopt*)

radial_pf() (page 268) - Solves the power flow using a backward-forward sweep method.

```
[mpc, success, iterations] = radial_pf(mpc,mpopt)

Inputs:
    mpc : MATPOWER case struct with internal bus numbering
    mpopt : MATPOWER options struct to override default options
        can be used to specify the solution algorithm, output options
        termination tolerances, and more.

Outputs:
    mpc : results struct with all fields from the input MATPOWER case,
          with solved voltages, active and reactive power flows
          and generator active and reactive power output.
    success : success flag, 1 = succeeded, 0 = failed
    iterations : number of iterations
```

See also caseformat, loadcase(), mpoption().

zgausspf

zgausspf(*Ybus*, *Sbus*, *V0*, *ref*, *pv*, *pq*, *Bpp*, *mpopt*)

zgausspf() - Solves the power flow using an Implicit Z-bus Gauss method.

```
[V, CONVERGED, I] = ZGAUSSPF(YBUS, SBUS, V0, REF, PV, PQ, BPP, MPOPT)
solves for bus voltages given the full system admittance matrix (for
all buses), the complex bus power injection vector (all buses),
the initial vector of complex bus voltages, column vectors with the
lists of bus indices for the swing bus, PV buses, and PQ buses,
respectively, and the fast-decoupled B double-prime matrix (all buses)
for Q updates at PV buses. The bus voltage vector contains the set point
for generator (including ref bus) buses, and the reference angle of the
swing bus, as well as an initial guess for remaining magnitudes and
angles. MPOPT is a MATPOWER options struct which can be used to
set the termination tolerance, maximum number of iterations, and
output options (see MPOPTION for details). Uses default options
if this parameter is not given. Returns the final complex voltages,
```

(continues on next page)

(continued from previous page)

```
a flag which indicates whether it converged or not, and the number
of iterations performed.

NOTE: This method does not scale well with the number of generators
    and seems to have serious problems with some systems with many
    PV buses.
```

See also `runpf()`.

5.2.5 Continuation Power Flow Functions

cpf_corrector

cpf_corrector(*Ybus*, *Sbusb*, *V_hat*, *ref*, *pv*, *pq*, *lam_hat*, *Sbust*, *Vprv*, *lamprv*, *z*, *step*, *parameterization*, *mpopt*)

cpf_corrector() (page 269) - Solves the corrector step of a continuation power flow.

```
[V, CONVERGED, I, LAM] = CPF_CORRECTOR(YBUS, SBUSB, V_HAT, REF, PV, PQ, ...
                                       LAM_HAT, SBUST, VPRV, LPRV, Z, ...
                                       STEP, PARAMETERIZATION, MPOPT)

Computes the corrector step of a continuation power flow using a
full Newton method with selected parameterization scheme.

Inputs:
    YBUS : complex bus admittance matrix
    SBUSB : handle of function returning nb x 1 vector of complex
            base case injections in p.u. and derivatives w.r.t. |V|
    V_HAT :  predicted complex bus voltage vector
    REF : vector of indices for REF buses
    PV : vector of indices of PV buses
    PQ : vector of indices of PQ buses
    LAM_HAT : predicted scalar lambda
    SBUST : handle of function returning nb x 1 vector of complex
            target case injections in p.u. and derivatives w.r.t. |V|
    VPRV : complex bus voltage vector at previous solution
    LAMPRV : scalar lambda value at previous solution
    STEP : continuation step length
    Z : normalized tangent prediction vector
    STEP : continuation step size
    PARAMETERIZATION : Value of cpf.parameterization option.
    MPOPT : Options struct

Outputs:
    V : complex bus voltage solution vector
    CONVERGED : Newton iteration count
    I : Newton iteration count
    LAM : lambda continuation parameter
```

See also `runcpf()`.

cpf_current_mpc

cpf_current_mpc(*mpc*, *mpct*, *Ybus*, *Yf*, *Yt*, *ref*, *pv*, *pq*, *V*, *lam*, *mpopt*)

cpf_current_mpc() (page 270) - Construct mpc for current continuation step.

```
MPC = CPF_CURRENT_MPC(MPC_BASE, MPC_TARGET, YBUS, YF, YT, REF, PV, PQ, V, LAM,␣
↪MPOPT)

Constructs the MATPOWER case struct for the current continuation step
based on the MPC_BASE and MPC_TARGET cases and the value of LAM.
```

cpf_default_callback

cpf_default_callback(*k*, *nx*, *cx*, *px*, *done*, *rollback*, *evnts*, *cb_data*, *cb_args*, *results*)

cpf_default_callback() (page 270) - Default callback function for CPF.

```
[NX, CX, DONE, ROLLBACK, EVNTS, CB_DATA, RESULTS] =
    CPF_DEFAULT_CALLBACK(K, NX, CX, PX, DONE, ROLLBACK, EVNTS, ...
                         CB_DATA, CB_ARGS, RESULTS)

Default callback function used by RUNCPF that collects the results and
optionally, plots the nose curve. Inputs and outputs are defined below,
with the RESULTS argument being optional, used only for the final call
when K is negative.

Inputs:
    K - continuation step iteration count
    NX - next state (corresponding to proposed next step), struct with
         the following fields:
        lam_hat - value of LAMBDA from predictor
        V_hat - vector of complex bus voltages from predictor
        lam - value of LAMBDA from corrector
        V - vector of complex bus voltages from corrector
        z - normalized tangent predictor
        default_step - default step size
        default_parm - default parameterization
        this_step - step size for this step only
        this_parm - paramterization for this step only
        step - current step size
        parm - current parameterization
        events - struct array, event log
        cb - user state, for callbacks (replaces CB_STATE), the user may
            add fields containing any information the callback function
            would like to pass from one invokation to the next, taking
            care not to step on fields being used by other callbacks,
            such as the 'default' field used by this default callback
        ef - cell array of event function values
    CX - current state (corresponding to most recent successful step)
```

(continues on next page)

(continued from previous page)

```
         (same structure as NX)
    PX - previous state (corresponding to last successful step prior to CX)
    DONE - struct, with flag to indicate CPF termination and reason,
        with fields:
        flag - termination flag, 1 => terminate, 0 => continue
        msg - string containing reason for termination
    ROLLBACK - scalar flag to indicate that the current step should be
        rolled back and retried with a different step size, etc.
    EVNTS - struct array listing any events detected for this step,
        see CPF_DETECT_EVENTS for details
    CB_DATA - struct containing potentially useful "static" data,
        with the following fields (all based on internal indexing):
        mpc_base - MATPOWER case struct of base state
        mpc_target - MATPOWER case struct of target state
        Sbusb - handle of function returning nb x 1 vector of complex
            base case injections in p.u. and derivatives w.r.t. |V|
        Sbust - handle of function returning nb x 1 vector of complex
            target case injections in p.u. and derivatives w.r.t. |V|
        Ybus - bus admittance matrix
        Yf - branch admittance matrix, "from" end of branches
        Yt - branch admittance matrix, "to" end of branches
        pv - vector of indices of PV buses
        pq - vector of indices of PQ buses
        ref - vector of indices of REF buses
        idx_pmax - vector of generator indices for generators fixed
            at their PMAX limits
        mpopt - MATPOWER options struct
    CB_ARGS - arbitrary data structure containing callback arguments
    RESULTS - initial value of output struct to be assigned to
        CPF field of results struct returned by RUNCPF

Outputs:
    (all are updated versions of the corresponding input arguments)
    NX - user state ('cb' field ) should be updated here if ROLLBACK
        is false
    CX - may contain updated 'this_step' or 'this_parm' values to be used
        if ROLLBACK is true
    DONE - callback may have requested termination and set the msg field
    ROLLBACK - callback can request a rollback step, even if it was not
        indicated by an event function
    EVNTS - msg field for a given event may be updated
    CB_DATA - this data should only be modified if the underlying problem
        has been changed (e.g. generator limit reached) and should always
        be followed by a step of zero length, i.e. set NX.this_step to 0
        It is the job of any callback modifying CB_DATA to ensure that
        all data in CB_DATA is kept consistent.
    RESULTS - updated version of RESULTS input arg

This function is called in three different contexts, distinguished by
the value of K, as follows:
(1) initial - called with K = 0, without RESULTS input/output args,
        after base power flow, before 1st CPF step.
```

(continues on next page)

(continued from previous page)

```
(2) iterations - called with K > 0, without RESULTS input/output args,
        at each iteration, after predictor-corrector step
(3) final - called with K < 0, with RESULTS input/output args, after
        exiting predictor-corrector loop, inputs identical to last
        iteration call, except K which is negated

User Defined CPF Callback Functions:
    The user can define their own callback functions which take
    the same form and are called in the same contexts as
    CPF_DEFAULT_CALLBACK. These are specified via the MATPOWER
    option 'cpf.user_callback'. This option can be a string containing
    the name of the callback function, or a struct with the following
    fields, where all but the first are optional:
        'fcn'       - string with name of callback function
        'priority'  - numerical value specifying callback priority
             (default = 20, see CPF_REGISTER_CALLBACK for details)
        'args'      - arbitrary value (any type) passed to the callback
                      as CB_ARGS each time it is invoked
    Multiple user callbacks can be registered by assigning a cell array
    of such strings and/or structs to the 'cpf.user_callback' option.
```

See also `runcpf()`, *cpf_register_callback()* (page 278).

cpf_detect_events

cpf_detect_events(*cpf_events*, *cef*, *pef*, *step*, *verbose*)

cpf_detect_events() (page 272) - Detect events from event function values.

```
[ROLLBACK, CRITICAL_EVENTS, CEF] = CPF_DETECT_EVENTS(CPF_EVENTS, CEF, PEF, STEP,␣
↪VERBOSE)

Inputs:
    CPF_EVENTS : struct containing info about registered CPF event fcns
    CEF : cell array of Current Event Function values
    PEF : cell array of Previous Event Function values
    STEP : current step size
    VERBOSE : 0 = no output, otherwise level of verbose output

Outputs:
    ROLLBACK : flag indicating whether any event has requested a
        rollback step
    CRITICAL_EVENTS : struct array containing information about any
        detected events, with fields:
        eidx        : event index, in list of registered events
                      0 if no event detected
        name        : name of event function, empty if none detected
        zero        : 1 if zero has been detected, 0 otherwise
                      (interval detected or no event detected)
        idx         : index(es) of critical elements in event function
        step_scale  : linearly interpolated estimate of scaling factor
```

(continues on next page)

(continued from previous page)

```
                    for current step size required to reach event zero
       log         : 1 log the event in the results, 0 don't log the event
                     (set to 1 for zero events, 0 otherwise, can be
                       modified by callbacks)
       msg         : event message, set to something generic like
                       'ZERO detected for TARGET_LAM event' or
                       'INTERVAL detected for QLIM(3) event', but intended
                     to be changed/updated by callbacks
   CEF : cell array of Current Event Function values
```

cpf_flim_event

cpf_flim_event(*cb_data*, *cx*)

cpf_flim_event() (page 273) - Event function to detect branch flow limit (MVA) violations.

```
EF = CPF_FLIM_EVENT(CB_DATA, CX)

CPF event function to detect branch flow limit (MVA) violations,
i.e. max(Sf,St) >= SrateA.

Inputs:
    CB_DATA : struct of data for callback functions
    CX : struct containing info about current point (continuation soln)

Outputs:
    EF : event function value
```

cpf_flim_event_cb

cpf_flim_event_cb(*k*, *nx*, *cx*, *px*, *done*, *rollback*, *evnts*, *cb_data*, *cb_args*, *results*)

cpf_flim_event_cb() (page 273) - Callback to handle FLIM events.

```
[NX, CX, DONE, ROLLBACK, EVNTS, CB_DATA, RESULTS] =
    CPF_NOSE_EVENT_CB(K, NX, CX, PX, DONE, ROLLBACK, EVNTS, ...
                            CB_DATA, CB_ARGS, RESULTS)

Callback to handle FLIM (branch flow limit violation) events,
triggered by event function CPF_FLIM_EVENT to indicate the point at which
a branch flow limit is reached.

All branch flows are expected to be within limits for the base case,
otherwise the continuation terminates.

This function sets the msg field of the event when the flow in any branch
reaches its limit, raises the DONE.flag and sets the DONE.msg.
```

For details of the input and output arguments see also *cpf_default_callback()* (page 270).

cpf_nose_event

cpf_nose_event(*cb_data*, *cx*)

cpf_nose_event() (page 274) - Event function to detect the nose point.

```
EF = CPF_NOSE_EVENT(CB_DATA, CX)

CPF event function to detect the nose point of the continuation curve,
based on the sign of the lambda component of the tangent vector.

Inputs:
    CB_DATA : struct of data for callback functions
    CX : struct containing info about current point (continuation soln)

Outputs:
    EF : event function value
```

cpf_nose_event_cb

cpf_nose_event_cb(*k*, *nx*, *cx*, *px*, *done*, *rollback*, *evnts*, *cb_data*, *cb_args*, *results*)

cpf_nose_event_cb() (page 274) - Callback to handle NOSE events.

```
[NX, CX, DONE, ROLLBACK, EVNTS, CB_DATA, RESULTS] =
    CPF_NOSE_EVENT_CB(K, NX, CX, PX, DONE, ROLLBACK, EVNTS, ...
                            CB_DATA, CB_ARGS, RESULTS)

Callback to handle NOSE events, triggered by event function
CPF_NOSE_EVENT to indicate the nose point of the continuation curve.

This function sets the msg field of the event when the nose point has
been found, raises the DONE.flag and sets the DONE.msg.
```

For details of the input and output arguments see also *cpf_default_callback()* (page 270).

cpf_p

cpf_p(*parameterization*, *step*, *z*, *V*, *lam*, *Vprv*, *lamprv*, *pv*, *pq*)

cpf_p() (page 274) m - Computes the value of the CPF parameterization function.

```
P = CPF_P(PARAMETERIZATION, STEP, Z, V, LAM, VPRV, LAMPRV, PV, PQ)

Computes the value of the parameterization function at the current
solution point.

Inputs:
```

(continues on next page)

(continued from previous page)

```
    PARAMETERIZATION : Value of cpf.parameterization option
    STEP : continuation step size
    Z : normalized tangent prediction vector from previous step
    V : complex bus voltage vector at current solution
    LAM : scalar lambda value at current solution
    VPRV : complex bus voltage vector at previous solution
    LAMPRV : scalar lambda value at previous solution
    PV : vector of indices of PV buses
    PQ : vector of indices of PQ buses

Outputs:
    P : value of the parameterization function at the current point
```

See also *cpf_predictor()* (page 276), *cpf_corrector()* (page 269).

cpf_p_jac

cpf_p_jac(*parameterization*, *z*, *V*, *lam*, *Vprv*, *lamprv*, *pv*, *pq*)

cpf_p_jac() (page 275) - Computes partial derivatives of CPF parameterization function.

```
[DP_DV, DP_DLAM ] = CPF_P_JAC(PARAMETERIZATION, Z, V, LAM, ...
                                                VPRV, LAMPRV, PV, PQ)

Computes the partial derivatives of the continuation power flow
parameterization function w.r.t. bus voltages and the continuation
parameter lambda.

Inputs:
    PARAMETERIZATION : Value of cpf.parameterization option.
    Z : normalized tangent prediction vector from previous step
    V : complex bus voltage vector at current solution
    LAM : scalar lambda value at current solution
    VPRV : complex bus voltage vector at previous solution
    LAMPRV : scalar lambda value at previous solution
    PV : vector of indices of PV buses
    PQ : vector of indices of PQ buses

Outputs:
    DP_DV : partial of parameterization function w.r.t. voltages
    DP_DLAM : partial of parameterization function w.r.t. lambda
```

See also *cpf_predictor()* (page 276), *cpf_corrector()* (page 269).

cpf_plim_event

cpf_plim_event(*cb_data*, *cx*)

cpf_plim_event() (page 276) - Event function to detect gen active power limit violations.

```
EF = CPF_PLIM_EVENT(CB_DATA, CX)

CPF event function to detect generator active power limit violations,
i.e. Pg >= Pmax.

Inputs:
    CB_DATA : struct of data for callback functions
    CX : struct containing info about current point (continuation soln)

Outputs:
    EF : event function value
```

cpf_plim_event_cb

cpf_plim_event_cb(*k*, *nx*, *cx*, *px*, *done*, *rollback*, *evnts*, *cb_data*, *cb_args*, *results*)

cpf_plim_event_cb() (page 276) - Callback to handle PLIM events.

```
[NX, CX, DONE, ROLLBACK, EVNTS, CB_DATA, RESULTS] =
    CPF_PLIM_EVENT_CB(K, NX, CX, PX, DONE, ROLLBACK, EVNTS, ...
                            CB_DATA, CB_ARGS, RESULTS)

Callback to handle PLIM (generator active power limit violation) events,
triggered by event function CPF_PLIM_EVENT to indicate the point at which
an upper active power output limit is reached for a generator.

When an active power limit is encountered, this function zeros out
subsequent transfers from that generator, chooses a new reference bus
if necessary, and updates the CB_DATA accordingly, setting the next
step size to zero. The event msg is updated with the details of the
changes. It also requests termination if all generators reach PMAX.
```

For details of the input and output arguments see also *cpf_default_callback()* (page 270).

cpf_predictor

cpf_predictor(*V*, *lam*, *z*, *step*, *pv*, *pq*)

cpf_predictor() (page 276) - Performs the predictor step for the continuation power flow.

```
[V_HAT, LAM_HAT] = CPF_PREDICTOR(V, LAM, Z, STEP, PV, PQ)

Computes a prediction (approximation) to the next solution of the
continuation power flow using a normalized tangent predictor.
```

(continues on next page)

(continued from previous page)

```
Inputs:
    V : complex bus voltage vector at current solution
    LAM : scalar lambda value at current solution
    Z : normalized tangent prediction vector from previous step
    STEP : continuation step length
    PV : vector of indices of PV buses
    PQ : vector of indices of PQ buses

Outputs:
    V_HAT : predicted complex bus voltage vector
    LAM_HAT : predicted lambda continuation parameter
```

cpf_qlim_event

cpf_qlim_event(*cb_data*, *cx*)

cpf_qlim_event() (page 277) - Event function to detect gen reactive power limit violations.

```
EF = CPF_QLIM_EVENT(CB_DATA, CX)

CPF event function to detect generator reactive power limit violations,
i.e. Qg <= Qmin or Qg >= Qmax.

Inputs:
    CB_DATA : struct of data for callback functions
    CX : struct containing info about current point (continuation soln)

Outputs:
    EF : event function value
```

cpf_qlim_event_cb

cpf_qlim_event_cb(*k*, *nx*, *cx*, *px*, *done*, *rollback*, *evnts*, *cb_data*, *cb_args*, *results*)

cpf_qlim_event_cb() (page 277) - Callback to handle QLIM events.

```
[NX, CX, DONE, ROLLBACK, EVNTS, CB_DATA, RESULTS] =
    CPF_QLIM_EVENT_CB(K, NX, CX, PX, DONE, ROLLBACK, EVNTS, ...
                            CB_DATA, CB_ARGS, RESULTS)

Callback to handle QLIM (generator reactive power limit violation) events,
triggered by event function CPF_QLIM_EVENT to indicate the point at which
an upper or lower reactive power output limit is reached for a generator.

When a reactive power limit is encountered, this function zeros out
subsequent transfers from that generator, changes it's bus type to PQ,
chooses a new reference bus if necessary, and updates the CB_DATA
accordingly, setting the next step size to zero. The event msg is updated
```

(continues on next page)

(continued from previous page)

```
with the details of the changes. It also requests termination if no more
PV or REF buses remain.
```

For details of the input and output arguments see also *cpf_default_callback()* (page 270).

cpf_register_callback

cpf_register_callback(*cpf_callbacks*, *fcn*, *priority*, *args*)

cpf_register_callback() (page 278) - Register CPF callback functions.

```
CPF_CALLBACKS = CPF_REGISTER_CALLBACK(CPF_CALLBACKS, FCN, PRIORITY)

Registers a CPF callback function to be called by RUNCPF.

Inputs:
    CPF_CALLBACKS : struct containing info about registered CPF
                    callback fcns
    FCN : string containing name of callback function
    PRIORITY : number that determines order of execution for multiple
               callback functions, where higher numbers run first,
               default priority is 20, where the standard callbacks
               are called with the following priority:
                    cpf_flim_event_cb       53
                    cpf_vlim_event_cb       52
                    cpf_nose_event_cb       51
                    cpf_target_lam_event_cb 50
                    cpf_qlim_event_cb       41
                    cpf_plim_event_cb       40
                    cpf_default_callback    0
    ARGS : arguments to be passed to the callback each time it is invoked

Outputs:
    CPF_CALLBACKS : updated struct containing info about registered
                    CPF callback fcns

User Defined CPF Callback Functions:
    The user can define their own callback functions which take
    the same form and are called in the same contexts as
    CPF_DEFAULT_CALLBACK. These are specified via the MATPOWER
    option 'cpf.user_callback'. This option can be a string containing
    the name of the callback function, or a struct with the following
    fields, where all but the first are optional:
        'fcn'       - string with name of callback function
        'priority'  - numerical value specifying callback priority
             (default = 20, see CPF_REGISTER_CALLBACK for details)
        'args'      - arbitrary value (any type) passed to the callback
                      as CB_ARGS each time it is invoked
    Multiple user callbacks can be registered by assigning a cell array
    of such strings and/or structs to the 'cpf.user_callback' option.
```

See also `runcpf()`, *cpf_default_callback()* (page 270).

cpf_register_event

cpf_register_event(*cpf_events*, *name*, *fcn*, *tol*, *locate*)

cpf_register_event() (page 279) - Register event functions.

```
CPF_EVENTS = CPF_REGISTER_EVENT(CPF_EVENTS, NAME, FCN, TOL, LOCATE)

Registers a CPF event function to be called by RUNCPF.

Inputs:
    CPF_EVENTS : struct containing info about registered CPF event fcns
    NAME : string containing event name
    FCN : string containing name of event function, returning numerical
          scalar or vector value that changes sign at location of the event
    TOL : scalar or vector of same dimension as event function return value
          of tolerance for detecting the event, i.e. abs(val) <= tol
    LOCATE : flag indicating whether the event requests a rollback step
             to locate the event function zero

Outputs:
    CPF_EVENTS : updated struct containing info about registered CPF event fcns
```

cpf_tangent

cpf_tangent(*V*, *lam*, *Ybus*, *Sbusb*, *Sbust*, *pv*, *pq*, *zprv*, *Vprv*, *lamprv*, *parameterization*, *direction*)

cpf_tangent() (page 279) - Computes normalized tangent predictor for continuation power flow.

```
Z = CPF_TANGENT(V, LAM, YBUS, SBUSB, SBUST, PV, PQ, ...
                              ZPRV, VPRV, LAMPRV, PARAMETERIZATION, DIRECTION)

Computes a normalized tangent predictor for the continuation power flow.

Inputs:
    V : complex bus voltage vector at current solution
    LAM : scalar lambda value at current solution
    YBUS : complex bus admittance matrix
    SBUSB : handle of function returning nb x 1 vector of complex
            base case injections in p.u. and derivatives w.r.t. |V|
    SBUST : handle of function returning nb x 1 vector of complex
            target case injections in p.u. and derivatives w.r.t. |V|
    PV : vector of indices of PV buses
    PQ : vector of indices of PQ buses
    ZPRV : normalized tangent prediction vector from previous step
    VPRV : complex bus voltage vector at previous solution
    LAMPRV : scalar lambda value at previous solution
    PARAMETERIZATION : value of cpf.parameterization option.
    DIRECTION: continuation direction (+1 for postive lambda
               increase, -1 otherwise)
```

(continues on next page)

(continued from previous page)

```
Outputs:
    Z : the normalized tangent prediction vector
```

cpf_target_lam_event

cpf_target_lam_event(*cb_data*, *cx*)

cpf_target_lam_event() (page 280) - Event function to detect a target lambda value.

```
EF = CPF_TARGET_LAM_EVENT(CB_DATA, CX)

CPF event function to detect the completion of the continuation curve
or another target value of lambda.

Inputs:
    CB_DATA : struct of data for callback functions
    CX : struct containing info about current point (continuation soln)

Outputs:
    EF : event function value
```

cpf_target_lam_event_cb

cpf_target_lam_event_cb(*k*, *nx*, *cx*, *px*, *done*, *rollback*, *evnts*, *cb_data*, *cb_args*, *results*)

cpf_target_lam_event_cb() (page 280) - Callback to handle TARGET_LAM events.

```
[NX, CX, DONE, ROLLBACK, EVNTS, CB_DATA, RESULTS] =
    CPF_TARGET_LAM_EVENT_CB(K, NX, CX, PX, DONE, ROLLBACK, EVNTS, ...
                            CB_DATA, CB_ARGS, RESULTS)

Callback to handle TARGET_LAM events, triggered by event function
CPF_TARGET_LAM_EVENT to indicate that a target lambda value has been
reached or that the full continuation curve has been traced.

This function sets the msg field of the event when the target lambda has
been found, raises the DONE.flag and sets the DONE.msg. If the current
or predicted next step overshoot the target lambda, it adjusts the step
size to be exactly what is needed to reach the target, and sets the
parameterization for that step to be the natural parameterization.
```

For details of the input and output arguments see also *cpf_default_callback()* (page 270).

cpf_vlim_event

cpf_vlim_event(*cb_data*, *cx*)

cpf_vlim_event() (page 281) - Event function to detect bus voltage limit violations.

```
EF = CPF_VLIM_EVENT(CB_DATA, CX)

CPF event function to detect bus voltage limits violations,
i.e. Vm <= Vmin or Vm >= Vmax.

Inputs:
    CB_DATA : struct of data for callback functions
    CX : struct containing info about current point (continuation soln)

Outputs:
    EF : event function value
```

cpf_vlim_event_cb

cpf_vlim_event_cb(*k*, *nx*, *cx*, *px*, *done*, *rollback*, *evnts*, *cb_data*, *cb_args*, *results*)

cpf_vlim_event_cb() (page 281) - Callback to handle VLIM events.

```
[NX, CX, DONE, ROLLBACK, EVNTS, CB_DATA, RESULTS] =
    CPF_VLIM_EVENT_CB(K, NX, CX, PX, DONE, ROLLBACK, EVNTS, ...
                              CB_DATA, CB_ARGS, RESULTS)

Callback to handle VLIM (bus voltage magnitude limit violation) events,
triggered by event function CPF_VLIM_EVENT to indicate the point at which
an upper or lower voltage magnitude limit is reached for a bus.

All bus voltages are expected to be within limits for the base case,
otherwise the continuation terminates.

This function sets the msg field of the event when the voltage magnitude
at any bus reaches its upper or lower limit, raises the DONE.flag and sets
the DONE.msg.
```

For details of the input and output arguments see also *cpf_default_callback()* (page 270).

5.2.6 OPF and Wrapper Functions

opf

opf(*varargin*)

opf() - Solves an optimal power flow.

```
[RESULTS, SUCCESS] = OPF(MPC, MPOPT)

Returns either a RESULTS struct and an optional SUCCESS flag, or individual
data matrices, the objective function value and a SUCCESS flag. In the
latter case, there are additional optional return values. See Examples
below for the possible calling syntax options.

Examples:
    Output argument options:

    results = opf(...)
    [results, success] = opf(...)
    [bus, gen, branch, f, success] = opf(...)
    [bus, gen, branch, f, success, info, et, g, jac, xr, pimul] = opf(...)

    Input arguments options:

    opf(mpc)
    opf(mpc, mpopt)
    opf(mpc, userfcn, mpopt)
    opf(mpc, A, l, u)
    opf(mpc, A, l, u, mpopt)
    opf(mpc, A, l, u, mpopt, N, fparm, H, Cw)
    opf(mpc, A, l, u, mpopt, N, fparm, H, Cw, z0, zl, zu)

    opf(baseMVA, bus, gen, branch, areas, gencost)
    opf(baseMVA, bus, gen, branch, areas, gencost, mpopt)
    opf(baseMVA, bus, gen, branch, areas, gencost, userfcn, mpopt)
    opf(baseMVA, bus, gen, branch, areas, gencost, A, l, u)
    opf(baseMVA, bus, gen, branch, areas, gencost, A, l, u, mpopt)
    opf(baseMVA, bus, gen, branch, areas, gencost, A, l, u, ...
                                mpopt, N, fparm, H, Cw)
    opf(baseMVA, bus, gen, branch, areas, gencost, A, l, u, ...
                                mpopt, N, fparm, H, Cw, z0, zl, zu)

The data for the problem can be specified in one of three ways:
(1) a string (mpc) containing the file name of a MATPOWER case
  which defines the data matrices baseMVA, bus, gen, branch, and
  gencost (areas is not used at all, it is only included for
  backward compatibility of the API).
(2) a struct (mpc) containing the data matrices as fields.
(3) the individual data matrices themselves.

The optional user parameters for user constraints (A, l, u), user costs
(N, fparm, H, Cw), user variable initializer (z0), and user variable
limits (zl, zu) can also be specified as fields in a case struct,
either passed in directly or defined in a case file referenced by name.
```

(continues on next page)

(continued from previous page)

```
When specified, A, l, u represent additional linear constraints on the
optimization variables, l <= A*[x; z] <= u. If the user specifies an A
matrix that has more columns than the number of "x" (OPF) variables,
then there are extra linearly constrained "z" variables. For an
explanation of the formulation used and instructions for forming the
A matrix, see the manual.

A generalized cost on all variables can be applied if input arguments
N, fparm, H and Cw are specified.  First, a linear transformation
of the optimization variables is defined by means of r = N * [x; z].
Then, to each element of r a function is applied as encoded in the
fparm matrix (see manual). If the resulting vector is named w,
then H and Cw define a quadratic cost on w: (1/2)*w'*H*w + Cw * w .
H and N should be sparse matrices and H should also be symmetric.

The optional mpopt vector specifies MATPOWER options. If the OPF
algorithm is not explicitly set in the options MATPOWER will use
the default solver, based on a primal-dual interior point method.
For the AC OPF this is opf.ac.solver = 'MIPS', unless the TSPOPF optional
package is installed, in which case the default is 'PDIPM'. For the
DC OPF, the default is opf.dc.solver = 'MIPS'. See MPOPTION for
more details on the available OPF solvers and other OPF options
and their default values.

The solved case is returned either in a single results struct (described
below) or in the individual data matrices, bus, gen and branch. Also
returned are the final objective function value (f) and a flag which is
true if the algorithm was successful in finding a solution (success).
Additional optional return values are an algorithm specific return status
(info), elapsed time in seconds (et), the constraint vector (g), the
Jacobian matrix (jac), and the vector of variables (xr) as well
as the constraint multipliers (pimul).

The single results struct is a MATPOWER case struct (mpc) with the
usual baseMVA, bus, branch, gen, gencost fields, along with the
following additional fields:

    .order      see 'help ext2int' for details of this field
    .et         elapsed time in seconds for solving OPF
    .success    1 if solver converged successfully, 0 otherwise
    .om         OPF model object, see 'help opf_model'
    .x          final value of optimization variables (internal order)
    .f          final objective function value
    .mu         shadow prices on ...
        .var
            .l  lower bounds on variables
            .u  upper bounds on variables
        .nln
            .l  lower bounds on nonlinear constraints
            .u  upper bounds on nonlinear constraints
        .lin
            .l  lower bounds on linear constraints
```

(continues on next page)

(continued from previous page)

```
        .u  upper bounds on linear constraints
.raw        raw solver output in form returned by MINOS, and more
    .xr     final value of optimization variables
    .pimul  constraint multipliers
    .info   solver specific termination code
    .output solver specific output information
       .alg algorithm code of solver used
    .g      (optional) constraint values
    .dg     (optional) constraint 1st derivatives
    .df     (optional) obj fun 1st derivatives (not yet implemented)
    .d2f    (optional) obj fun 2nd derivatives (not yet implemented)
.var
    .val    optimization variable values, by named block
        .Va     voltage angles
        .Vm     voltage magnitudes (AC only)
        .Pg     real power injections
        .Qg     reactive power injections (AC only)
        .y      constrained cost variable (only if have pwl costs)
        (other) any user defined variable blocks
    .mu     variable bound shadow prices, by named block
        .l  lower bound shadow prices
            .Va, Vm, Pg, Qg, y, (other)
        .u  upper bound shadow prices
            .Va, Vm, Pg, Qg, y, (other)
.nle    (AC only)
    .lambda shadow prices on nonlinear equality constraints,
            by named block
            .Pmis   real power mismatch equations
            .Qmis   reactive power mismatch equations
            (other) use defined constraints
.nli    (AC only)
    .mu     shadow prices on nonlinear inequality constraints,
            by named block
            .Sf     flow limits at "from" end of branches
            .St     flow limits at "to" end of branches
            (other) use defined constraints
.lin
    .mu     shadow prices on linear constraints, by named block
        .l  lower bounds
            .Pmis   real power mistmatch equations (DC only)
            .Pf     flow limits at "from" end of branches (DC only)
            .Pt     flow limits at "to" end of branches (DC only)
            .PQh    upper portion of gen PQ-capability curve (AC only)
            .PQl    lower portion of gen PQ-capability curve (AC only)
            .vl     constant power factor constraint for loads (AC only)
            .ycon   basin constraints for CCV for pwl costs
            (other) any user defined constraint blocks
        .u  upper bounds
            .Pmis, Pf, Pt, PQh, PQl, vl, ycon, (other)
.cost       user defined cost values, by named block
```

See also `runopf()`, `dcopf()`, `uopf()`, `caseformat`.

dcopf

dcopf(*varargin*)

dcopf() - Solves a DC optimal power flow.

This is a simple wrapper function around opf() that sets the model option to 'DC' before calling opf(). See opf() for the details of input and output arguments.

See also rundcopf().

fmincopf

fmincopf(*varargin*)

fmincopf() - Solves an AC optimal power flow using FMINCON (Opt Tbx 2.x & later).

Uses algorithm 520. Please see opf() for the details of input and output arguments.

uopf

uopf(*varargin*)

uopf() - Solves combined unit decommitment / optimal power flow.

```
[RESULTS, SUCCESS] = UOPF(MPC, MPOPT)

Returns either a RESULTS struct and an optional SUCCESS flag, or individual
data matrices, the objective function value and a SUCCESS flag. In the
latter case, there are additional optional return values. See Examples
below for the possible calling syntax options.

Examples:
    Output argument options:

    results = uopf(...)
    [results, success] = uopf(...)
    [bus, gen, branch, f, success] = uopf(...)
    [bus, gen, branch, f, success, info, et, g, jac, xr, pimul] = uopf(...)

    Input arguments options:

    uopf(mpc)
    uopf(mpc, mpopt)
    uopf(mpc, userfcn, mpopt)
    uopf(mpc, A, l, u)
    uopf(mpc, A, l, u, mpopt)
    uopf(mpc, A, l, u, mpopt, N, fparm, H, Cw)
    uopf(mpc, A, l, u, mpopt, N, fparm, H, Cw, z0, zl, zu)
```

(continues on next page)

(continued from previous page)

```
    uopf(baseMVA, bus, gen, branch, areas, gencost)
    uopf(baseMVA, bus, gen, branch, areas, gencost, mpopt)
    uopf(baseMVA, bus, gen, branch, areas, gencost, userfcn, mpopt)
    uopf(baseMVA, bus, gen, branch, areas, gencost, A, l, u)
    uopf(baseMVA, bus, gen, branch, areas, gencost, A, l, u, mpopt)
    uopf(baseMVA, bus, gen, branch, areas, gencost, A, l, u, ...
                               mpopt, N, fparm, H, Cw)
    uopf(baseMVA, bus, gen, branch, areas, gencost, A, l, u, ...
                               mpopt, N, fparm, H, Cw, z0, zl, zu)

See OPF for more information on input and output arguments.

Solves a combined unit decommitment and optimal power flow for a single
time period. Uses an algorithm similar to dynamic programming. It proceeds
through a sequence of stages, where stage N has N generators shut down,
starting with N=0. In each stage, it forms a list of candidates (gens at
their Pmin limits) and computes the cost with each one of them shut down.
It selects the least cost case as the starting point for the next stage,
continuing until there are no more candidates to be shut down or no
more improvement can be gained by shutting something down.
If MPOPT.verbose (see MPOPTION) is true, it prints progress
info, if it is > 1 it prints the output of each individual opf.
```

See also `opf()`, `runuopf()`.

5.2.7 Other OPF Functions

dcopf_solver

dcopf_solver(*om*, *mpopt*)

dcopf_solver() (page 286) - Solves a DC optimal power flow.

```
[RESULTS, SUCCESS, RAW] = DCOPF_SOLVER(OM, MPOPT)

Inputs are an OPF model object and a MATPOWER options struct.

Outputs are a RESULTS struct, SUCCESS flag and RAW output struct.

RESULTS is a MATPOWER case struct (mpc) with the usual baseMVA, bus
branch, gen, gencost fields, along with the following additional
fields:
    .order      see 'help ext2int' for details of this field
    .x          final value of optimization variables (internal order)
    .f          final objective function value
    .mu         shadow prices on ...
        .var
            .l  lower bounds on variables
            .u  upper bounds on variables
```

(continues on next page)

(continued from previous page)

```
        .lin
            .l  lower bounds on linear constraints
            .u  upper bounds on linear constraints

SUCCESS     1 if solver converged successfully, 0 otherwise

RAW         raw output in form returned by MINOS
    .xr     final value of optimization variables
    .pimul  constraint multipliers
    .info   solver specific termination code
    .output solver specific output information
```

See also `opf()`, `opt_model.solve()`.

nlpopf_solver

nlpopf_solver(*om*, *mpopt*)

nlpopf_solver() (page 287) - Solves AC optimal power flow using MP-Opt-Model.

```
[RESULTS, SUCCESS, RAW] = NLPOPF_SOLVER(OM, MPOPT)

Inputs are an OPF model object and a MATPOWER options struct.

Outputs are a RESULTS struct, SUCCESS flag and RAW output struct.

RESULTS is a MATPOWER case struct (mpc) with the usual baseMVA, bus
branch, gen, gencost fields, along with the following additional
fields:
    .order      see 'help ext2int' for details of this field
    .x          final value of optimization variables (internal order)
    .f          final objective function value
    .mu         shadow prices on ...
        .var
            .l  lower bounds on variables
            .u  upper bounds on variables
        .nln    (deprecated) 2*nb+2*nl - Pmis, Qmis, Sf, St
            .l  lower bounds on nonlinear constraints
            .u  upper bounds on nonlinear constraints
        .nle    nonlinear equality constraints
        .nli    nonlinear inequality constraints
        .lin
            .l  lower bounds on linear constraints
            .u  upper bounds on linear constraints

SUCCESS     1 if solver converged successfully, 0 otherwise

RAW         raw output in form returned by MINOS
    .xr     final value of optimization variables
    .pimul  constraint multipliers
```

(continues on next page)

(continued from previous page)

```
    .info   solver specific termination code
    .output solver specific output information
```

See also `opf()`, `mips()`.

makeAang

makeAang(*baseMVA*, *branch*, *nb*, *mpopt*)

makeAang() (page 288) - Construct constraints for branch angle difference limits.

```
[AANG, LANG, UANG, IANG]  = MAKEAANG(BASEMVA, BRANCH, NB, MPOPT)

Constructs the parameters for the following linear constraint limiting
the voltage angle differences across branches, where Va is the vector
of bus voltage angles. NB is the number of buses.

    LANG <= AANG * Va <= UANG

IANG is the vector of indices of branches with angle difference limits.
The limits are given in the ANGMIN and ANGMAX columns of the branch
matrix. Voltage angle differences are taken to be unbounded below if
ANGMIN < -360 and unbounded above if ANGMAX > 360. If both ANGMIN and
ANGMAX are zero, the angle difference is assumed to be unconstrained.

Example:
    [Aang, lang, uang, iang]  = makeAang(baseMVA, branch, nb, mpopt);
```

makeApq

makeApq(*baseMVA*, *gen*)

makeApq() (page 288) - Construct linear constraints for generator capability curves.

```
[APQH, UBPQH, APQL, UBPQL, DATA] = MAKEAPQ(BASEMVA, GEN)

Constructs the parameters for the following linear constraints
implementing trapezoidal generator capability curves, where
Pg and Qg are the real and reactive generator injections.

APQH * [Pg; Qg] <= UBPQH
APQL * [Pg; Qg] <= UBPQL

DATA constains additional information as shown below.

Example:
    [Apqh, ubpqh, Apql, ubpql, data] = makeApq(baseMVA, gen);

    data.h      [QC1MAX-QC2MAX, PC2-PC1]
```

(continues on next page)

(continued from previous page)

```
    data.l      [QC2MIN-QC1MIN, PC1-PC2]
    data.ipqh   indices of gens with general PQ cap curves (upper)
    data.ipql   indices of gens with general PQ cap curves (lower)
```

makeAvl

makeAvl(*baseMVA*, *gen*)

makeAvl() (page 289) - Construct linear constraints for constant power factor var loads.

```
[AVL, LVL, UVL, IVL]  = MAKEAVL(MPC)
[AVL, LVL, UVL, IVL]  = MAKEAVL(BASEMVA, GEN) (deprecated)

Constructs parameters for the following linear constraint enforcing a
constant power factor constraint for dispatchable loads.

     LVL <= AVL * [Pg; Qg] <= UVL

IVL is the vector of indices of generators representing variable loads.

Example:
    [Avl, lvl, uvl, ivl]  = makeAvl(mpc);
    [Avl, lvl, uvl, ivl]  = makeAvl(baseMVA, gen);  %% deprecated
```

makeAy

makeAy(*baseMVA*, *ng*, *gencost*, *pgbas*, *qgbas*, *ybas*)

makeAy() (page 289) - Make the A matrix and RHS for the CCV formulation.

```
[AY, BY]  = MAKEAY(BASEMVA, NG, GENCOST, PGBAS, QGBAS, YBAS)

Constructs the parameters for linear "basin constraints" on Pg, Qg
and Y used by the CCV cost formulation, expressed as

    AY * X <= BY

where X is the vector of optimization variables. The starting index
within the X vector for the active, reactive sources and the Y
variables should be provided in arguments PGBAS, QGBAS, YBAS. The
number of generators is NG.

Assumptions: All generators are in-service.  Filter any generators
that are offline from the GENCOST matrix before calling MAKEAY.
Efficiency depends on Qg variables being after Pg variables, and
the Y variables must be the last variables within the vector X for
the dimensions of the resulting AY to be conformable with X.
```

(continues on next page)

(continued from previous page)

```
Example:
    [Ay, by]  = makeAy(baseMVA, ng, gencost, pgbas, qgbas, ybas);
```

margcost

margcost(*gencost*, *Pg*)

margcost() - Computes marginal cost for generators at given output level.

```
MARGINALCOST = MARGCOST(GENCOST, PG) computes marginal cost for generators
given a matrix in gencost format and a column vector of generation levels.
The return value has the same dimensions as PG. Each row of GENCOST is
used to evaluate the cost at the points specified in the corresponding row
of PG.
```

opf_args

opf_args(*baseMVA*, *bus*, *gen*, *branch*, *areas*, *gencost*, *Au*, *lbu*, *ubu*, *mpopt*, *N*, *fparm*, *H*, *Cw*, *z0*, *zl*, *zu*)

opf_args() (page 290) - Parses and initializes OPF input arguments.

```
[MPC, MPOPT] = OPF_ARGS( ... )
[BASEMVA, BUS, GEN, BRANCH, GENCOST, A, L, U, MPOPT, ...
    N, FPARM, H, CW, Z0, ZL, ZU, USERFCN] = OPF_ARGS( ... )
Returns the full set of initialized OPF input arguments, filling in
default values for missing arguments. See Examples below for the
possible calling syntax options.

Examples:
    Output argument options:

    [mpc, mpopt] = opf_args( ... )
    [baseMVA, bus, gen, branch, gencost, A, l, u, mpopt, ...
        N, fparm, H, Cw, z0, zl, zu, userfcn] = opf_args( ... )

    Input arguments options:

    opf_args(mpc)
    opf_args(mpc, mpopt)
    opf_args(mpc, userfcn, mpopt)
    opf_args(mpc, A, l, u)
    opf_args(mpc, A, l, u, mpopt)
    opf_args(mpc, A, l, u, mpopt, N, fparm, H, Cw)
    opf_args(mpc, A, l, u, mpopt, N, fparm, H, Cw, z0, zl, zu)

    opf_args(baseMVA, bus, gen, branch, areas, gencost)
    opf_args(baseMVA, bus, gen, branch, areas, gencost, mpopt)
    opf_args(baseMVA, bus, gen, branch, areas, gencost, userfcn, mpopt)
    opf_args(baseMVA, bus, gen, branch, areas, gencost, A, l, u)
```

(continues on next page)

(continued from previous page)

```
    opf_args(baseMVA, bus, gen, branch, areas, gencost, A, l, u, mpopt)
    opf_args(baseMVA, bus, gen, branch, areas, gencost, A, l, u, ...
                                mpopt, N, fparm, H, Cw)
    opf_args(baseMVA, bus, gen, branch, areas, gencost, A, l, u, ...
                                mpopt, N, fparm, H, Cw, z0, zl, zu)

The data for the problem can be specified in one of three ways:
(1) a string (mpc) containing the file name of a MATPOWER case
  which defines the data matrices baseMVA, bus, gen, branch, and
  gencost (areas is not used at all, it is only included for
  backward compatibility of the API).
(2) a struct (mpc) containing the data matrices as fields.
(3) the individual data matrices themselves.

The optional user parameters for user constraints (A, l, u), user costs
(N, fparm, H, Cw), user variable initializer (z0), and user variable
limits (zl, zu) can also be specified as fields in a case struct,
either passed in directly or defined in a case file referenced by name.

When specified, A, l, u represent additional linear constraints on the
optimization variables, l <= A*[x; z] <= u. If the user specifies an A
matrix that has more columns than the number of "x" (OPF) variables,
then there are extra linearly constrained "z" variables. For an
explanation of the formulation used and instructions for forming the
A matrix, see the manual.

A generalized cost on all variables can be applied if input arguments
N, fparm, H and Cw are specified.  First, a linear transformation
of the optimization variables is defined by means of r = N * [x; z].
Then, to each element of r a function is applied as encoded in the
fparm matrix (see manual). If the resulting vector is named w,
then H and Cw define a quadratic cost on w: (1/2)*w'*H*w + Cw * w .
H and N should be sparse matrices and H should also be symmetric.

The optional mpopt vector specifies MATPOWER options. See MPOPTION
for details and default values.
```

opf_setup

opf_setup(*mpc*, *mpopt*)

opf_setup() (page 291) - Constructs an OPF model object from a MATPOWER case struct.

```
OM = OPF_SETUP(MPC, MPOPT)

Assumes that MPC is a MATPOWER case struct with internal indexing,
all equipment in-service, etc.
```

See also `opf()`, `ext2int()`, *opf_execute()* (page 292).

opf_execute

opf_execute(*om*, *mpopt*)

opf_execute() (page 292) - Executes the OPF specified by an OPF model object.

```
[RESULTS, SUCCESS, RAW] = OPF_EXECUTE(OM, MPOPT)

RESULTS are returned with internal indexing, all equipment
in-service, etc.
```

See also opf(), *opf_setup()* (page 291).

opf_branch_ang_fcn

opf_branch_ang_fcn(*x*, *Aang*, *lang*, *uang*)

opf_branch_ang_fcn() (page 292) - Evaluates branch angle difference constraints and gradients.

```
[VADIF, DVADIF] = OPF_BRANCH_ANG_FCN(X, AANG, LANG, UANG);

Computes the lower and upper constraints on branch angle differences
for voltages in cartesian coordinates. Computes constraint vectors and
their gradients. The constraints are of the form:
    Aang * Va >= lang
    Aang * Va <= uang
where Va is the voltage angle, a non-linear function of the Vr and Vi.

Inputs:
  X : optimization vector
  AANG : constraint matrix, see MAKEAANG
  LANG : lower bound vector, see MAKEAANG
  UANG : upper bound vector, see MAKEAANG

Outputs:
  VADIF  : constraint vector [ lang - Aang * Va; Aang * Va - uang ]
  DVADIF : (optional) constraint gradients

Examples:
    VaDif = opf_branch_ang_fcn(x, Aang, lang, uang);
    [VaDif, dVaDif] = opf_branch_ang_fcn(x, Aang, lang, uang);
```

See also *opf_branch_ang_hess()* (page 293).

opf_branch_ang_hess

opf_branch_ang_hess(*x*, *lambda*, *Aang*, *lang*, *uang*)

opf_branch_ang_hess() (page 293) - Evaluates Hessian of branch angle difference constraints.

```
D2VADIF = OPF_BRANCH_ANG_HESS(X, LAMBDA, AANG, LANG, UANG)

Hessian evaluation function for branch angle difference constraints
for voltages in cartesian coordinates.

Inputs:
  X : optimization vector
  LAMBDA : column vector of Lagrange multipliers on branch angle
        difference constraints, lower, then upper
  AANG : constraint matrix, see MAKEAANG
  LANG : lower bound vector, see MAKEAANG
  UANG : upper bound vector, see MAKEAANG

Outputs:
  D2VADIF : Hessian of branch angle difference constraints.

Example:
    d2VaDif = opf_branch_ang_hess(x, lambda, Aang, lang, uang);
```

See also *opf_branch_ang_fcn()* (page 292).

opf_branch_flow_fcn

opf_branch_flow_fcn(*x*, *mpc*, *Yf*, *Yt*, *il*, *mpopt*)

opf_branch_flow_fcn() (page 293) - Evaluates AC branch flow constraints and Jacobian.

```
[H, DH] = OPF_BRANCH_FLOW_FCN(X, OM, YF, YT, IL, MPOPT)

Branch flow constraints for AC optimal power flow.
Computes constraint vectors and their gradients.

Inputs:
  X : optimization vector
  MPC : MATPOWER case struct
  YF : admittance matrix for "from" end of constrained branches
  YT : admittance matrix for "to" end of constrained branches
  IL : vector of branch indices corresponding to branches with
       flow limits (all others are assumed to be unconstrained).
       YF and YT contain only the rows corresponding to IL.
  MPOPT : MATPOWER options struct

Outputs:
  H  : vector of inequality constraint values (flow limits)
       where the flow can be apparent power, real power, or
       current, depending on the value of opf.flow_lim in MPOPT
       (only for constrained lines), normally expressed as
```

(continues on next page)

(continued from previous page)

```
       (limit^2 - flow^2), except when opf.flow_lim == 'P',
       in which case it is simply (limit - flow).
  DH : (optional) inequality constraint gradients, column j is
       gradient of H(j)

Examples:
    h = opf_branch_flow_fcn(x, mpc, Yf, Yt, il, mpopt);
    [h, dh] = opf_branch_flow_fcn(x, mpc, Yf, Yt, il, mpopt);
```

See also *opf_branch_flow_hess()* (page 294).

opf_branch_flow_hess

opf_branch_flow_hess(*x*, *lambda*, *mpc*, *Yf*, *Yt*, *il*, *mpopt*)

opf_branch_flow_hess() (page 294) - Evaluates Hessian of branch flow constraints.

```
D2H = OPF_BRANCH_FLOW_HESS(X, LAMBDA, OM, YF, YT, IL, MPOPT)

Hessian evaluation function for AC branch flow constraints.

Inputs:
  X : optimization vector
  LAMBDA : column vector of Kuhn-Tucker multipliers on constrained
           branch flows
  MPC : MATPOWER case struct
  YF : admittance matrix for "from" end of constrained branches
  YT : admittance matrix for "to" end of constrained branches
  IL : vector of branch indices corresponding to branches with
       flow limits (all others are assumed to be unconstrained).
       YF and YT contain only the rows corresponding to IL.
  MPOPT : MATPOWER options struct

Outputs:
  D2H : Hessian of AC branch flow constraints.

Example:
    d2H = opf_branch_flow_hess(x, lambda, mpc, Yf, Yt, il, mpopt);
```

See also *opf_branch_flow_fcn()* (page 293).

opf_current_balance_fcn

opf_current_balance_fcn(*x*, *mpc*, *Ybus*, *mpopt*)

opf_current_balance_fcn() (page 295) - Evaluates AC current balance constraints and their gradients.

```
[G, DG] = OPF_CURRENT_BALANCE_FCN(X, OM, YBUS, MPOPT)

Computes the real or imaginary current balance equality constraints for
AC optimal power flow. Computes constraint vectors and their gradients.

Inputs:
  X : optimization vector
  MPC : MATPOWER case struct
  YBUS : bus admittance matrix
  MPOPT : MATPOWER options struct

Outputs:
  G  : vector of equality constraint values (real/imaginary current balances)
  DG : (optional) equality constraint gradients

Examples:
    g = opf_current_balance_fcn(x, mpc, Ybus, mpopt);
    [g, dg] = opf_current_balance_fcn(x, mpc, Ybus, mpopt);
```

See also *opf_power_balance_hess()* (page 297).

opf_current_balance_hess

opf_current_balance_hess(*x*, *lambda*, *mpc*, *Ybus*, *mpopt*)

opf_current_balance_hess() (page 295) - Evaluates Hessian of current balance constraints.

```
D2G = OPF_CURRENT_BALANCE_HESS(X, LAMBDA, OM, YBUS, MPOPT)

Hessian evaluation function for AC real and imaginary current balance
constraints.

Inputs:
  X : optimization vector
  LAMBDA : column vector of Lagrange multipliers on real and imaginary
           current balance constraints
  MPC : MATPOWER case struct
  YBUS : bus admittance matrix
  MPOPT : MATPOWER options struct

Outputs:
  D2G : Hessian of current balance constraints.

Example:
    d2G = opf_current_balance_hess(x, lambda, mpc, Ybus, mpopt);
```

See also *opf_current_balance_fcn()* (page 295).

opf_gen_cost_fcn

opf_gen_cost_fcn(*x*, *baseMVA*, *gencost*, *ig*)

opf_gen_cost_fcn() (page 296) - Evaluates polynomial generator costs and derivatives.

```
[F, DF, D2F] = OPF_GEN_COST_FCN(X, BASEMVA, COST)

Evaluates the polynomial generator costs and derivatives.

Inputs:
  X : single-element cell array with vector of (active or reactive)
      dispatches (in per unit)
  BASEMVA : system per unit base
  GENCOST : standard gencost matrix corresponding to dispatch
            (active or reactive) provided in X
  IG : vector of generator indices of interest
  MPOPT : MATPOWER options struct

Outputs:
  F  : sum of generator polynomial costs
  DF : (optional) gradient (column vector) of polynomial costs
  D2F : (optional) Hessian of polynomial costs

Examples:
    f = opf_gen_cost_fcn(x, baseMVA, gencost, ig);
    [f, df] = opf_gen_cost_fcn(x, baseMVA, gencost, ig);
    [f, df, d2f] = opf_gen_cost_fcn(x, baseMVA, gencost, ig);
```

opf_legacy_user_cost_fcn

opf_legacy_user_cost_fcn(*x*, *cp*)

opf_legacy_user_cost_fcn() (page 296) - Evaluates legacy user costs and derivatives.

```
[F, DF, D2F] = OPF_LEGACY_USER_COST_FCN(X, CP)

Evaluates the legacy user-defined costs and derivatives.

Inputs:
  X : cell array with vectors of optimization variables
  CP : legacy user-defined cost parameter struct such as returned by
       OPT_MODEL.GET_COST_PARAMS

Outputs:
  F  : sum of generator polynomial costs
  DF : (optional) gradient (column vector) of polynomial costs
  D2F : (optional) Hessian of polynomial costs

Examples:
```

(continues on next page)

(continued from previous page)

```
    f = opf_legacy_user_cost_fcn(x, cp);
    [f, df] = opf_legacy_user_cost_fcn(x, cp);
    [f, df, d2f] = opf_legacy_user_cost_fcn(x, cp);
```

opf_power_balance_fcn

opf_power_balance_fcn(*x*, *mpc*, *Ybus*, *mpopt*)

opf_power_balance_fcn() (page 297) - Evaluates AC power balance constraints and their gradients.

```
[G, DG] = OPF_POWER_BALANCE_FCN(X, OM, YBUS, MPOPT)

Computes the active or reactive power balance equality constraints for
AC optimal power flow. Computes constraint vectors and their gradients.

Inputs:
  X : optimization vector
  MPC : MATPOWER case struct
  YBUS : bus admittance matrix
  MPOPT : MATPOWER options struct

Outputs:
  G  : vector of equality constraint values (active/reactive power balances)
  DG : (optional) equality constraint gradients

Examples:
    g = opf_power_balance_fcn(x, mpc, Ybus, mpopt);
    [g, dg] = opf_power_balance_fcn(x, mpc, Ybus, mpopt);
```

See also *opf_power_balance_hess()* (page 297).

opf_power_balance_hess

opf_power_balance_hess(*x*, *lambda*, *mpc*, *Ybus*, *mpopt*)

opf_power_balance_hess() (page 297) - Evaluates Hessian of power balance constraints.

```
D2G = OPF_POWER_BALANCE_HESS(X, LAMBDA, OM, YBUS, MPOPT)

Hessian evaluation function for AC active and reactive power balance
constraints.

Inputs:
  X : optimization vector
  LAMBDA : column vector of Lagrange multipliers on active and reactive
           power balance constraints
  MPC : MATPOWER case struct
  YBUS : bus admittance matrix
  MPOPT : MATPOWER options struct
```

(continues on next page)

(continued from previous page)

```
Outputs:
  D2G : Hessian of power balance constraints.

Example:
    d2G = opf_power_balance_hess(x, lambda, mpc, Ybus, mpopt);
```

See also *opf_power_balance_fcn()* (page 297).

opf_veq_fcn

opf_veq_fcn(*x*, *mpc*, *idx*, *mpopt*)

opf_veq_fcn() (page 298) - Evaluates voltage magnitude equality constraint and gradients.

```
[Veq, dVeq] = OPF_VEQ_FCN(X, MPC, IDX, MPOPT)

Computes the voltage magnitudes using real and imaginary part of complex voltage for
AC optimal power flow. Computes constraint vectors and their gradients.

Inputs:
  X : optimization vector
  MPC : MATPOWER case struct
  IDX : index of buses whose voltage magnitudes should be fixed
  MPOPT : MATPOWER options struct

Outputs:
  VEQ  : vector of voltage magnitudes
  DVEQ : (optional) magnitude gradients

Examples:
    Veq = opf_veq_fcn(x, mpc, mpopt);
    [Veq, dVeq] = opf_veq_fcn(x, mpc, idx, mpopt);
```

See also *opf_veq_hess()* (page 298).

opf_veq_hess

opf_veq_hess(*x*, *lambda*, *mpc*, *idx*, *mpopt*)

opf_veq_hess() (page 298) - Evaluates Hessian of voltage magnitude equality constraint.

```
D2VEQ = OPF_VEQ_HESS(X, LAMBDA, MPC, IDX, MPOPT)

Hessian evaluation function for voltage magnitudes.

Inputs:
  X : optimization vector
  LAMBDA : column vector of Lagrange multipliers on active and reactive
```

(continues on next page)

(continued from previous page)

```
           power balance constraints
  MPC : MATPOWER case struct
  IDX : index of buses whose voltage magnitudes should be fixed
  MPOPT : MATPOWER options struct

Outputs:
  D2VEQ : Hessian of voltage magnitudes.

Example:
    d2Veq = opf_veq_hess(x, lambda, mpc, idx, mpopt);
```

See also *opf_veq_fcn()* (page 298).

opf_vlim_fcn

opf_vlim_fcn(*x*, *mpc*, *idx*, *mpopt*)

opf_vlim_fcn() (page 299) - Evaluates voltage magnitudes and their gradients.

```
[Vlims, dVlims] = OPF_VLIM_FCN(X, MPC, IDX, MPOPT)

Computes the voltage magnitudes using real and imaginary part of complex voltage for
AC optimal power flow. Computes constraint vectors and their gradients.

Inputs:
  X : optimization vector
  MPC : MATPOWER case struct
  IDX : index of buses whose voltage magnitudes should be fixed
  MPOPT : MATPOWER options struct

Outputs:
  VLIMS  : vector of voltage magnitudes
  DVLIMS : (optional) magnitude gradients

Examples:
    Vlims = opf_vlim_fcn(x, mpc, mpopt);
    [Vlims, dVlims] = opf_vlim_fcn(x, mpc, idx, mpopt);
```

See also *opf_vlim_hess()* (page 300).

opf_vlim_hess

opf_vlim_hess(*x*, *lambda*, *mpc*, *idx*, *mpopt*)

opf_vlim_hess() (page 300) - Evaluates Hessian of voltage magnitudes.

```
D2VLIMS = OPF_VLIM_HESS(X, LAMBDA, MPC, IDX, MPOPT)

Hessian evaluation function for voltage magnitudes.

Inputs:
  X : optimization vector
  LAMBDA : column vector of Lagrange multipliers on active and reactive
           power balance constraints
  MPC : MATPOWER case struct
  IDX : index of buses whose voltage magnitudes should be fixed
  MPOPT : MATPOWER options struct

Outputs:
  D2VLIMS : Hessian of voltage magnitudes.

Example:
    d2Vlims = opf_vlim_hess(x, lambda, mpc, idx, mpopt);
```

See also *opf_vlim_fcn()* (page 299).

opf_vref_fcn

opf_vref_fcn(*x*, *mpc*, *refs*, *mpopt*)

opf_vref_fcn() (page 300) - Evaluates voltage angle reference and their gradients.

```
[Vref, dVref] = OPF_VREF_FCN(X, mpc, ref, MPOPT)

Computes the voltage angle reference using real and imaginary part of complex␣
↪voltage for
AC optimal power flow. Computes constraint vectors and their gradients.

Inputs:
  X : optimization vector
  MPC : MATPOWER case struct
  REFS : reference vector
  MPOPT : MATPOWER options struct

Outputs:
  VREF  : vector of voltage angle reference
  DVREF : (optional) angle reference gradients

Examples:
    Vref = opf_vref_fcn(x, mpc, refs, mpopt);
    [Vref, dVref] = opf_vref_fcn(x, mpc, refs, mpopt);
```

See also *opf_vref_hess()* (page 301).

opf_vref_hess

opf_vref_hess(*x*, *lam*, *mpc*, *refs*, *mpopt*)

opf_vref_hess() (page 301) - Evaluates Hessian of voltage angle reference.

```
D2VREF = OPF_VREF_HESS(X, LAMBDA, MPC, REFS, MPOPT)

Hessian evaluation function for voltage angle reference.

Inputs:
  X : optimization vector
  LAMBDA : column vector of Lagrange multipliers on active and reactive
           power balance constraints
  MPC : MATPOWER case struct
  REFS : reference vector
  MPOPT : MATPOWER options struct

Outputs:
  D2VREF : Hessian of voltage angle reference.

Example:
    d2Vref = opf_vref_hess(x, lambda, mpc, refs, mpopt);
```

See also *opf_vref_fcn()* (page 300).

totcost

totcost(*gencost*, *Pg*)

totcost() - Computes total cost for generators at given output level.

```
TOTALCOST = TOTCOST(GENCOST, PG) computes total cost for generators given
a matrix in gencost format and a column vector or matrix of generation
levels. The return value has the same dimensions as PG. Each row
of GENCOST is used to evaluate the cost at the points specified in the
corresponding row of PG.
```

update_mupq

update_mupq(*baseMVA*, *gen*, *mu_PQh*, *mu_PQl*, *data*)

update_mupq() (page 301) - Updates values of generator limit shadow prices.

```
GEN = UPDATE_MUPQ(BASEMVA, GEN, MU_PQH, MU_PQL, DATA)

Updates the values of MU_PMIN, MU_PMAX, MU_QMIN, MU_QMAX based
on any shadow prices on the sloped portions of the generator
```

(continues on next page)

(continued from previous page)

```
capability curve constraints.

MU_PQH - shadow prices on upper sloped portion of capability curves
MU_PQL - shadow prices on lower sloped portion of capability curves
DATA   - "data" struct returned by MAKEAPQ
```

See also *makeApq()* (page 288).

5.2.8 OPF User Callback Functions

add_userfcn

add_userfcn(*mpc*, *stage*, *fcn*, *args*, *allow_multiple*)

add_userfcn() (page 302) - Appends a userfcn to the list to be called for a case.

```
MPC = ADD_USERFCN(MPC, STAGE, FCN)
MPC = ADD_USERFCN(MPC, STAGE, FCN, ARGS)
MPC = ADD_USERFCN(MPC, STAGE, FCN, ARGS, ALLOW_MULTIPLE)

A userfcn is a callback function that can be called automatically by
MATPOWER at one of various stages in a simulation.

MPC   : the case struct
STAGE : the name of the stage at which this function should be
        called: ext2int, formulation, int2ext, printpf, savecase
FCN   : the name of the userfcn
ARGS  : (optional) the value to be passed as an argument to the
        userfcn (typically a struct)
ALLOW_MULTIPLE : (optional) if TRUE, allows the same function to
       be added more than once.

Currently there are 5 different callback stages defined. Each stage has
a name, and by convention, the name of a user-defined callback function
ends with the name of the stage. The following is a description of each
stage, when it is called and the input and output arguments which vary
depending on the stage. The reserves example (see RUNOPF_W_RES) is used
to illustrate how these callback userfcns might be used.

1. ext2int

Called from EXT2INT immediately after the case is converted from
external to internal indexing. Inputs are a MATPOWER case struct (MPC),
freshly converted to internal indexing and any (optional) ARGS value
supplied via ADD_USERFCN. Output is the (presumably updated) MPC. This is
typically used to reorder any input arguments that may be needed in
internal ordering by the formulation stage.

E.g. mpc = userfcn_reserves_ext2int(mpc, mpopt, args)
```

(continues on next page)

(continued from previous page)

```
2. formulation

Called from OPF after the OPF Model (OM) object has been initialized
with the standard OPF formulation, but before calling the solver. Inputs
are the OM object and any (optional) ARGS supplied via ADD_USERFCN.
Output is the OM object. This is the ideal place to add any additional
vars, constraints or costs to the OPF formulation.

E.g. om = userfcn_reserves_formulation(om, mpopt, args)

3. int2ext

Called from INT2EXT immediately before the resulting case is converted
from internal back to external indexing. Inputs are the RESULTS struct
and any (optional) ARGS supplied via ADD_USERFCN. Output is the RESULTS
struct. This is typically used to convert any results to external
indexing and populate any corresponding fields in the RESULTS struct.

E.g. results = userfcn_reserves_int2ext(results, mpopt, args)

4. printpf

Called from PRINTPF after the pretty-printing of the standard OPF
output. Inputs are the RESULTS struct, the file descriptor to write to,
a MATPOWER options struct, and any (optional) ARGS supplied via
ADD_USERFCN. Output is the RESULTS struct. This is typically used for
any additional pretty-printing of results.

E.g. results = userfcn_reserves_printpf(results, fd, mpopt, args)

5. savecase

Called from SAVECASE when saving a case struct to an M-file after
printing all of the other data to the file. Inputs are the case struct,
the file descriptor to write to, the variable prefix (typically 'mpc.')
and any (optional) ARGS supplied via ADD_USERFCN. Output is the case
struct. This is typically used to write any non-standard case struct
fields to the case file.

E.g. mpc = userfcn_reserves_printpf(mpc, fd, prefix, args)
```

See also *run_userfcn()* (page 304), *remove_userfcn()* (page 304), *toggle_reserves()* (page 306), *toggle_iflims()* (page 305), *toggle_dcline()* (page 304), *toggle_softlims()* (page 307), *runopf_w_res()* (page 235).

remove_userfcn

remove_userfcn(*mpc*, *stage*, *fcn*)

remove_userfcn() (page 304) - Removes a userfcn from the list to be called for a case.

```
MPC = REMOVE_USERFCN(MPC, STAGE, FCN)

A userfcn is a callback function that can be called automatically by
MATPOWER at one of various stages in a simulation. This function removes
the last instance of the userfcn for the given STAGE with the function
handle specified by FCN.
```

See also *add_userfcn()* (page 302), *run_userfcn()* (page 304), *toggle_reserves()* (page 306), *toggle_iflims()* (page 305), *runopf_w_res()* (page 235).

run_userfcn

run_userfcn(*userfcn*, *stage*, *varargin*)

run_userfcn() (page 304) - Runs the userfcn callbacks for a given stage.

```
RV = RUN_USERFCN(USERFCN, STAGE, VARARGIN)

USERFCN : the 'userfcn' field of mpc, populated by ADD_USERFCN
STAGE   : the name of the callback stage being executed
(additional arguments) some stages require additional arguments.

Example:
    mpc = om.get_mpc();
    om = run_userfcn(mpc.userfcn, 'formulation', om);
```

See also *add_userfcn()* (page 302), *remove_userfcn()* (page 304), *toggle_reserves()* (page 306), *toggle_iflims()* (page 305), *runopf_w_res()* (page 235).

toggle_dcline

toggle_dcline(*mpc*, *on_off*)

toggle_dcline() (page 304) - Enable, disable or check status of DC line modeling.

```
MPC = TOGGLE_DCLINE(MPC, 'on')
MPC = TOGGLE_DCLINE(MPC, 'off')
T_F = TOGGLE_DCLINE(MPC, 'status')

Enables, disables or checks the status of a set of OPF userfcn
callbacks to implement DC lines as a pair of linked generators.
While it uses the OPF extension mechanism, this implementation
works for simple power flow as well as OPF problems.

These callbacks expect to find a 'dcline' field in the input MPC,
where MPC.dcline is an ndc x 17 matrix with columns as defined
```

(continues on next page)

(continued from previous page)

```
in IDX_DCLINE, where ndc is the number of DC lines.

The 'int2ext' callback also packages up flow results and stores them
in appropriate columns of MPC.dcline.

NOTE: Because of the way this extension modifies the number of
rows in the gen and gencost matrices, caution must be taken
when using it with other extensions that deal with generators.

Examples:
    mpc = loadcase('t_case9_dcline');
    mpc = toggle_dcline(mpc, 'on');
    results1 = runpf(mpc);
    results2 = runopf(mpc);
```

See also *idx_dcline()* (page 343), *add_userfcn()* (page 302), *remove_userfcn()* (page 304), *run_userfcn()* (page 304).

toggle_iflims

toggle_iflims(*mpc*, *on_off*)

toggle_iflims() (page 305) - Enable, disable or check status of set of interface flow limits.

```
MPC = TOGGLE_IFLIMS(MPC, 'on')
MPC = TOGGLE_IFLIMS(MPC, 'off')
T_F = TOGGLE_IFLIMS(MPC, 'status')

Enables, disables or checks the status of a set of OPF userfcn
callbacks to implement interface flow limits based on a DC flow model.

These callbacks expect to find an 'if' field in the input MPC, where
MPC.if is a struct with the following fields:
    map     n x 2, defines each interface in terms of a set of
            branch indices and directions. Interface I is defined
            by the set of rows whose 1st col is equal to I. The
            2nd column is a branch index multiplied by 1 or -1
            respectively for lines whose orientation is the same
            as or opposite to that of the interface.
    lims    nif x 3, defines the DC model flow limits in MW
            for specified interfaces. The first column is the index
            of the interface, the 2nd and 3rd columns specify
            the lower and upper limits on the (DC model) flow
            across the interface, respectively. Normally, the lower
            limit is negative, indicating a flow in the opposite
            direction.

The 'int2ext' callback also packages up results and stores them in
the following output fields of results.if:
    P       - nif x 1, actual flow across each interface in MW
```

(continues on next page)

(continued from previous page)

```
    mu.l    - nif x 1, shadow price on lower flow limit, ($/MW)
    mu.u    - nif x 1, shadow price on upper flow limit, ($/MW)
```

See also *add_userfcn()* (page 302), *remove_userfcn()* (page 304), *run_userfcn()* (page 304), *t_case30_userfcns()* (page 381).

toggle_reserves

toggle_reserves(*mpc*, *on_off*)

toggle_reserves() (page 306) - Enable, disable or check status of fixed reserve requirements.

```
MPC = TOGGLE_RESERVES(MPC, 'on')
MPC = TOGGLE_RESERVES(MPC, 'off')
T_F = TOGGLE_RESERVES(MPC, 'status')

Enables, disables or checks the status of a set of OPF userfcn
callbacks to implement co-optimization of reserves with fixed zonal
reserve requirements.

These callbacks expect to find a 'reserves' field in the input MPC,
where MPC.reserves is a struct with the following fields:
    zones   nrz x ng, zone(i, j) = 1, if gen j belongs to zone i
                                      0, otherwise
    req     nrz x 1, zonal reserve requirement in MW
    cost    (ng or ngr) x 1, cost of reserves in $/MW
    qty     (ng or ngr) x 1, max quantity of reserves in MW (optional)
where nrz is the number of reserve zones and ngr is the number of
generators belonging to at least one reserve zone and ng is the total
number of generators.

The 'int2ext' callback also packages up results and stores them in
the following output fields of results.reserves:
    R       - ng x 1, reserves provided by each gen in MW
    Rmin    - ng x 1, lower limit on reserves provided by each gen, (MW)
    Rmax    - ng x 1, upper limit on reserves provided by each gen, (MW)
    mu.l    - ng x 1, shadow price on reserve lower limit, ($/MW)
    mu.u    - ng x 1, shadow price on reserve upper limit, ($/MW)
    mu.Pmax - ng x 1, shadow price on Pg + R <= Pmax constraint, ($/MW)
    prc     - ng x 1, reserve price for each gen equal to maximum of the
                      shadow prices on the zonal requirement constraint
                      for each zone the generator belongs to
```

See also *runopf_w_res()* (page 235), *add_userfcn()* (page 302), *remove_userfcn()* (page 304), *run_userfcn()* (page 304), *t_case30_userfcns()* (page 381).

toggle_softlims

toggle_softlims(*mpc*, *on_off*)

toggle_softlims() (page 307) - Relax DC optimal power flow branch limits.

```
MPC = TOGGLE_SOFTLIMS(MPC, 'on')
MPC = TOGGLE_SOFTLIMS(MPC, 'off')
T_F = TOGGLE_SOFTLIMS(MPC, 'status')

Enables, disables or checks the status of a set of OPF userfcn
callbacks to implement relaxed inequality constraints for an OPF model.

These callbacks expect to find a 'softlims' field in the input MPC,
where MPC.softlims is a struct with fields corresponding to the
possible limits, namely:
    VMIN, VMAX, RATE_A, PMIN, PMAX, QMIN, QMAX, ANGMAX, ANGMIN
Each of these is itself a struct with the following fields, all of which
are optional:
    idx     index of affected buses, branches, or generators. These are
            row indices into the respective matrices. The default is to
            include all online elements for which the constraint in
            question is not unbounded, except for generators, which also
            exclude those used to model dispatchable loads
            (i.e. those for which isload(gen) is true).
    busnum  for bus constraints, such as VMIN and VMAX, the affected
            buses can be specified by a vector of external bus numbers
            in the 'busnum' field instead of bus row indices in the 'idx'
            field. If both are present, 'idx' overrides 'busnum'.
    cost    linear marginal cost of exceeding the original limit
            The defaults are set as:
                base_cost x 100 $/pu    for VMAX and VMIN
                base_cost $/MW          for RATE_A, PMAX, and PMIN
                base_cost $/MVAr        for QMAX, QMIN
                base_cost $/deg         for ANGMAX, ANGMIN
            where base_cost is the maximum of $1000 and twice the
            maximum generator cost of all online generators.
    hl_mod  type of modification to hard limit, hl:
                'none'    : do *not* add soft limit, no change to original
                            hard limit
                'remove'  : add soft limit, relax hard limit by removing
                            it completely
                'replace' : add soft limit, relax hard limit by replacing
                            original with value specified in hl_val
                'scale'   : add soft limit, relax hard limit by scaling
                            original by value specified in hl_val
                'shift'   : add soft limit, relax hard limit by shifting
                            original by value specified in hl_val
    hl_val  value used to modify hard limit according to hl_mod. Ignored
            for 'none' and 'remove', required for 'replace', and optional,
            with the following defaults, for 'scale' and 'shift':
                'scale' :   2 for positive upper limits or negative lower
                            limits, 0.5 otherwise
                'shift' :   0.25 for VMAX and VMIN, 10 otherwise
```

(continues on next page)

(continued from previous page)

```
For limits that are left unspecified in the structure, the default
behavior is determined by the value of the mpopt.opf.softlims.default
option. If mpopt.opf.softlims.default = 0, then the unspecified softlims
are ignored (hl_mod = 'none', i.e. original hard limits left in place).
If mpopt.opf.softlims.default = 1 (default), then the unspecified
softlims are enabled with default values, which specify to 'remove'
the hard limit, except in the case of VMIN and PMIN, whose defaults
are set as follows:
      .VMIN
        .hl_mod = 'replace'
        .hl_val = 0
      .PMIN
        .hl_mod = 'replace'
        .hl_val = 0     for normal generators (PMIN > 0)
        .hl_val = -Inf  for for generators with PMIN < 0 AND PMAX > 0

With mpopt.opf.softlims.default = 0, it is still possible to enable a
softlim with default values by setting that specification to an empty
struct. E.g. mpc.softlims.VMAX = struct() would enable a default
softlim on VMAX.

The 'int2ext' callback also packages up results and stores them in
the following output fields of results.softlims.(lim), where lim is
one of the above mentioned limits:
    overload - amount of overload, i.e. violation of hard-limit.
    ovl_cost - total cost of overload in $/hr

The shadow prices on the soft limit constraints are also returned in the
relevant columns of the respective matrices (MU_SF, MU_ST for RATE_A,
MU_VMAX for VMAX, etc.)
Note: These shadow prices are equal to the corresponding hard limit
    shadow prices when the soft limits are not violated. When violated,
    the shadow price on a soft limit constraint is equal to the
    user-specified soft limit violation cost + the shadow price on any
    binding remaining hard limit.
```

See also *add_userfcn()* (page 302), *remove_userfcn()* (page 304), *run_userfcn()* (page 304), *t_opf_softlims()* (page 378).

5.2.9 Power Flow Derivative Functions

dIbr_dV

dIbr_dV(*branch*, *Yf*, *Yt*, *V*, *vcart*)

dIbr_dV() (page 309) - Computes partial derivatives of branch currents w.r.t. voltage.

```
The derivatives can be take with respect to polar or cartesian coordinates
of voltage, depending on the 5th argument.

[DIF_DVA, DIF_DVM, DIT_DVA, DIT_DVM, IF, IT] = DIBR_DV(BRANCH, YF, YT, V)
[DIF_DVA, DIF_DVM, DIT_DVA, DIT_DVM, IF, IT] = DIBR_DV(BRANCH, YF, YT, V, 0)

Returns four matrices containing partial derivatives of the complex
branch currents at "from" and "to" ends of each branch w.r.t voltage
magnitude and voltage angle, respectively (for all buses).

[DIF_DVR, DIF_DVI, DIT_DVR, DIT_DVI, IF, IT] = DIBR_DV(BRANCH, YF, YT, V, 1)

Returns four matrices containing partial derivatives of the complex
branch currents at "from" and "to" ends of each branch w.r.t real and
imaginary parts of voltage, respectively (for all buses).

If YF is a sparse matrix, the partial derivative matrices will be as well.
Optionally returns vectors containing the currents themselves. The
following explains the expressions used to form the matrices:

If = Yf * V;

Polar coordinates:
  Partials of V, Vf & If w.r.t. voltage angles
    dV/dVa  = j * diag(V)
    dVf/dVa = sparse(1:nl, f, j * V(f)) = j * sparse(1:nl, f, V(f))
    dIf/dVa = Yf * dV/dVa = Yf * j * diag(V)

  Partials of V, Vf & If w.r.t. voltage magnitudes
    dV/dVm  = diag(V./abs(V))
    dVf/dVm = sparse(1:nl, f, V(f)./abs(V(f))
    dIf/dVm = Yf * dV/dVm = Yf * diag(V./abs(V))

Cartesian coordinates:
  Partials of V, Vf & If w.r.t. real part of complex voltage
    dV/dVr  = diag(ones(n,1))
    dVf/dVr = Cf
    dIf/dVr = Yf
  where Cf is the connection matrix for line & from buses

  Partials of V, Vf & If w.r.t. imaginary part of complex voltage
    dV/dVi  = j * diag(ones(n,1))
    dVf/dVi = j * Cf
```

(continues on next page)

(continued from previous page)

```
    dIf/dVi = j * Yf

Derivations for "to" bus are similar.

Example:
    [Ybus, Yf, Yt] = makeYbus(baseMVA, bus, branch);
    [dIf_dVa, dIf_dVm, dIt_dVa, dIt_dVm, If, It] = ...
        dIbr_dV(branch, Yf, Yt, V);
    [dIf_dVr, dIf_dVi, dIt_dVr, dIt_dVi, If, It] = ...
        dIbr_dV(branch, Yf, Yt, V, 1);
```

For more details on the derivations behind the derivative code used in MATPOWER information, see:

```
[TN2]  R. D. Zimmerman, "AC Power Flows, Generalized OPF Costs and
       their Derivatives using Complex Matrix Notation", MATPOWER
       Technical Note 2, February 2010. [Online]. Available:
       https://matpower.org/docs/TN2-OPF-Derivatives.pdf
       doi: 10.5281/zenodo.3237866
[TN4]  B. Sereeter and R. D. Zimmerman, "AC Power Flows and their
       Derivatives using Complex Matrix Notation and Cartesian
       Coordinate Voltages," MATPOWER Technical Note 4, April 2018.
       [Online]. Available: https://matpower.org/docs/TN4-OPF-Derivatives-Cartesian.
↪pdf
       doi: 10.5281/zenodo.3237909
```

dSbr_dV

dSbr_dV(*branch*, *Yf*, *Yt*, *V*, *vcart*)

dSbr_dV() (page 310) - Computes partial derivatives of branch power flows w.r.t. voltage.

```
The derivatives can be taken with respect to polar or cartesian coordinates
of voltage, depending on the 5th argument.

[DSF_DVA, DSF_DVM, DST_DVA, DST_DVM, SF, ST] = DSBR_DV(BRANCH, YF, YT, V)
[DSF_DVA, DSF_DVM, DST_DVA, DST_DVM, SF, ST] = DSBR_DV(BRANCH, YF, YT, V, 0)

Returns four matrices containing partial derivatives of the complex
branch power flows at "from" and "to" ends of each branch w.r.t voltage
magnitude and voltage angle, respectively (for all buses).

[DSF_DVR, DSF_DVI, DST_DVR, DST_DVI, SF, ST] = DSBR_DV(BRANCH, YF, YT, V, 1)

Returns four matrices containing partial derivatives of the complex
branch power flows at "from" and "to" ends of each branch w.r.t real and
imaginary parts of voltage, respectively (for all buses).

If YF is a sparse matrix, the partial derivative matrices will be as well.
Optionally returns vectors containing the power flows themselves. The
following explains the expressions used to form the matrices:
```

(continues on next page)

(continued from previous page)

```
If = Yf * V;
Sf = diag(Vf) * conj(If) = diag(conj(If)) * Vf

Polar coordinates:
  Partials of V, Vf & If w.r.t. voltage angles
    dV/dVa  = j * diag(V)
    dVf/dVa = sparse(1:nl, f, j * V(f)) = j * sparse(1:nl, f, V(f))
    dIf/dVa = Yf * dV/dVa = Yf * j * diag(V)

  Partials of V, Vf & If w.r.t. voltage magnitudes
    dV/dVm  = diag(V./abs(V))
    dVf/dVm = sparse(1:nl, f, V(f)./abs(V(f))
    dIf/dVm = Yf * dV/dVm = Yf * diag(V./abs(V))

  Partials of Sf w.r.t. voltage angles
    dSf/dVa = diag(Vf) * conj(dIf/dVa)
                    + diag(conj(If)) * dVf/dVa
            = diag(Vf) * conj(Yf * j * diag(V))
                    + conj(diag(If)) * j * sparse(1:nl, f, V(f))
            = -j * diag(Vf) * conj(Yf * diag(V))
                    + j * conj(diag(If)) * sparse(1:nl, f, V(f))
            = j * (conj(diag(If)) * sparse(1:nl, f, V(f))
                    - diag(Vf) * conj(Yf * diag(V)))

  Partials of Sf w.r.t. voltage magnitudes
    dSf/dVm = diag(Vf) * conj(dIf/dVm)
                    + diag(conj(If)) * dVf/dVm
            = diag(Vf) * conj(Yf * diag(V./abs(V)))
                    + conj(diag(If)) * sparse(1:nl, f, V(f)./abs(V(f)))

Cartesian coordinates:
  Partials of V, Vf & If w.r.t. real part of complex voltage
    dV/dVr  = diag(ones(n,1))
    dVf/dVr = Cf
    dIf/dVr = Yf
  where Cf is the connection matrix for line & from buses

  Partials of V, Vf & If w.r.t. imaginary part of complex voltage
    dV/dVi  = j * diag(ones(n,1))
    dVf/dVi = j * Cf
    dIf/dVi = j * Yf

  Partials of Sf w.r.t. real part of complex voltage
    dSf/dVr = conj(diag(If)) * Cf + diag(Vf) * conj(Yf)

  Partials of Sf w.r.t. imaginary part of complex voltage
    dSf/dVi = j * (conj(diag(If)) * Cf - diag(Vf) * conj(Yf))

Derivations for "to" bus are similar.

Examples:
```

(continues on next page)

(continued from previous page)

```
    [Ybus, Yf, Yt] = makeYbus(baseMVA, bus, branch);
    [dSf_dVa, dSf_dVm, dSt_dVa, dSt_dVm, Sf, St] = ...
        dSbr_dV(branch, Yf, Yt, V);
    [dSf_dVr, dSf_dVi, dSt_dVr, dSt_dVi, Sf, St] = ...
        dSbr_dV(branch, Yf, Yt, V, 1);
```

For more details on the derivations behind the derivative code used in MATPOWER, see:

```
[TN2]  R. D. Zimmerman, "AC Power Flows, Generalized OPF Costs and
       their Derivatives using Complex Matrix Notation", MATPOWER
       Technical Note 2, February 2010. [Online]. Available:
       https://matpower.org/docs/TN2-OPF-Derivatives.pdf
       doi: 10.5281/zenodo.3237866
[TN4]  B. Sereeter and R. D. Zimmerman, "AC Power Flows and their
       Derivatives using Complex Matrix Notation and Cartesian
       Coordinate Voltages," MATPOWER Technical Note 4, April 2018.
       [Online]. Available: https://matpower.org/docs/TN4-OPF-Derivatives-Cartesian.
↪pdf
       doi: 10.5281/zenodo.3237909
```

dAbr_dV

dAbr_dV(*dFf_dV1*, *dFf_dV2*, *dFt_dV1*, *dFt_dV2*, *Ff*, *Ft*)

dAbr_dV() (page 312) - Partial derivatives of squared flow magnitudes w.r.t voltage.

```
[DAF_DV1, DAF_DV2, DAT_DV1, DAT_DV2] = ...
           DABR_DV(DFF_DV1, DFF_DV2, DFT_DV1, DFT_DV2, FF, FT)
returns four matrices containing partial derivatives of the square of
the branch flow magnitudes at "from" & "to" ends of each branch w.r.t
voltage components (either angle and magnitude, respectively, if polar,
or real and imaginary, respectively, if cartesian) for all buses, given
the flows and flow sensitivities. Flows could be complex current or
complex or real power. Notation below is based on complex power. The
following explains the expressions used to form the matrices:

Let Af refer to the square of the apparent power at the "from" end of
each branch,

    Af = abs(Sf).^2
       = Sf .* conj(Sf)
       = Pf.^2 + Qf.^2

then ...

Partial w.r.t real power,
    dAf/dPf = 2 * diag(Pf)

Partial w.r.t reactive power,
    dAf/dQf = 2 * diag(Qf)
```

(continues on next page)

(continued from previous page)

```
Partial w.r.t V1 & V2 (e.g. Va and Vm, or Vr and Vi)
    dAf/dV1 = dAf/dPf * dPf/dV1 + dAf/dQf * dQf/dV1
    dAf/dV2 = dAf/dPf * dPf/dV2 + dAf/dQf * dQf/dV2

Derivations for "to" bus are similar.

Examples:
    %% squared current magnitude
    [dFf_dV1, dFf_dV2, dFt_dV1, dFt_dV2, Ff, Ft] = ...
            dIbr_dV(branch(il,:), Yf, Yt, V);
    [dAf_dV1, dAf_dV2, dAt_dV1, dAt_dV2] = ...
            dAbr_dV(dFf_dV1, dFf_dV2, dFt_dV1, dFt_dV2, Ff, Ft);

    %% squared apparent power flow
    [dFf_dV1, dFf_dV2, dFt_dV1, dFt_dV2, Ff, Ft] = ...
            dSbr_dV(branch(il,:), Yf, Yt, V);
    [dAf_dV1, dAf_dV2, dAt_dV1, dAt_dV2] = ...
            dAbr_dV(dFf_dV1, dFf_dV2, dFt_dV1, dFt_dV2, Ff, Ft);

    %% squared real power flow
    [dFf_dV1, dFf_dV2, dFt_dV1, dFt_dV2, Ff, Ft] = ...
            dSbr_dV(branch(il,:), Yf, Yt, V);
    dFf_dV1 = real(dFf_dV1);
    dFf_dV2 = real(dFf_dV2);
    dFt_dV1 = real(dFt_dV1);
    dFt_dV2 = real(dFt_dV2);
    [dAf_dV1, dAf_dV2, dAt_dV1, dAt_dV2] = ...
            dAbr_dV(dFf_dV1, dFf_dV2, dFt_dV1, dFt_dV2, Ff, Ft);
```

See also *dIbr_dV()* (page 309), *dSbr_dV()* (page 310).

For more details on the derivations behind the derivative code used in MATPOWER information, see:

```
[TN2]  R. D. Zimmerman, "AC Power Flows, Generalized OPF Costs and
       their Derivatives using Complex Matrix Notation", MATPOWER
       Technical Note 2, February 2010. [Online]. Available:
       https://matpower.org/docs/TN2-OPF-Derivatives.pdf
       doi: 10.5281/zenodo.3237866
```

dImis_dV

dImis_dV(*Sbus*, *Ybus*, *V*, *vcart*)

dImis_dV() (page 313) - Computes partial derivatives of current balance w.r.t. voltage.

```
The derivatives can be take with respect to polar or cartesian coordinates
of voltage, depending on the 3rd argument.

[DIMIS_DVM, DIMIS_DVA] = DIMIS_DV(SBUS, YBUS, V)
[DIMIS_DVM, DIMIS_DVA] = DIMIS_DV(SBUS, YBUS, V, 0)
```

(continues on next page)

(continued from previous page)

```
Returns two matrices containing partial derivatives of the complex bus
current balance w.r.t voltage magnitude and voltage angle, respectively
(for all buses).

[DIMIS_DVR, DIMIS_DVI] = DIMIS_DV(SBUS, YBUS, V, 1)

Returns two matrices containing partial derivatives of the complex bus
current balance w.r.t the real and imaginary parts of voltage,
respectively (for all buses).

If YBUS is a sparse matrix, the return values will be also. The following
explains the expressions used to form the matrices:

Imis = Ibus + Idg = Ybus * V - conj(Sbus./V)

Polar coordinates:
  Partials of V & Ibus w.r.t. voltage angles
    dV/dVa = j * diag(V)
    dI/dVa = Ybus * dV/dVa = Ybus * j * diag(V)

  Partials of V & Ibus w.r.t. voltage magnitudes
    dV/dVm = diag(V./abs(V))
    dI/dVm = Ybus * dV/dVm = Ybus * diag(V./abs(V))

  Partials of Imis w.r.t. voltage angles
    dImis/dVa = j * (Ybus* diag(V) - diag(conj(Sbus./V)))

  Partials of Imis w.r.t. voltage magnitudes
    dImis/dVm = Ybus * diag(V./abs(V)) +  diag(conj(Sbus./(V*abs(V))))

Cartesian coordinates:
  Partials of V & Ibus w.r.t. real part of complex voltage
    dV/dVr = diag(ones(n,1))
    dI/dVr = Ybus * dV/dVr = Ybus

  Partials of V & Ibus w.r.t. imaginary part of complex voltage
    dV/dVi = j * diag(ones(n,1))
    dI/dVi = Ybus * dV/dVi = Ybus * j

  Partials of Imis w.r.t. real part of complex voltage
    dImis/dVr = Ybus + conj(diag(Sbus./(V.^2)))

  Partials of S w.r.t. imaginary part of complex voltage
    dImis/dVi = j * (Ybus - diag(conj(Sbus./(V.^2))))

Examples:
    Sbus = makeSbus(baseMVA, bus, gen);
    [Ybus, Yf, Yt] = makeYbus(baseMVA, bus, branch);
    [dImis_dVm, dImis_dVa] = dImis_dV(Sbus, Ybus, V);
    [dImis_dVr, dImis_dVi] = dImis_dV(Sbus, Ybus, V, 1);
```

For more details on the derivations behind the derivative code used in MATPOWER information, see:

```
[TN2]  R. D. Zimmerman, "AC Power Flows, Generalized OPF Costs and
       their Derivatives using Complex Matrix Notation", MATPOWER
       Technical Note 2, February 2010. [Online]. Available:
       https://matpower.org/docs/TN2-OPF-Derivatives.pdf
       doi: 10.5281/zenodo.3237866
[TN3]  B. Sereeter and R. D. Zimmerman, "Addendum to AC Power Flows and
       their Derivatives using Complex Matrix Notation: Nodal Current
       Balance," MATPOWER Technical Note 3, April 2018. [Online].
       Available: https://matpower.org/docs/TN3-More-OPF-Derivatives.pdf
       doi: 10.5281/zenodo.3237900
[TN4]  B. Sereeter and R. D. Zimmerman, "AC Power Flows and their
       Derivatives using Complex Matrix Notation and Cartesian
       Coordinate Voltages," MATPOWER Technical Note 4, April 2018.
       [Online]. Available: https://matpower.org/docs/TN4-OPF-Derivatives-Cartesian.
↪pdf
       doi: 10.5281/zenodo.3237909
```

dSbus_dV

dSbus_dV(*Ybus*, *V*, *vcart*)

dSbus_dV() (page 315) - Computes partial derivatives of power injection w.r.t. voltage.

```
The derivatives can be taken with respect to polar or cartesian coordinates
of voltage, depending on the 3rd argument.

[DSBUS_DVA, DSBUS_DVM] = DSBUS_DV(YBUS, V)
[DSBUS_DVA, DSBUS_DVM] = DSBUS_DV(YBUS, V, 0)

Returns two matrices containing partial derivatives of the complex bus
power injections w.r.t voltage angle and voltage magnitude, respectively
(for all buses).

[DSBUS_DVR, DSBUS_DVI] = DSBUS_DV(YBUS, V, 1)

Returns two matrices containing partial derivatives of the complex bus
power injections w.r.t the real and imaginary parts of voltage,
respectively (for all buses).

If YBUS is a sparse matrix, the return values will be also. The following
explains the expressions used to form the matrices:

S = diag(V) * conj(Ibus) = diag(conj(Ibus)) * V

Polar coordinates:
  Partials of V & Ibus w.r.t. voltage magnitudes
    dV/dVm = diag(V./abs(V))
    dI/dVm = Ybus * dV/dVm = Ybus * diag(V./abs(V))

  Partials of V & Ibus w.r.t. voltage angles
    dV/dVa = j * diag(V)
```

(continues on next page)

(continued from previous page)

```
    dI/dVa = Ybus * dV/dVa = Ybus * j * diag(V)

  Partials of S w.r.t. voltage magnitudes
    dS/dVm = diag(V) * conj(dI/dVm) + diag(conj(Ibus)) * dV/dVm
           = diag(V) * conj(Ybus * diag(V./abs(V)))
                                   + conj(diag(Ibus)) * diag(V./abs(V))

  Partials of S w.r.t. voltage angles
    dS/dVa = diag(V) * conj(dI/dVa) + diag(conj(Ibus)) * dV/dVa
           = diag(V) * conj(Ybus * j * diag(V))
                                   + conj(diag(Ibus)) * j * diag(V)
           = -j * diag(V) * conj(Ybus * diag(V))
                                   + conj(diag(Ibus)) * j * diag(V)
           = j * diag(V) * conj(diag(Ibus) - Ybus * diag(V))

Cartesian coordinates:
  Partials of V & Ibus w.r.t. real part of complex voltage
    dV/dVr = diag(ones(n,1))
    dI/dVr = Ybus * dV/dVr = Ybus

  Partials of V & Ibus w.r.t. imaginary part of complex voltage
    dV/dVi = j * diag(ones(n,1))
    dI/dVi = Ybus * dV/dVi = Ybus * j

  Partials of S w.r.t. real part of complex voltage
    dS/dVr = diag(V) * conj(dI/dVr) + diag(conj(Ibus)) * dV/dVr
           = diag(V) * conj(Ybus) + conj(diag(Ibus))

  Partials of S w.r.t. imaginary part of complex voltage
    dS/dVi = diag(V) * conj(dI/dVi) + diag(conj(Ibus)) * dV/dVi
           = j * (conj(diag(Ibus)) - diag(V) conj(Ybus))

Examples:
    [Ybus, Yf, Yt] = makeYbus(baseMVA, bus, branch);
    [dSbus_dVa, dSbus_dVm] = dSbus_dV(Ybus, V);
    [dSbus_dVr, dSbus_dVi] = dSbus_dV(Ybus, V, 1);
```

For more details on the derivations behind the derivative code used in MATPOWER information, see:

```
[TN2]  R. D. Zimmerman, "AC Power Flows, Generalized OPF Costs and
       their Derivatives using Complex Matrix Notation", MATPOWER
       Technical Note 2, February 2010. [Online]. Available:
       https://matpower.org/docs/TN2-OPF-Derivatives.pdf
       doi: 10.5281/zenodo.3237866
[TN4]  B. Sereeter and R. D. Zimmerman, "AC Power Flows and their
       Derivatives using Complex Matrix Notation and Cartesian
       Coordinate Voltages," MATPOWER Technical Note 4, April 2018.
       [Online]. Available: https://matpower.org/docs/TN4-OPF-Derivatives-Cartesian.
↪pdf
       doi: 10.5281/zenodo.3237909
```

d2Ibr_dV2

d2Ibr_dV2(*Ybr*, *V*, *mu*, *vcart*)

d2Ibr_dV2() (page 317) - Computes 2nd derivatives of complex branch current w.r.t. voltage.

```
The derivatives can be take with respect to polar or cartesian coordinates
of voltage, depending on the 4th argument.

[HAA, HAV, HVA, HVV] = D2IBR_DV2(YBR, V, MU)
[HAA, HAV, HVA, HVV] = D2IBR_DV2(YBR, V, MU, 0)

Returns 4 matrices containing the partial derivatives w.r.t. voltage angle
and magnitude of the product of a vector MU with the 1st partial
derivatives of the complex branch currents.

[HRR, HRI, HIR, HII] = D2IBR_DV2(YBR, V, MU, 1)

Returns 4 matrices (all zeros) containing the partial derivatives w.r.t.
real and imaginary part of complex voltage of the product of a vector MU
with the 1st partial derivatives of the complex branch currents.

Takes sparse branch admittance matrix YBR, voltage vector V and nl x 1
vector of multipliers MU. Output matrices are sparse.

Examples:
    [Ybus, Yf, Yt] = makeYbus(baseMVA, bus, branch);
    Ybr = Yf;
    [Haa, Hav, Hva, Hvv] = d2Ibr_dV2(Ybr, V, mu);

Here the output matrices correspond to:
    Haa = d/dVa (dIbr_dVa.' * mu)
    Hav = d/dVm (dIbr_dVa.' * mu)
    Hva = d/dVa (dIbr_dVm.' * mu)
    Hvv = d/dVm (dIbr_dVm.' * mu)

    [Hrr, Hri, Hir, Hii] = d2Ibr_dV2(Ybr, V, mu, 1);

Here the output matrices correspond to:
    Hrr = d/dVr (dIbr_dVr.' * mu)
    Hri = d/dVi (dIbr_dVr.' * mu)
    Hir = d/dVr (dIbr_dVi.' * mu)
    Hii = d/dVi (dIbr_dVi.' * mu)
```

For more details on the derivations behind the derivative code used in MATPOWER information, see:

```
[TN2]  R. D. Zimmerman, "AC Power Flows, Generalized OPF Costs and
       their Derivatives using Complex Matrix Notation", MATPOWER
       Technical Note 2, February 2010. [Online]. Available:
       https://matpower.org/docs/TN2-OPF-Derivatives.pdf
       doi: 10.5281/zenodo.3237866
[TN4]  B. Sereeter and R. D. Zimmerman, "AC Power Flows and their
       Derivatives using Complex Matrix Notation and Cartesian
       Coordinate Voltages," MATPOWER Technical Note 4, April 2018.
```

(continues on next page)

(continued from previous page)

```
      [Online]. Available: https://matpower.org/docs/TN4-OPF-Derivatives-Cartesian.
↪pdf
      doi: 10.5281/zenodo.3237909
```

d2Sbr_dV2

d2Sbr_dV2(*Cbr*, *Ybr*, *V*, *mu*, *vcart*)

d2Sbr_dV2() (page 318) - Computes 2nd derivatives of complex brch power flow w.r.t. voltage.

```
The derivatives can be take with respect to polar or cartesian coordinates
of voltage, depending on the 5th argument.

[HAA, HAV, HVA, HVV] = D2SBR_DV2(CBR, YBR, V, MU)
[HAA, HAV, HVA, HVV] = D2SBR_DV2(CBR, YBR, V, MU, 0)

Returns 4 matrices containing the partial derivatives w.r.t. voltage angle
and magnitude of the product of a vector MU with the 1st partial
derivatives of the complex branch power flows.

[HRR, HRI, HIR, HII] = d2Sbr_dV2(CBR, YBR, V, MU, 1)

Returns 4 matrices containing the partial derivatives w.r.t. real and
imaginary part of complex voltage of the product of a vector MU with the
1st partial derivatives of the complex branch power flows.

Takes sparse connection matrix CBR, sparse branch admittance matrix YBR,
voltage vector V and nl x 1 vector of multipliers MU. Output matrices are
sparse.

Examples:
    f = branch(:, F_BUS);
    Cf =  sparse(1:nl, f, ones(nl, 1), nl, nb);
    [Ybus, Yf, Yt] = makeYbus(baseMVA, bus, branch);
    Cbr = Cf;
    Ybr = Yf;
    [Haa, Hav, Hva, Hvv] = d2Sbr_dV2(Cbr, Ybr, V, mu);

    Here the output matrices correspond to:
        Haa = d/dVa (dSbr_dVa.' * mu)
        Hav = d/dVm (dSbr_dVa.' * mu)
        Hva = d/dVa (dSbr_dVm.' * mu)
        Hvv = d/dVm (dSbr_dVm.' * mu)

    [Hrr, Hri, Hir, Hii] = d2Sbr_dV2(Cbr, Ybr, V, mu, 1);

    Here the output matrices correspond to:
        Hrr = d/dVr (dSbr_dVr.' * mu)
        Hri = d/dVi (dSbr_dVr.' * mu)
        Hir = d/dVr (dSbr_dVi.' * mu)
        Hii = d/dVi (dSbr_dVi.' * mu)
```

For more details on the derivations behind the derivative code used in MATPOWER information, see:

```
[TN2]  R. D. Zimmerman, "AC Power Flows, Generalized OPF Costs and
       their Derivatives using Complex Matrix Notation", MATPOWER
       Technical Note 2, February 2010. [Online]. Available:
       https://matpower.org/docs/TN2-OPF-Derivatives.pdf
       doi: 10.5281/zenodo.3237866
[TN4]  B. Sereeter and R. D. Zimmerman, "AC Power Flows and their
       Derivatives using Complex Matrix Notation and Cartesian
       Coordinate Voltages," MATPOWER Technical Note 4, April 2018.
       [Online]. Available: https://matpower.org/docs/TN4-OPF-Derivatives-Cartesian.
↪pdf
       doi: 10.5281/zenodo.3237909
```

d2Abr_dV2

d2Abr_dV2(*d2F_dV2*, *dF_dV1*, *dF_dV2*, *F*, *V*, *mu*)

d2Abr_dV2() (page 319) - Computes 2nd derivatives of |branch flow|^2 w.r.t. V.

```
The derivatives can be take with respect to polar or cartesian coordinates
of voltage, depending on the first 3 arguments. Flows could be complex
current or complex or real power. Notation below is based on complex power.

[H11, H12, H21, H22] = D2ABR_DV2(D2F_DV2, DF_DV1, DF_DV2, F, V, MU)

Returns 4 matrices containing the partial derivatives w.r.t. voltage
components (angle, magnitude or real, imaginary) of the product of a
vector MU with the 1st partial derivatives of the square of the magnitude
of branch flows.

Takes as inputs a handle to a function that evaluates the 2nd derivatives
of the flows (with args V and mu only), sparse first derivative matrices
of flow, flow vector, voltage vector V and nl x 1 vector of multipliers
MU. Output matrices are sparse.

Example:
    f = branch(:, F_BUS);
    Cf =  sparse(1:nl, f, ones(nl, 1), nl, nb);
    [Ybus, Yf, Yt] = makeYbus(baseMVA, bus, branch);
    [dSf_dV1, dSf_dV2, dSt_dV1, dSt_dV2, Sf, St] = ...
            dSbr_dV(branch, Yf, Yt, V);
    dF_dV1 = dSf_dV1;
    dF_dV2 = dSf_dV2;
    F = Sf;
    d2F_dV2 = @(V, mu)d2Sbr_dV2(Cf, Yf, V, mu, 0);
    [H11, H12, H21, H22] = ...
          d2Abr_dV2(d2F_dV2, dF_dV1, dF_dV2, F, V, mu);

Here the output matrices correspond to:
  H11 = d/dV1 (dAF_dV1.' * mu)
  H12 = d/dV2 (dAF_dV1.' * mu)
```

(continues on next page)

(continued from previous page)

```
  H21 = d/dV1 (dAF_dV2.' * mu)
  H22 = d/dV2 (dAF_dV2.' * mu)
```

See also *dAbr_dV()* (page 312), *dIbr_dV()* (page 309), *dSbr_dV()* (page 310).

For more details on the derivations behind the derivative code used in MATPOWER information, see:

```
[TN2]  R. D. Zimmerman, "AC Power Flows, Generalized OPF Costs and
       their Derivatives using Complex Matrix Notation", MATPOWER
       Technical Note 2, February 2010. [Online]. Available:
       https://matpower.org/docs/TN2-OPF-Derivatives.pdf
       doi: 10.5281/zenodo.3237866
```

d2Imis_dV2

d2Imis_dV2(*Sbus*, *Ybus*, *V*, *lam*, *vcart*)

d2Imis_dV2() (page 320) - Computes 2nd derivatives of current balance w.r.t. voltage.

```
The derivatives can be take with respect to polar or cartesian coordinates
of voltage, depending on the 5th argument.

[GAA, GAV, GVA, GVV] = D2IMIS_DV2(SBUS, YBUS, V, LAM)
[GAA, GAV, GVA, GVV] = D2IMIS_DV2(SBUS, YBUS, V, LAM, 0)

Returns 4 matrices containing the partial derivatives w.r.t. voltage angle
and magnitude of the product of a vector LAM with the 1st partial
derivatives of the complex bus current balance.

[GRR, GIR, GIR, GII] = D2IMIS_DV2(SBUS, YBUS, V, LAM, 1)

Returns 4 matrices containing the partial derivatives w.r.t. real and
imaginary parts of voltage of the product of a vector LAM with the 1st
partial derivatives of the complex bus current balance.

Takes bus complex power injection (gen-load) vector, sparse bus admittance
matrix YBUS, voltage vector V and nb x 1 vector of multipliers LAM. Output
matrices are sparse.

Examples:
    Sbus = makeSbus(baseMVA, bus, gen);
    [Ybus, Yf, Yt] = makeYbus(baseMVA, bus, branch);
    [Gaa, Gav, Gva, Gvv] = d2Imis_dV2(Sbus, Ybus, V, lam);

    Here the output matrices correspond to:
        Gaa = d/dVa (dImis_dVa.' * lam)
        Gav = d/dVm (dImis_dVa.' * lam)
        Gva = d/dVa (dImis_dVm.' * lam)
        Gvv = d/dVm (dImis_dVm.' * lam)

    [Grr, Gri, Gir, Gii] = d2Imis_dV2(Sbus, Ybus, V, lam, 1);
```

(continues on next page)

(continued from previous page)

```
   Here the output matrices correspond to:
       Grr = d/dVr (dImis_dVr.' * lam)
       Gri = d/dVi (dImis_dVr.' * lam)
       Gir = d/dVr (dImis_dVi.' * lam)
       Gii = d/dVi (dImis_dVi.' * lam)
```

For more details on the derivations behind the derivative code used in MATPOWER, see:

```
[TN2]  R. D. Zimmerman, "AC Power Flows, Generalized OPF Costs and
       their Derivatives using Complex Matrix Notation", MATPOWER
       Technical Note 2, February 2010. [Online]. Available:
       https://matpower.org/docs/TN2-OPF-Derivatives.pdf
       doi: 10.5281/zenodo.3237866
[TN3]  B. Sereeter and R. D. Zimmerman, "Addendum to AC Power Flows and
       their Derivatives using Complex Matrix Notation: Nodal Current
       Balance," MATPOWER Technical Note 3, April 2018. [Online].
       Available: https://matpower.org/docs/TN3-More-OPF-Derivatives.pdf
       doi: 10.5281/zenodo.3237900
[TN4]  B. Sereeter and R. D. Zimmerman, "AC Power Flows and their
       Derivatives using Complex Matrix Notation and Cartesian
       Coordinate Voltages," MATPOWER Technical Note 4, April 2018.
       [Online]. Available: https://matpower.org/docs/TN4-OPF-Derivatives-Cartesian.
↪pdf
       doi: 10.5281/zenodo.3237909
```

d2Imis_dVdSg

d2Imis_dVdSg(*Cg*, *V*, *lam*, *vcart*)

d2Imis_dVdSg() (page 321) - Computes 2nd derivatives of current balance w.r.t. V and Sg.

```
The derivatives can be take with respect to polar or cartesian coordinates
of voltage, depending on the 4th argument.

GSV = D2IMIS_DVDSG(CG, V, LAM)
GSV = D2IMIS_DVDSG(CG, V, LAM, 0)

Returns a matrix containing the partial derivatives w.r.t. voltage angle
and magnitude of the product of a vector LAM with the 1st partial
derivatives of the real and reactive power generation.

GSV = D2IMIS_DVDSG(CG, V, LAM, 1)

Returns a matrix containing the partial derivatives w.r.t. real and
imaginary parts of voltage of the product of a vector LAM with the 1st
partial derivatives of the real and reactive power generation.

Takes the generator connection matrix, complex voltage vector V and
nb x 1 vector of multipliers LAM. Output matrices are sparse.
```

(continues on next page)

(continued from previous page)

```
Examples:
    Cg = sparse(gen(:, GEN_BUS), 1:ng, -, nb, ng);
    Gsv = d2Imis_dVdSg(Cg, V, lam);

    Here the output matrix corresponds to:
        Gsv = [ Gpa Gpv;
                Gqa Gqv ];
        Gpa = d/dVa (dImis_dPg.' * lam)
        Gpv = d/dVm (dImis_dPg.' * lam)
        Gqa = d/dVa (dImis_dQg.' * lam)
        Gqv = d/dVm (dImis_dQg.' * lam)

    [Grr, Gri, Gir, Gii] = d2Imis_dVdSg(Cg, V, lam, 1);

    Here the output matrices correspond to:
        Gsv = [ Gpr Gpi;
                Gqr Gqi ];
        Gpr = d/dVr (dImis_dPg.' * lam)
        Gpi = d/dVi (dImis_dPg.' * lam)
        Gqr = d/dVr (dImis_dQg.' * lam)
        Gqi = d/dVi (dImis_dQg.' * lam)
```

For more details on the derivations behind the derivative code used in MATPOWER, see:

```
[TN2]  R. D. Zimmerman, "AC Power Flows, Generalized OPF Costs and
       their Derivatives using Complex Matrix Notation", MATPOWER
       Technical Note 2, February 2010. [Online]. Available:
       https://matpower.org/docs/TN2-OPF-Derivatives.pdf
       doi: 10.5281/zenodo.3237866
[TN3]  B. Sereeter and R. D. Zimmerman, "Addendum to AC Power Flows and
       their Derivatives using Complex Matrix Notation: Nodal Current
       Balance," MATPOWER Technical Note 3, April 2018. [Online].
       Available: https://matpower.org/docs/TN3-More-OPF-Derivatives.pdf
       doi: 10.5281/zenodo.3237900
[TN4]  B. Sereeter and R. D. Zimmerman, "AC Power Flows and their
       Derivatives using Complex Matrix Notation and Cartesian
       Coordinate Voltages," MATPOWER Technical Note 4, April 2018.
       [Online]. Available: https://matpower.org/docs/TN4-OPF-Derivatives-Cartesian.
↪pdf
       doi: 10.5281/zenodo.3237909
```

d2Sbus_dV2

d2Sbus_dV2(*Ybus*, *V*, *lam*, *vcart*)

d2Sbus_dV2() (page 323) - Computes 2nd derivatives of power injection w.r.t. voltage.

```
The derivatives can be take with respect to polar or cartesian coordinates
of voltage, depending on the 4th argument.

[GAA, GAV, GVA, GVV] = D2SBUS_DV2(YBUS, V, LAM)
[GAA, GAV, GVA, GVV] = D2SBUS_DV2(YBUS, V, LAM, 0)

Returns 4 matrices containing the partial derivatives w.r.t. voltage angle
and magnitude of the product of a vector LAM with the 1st partial
derivatives of the complex bus power injections.

[GRR, GIR, GIR, GII] = D2SBUS_DV2(YBUS, V, LAM, 1)

Returns 4 matrices containing the partial derivatives w.r.t. real and
imaginary parts of voltage of the product of a vector LAM with the 1st
partial derivatives of the complex bus power injections.

Takes sparse bus admittance matrix YBUS, voltage vector V and nb x 1 vector
of multipliers LAM. Output matrices are sparse.

Examples:
    [Ybus, Yf, Yt] = makeYbus(baseMVA, bus, branch);
    [Gaa, Gav, Gva, Gvv] = d2Sbus_dV2(Ybus, V, lam);

    Here the output matrices correspond to:
        Gaa = d/dVa (dSbus_dVa.' * lam)
        Gav = d/dVm (dSbus_dVa.' * lam)
        Gva = d/dVa (dSbus_dVm.' * lam)
        Gvv = d/dVm (dSbus_dVm.' * lam)

    [Grr, Gri, Gir, Gii] = d2Sbus_dV2(Ybus, V, lam, 1);

    Here the output matrices correspond to:
        Grr = d/dVr (dSbus_dVr.' * lam)
        Gri = d/dVi (dSbus_dVr.' * lam)
        Gir = d/dVr (dSbus_dVi.' * lam)
        Gii = d/dVi (dSbus_dVi.' * lam)
```

For more details on the derivations behind the derivative code used in MATPOWER, see:

```
[TN2]  R. D. Zimmerman, "AC Power Flows, Generalized OPF Costs and
       their Derivatives using Complex Matrix Notation", MATPOWER
       Technical Note 2, February 2010. [Online]. Available:
       https://matpower.org/docs/TN2-OPF-Derivatives.pdf
       doi: 10.5281/zenodo.3237866
[TN4]  B. Sereeter and R. D. Zimmerman, "AC Power Flows and their
       Derivatives using Complex Matrix Notation and Cartesian
       Coordinate Voltages," MATPOWER Technical Note 4, April 2018.
       [Online]. Available: https://matpower.org/docs/TN4-OPF-Derivatives-Cartesian.
```

(continues on next page)

(continued from previous page)

```
↪pdf
      doi: 10.5281/zenodo.3237909
```

5.2.10 LP, QP, MILP & MIQP Solver Functions

miqps_matpower

miqps_matpower(*varargin*)

miqps_matpower() (page 324) - Deprecated, please use `miqps_master()` instead.

qps_matpower

qps_matpower(*varargin*)

qps_matpower() (page 324) - Deprecated, please use `qps_master()` instead.

5.2.11 Matrix Building Functions

makeB

makeB(*baseMVA*, *bus*, *branch*, *alg*)

makeB() (page 324) - Builds the FDPF matrices, B prime and B double prime.

```
[BP, BPP] = MAKEB(MPC, ALG)
[BP, BPP] = MAKEB(BASEMVA, BUS, BRANCH, ALG)

Returns the two matrices B prime and B double prime used in the fast
decoupled power flow. Does appropriate conversions to p.u. ALG is either
'FDXB' or 'FDBX', the corresponding value of MPOPT.pf.alg option
specifying the power flow algorithm.
Bus numbers must be consecutive beginning at 1 (i.e. internal ordering).

Note: For backward compatibility, ALG can also take on a value of
2 or 3, corresponding to values of the old PF_ALG option. This usage
is deprecated and will be removed in a future version.

Example:
    [Bp, Bpp] = makeB(baseMVA, bus, branch, 'FDXB');
```

See also `fdpf()`.

makeBdc

makeBdc(*baseMVA*, *bus*, *branch*)

makeBdc() (page 325) - Builds the B matrices and phase shift injections for DC power flow.

```
[BBUS, BF, PBUSINJ, PFINJ] = MAKEBDC(MPC)
[BBUS, BF, PBUSINJ, PFINJ] = MAKEBDC(BASEMVA, BUS, BRANCH)

Returns the B matrices and phase shift injection vectors needed for
a DC power flow. The bus real power injections are related to bus
voltage angles by
    P = BBUS * Va + PBUSINJ
The real power flows at the from end the lines are related to the bus
voltage angles by
    Pf = BF * Va + PFINJ
Does appropriate conversions to p.u.
Bus numbers must be consecutive beginning at 1 (i.e. internal ordering).

Example:
    [Bbus, Bf, Pbusinj, Pfinj] = makeBdc(baseMVA, bus, branch);
```

See also `dcpf()`.

makeJac

makeJac(*baseMVA*, *bus*, *branch*, *gen*, *fullJac*)

makeJac() (page 325) - Forms the power flow Jacobian.

```
J = MAKEJAC(MPC)
J = MAKEJAC(MPC, FULLJAC)
J = MAKEJAC(BASEMVA, BUS, BRANCH, GEN)
J = MAKEJAC(BASEMVA, BUS, BRANCH, GEN, FULLJAC)
[J, YBUS, YF, YT] = MAKEJAC(MPC)

Returns the power flow Jacobian and, optionally, the system admittance
matrices. Inputs can be a MATPOWER case struct or individual BASEMVA,
BUS, BRANCH and GEN values. Bus numbers must be consecutive beginning
at 1 (i.e. internal ordering). If the FULLJAC argument is present and
true, it returns the full Jacobian (sensitivities of all bus injections
w.r.t all voltage angles/magnitudes) as opposed to the reduced version
used in the Newton power flow updates. The units for all quantities are
in per unit with radians for voltage angles.

Note: This function builds the Jacobian from scratch, rebuilding the
      YBUS matrix in the process. You probably don't want to use this
      in performance critical code.
```

See also *makeYbus()* (page 328), `ext2int()`.

makeLODF

makeLODF(*branch*, *PTDF*, *mask_bridge*)

makeLODF() (page 326) - Builds the line outage distribution factor matrix.

```
LODF = MAKELODF(BRANCH, PTDF)
LODF = MAKELODF(MPC, PTDF)
LODF = MAKELODF(MPC, PTDF, MASK_BRIDGE)

Returns the DC model line outage distribution factor matrix corresponding
to a given PTDF matrix. The LODF matrix is nbr x nbr, where nbr is the
number of branches. If the optional MASK_BRIDGE argument is true, columns
corresponding to bridge branches (those whose removal result in
islanding) are replaced with NaN.

Example:
    H = makePTDF(mpc);
    LODF = makeLODF(branch, H);
    LODF = makeLODF(mpc, H);

    % mask bridge branches in LODF
    makeLODF(mpc, H, 1);
```

See also *makePTDF()* (page 326), *find_bridges()* (page 334).

makePTDF

makePTDF(*baseMVA*, *bus*, *branch*, *slack*, *bus_idx*)

makeLODF() (page 326) - Builds the DC PTDF matrix for a given choice of slack.

```
H = MAKEPTDF(MPC)
H = MAKEPTDF(MPC, SLACK)
H = MAKEPTDF(MPC, SLACK, TXFR)
H = MAKEPTDF(MPC, SLACK, BUS_IDX)
H = MAKEPTDF(BASEMVA, BUS, BRANCH)
H = MAKEPTDF(BASEMVA, BUS, BRANCH, SLACK)
H = MAKEPTDF(BASEMVA, BUS, BRANCH, SLACK, TXFR)
H = MAKEPTDF(BASEMVA, BUS, BRANCH, SLACK, BUS_IDX)

Returns the DC PTDF matrix for a given choice of slack. The matrix is
nbr x nb, where nbr is the number of branches and nb is the number of
buses. The SLACK can be a scalar (single slack bus) or an nb x 1 column
vector of weights specifying the proportion of the slack taken up at each
bus. If the SLACK is not specified the reference bus is used by default.
Bus numbers must be consecutive beginning at 1 (i.e. internal ordering).

For convenience, SLACK can also be an nb x nb matrix, where each
column specifies how the slack should be handled for injections
at that bus. This option only applies when computing the full
PTDF matrix (i.e. when TXFR and BUS_IDX are not provided.)
```

(continues on next page)

(continued from previous page)

```
If TXFR is supplied it must be a matrix (or vector) with nb rows whose
columns each sum to zero, where each column defines a specific (slack
independent) transfer. E.g. if k-th transfer is from bus i to bus j,
TXFR(i, k) = 1 and TXFR(j, k) = -1. In this case H has the same number
of columns as TXFR.

If BUS_IDX is supplied, it contains a column vector of bus indices.
The columns of H correspond to these indices, but they are computed
individually rather than computing the full PTDF matrix and selecting
the desired columns.

Examples:
    H = makePTDF(mpc);
    H = makePTDF(baseMVA, bus, branch, 1);
    slack = rand(size(bus, 1), 1);
    H = makePTDF(mpc, slack);

    % for transfer from bus i to bus j
    txfr = zeros(nb, 1); txfr(i) = 1; txfr(j) = -1;
    H = makePTDF(mpc, slack, txfr);

    % for buses i and j only
    H = makePTDF(mpc, slack, [i;j]);
```

See also *makeLODF()* (page 326).

makeSbus

makeSbus(*baseMVA*, *bus*, *gen*, *mpopt*, *Vm*, *Sg*)

makeSbus() (page 327) - Builds the vector of complex bus power injections.

```
SBUS = MAKESBUS(BASEMVA, BUS, GEN)
SBUS = MAKESBUS(BASEMVA, BUS, GEN, MPOPT, VM)
SBUS = MAKESBUS(BASEMVA, BUS, GEN, MPOPT, VM, SG)
returns the vector of complex bus power injections, that is, generation
minus load. Power is expressed in per unit. If the MPOPT and VM arguments
are present it evaluates any ZIP loads based on the provided voltage
magnitude vector. If VM is empty, it assumes nominal voltage. If SG is
provided, it is a complex ng x 1 vector of generator power injections in
p.u., and overrides the PG and QG columns in GEN, using GEN only for
connectivity information.

[SBUS, DSBUS_DVM] = MAKESBUS(BASEMVA, BUS, GEN, MPOPT, VM)
With two output arguments, it computes the partial derivative of the
bus injections with respect to voltage magnitude, leaving the first
return value SBUS empty. If VM is empty, it assumes no voltage dependence
and returns a sparse zero matrix.
```

See also *makeYbus()* (page 328).

makeSdzip

makeSdzip(*baseMVA*, *bus*, *mpopt*)

makeSdzip() (page 328) - Builds vectors of nominal complex bus power demands for ZIP loads.

```
SD = MAKESDZIP(BASEMVA, BUS, MPOPT) returns a struct with three fields,
each an nb x 1 vectors. The fields 'z', 'i' and 'p' correspond to the
nominal p.u. complex power (at 1 p.u. voltage magnitude) of the constant
impedance, constant current, and constant power portions, respectively of
the ZIP load model.

Example:
    Sd = makeSdzip(baseMVA, bus, mpopt);
```

makeYbus

makeYbus(*baseMVA*, *bus*, *branch*)

makeYbus() (page 328) - Builds the bus admittance matrix and branch admittance matrices.

```
[YBUS, YF, YT] = MAKEYBUS(MPC)
[YBUS, YF, YT] = MAKEYBUS(BASEMVA, BUS, BRANCH)

Returns the full bus admittance matrix (i.e. for all buses) and the
matrices YF and YT which, when multiplied by a complex voltage vector,
yield the vector currents injected into each line from the "from" and
"to" buses respectively of each line. Does appropriate conversions to p.u.
Inputs can be a MATPOWER case struct or individual BASEMVA, BUS and
BRANCH values. Bus numbers must be consecutive beginning at 1
(i.e. internal ordering).
```

See also *makeJac()* (page 325), *makeSbus()* (page 327), `ext2int()`.

5.2.12 Utility Functions

apply_changes

apply_changes(*label*, *mpc*, *chgtab*)

apply_changes() (page 328) - Applies a set of changes to a MATPOWER case

```
mpc_modified = apply_changes(label, mpc_original, chgtab)

Applies the set of changes identified by LABEL to the case in MPC, where
the change sets are specified in CHGTAB.

LABEL is an integer which identifies the set of changes of interest

MPC is a MATPOWER case struct with at least fields bus, gen and branch
```

(continues on next page)

(continued from previous page)

```
CHGTAB is the table of changes that lists the individual changes required
by each change set, one "change" per row (multiple rows or changes
allowed for each change set). Type "help idx_ct" for more complete
information about the format.
1st column: change set label, integer > 0
2nd column: change set probability
3rd column: table to be modified (1:bus, 2:gen, 3:branch) or
            4: bus area changes, apply to all gens/buses/branches in
            a given area; 5: gen table area changes apply to all
            generators in a given area; or 6: branch area changes apply
            to all branches connected to buses in a given area.
4th column: row of table to be modified (if 3rd col is 1-3),
            or area number for overall changes (if 3rd column is 4-6).
5th column: column of table to be modified. It is best to use the
            named column index defined in the corresponding idx_bus,
            idx_gen, idx_branch or idx_cost M-files in MATPOWER.
6th column: type of change: 1: absolute (replace)
                            2: relative (multiply by factor)
                            3: additive (add to value)
7th column: new value or multiplicative or additive factor

Examples:

chgtab = [ ...
    1   0.1   CT_TGEN       2  GEN_STATUS     CT_REP  0;
    2   0.05  CT_TGEN       3  PMAX           CT_REP  100;
    3   0.2   CT_TBRCH      2  BR_STATUS      CT_REP  0;
    4   0.1   CT_TAREALOAD  2  CT_LOAD_ALL_P  CT_REL  1.1;
 ];

Description of each change set:
1. Turn off generator 2, 10% probability.
2. Set generator 3's max output to 100 MW, 5% probability.
3. Take branch 2 out of service, 20% probability.
4. Scale all loads in area 2 (real & reactive, fixed and dispatchable)
   by a factor of 1.1, 10% probability.
```

See also *idx_ct()* (page 341).

bustypes

bustypes(*bus*, *gen*)

bustypes() - Builds index lists for each type of bus (REF, PV, PQ).

```
[REF, PV, PQ] = BUSTYPES(BUS, GEN)
Generators with "out-of-service" status are treated as PQ buses with
zero generation (regardless of Pg/Qg values in gen). Expects BUS and
GEN have been converted to use internal consecutive bus numbering.
```

calc_branch_angle

calc_branch_angle(*mpc*)

calc_branch_angle() (page 330) - Calculate branch angle differences across active branches

```
DELTA = CALC_BRANCH_ANGLE(MPC)

Calculates the angle difference (in degrees) across all active branches
in the MATPOWER case. Angles are calculated as the difference between
the FROM bus and the TO bus.

Input:
    MPC   - MATPOWER case struct (can have external bus numbering)

Output:
    DELTA - nl x 1 vector of branch angle differences Af - At, where
            Af and At are vectors of voltage angles at "from" and "to"
            ends of each line respectively. DELTA is 0 for out-of-service
            branches.
```

See also *toggle_softlims()* (page 307).

case_info

case_info(*mpc*, *fd*)

case_info() (page 330) - Prints information about islands in a network.

```
CASE_INFO(MPC)
CASE_INFO(MPC, FD)
[GROUPS, ISOLATED] = CASE_INFO(...)

Prints out detailed information about a MATPOWER case. Optionally prints
to an open file, whose file identifier, as returned by FOPEN, is
specified in the optional second parameter FD. Optional return arguments
include GROUPS and ISOLATED buses, as returned by FIND_ISLANDS.
```

compare_case

compare_case(*mpc1*, *mpc2*)

compare_case() (page 330) - Compares the bus, gen, branch matrices of 2 MATPOWER cases.

```
COMPARE_CASE(MPC1, MPC2)
Compares the bus, branch and gen matrices of two MATPOWER cases and
prints a summary of the differences. For each column of the matrix it
prints the maximum of any non-zero differences.
```

define_constants

define_constants()

define_constants - Defines useful constants for indexing data, etc.

```
This is simply a convenience script that defines the constants
listed below, consisting primarily of named indices for the
columns of the data matrices: bus, branch, gen and gencost.
This includes input columns defined in caseformat as well as
columns that are added in the power flow and OPF output. It also
defines constants for the change tables used by apply_changes().

bus:
   PQ, PV, REF, NONE, BUS_I, BUS_TYPE, PD, QD, GS, BS, BUS_AREA, VM,
   VA, BASE_KV, ZONE, VMAX, VMIN, LAM_P, LAM_Q, MU_VMAX, MU_VMIN

branch:
   F_BUS, T_BUS, BR_R, BR_X, BR_B, RATE_A, RATE_B, RATE_C,
   TAP, SHIFT, BR_STATUS, PF, QF, PT, QT, MU_SF, MU_ST,
   ANGMIN, ANGMAX, MU_ANGMIN, MU_ANGMAX

gen:
   GEN_BUS, PG, QG, QMAX, QMIN, VG, MBASE, GEN_STATUS, PMAX, PMIN,
   MU_PMAX, MU_PMIN, MU_QMAX, MU_QMIN, PC1, PC2, QC1MIN, QC1MAX,
   QC2MIN, QC2MAX, RAMP_AGC, RAMP_10, RAMP_30, RAMP_Q, APF

gencost:
   PW_LINEAR, POLYNOMIAL, MODEL, STARTUP, SHUTDOWN, NCOST, COST

change tables:
    CT_LABEL, CT_PROB, CT_TABLE, CT_TBUS, CT_TGEN, CT_TBRCH, CT_TAREABUS,
    CT_TAREAGEN, CT_TAREABRCH, CT_ROW, CT_COL, CT_CHGTYPE, CT_REP,
    CT_REL, CT_ADD, CT_NEWVAL, CT_TLOAD, CT_TAREALOAD, CT_LOAD_ALL_PQ,
    CT_LOAD_FIX_PQ, CT_LOAD_DIS_PQ, CT_LOAD_ALL_P, CT_LOAD_FIX_P,
    CT_LOAD_DIS_P, CT_TGENCOST, CT_TAREAGENCOST, CT_MODCOST_F,
    CT_MODCOST_X

See CASEFORMAT, IDX_BUS, IDX_BRCH, IDX_GEN, IDX_COST and IDX_CT for
details on the meaning of these constants. Internally
DEFINE_CONSTANTS calls IDX_BUS, IDX_BRCH, IDX_GEN, IDX_COST and IDX_CT.
In performance sensitive code, such as internal MATPOWER functions
that are called frequently, it is preferred to call these
functions directly rather than using the DEFINE_CONSTANTS script,
which is less efficient.

This script is included for convenience for interactive use or
for high-level code where maximum performance is not a concern.
```

extract_islands

extract_islands(*mpc*, *varargin*)

extract_islands() (page 332) - Extracts each island in a network with islands.

```
MPC_ARRAY = EXTRACT_ISLANDS(MPC)
MPC_ARRAY = EXTRACT_ISLANDS(MPC, GROUPS)
MPC_K = EXTRACT_ISLANDS(MPC, K)
MPC_K = EXTRACT_ISLANDS(MPC, GROUPS, K)
MPC_K = EXTRACT_ISLANDS(MPC, K, CUSTOM)
MPC_K = EXTRACT_ISLANDS(MPC, GROUPS, K, CUSTOM)

Returns a cell array of MATPOWER case structs for each island in
the input case struct. If the optional second argument is a cell
array GROUPS it is assumed to be a cell array of vectors of bus
indices for each island (as returned by FIND_ISLANDS). Providing
the GROUPS avoids the need for another traversal of the network
connectivity and can save a significant amount of time on very
large systems. If an additional argument K is included, it indicates
which island(s) to return and the return value is a single case
struct, rather than a cell array. If K is a scalar or vector, it
it specifies the index(indices) of the island(s) to include in
the resulting case file. K can also be the string 'all' which
will include all islands. This is the same as simply eliminating
all isolated buses.

A final optional argument CUSTOM is a struct that can be used to
indicate custom fields of MPC from which to extract data
corresponding to buses generators, branches or DC lines. It has
the following structure:

    CUSTOM.<ORDERING>{DIM} = FIELDS

<ORDERING> is either 'bus', 'gen', 'branch' or 'dcline' and
indicates that dimension DIM of FIELDS has dimensions
corresponding to this <ORDERING> and should have the appropriate
dimension extracted as well. FIELDS is a cell array, where
each element is either a single string (field name of MPC) or
a cell array of strings (nested fields of MPC).

Examples:
    Extract each island into it's own case struct:
        mpc_list = extract_islands(mpc);

    Extract the 2nd (that is, 2nd largest) island:
        mpc2 = extract_islands(mpc, 2);

    Extract the first and 3rd islands without a re-traverals of the
    network:
        groups = find_islands(mpc);
        mpc1 = extract_islands(mpc, groups, 1);
        mpc3 = extract_islands(mpc, groups, 3);
```

(continues on next page)

(continued from previous page)

```
    Extract the 2nd island, including custom fields, where
    mpc.bus_label{b} contains a label for bus b, and mpc.gen_name{g},
    mpc.emissions.rate(g, :), and mpc.genloc(:, g) contain,
    respectively, the generator's name, emission rates and
    location coordinates:
        custom.bus{1} = {'bus_label'};
        custom.gen{1} = {'gen_name', {'emissions', 'rate'}};
        custom.gen{2} = {'genloc'};
        mpc = extract_islands(mpc, 1, custom);

    Note: Fields bus_name, gentype and genfuel are handled automatically
          and do not need to be included in custom.
```

See also *find_islands()* (page 334), *case_info()* (page 330), *connected_components()* (page 354).

feval_w_path

feval_w_path(*fpath*, *fname*, *varargin*)

feval_w_path() (page 333) - Calls a function located by the specified path.

```
FEVAL_W_PATH(FPATH, F, x1, ..., xn)
[y1, ..., yn] = FEVAL_W_PATH(FPATH, F, x1, ..., xn)

Identical to the built-in FEVAL, except that the function F need not be
in the MATLAB/Octave path if it is defined in a file in the path specified
by FPATH. Assumes that the current working directory is always first in
the MATLAB/Octave path.

Inputs:
    FPATH - string containing the path to the function to be called,
            can be absolute or relative to current working directory
    F - string containing the name of the function to be called
    x1, ..., xn - variable number of input arguments to be passed to F

Output:
    y1, ..., yn - variable number arguments returned by F (depending on
                  the caller)

Note that any sub-functions located in the directory specified by FPATH
will also be available to be called by the F function.

Examples:
    % Assume '/opt/testfunctions' is NOT in the MATLAB/Octave path, but
    % /opt/testfunctions/mytestfcn.m defines the function mytestfcn()
    % which takes 2 input arguments and outputs 1 return argument.
    y = feval_w_path('/opt/testfunctions', 'mytestfcn', x1, x2);
```

find_bridges

find_bridges(*mpc*)

find_bridges() (page 334) - Finds bridges in a network.

```
[ISLANDS, BRIDGES, NONBRIDGES] = FIND_BRIDGES(MPC)

Returns the islands, bridges and non-bridges in a network.
Bridges are filtered out using Tarjan's algorithm. A BRIDGE is a branch
whose removal breaks the island to multiple parts. The return value BRIDGES
is a cell array of vectors of the bus indices for each island.
```

find_islands

find_islands(*mpc*)

find_islands() (page 334) - Finds islands in a network.

```
GROUPS = FIND_ISLANDS(MPC)
[GROUPS, ISOLATED] = FIND_ISLANDS(MPC)

Returns the islands in a network. The return value GROUPS
is a cell array of vectors of the bus indices for each island.
The second and optional return value ISOLATED is a vector of
indices of isolated buses that have no connecting branches.
```

See also *extract_islands()* (page 332), *connected_components()* (page 354).

genfuels

genfuels()

genfuels() - Return list of standard values for generator fuel types.

```
GF = GENFUELS()

Returns a cell array of strings containing the following standard
generator fuel types for use in the optional MPC.GENFUEL field of the
MATPOWER case struct. This is to be considered an unordered list,
where the position of a particular fuel type in the list is not
defined and is therefore subject to change.

    biomass     - Biomass
    coal        - Coal
    dfo         - Distillate Fuel Oil (Diesel, FO1, FO2, FO4)
    geothermal  - Geothermal
    hydro       - Hydro
    hydrops     - Hydro Pumped Storage
    jetfuel     - Jet Fuel
    lng         - Liquefied Natural Gas
```

(continues on next page)

(continued from previous page)

```
    ng          - Natural Gas
    nuclear     - Nuclear
    oil         - Unspecified Oil
    refuse      - Refuse, Municipal Solid Waste
    rfo         - Residual Fuel Oil (FO5, FO6)
    solar       - Solar
    syncgen     - Synchronous Condensor
    wasteheat   - Waste Heat
    wind        - Wind
    wood        - Wood or Wood Waste
    other       - Other
    unknown     - Unknown
    dl          - Dispatchable Load
    ess         - Energy Storage System

Example:
    if ~ismember(mpc.genfuel{k}, genfuels())
        error('unknown fuel type');
    end
```

See also `gentypes()`, `savecase()`.

gentypes

gentypes()

`gentypes()` - Return list of standard values for generator unit types.

```
GT = GENTYPES()

Returns a cell array of strings containing the following standard
two character generator unit types for use in the optional MPC.GENTYPE
field of the MATPOWER case struct. This is to be considered an unordered
list, where the position of a particular fuel type in the list is not
defined and is therefore subject to change.

From Form EIA-860 Instructions, Table 2. Prime Mover Codes and Descriptions
https://www.eia.gov/survey/form/eia_860/instructions.pdf
    BA  - Energy Storage, Battery
    CE  - Energy Storage, Compressed Air
    CP  - Energy Storage, Concentrated Solar Power
    FW  - Energy Storage, Flywheel
    PS  - Hydraulic Turbine, Reversible (pumped storage)
    ES  - Energy Storage, Other
    ST  - Steam Turbine, including nuclear, geothermal and solar steam
            (does not include combined cycle)
    GT  - Combustion (Gas) Turbine (includes jet engine design)
    IC  - Internal Combustion Engine (diesel, piston, reciprocating)
    CA  - Combined Cycle Steam Part
    CT  - Combined Cycle Combustion Turbine Part
            (type of coal or solid must be reported as energy source
```

(continues on next page)

(continued from previous page)

```
            for integrated coal gasification)
    CS  - Combined Cycle Single Shaft
            (combustion turbine and steam turbine share a single generator)
    CC  - Combined Cycle Total Unit
            (use only for plants/generators that are in planning stage,
            for which specific generator details cannot be provided)
    HA  - Hydrokinetic, Axial Flow Turbine
    HB  - Hydrokinetic, Wave Buoy
    HK  - Hydrokinetic, Other
    HY  - Hydroelectric Turbine (includes turbines associated with
            delivery of water by pipeline)
    BT  - Turbines Used in a Binary Cycle
            (including those used for geothermal applications)
    PV  - Photovoltaic
    WT  - Wind Turbine, Onshore
    WS  - Wind Turbine, Offshore
    FC  - Fuel Cell
    OT  - Other
Additional codes (some from PowerWorld)
    UN  - Unknown
    JE  - Jet Engine
    NB  - ST - Boiling Water Nuclear Reactor
    NG  - ST - Graphite Nuclear Reactor
    NH  - ST - High Temperature Gas Nuclear Reactor
    NP  - ST - Pressurized Water Nuclear Reactor
    IT  - Internal Combustion Turbo Charged
    SC  - Synchronous Condenser
    DC  - represents DC ties
    MP  - Motor/Pump
    W1  - Wind Turbine, Type 1
    W2  - Wind Turbine, Type 2
    W3  - Wind Turbine, Type 3
    W4  - Wind Turbine, Type 4
    SV  - Static Var Compensator
    DL  - Dispatchable Load

Example:
    if ~ismember(mpc.gentype{k}, gentypes())
        error('unknown generator unit type');
    end
```

See also `genfuels()`, `savecase()`.

get_losses

get_losses(*baseMVA*, *bus*, *branch*)

get_losses() (page 337) - Returns series losses (and reactive injections) per branch.

```
LOSS = GET_LOSSES(RESULTS)
LOSS = GET_LOSSES(BASEMVA, BUS, BRANCH)

[LOSS, CHG] = GET_LOSSES(RESULTS)
[LOSS, FCHG, TCHG] = GET_LOSSES(RESULTS)
[LOSS, FCHG, TCHG, DLOSS_DV] = GET_LOSSES(RESULTS)
[LOSS, FCHG, TCHG, DLOSS_DV, DCHG_DVM] = GET_LOSSES(RESULTS)

Computes branch series losses, and optionally reactive injections from
line charging, as functions of bus voltages and branch parameters, using the
following formulae:

    loss = abs( Vf / tau - Vt ) ^ 2 / (Rs - j Xs)
    fchg = abs( Vf / tau ) ^ 2 * Bc / 2
    tchg = abs( Vt ) ^ 2 * Bc / 2

Optionally, computes the partial derivatives of the line losses with
respect to voltage angles and magnitudes.

Input:
    RESULTS - a MATPOWER case struct with bus voltages corresponding to
              a valid power flow solution.
              (Can optionally be specified as individual fields BASEMVA,
               BUS, and BRANCH.)

Output(s):
    LOSS - complex NL x 1 vector of losses (in MW), where NL is the number
           of branches in the system, representing only the losses in the
           series impedance element of the PI model for each branch.
    CHG -  NL x 1 vector of total reactive injection for each line
           (in MVAr), representing the line charging injections of both
           of the shunt elements of PI model for each branch.
    FCHG - Same as CHG, but for the element at the "from" end of the
           branch only.
    TCHG - Same as CHG, but for the element at the "to" end of the branch.
    DLOSS_DV - Struct with partial derivatives of LOSS with respect to bus
           voltages, with fields:
        .a  - Partial with respect to bus voltage angles.
        .m  - Partial with respect to bus voltage magnitudes.
    DCHG_DVM - Struct with partial derivatives of FCHG and TCHG with
           respect to bus voltage magnitudes, with fields:
        .f  - Partial of FCHG with respect to bus voltage magnitudes.
        .t  - Partial of TCHG with respect to bus voltage magnitudes.

Example:
    results = runpf(mycase);
    [loss, chg] = get_losses(results);
    total_system_real_losses = sum(real(loss));
```

(continues on next page)

(continued from previous page)

```
    total_system_reac_losses = sum(imag(loss)) - sum(chg);

    [loss, fchg, tchg, dloss_dV] = get_losses(results);
```

hasPQcap

hasPQcap(*gen*, *hilo*)

hasPQcap() (page 338) - Checks for P-Q capability curve constraints.

```
TORF = HASPQCAP(GEN, HILO) returns a column vector of 1's and 0's. The 1's
correspond to rows of the GEN matrix which correspond to generators which
have defined a capability curve (with sloped upper and/or lower bound on
Q) and require that additional linear constraints be added to the OPF.

The GEN matrix in version 2 of the MATPOWER case format includes columns
for specifying a P-Q capability curve for a generator defined as the
intersection of two half-planes and the box constraints on P and Q. The
two half planes are defined respectively as the area below the line
connecting (Pc1, Qc1max) and (Pc2, Qc2max) and the area above the line
connecting (Pc1, Qc1min) and (Pc2, Qc2min).

If the optional 2nd argument is 'U' this function returns true only for
rows corresponding to generators that require the upper constraint on Q.
If it is 'L', only for those requiring the lower constraint. If the 2nd
argument is not specified or has any other value it returns true for rows
corresponding to gens that require either or both of the constraints.

It is smart enough to return true only if the corresponding linear
constraint is not redundant w.r.t the box constraints.
```

idx_brch

idx_brch()

idx_brch() (page 338) - Defines constants for named column indices to branch matrix.

```
Example:

[F_BUS, T_BUS, BR_R, BR_X, BR_B, RATE_A, RATE_B, RATE_C, ...
TAP, SHIFT, BR_STATUS, PF, QF, PT, QT, MU_SF, MU_ST, ...
ANGMIN, ANGMAX, MU_ANGMIN, MU_ANGMAX] = idx_brch;

Some examples of usage, after defining the constants using the line above,
are:

 branch(4, BR_STATUS) = 0;              % take branch 4 out of service
 Ploss = branch(:, PF) + branch(:, PT); % compute real power loss vector
```

(continues on next page)

(continued from previous page)

```
The index, name and meaning of each column of the branch matrix is given
below:

columns 1-11 must be included in input matrix (in case file)
 1  F_BUS       f, from bus number
 2  T_BUS       t, to bus number
 3  BR_R        r, resistance (p.u.)
 4  BR_X        x, reactance (p.u.)
 5  BR_B        b, total line charging susceptance (p.u.)
 6  RATE_A      rateA, MVA rating A (long term rating)
 7  RATE_B      rateB, MVA rating B (short term rating)
 8  RATE_C      rateC, MVA rating C (emergency rating)
 9  TAP         ratio, transformer off nominal turns ratio
 10 SHIFT       angle, transformer phase shift angle (degrees)
 11 BR_STATUS   initial branch status, 1 - in service, 0 - out of service
 12 ANGMIN      minimum angle difference, angle(Vf) - angle(Vt) (degrees)
 13 ANGMAX      maximum angle difference, angle(Vf) - angle(Vt) (degrees)
                (The voltage angle difference is taken to be unbounded below
                 if ANGMIN < -360 and unbounded above if ANGMAX > 360.
                 If both parameters are zero, it is unconstrained.)

columns 14-17 are added to matrix after power flow or OPF solution
they are typically not present in the input matrix
 14 PF          real power injected into "from" end of branch (MW)
 15 QF          reactive power injected into "from" end of branch (MVAr)
 16 PT          real power injected into "to" end of branch (MW)
 17 QT          reactive power injected into "to" end of branch (MVAr)

columns 18-21 are added to matrix after OPF solution
they are typically not present in the input matrix
                (assume OPF objective function has units, u)
 18 MU_SF       Kuhn-Tucker multiplier on MVA limit at "from" bus (u/MVA)
 19 MU_ST       Kuhn-Tucker multiplier on MVA limit at "to" bus (u/MVA)
 20 MU_ANGMIN   Kuhn-Tucker multiplier lower angle difference limit (u/degree)
 21 MU_ANGMAX   Kuhn-Tucker multiplier upper angle difference limit (u/degree)
```

See also `define_constants`.

idx_bus

idx_bus()

idx_bus() (page 339) - Defines constants for named column indices to bus matrix.

```
Example:

[PQ, PV, REF, NONE, BUS_I, BUS_TYPE, PD, QD, GS, BS, BUS_AREA, VM, ...
VA, BASE_KV, ZONE, VMAX, VMIN, LAM_P, LAM_Q, MU_VMAX, MU_VMIN] = idx_bus;

Some examples of usage, after defining the constants using the line above,
are:
```

(continues on next page)

(continued from previous page)

```
 Pd = bus(4, PD);       % get the real power demand at bus 4
 bus(:, VMIN) = 0.95;   % set the min voltage magnitude to 0.95 at all buses

The index, name and meaning of each column of the bus matrix is given
below:

columns 1-13 must be included in input matrix (in case file)
 1  BUS_I       bus number (positive integer)
 2  BUS_TYPE    bus type (1 = PQ, 2 = PV, 3 = ref, 4 = isolated)
 3  PD          Pd, real power demand (MW)
 4  QD          Qd, reactive power demand (MVAr)
 5  GS          Gs, shunt conductance (MW demanded at V = 1.0 p.u.)
 6  BS          Bs, shunt susceptance (MVAr injected at V = 1.0 p.u.)
 7  BUS_AREA    area number, (positive integer)
 8  VM          Vm, voltage magnitude (p.u.)
 9  VA          Va, voltage angle (degrees)
 10 BASE_KV     baseKV, base voltage (kV)
 11 ZONE        zone, loss zone (positive integer)
 12 VMAX        maxVm, maximum voltage magnitude (p.u.)
 13 VMIN        minVm, minimum voltage magnitude (p.u.)

columns 14-17 are added to matrix after OPF solution
they are typically not present in the input matrix
                (assume OPF objective function has units, u)
 14 LAM_P       Lagrange multiplier on real power mismatch (u/MW)
 15 LAM_Q       Lagrange multiplier on reactive power mismatch (u/MVAr)
 16 MU_VMAX     Kuhn-Tucker multiplier on upper voltage limit (u/p.u.)
 17 MU_VMIN     Kuhn-Tucker multiplier on lower voltage limit (u/p.u.)

additional constants, used to assign/compare values in the BUS_TYPE column
 1  PQ    PQ bus
 2  PV    PV bus
 3  REF   reference bus
 4  NONE  isolated bus
```

See also `define_constants`.

idx_cost

idx_cost()

idx_cost() (page 340) - Defines constants for named column indices to `gencost` matrix.

```
Example:

[PW_LINEAR, POLYNOMIAL, MODEL, STARTUP, SHUTDOWN, NCOST, COST] = idx_cost;

Some examples of usage, after defining the constants using the line above,
are:
```

(continues on next page)

(continued from previous page)

```
 start = gencost(4, STARTUP);       % get startup cost of generator 4
 gencost(2, [MODEL, NCOST:COST+1]) = [ POLYNOMIAL 2 30 0 ];
 % set the cost of generator 2 to a linear function COST = 30 * Pg

The index, name and meaning of each column of the gencost matrix is given
below:

columns 1-5
 1  MODEL       cost model, 1 = piecewise linear, 2 = polynomial
 2  STARTUP     startup cost in US dollars
 3  SHUTDOWN    shutdown cost in US dollars
 4  NCOST       number N = n+1 of data points to follow defining an
                n-segment piecewise linear cost function, or of cost
                coefficients defining an n-th order polynomial cost function
 5  COST        parameters defining total cost function f(p) begin in
                this column
                (MODEL = 1) : p1, f1, p2, f2, ..., pN, fN
                    where p1 < p2 < ... < pN and the cost f(p) is defined
                    by the coordinates (p1,f1), (p2,f2), ..., (pN,fN) of
                    the end/break-points of the piecewise linear cost fcn
                (MODEL = 2) : cn, ..., c1, c0
                    N coefficients of an n-th order polynomial cost
                    function, starting with highest order, where cost is
                    f(p) = cn*p^n + ... + c1*p + c0

additional constants, used to assign/compare values in the MODEL column
 1  PW_LINEAR   piecewise linear generator cost model
 2  POLYNOMIAL  polynomial generator cost model
```

See also `define_constants`.

idx_ct

idx_ct()

idx_ct() (page 341) - Defines constants for named column indices to changes table

```
[CT_LABEL, CT_PROB, CT_TABLE, CT_TBUS, CT_TGEN, CT_TBRCH, CT_TAREABUS, ...
CT_TAREAGEN, CT_TAREABRCH, CT_ROW, CT_COL, CT_CHGTYPE, CT_REP, ...
CT_REL, CT_ADD, CT_NEWVAL, CT_TLOAD, CT_TAREALOAD, CT_LOAD_ALL_PQ, ...
CT_LOAD_FIX_PQ, CT_LOAD_DIS_PQ, CT_LOAD_ALL_P, CT_LOAD_FIX_P, ...
CT_LOAD_DIS_P, CT_TGENCOST, CT_TAREAGENCOST, CT_MODCOST_F, ...
CT_MODCOST_X] = idx_ct;

CT_LABEL: column of changes table where the change set label is stored

CT_PROB:  column of changes table where the probability of the
          change set is stored

CT_TABLE: column of the changes table where the type of system data
        table to be modified is stored;
```

(continues on next page)

(continued from previous page)

```
        type CT_TBUS indicates bus table
        type CT_TGEN indicates gen table
        type CT_TBRCH indicates branch table
        type CT_TLOAD indicates a load modification (bus and/or gen tables)
        type CT_TAREABUS indicates area-wide change in bus table
        type CT_TAREAGEN indicates area-wide change in generator table
        type CT_TAREABRCH indicates area-wide change in branch table
        type CT_TAREALOAD indicates area-wide change in load
                          (bus and/or gen tables)

CT_ROW: column of changes table where the row number in the data
        table to be modified is stored. A value of "0" in this column
        has the special meaning "apply to all rows".  For an area-wide
        type of change, the area number is stored here instead.

CT_COL: column of changes table where the number of the column in
        the data table to be modified is stored
        For CT_TLOAD and CT_TAREALOAD, the value entered in this column
        is one of the following codes (or its negative), rather than
        a column index:
        type CT_LOAD_ALL_PQ modify all loads, real & reactive
        type CT_LOAD_FIX_PQ modify only fixed loads, real & reactive
        type CT_LOAD_DIS_PQ modify only dispatchable loads, real & reactive
        type CT_LOAD_ALL_P modify all loads, real only
        type CT_LOAD_FIX_P modify only fixed loads, real only
        type CT_LOAD_DIS_P modify only dispatchable loads, real only
        If the negative of one of these codes is used, then any affected
        dispatchable loads will have their costs scaled as well.
        For CT_TGENCOST and CT_TAREAGENCOST, in addition to an actual
        column index, this value can also take one of the following
        codes to indicate a scaling (CT_REL change type) or shifting
        (CT_ADD change type) of the specified cost functions:
        type CT_MODCOST_F scales or shifts the cost function vertically
        type CT_MODCOST_X scales or shifts the cost function horizontally
        See MODCOST.

CT_CHGTYPE: column of changes table where the type of change to
        be made is stored:
        type CT_REP replaces old value by value in CT_NEWVAL column
        type CT_REL multiplies old value by factor in CT_NEWVAL column
        type CT_ADD adds value in CT_NEWVAL column to old value
```

See also *apply_changes()* (page 328), modcost().

idx_dcline

idx_dcline()

idx_dcline() (page 343) - Defines constants for named column indices to dcline matrix.

```
Example:

c = idx_dcline;

Some examples of usage, after defining the constants using the line above,
are:

 mpc.dcline(4, c.BR_STATUS) = 0;        % take dcline 4 out of service

The index, name and meaning of each column of the dcline matrix is given
below:

columns 1-17 must be included in input matrix (in case file)
 1  F_BUS     f, "from" bus number
 2  T_BUS     t,  "to"  bus number
 3  BR_STATUS initial dcline status, 1 - in service, 0 - out of service
 4  PF        MW flow at "from" bus ("from" -> "to")
 5  PT        MW flow at  "to"  bus ("from" -> "to")
 6  QF        MVAr injection at "from" bus ("from" -> "to")
 7  QT        MVAr injection at  "to"  bus ("from" -> "to")
 8  VF        voltage setpoint at "from" bus (p.u.)
 9  VT        voltage setpoint at  "to"  bus (p.u.)
10  PMIN      lower limit on PF (MW flow at "from" end)
11  PMAX      upper limit on PF (MW flow at "from" end)
12  QMINF     lower limit on MVAr injection at "from" bus
13  QMAXF     upper limit on MVAr injection at "from" bus
14  QMINT     lower limit on MVAr injection at  "to"  bus
15  QMAXT     upper limit on MVAr injection at  "to"  bus
16  LOSS0     constant term of linear loss function (MW)
17  LOSS1     linear term of linear loss function (MW/MW)
              (loss = LOSS0 + LOSS1 * PF)

columns 18-23 are added to matrix after OPF solution
they are typically not present in the input matrix
              (assume OPF objective function has units, u)
18  MU_PMIN   Kuhn-Tucker multiplier on lower flow lim at "from" bus (u/MW)
19  MU_PMAX   Kuhn-Tucker multiplier on upper flow lim at "from" bus (u/MW)
20  MU_QMINF  Kuhn-Tucker multiplier on lower VAr lim at "from" bus (u/MVAr)
21  MU_QMAXF  Kuhn-Tucker multiplier on upper VAr lim at "from" bus (u/MVAr)
22  MU_QMINT  Kuhn-Tucker multiplier on lower VAr lim at  "to"  bus (u/MVAr)
23  MU_QMAXT  Kuhn-Tucker multiplier on upper VAr lim at  "to"  bus (u/MVAr)
```

See also *toggle_dcline()* (page 304).

idx_gen

idx_gen()

idx_gen() (page 344) - Defines constants for named column indices to gen matrix.

```
Example:

[GEN_BUS, PG, QG, QMAX, QMIN, VG, MBASE, GEN_STATUS, PMAX, PMIN, ...
MU_PMAX, MU_PMIN, MU_QMAX, MU_QMIN, PC1, PC2, QC1MIN, QC1MAX, ...
QC2MIN, QC2MAX, RAMP_AGC, RAMP_10, RAMP_30, RAMP_Q, APF] = idx_gen;

Some examples of usage, after defining the constants using the line above,
are:

 Pg = gen(4, PG);   % get the real power output of generator 4
 gen(:, PMIN) = 0;  % set to zero the minimum real power limit of all gens

The index, name and meaning of each column of the gen matrix is given
below:

columns 1-21 must be included in input matrix (in case file)
 1  GEN_BUS     bus number
 2  PG          Pg, real power output (MW)
 3  QG          Qg, reactive power output (MVAr)
 4  QMAX        Qmax, maximum reactive power output (MVAr)
 5  QMIN        Qmin, minimum reactive power output (MVAr)
 6  VG          Vg, voltage magnitude setpoint (p.u.)
 7  MBASE       mBase, total MVA base of machine, defaults to baseMVA
 8  GEN_STATUS  status, > 0 - in service, <= 0 - out of service
 9  PMAX        Pmax, maximum real power output (MW)
 10 PMIN        Pmin, minimum real power output (MW)
 11 PC1         Pc1, lower real power output of PQ capability curve (MW)
 12 PC2         Pc2, upper real power output of PQ capability curve (MW)
 13 QC1MIN      Qc1min, minimum reactive power output at Pc1 (MVAr)
 14 QC1MAX      Qc1max, maximum reactive power output at Pc1 (MVAr)
 15 QC2MIN      Qc2min, minimum reactive power output at Pc2 (MVAr)
 16 QC2MAX      Qc2max, maximum reactive power output at Pc2 (MVAr)
 17 RAMP_AGC    ramp rate for load following/AGC (MW/min)
 18 RAMP_10     ramp rate for 10 minute reserves (MW)
 19 RAMP_30     ramp rate for 30 minute reserves (MW)
 20 RAMP_Q      ramp rate for reactive power (2 sec timescale) (MVAr/min)
 21 APF         area participation factor

columns 22-25 are added to matrix after OPF solution
they are typically not present in the input matrix
                (assume OPF objective function has units, u)
 22 MU_PMAX     Kuhn-Tucker multiplier on upper Pg limit (u/MW)
 23 MU_PMIN     Kuhn-Tucker multiplier on lower Pg limit (u/MW)
 24 MU_QMAX     Kuhn-Tucker multiplier on upper Qg limit (u/MVAr)
 25 MU_QMIN     Kuhn-Tucker multiplier on lower Qg limit (u/MVAr)
```

See also define_constants.

isload

isload(*gen*)

isload() - Checks for dispatchable loads.

```
TORF = ISLOAD(GEN) returns a column vector of 1's and 0's. The 1's
correspond to rows of the GEN matrix which represent dispatchable loads.
The current test is Pmin < 0 AND Pmax == 0.
This may need to be revised to allow sensible specification
of both elastic demand and pumped storage units.
```

load2disp

load2disp(*mpc0*, *fname*, *idx*, *voll*)

load2disp() - Converts fixed loads to dispatchable.

```
MPC = LOAD2DISP(MPC0);
MPC = LOAD2DISP(MPC0, FNAME);
MPC = LOAD2DISP(MPC0, FNAME, IDX);
MPC = LOAD2DISP(MPC0, FNAME, IDX, VOLL);

Takes a MATPOWER case file or struct and converts fixed loads to
dispatchable loads and returns the resulting case struct. Inputs
are as follows:

MPC0 - File name or struct with initial MATPOWER case.

FNAME (optional) - Name to use to save resulting MATPOWER case. If empty,
    the case will not be saved to a file.

IDX (optional) - Vector of bus indices of loads to be converted. If empty
    or not supplied, it will convert all loads with positive real
    power demand.

VOLL (optional) - Scalar or vector specifying the value of lost
    load to use as the value for the dispatchable loads. If it is
    a scalar it is used for all loads, if a vector, the dimension
    must match that of IDX. Default is $5000 per MWh.
```

loadshed

loadshed(*gen*, *ild*)

loadshed() - Returns a vector of curtailments of dispatchable loads.

```
SHED = LOADSHED(GEN)
SHED = LOADSHED(GEN, ILD)

Returns a column vector of MW curtailments of dispatchable loads.

Inputs:
    GEN - MATPOWER generator matrix
    ILD - (optional) NLD x 1 vector of generator indices corresponding
          to the dispatchable loads of interest, default is all
          dispatchable loads as determined by the ISLOAD() function.

Output:
    SHED - NLD x 1 vector of the MW curtailment for each dispatchable
           load of interest

Example:
    total_load_shed = max(loadshed(mpc.gen));
```

modcost

modcost(*gencost*, *alpha*, *modtype*)

modcost() - Modifies generator costs by shifting or scaling (F or X).

```
NEWGENCOST = MODCOST(GENCOST, ALPHA)
NEWGENCOST = MODCOST(GENCOST, ALPHA, MODTYPE)

For each generator cost F(X) (for real or reactive power) in
GENCOST, this function modifies the cost by scaling or shifting
the function by ALPHA, depending on the value of MODTYPE, and
and returns the modified GENCOST. Rows of GENCOST can be a mix
of polynomial or piecewise linear costs. ALPHA can be a scalar,
applied to each row of GENCOST, or an NG x 1 vector, where each
element is applied to the corresponding row of GENCOST.

MODTYPE takes one of the 4 possible values (let F_alpha(X) denote the
the modified function):
    'SCALE_F' (default) : F_alpha(X)         == F(X) * ALPHA
    'SCALE_X'           : F_alpha(X * ALPHA) == F(X)
    'SHIFT_F'           : F_alpha(X)         == F(X) + ALPHA
    'SHIFT_X'           : F_alpha(X + ALPHA) == F(X)
```

mpver

mpver(*varargin*)

mpver() - Prints or returns installed MATPOWER version info.

```
mpver
v = mpver
v = mpver('all')
```

When called with an output argument and no input argument, mpver() returns the current MATPOWER version numbers. With an input argument (e.g. 'all') it returns a struct with the fields Name, Version, Release, and Date *(all char arrays)*. Calling mpver() without assigning the return value prints the version and release date of the current installation of MATPOWER, MATLAB (or MATLAB), the Optimization Toolbox, MP-Test, MIPS, MP-Opt-Model, MOST, and any optional MATPOWER packages.

poly2pwl

poly2pwl(*polycost*, *Pmin*, *Pmax*, *npts*)

poly2pwl() - Converts polynomial cost variable to piecewise linear.

```
PWLCOST = POLY2PWL(POLYCOST, PMIN, PMAX, NPTS) converts the polynomial
cost variable POLYCOST into a piece-wise linear cost by evaluating at
NPTS evenly spaced points between PMIN and PMAX. If the range does not
include 0, then it is evaluated at 0 and NPTS-1 evenly spaced points
between PMIN and PMAX.
```

polycost

polycost(*gencost*, *Pg*, *der*)

polycost() - Evaluates polynomial generator cost & derivatives.

```
F = POLYCOST(GENCOST, PG) returns the vector of costs evaluated at PG

DF = POLYCOST(GENCOST, PG, 1) returns the vector of first derivatives
of costs evaluated at PG

D2F = POLYCOST(GENCOST, PG, 2) returns the vector of second derivatives
of costs evaluated at PG

GENCOST must contain only polynomial costs
PG is in MW, not p.u. (works for QG too)

This is a more effecient implementation that what can be done with
MATLAB's built-in POLYVAL and POLYDER functions.
```

pqcost

pqcost(*gencost*, *ng*, *on*)

pqcost() - Splits the gencost variable into two pieces if costs are given for Qg.

```
[PCOST, QCOST] = PQCOST(GENCOST, NG, ON) checks whether GENCOST has
cost information for reactive power generation (rows ng+1 to 2*ng).
If so, it returns the first NG rows in PCOST and the last NG rows in
QCOST. Otherwise, leaves QCOST empty. Also does some error checking.
If ON is specified (list of indices of generators which are on line)
it only returns the rows corresponding to these generators.
```

scale_load

scale_load(*dmd*, *bus*, *gen*, *load_zone*, *opt*, *gencost*)

scale_load() (page 348) - Scales fixed and/or dispatchable loads.

```
MPC = SCALE_LOAD(LOAD, MPC);
MPC = SCALE_LOAD(LOAD, MPC, LOAD_ZONE)
MPC = SCALE_LOAD(LOAD, MPC, LOAD_ZONE, OPT)
BUS = SCALE_LOAD(LOAD, BUS);
[BUS, GEN] = SCALE_LOAD(LOAD, BUS, GEN, LOAD_ZONE, OPT)
[BUS, GEN, GENCOST] = ...
    SCALE_LOAD(LOAD, BUS, GEN, LOAD_ZONE, OPT, GENCOST)

Scales active (and optionally reactive) loads in each zone by a
zone-specific ratio, i.e. R(k) for zone k. Inputs are ...

LOAD - Each element specifies the amount of scaling for the
    corresponding load zone, either as a direct scale factor
    or as a target quantity. If there are nz load zones this
    vector has nz elements.

MPC - standard MATPOWER case struct or case file name

BUS - standard BUS matrix with nb rows, where the fixed active
    and reactive loads available for scaling are specified in
    columns PD and QD

GEN - (optional) standard GEN matrix with ng rows, where the
    dispatchable loads available for scaling are specified by
    columns PG, QG, PMIN, QMIN and QMAX (in rows for which
    ISLOAD(GEN) returns true). If GEN is empty, it assumes
    there are no dispatchable loads.

LOAD_ZONE - (optional) nb element vector where the value of
    each element is either zero or the index of the load zone
    to which the corresponding bus belongs. If LOAD_ZONE(b) = k
    then the loads at bus b will be scaled according to the
    value of LOAD(k). If LOAD_ZONE(b) = 0, the loads at bus b
```

(continues on next page)

(continued from previous page)

```
    will not be modified. If LOAD_ZONE is empty, the default is
    determined by the dimensions of the LOAD vector. If LOAD is
    a scalar, a single system-wide zone including all buses is
    used, i.e. LOAD_ZONE = ONES(nb, 1). If LOAD is a vector, the
    default LOAD_ZONE is defined as the areas specified in the
    BUS matrix, i.e. LOAD_ZONE = BUS(:, BUS_AREA), and LOAD
    should have dimension = MAX(BUS(:, BUS_AREA)).

OPT - (optional) struct with three possible fields, 'scale',
    'pq' and 'which' that determine the behavior as follows:

  OPT.scale (default is 'FACTOR')
    'FACTOR'   : LOAD consists of direct scale factors, where
                 LOAD(k) = scale factor R(k) for zone k
    'QUANTITY' : LOAD consists of target quantities, where
                 LOAD(k) = desired total active load in MW for
                 zone k after scaling by an appropriate R(k)

  OPT.pq    (default is 'PQ')
    'PQ' : scale both active and reactive loads
    'P'  : scale only active loads

  OPT.which (default is 'BOTH' if GEN is provided, else 'FIXED')
    'FIXED'        : scale only fixed loads
    'DISPATCHABLE' : scale only dispatchable loads
    'BOTH'         : scale both fixed and dispatchable loads

  OPT.cost : (default = -1) flag to include cost in scaling or not
    -1 : include cost if gencost is available
     0 : do not include cost
     1 : include cost (error if gencost not available)

GENCOST - (optional) standard GENCOST matrix with ng (or 2*ng)
    rows, where the dispatchable load rows are determined by
    the GEN matrix. If included, the quantity axis of the marginal
    "cost" or benefit function of any dispatchable loads will be
    scaled with the size of the load itself (using MODCOST twice,
    once with MODTYPE equal to SCALE_F and once with SCALE_X).

Examples:
    Scale all real and reactive fixed loads up by 10%.

    bus = scale_load(1.1, bus);

    Scale all active loads (fixed and dispatchable) at the first 10
    buses so their total equals 100 MW, and at next 10 buses so their
    total equals 50 MW.

    load_zone = zeros(nb, 1);
    load_zone(1:10) = 1;
    load_zone(11:20) = 2;
    opt = struct('pq', 'P', 'scale', 'QUANTITY');
```

(continues on next page)

(continued from previous page)

```
    dmd = [100; 50];
    [bus, gen] = scale_load(dmd, bus, gen, load_zone, opt);
```

See also *total_load()* (page 350).

total_load

total_load(*bus*, *gen*, *load_zone*, *opt*, *mpopt*)

total_load() (page 350) - Returns vector of total load in each load zone.

```
PD = TOTAL_LOAD(MPC)
PD = TOTAL_LOAD(MPC, LOAD_ZONE)
PD = TOTAL_LOAD(MPC, LOAD_ZONE, OPT)
PD = TOTAL_LOAD(MPC, LOAD_ZONE, OPT, MPOPT)
PD = TOTAL_LOAD(BUS)
PD = TOTAL_LOAD(BUS, GEN)
PD = TOTAL_LOAD(BUS, GEN, LOAD_ZONE)
PD = TOTAL_LOAD(BUS, GEN, LOAD_ZONE, OPT)
PD = TOTAL_LOAD(BUS, GEN, LOAD_ZONE, OPT, MPOPT)
[PD, QD] = TOTAL_LOAD(...) returns both active and reative power
demand for each zone.

MPC - standard MATPOWER case struct

BUS - standard BUS matrix with nb rows, where the fixed active
    and reactive loads are specified in columns PD and QD

GEN - (optional) standard GEN matrix with ng rows, where the
    dispatchable loads are specified by columns PG, QG, PMIN,
    QMIN and QMAX (in rows for which ISLOAD(GEN) returns true).
    If GEN is empty, it assumes there are no dispatchable loads.

LOAD_ZONE - (optional) nb element vector where the value of
    each element is either zero or the index of the load zone
    to which the corresponding bus belongs. If LOAD_ZONE(b) = k
    then the loads at bus b will added to the values of PD(k) and
    QD(k). If LOAD_ZONE is empty, the default is defined as the areas
    specified in the BUS matrix, i.e. LOAD_ZONE = BUS(:, BUS_AREA)
    and load will have dimension = MAX(BUS(:, BUS_AREA)). LOAD_ZONE
    can also take the following string values:
        'all'  - use a single zone for the entire system (return scalar)
        'area' - use LOAD_ZONE = BUS(:, BUS_AREA), same as default
        'bus'  - use a different zone for each bus (i.e. to compute
            final values of bus-wise loads, including voltage dependent
            fixed loads and or dispatchable loads)

OPT - (optional) option struct, with the following fields:
        'type'  -  string specifying types of loads to include, default
                   is 'BOTH' if GEN is provided, otherwise 'FIXED'
            'FIXED'        : sum only fixed loads
```

(continues on next page)

(continued from previous page)

```
            'DISPATCHABLE' : sum only dispatchable loads
            'BOTH'         : sum both fixed and dispatchable loads
        'nominal' -  1 : use nominal load for dispatchable loads
                     0 : (default) use actual realized load for
                          dispatchable loads

    For backward compatibility with MATPOWER 4.x, OPT can also
    take the form of a string, with the same options as OPT.type above.
    In this case, again for backward compatibility, it is the "nominal"
    load that is computed for dispatchable loads, not the actual
    realized load. Using a string for OPT is deprecated and
    will be removed in a future version.

MPOPT - (optional) MATPOWER options struct, which may specify
    a voltage dependent (ZIP) load model for fixed loads

Examples:
    Return the total active load for each area as defined in BUS_AREA.

    Pd = total_load(bus);

    Return total active and reactive load, fixed and dispatchable, for
    entire system.

    [Pd, Qd] = total_load(bus, gen, 'all');

    Return the total of the nominal dispatchable loads at buses 10-20.

    load_zone = zeros(nb, 1);
    load_zone(10:20) = 1;
    opt = struct('type', 'DISPATCHABLE', 'nominal', 1);
    Pd = total_load(mpc, load_zone, opt)
```

See also *scale_load()* (page 348).

5.2.13 Private Feature Detection Functions

have_feature_e4st

have_feature_e4st()

have_feature_e4st() (page 351) - Detect availability/version info for E4ST.

Private feature detection function implementing `'e4st'` tag for `have_feature()` to detect availability/version of E4ST, the Engineering, Economic, and Environmental Electricity Simulation Tool (https://e4st.com).

See also `have_feature()`.

have_feature_minopf

have_feature_minopf()

have_feature_minopf() (page 352) - Detect availability/version info for MINOPF.

Private feature detection function implementing `'minopf'` tag for `have_feature()` to detect availability/version of MINOPF, a MINOS-based optimal power flow (OPF) solver.

See also `have_feature()`, `minopf`.

have_feature_most

have_feature_most()

have_feature_most() (page 352) - Detect availability/version info for MOST.

Private feature detection function implementing `':func:`most``'` tag for `have_feature()` to detect availability/version of MOST (MATPOWER Optimal Scheduling Tool).

See also `have_feature()`, `most()`.

have_feature_mp_core

have_feature_mp_core()

have_feature_mp_core() (page 352) - Detect availability of MP-Core.

Private feature detection function implementing `'mp_core'` tag for `have_feature()` to detect availability/version of MP-Core.

See also `have_feature()`.

have_feature_pdipmopf

have_feature_pdipmopf()

have_feature_pdipmopf() (page 352) - Detect availability/version info for PDIPMOPF.

Private feature detection function implementing `'pdipmopf'` tag for `have_feature()` to detect availability/version of PDIPMOPF, a primal-dual interior point method optimal power flow (OPF) solver included in TSPOPF. (https://www.pserc.cornell.edu/tspopf)

See also `have_feature()`, `pdipmopf`.

have_feature_regexp_split

have_feature_regexp_split()

have_feature_regexp_split() (page 353) - Detect availability/version info for REGEXP 'split'.

Private feature detection function implementing 'regexp_split' tag for have_feature() to detect support for the 'split' argument to REGEXP.

See also have_feature(), regexp.

have_feature_scpdipmopf

have_feature_scpdipmopf()

have_feature_scpdipmopf() (page 353) - Detect availability/version info for SCPDIPMOPF.

Private feature detection function implementing 'scpdipmopf' tag for have_feature() to detect availability/version of SCPDIPMOPF, step-controlled primal-dual interior point method optimal power flow (OPF) solver included in TSPOPF. (https://www.pserc.cornell.edu/tspopf)

See also have_feature(), scpdipmopf.

have_feature_sdp_pf

have_feature_sdp_pf()

have_feature_sdp_pf() (page 353) - Detect availability/version info for SDP_PF.

Private feature detection function implementing 'sdp_pf' tag for have_feature() to detect availability/version of SDP_PF, a MATPOWER extension for applications of semi-definite programming relaxations of power flow equations (https://github.com/MATPOWER/mx-sdp_pf/).

See also have_feature().

have_feature_smartmarket

have_feature_smartmarket()

have_feature_smartmarket() (page 353) - Detect availability/version info for SMARTMARKET.

Private feature detection function implementing 'smartmarket' tag for have_feature() to detect availability/version of RUNMARKET and related files for running an energy auction, found under smartmarket in MATPOWER Extras. (https://github.com/MATPOWER/matpower-extras/).

See also have_feature(), runmarket.

have_feature_syngrid

have_feature_syngrid()

have_feature_syngrid() (page 354) - Detect availability/version info for SynGrid.

Private feature detection function implementing `'syngrid'` tag for `have_feature()` to detect availability/version of SynGrid, Synthetic Grid Creation for MATPOWER (https://github.com/MATPOWER/mx-syngrid).

See also `have_feature()`, `syngrid`.

have_feature_table

have_feature_table()

have_feature_table() (page 354) - Detect availability/version info for `table`.

Private feature detection function implementing `'table'` tag for `have_feature()` to detect availability/version of TABLE, included in MATLAB R2013b and as of this writing in Mar 2024, available for Octave as Tablicious: https://github.com/apjanke/octave-tablicious

See also `have_feature()`, `table`.

have_feature_tralmopf

have_feature_tralmopf()

have_feature_tralmopf() (page 354) - Detect availability/version info for TRALMOPF

Private feature detection function implementing `'tralmopf'` tag for `have_feature()` to detect availability/version of TRALMOPF, trust region based augmented Langrangian optimal power flow (OPF) solver included in TSPOPF. (https://www.pserc.cornell.edu/tspopf)

See also `have_feature()`, `tralmopf`.

5.2.14 Other Functions

connected_components

connected_components(*C*, *groups*, *unvisited*)

connected_components() (page 354) - Returns the connected components of a graph.

```
[GROUPS, ISOLATED] = CONNECTED_COMPONENTS(C)

Returns the connected components of a directed graph, specified by
a node-branch incidence matrix C, where C(I, J) = -1 if node J is
connected to the beginning of branch I, 1 if it is connected to
the end of branch I, and zero otherwise. The return value GROUPS
is a cell array of vectors of the node indices for each component.
The second return value ISOLATED is a vector of indices of isolated
nodes that have no connecting branches.
```

mpoption_info_clp

mpoption_info_clp(*selector*)

mpoption_info_clp() (page 355) - Returns MATPOWER option info for CLP.

```
DEFAULT_OPTS = MPOPTION_INFO_CLP('D')
VALID_OPTS   = MPOPTION_INFO_CLP('V')
EXCEPTIONS   = MPOPTION_INFO_CLP('E')

Returns a structure for CLP options for MATPOWER containing ...
(1) default options,
(2) valid options, or
(3) NESTED_STRUCT_COPY exceptions for setting options
... depending on the value of the input argument.

This function is used by MPOPTION to set default options, check validity
of option names or modify option setting/copying behavior for this
subset of optional MATPOWER options.
```

See also `mpoption()`.

mpoption_info_cplex

mpoption_info_cplex(*selector*)

mpoption_info_cplex() (page 355) - Returns MATPOWER option info for CPLEX.

```
DEFAULT_OPTS = MPOPTION_INFO_CPLEX('D')
VALID_OPTS   = MPOPTION_INFO_CPLEX('V')
EXCEPTIONS   = MPOPTION_INFO_CPLEX('E')

Returns a structure for CPLEX options for MATPOWER containing ...
(1) default options,
(2) valid options, or
(3) NESTED_STRUCT_COPY exceptions for setting options
... depending on the value of the input argument.

This function is used by MPOPTION to set default options, check validity
of option names or modify option setting/copying behavior for this
subset of optional MATPOWER options.
```

See also `mpoption()`.

mpoption_info_fmincon

mpoption_info_fmincon(*selector*)

mpoption_info_fmincon() (page 356) - Returns MATPOWER option info for FMINCON.

```
DEFAULT_OPTS = MPOPTION_INFO_FMINCON('D')
VALID_OPTS   = MPOPTION_INFO_FMINCON('V')
EXCEPTIONS   = MPOPTION_INFO_FMINCON('E')

Returns a structure for FMINCON options for MATPOWER containing ...
(1) default options,
(2) valid options, or
(3) NESTED_STRUCT_COPY exceptions for setting options
... depending on the value of the input argument.

This function is used by MPOPTION to set default options, check validity
of option names or modify option setting/copying behavior for this
subset of optional MATPOWER options.
```

See also `mpoption()`.

mpoption_info_glpk

mpoption_info_glpk(*selector*)

mpoption_info_glpk() (page 356) - Returns MATPOWER option info for GLPK.

```
DEFAULT_OPTS = MPOPTION_INFO_GLPK('D')
VALID_OPTS   = MPOPTION_INFO_GLPK('V')
EXCEPTIONS   = MPOPTION_INFO_GLPK('E')

Returns a structure for GLPK options for MATPOWER containing ...
(1) default options,
(2) valid options, or
(3) NESTED_STRUCT_COPY exceptions for setting options
... depending on the value of the input argument.

This function is used by MPOPTION to set default options, check validity
of option names or modify option setting/copying behavior for this
subset of optional MATPOWER options.
```

See also `mpoption()`.

mpoption_info_gurobi

mpoption_info_gurobi(*selector*)

mpoption_info_gurobi() (page 357) - Returns MATPOWER option info for Gurobi.

```
DEFAULT_OPTS = MPOPTION_INFO_GUROBI('D')
VALID_OPTS   = MPOPTION_INFO_GUROBI('V')
EXCEPTIONS   = MPOPTION_INFO_GUROBI('E')

Returns a structure for Gurobi options for MATPOWER containing ...
(1) default options,
(2) valid options, or
(3) NESTED_STRUCT_COPY exceptions for setting options
... depending on the value of the input argument.

This function is used by MPOPTION to set default options, check validity
of option names or modify option setting/copying behavior for this
subset of optional MATPOWER options.
```

See also `mpoption()`.

mpoption_info_intlinprog

mpoption_info_intlinprog(*selector*)

mpoption_info_intlinprog() (page 357) - Returns MATPOWER option info for INTLINPROG.

```
DEFAULT_OPTS = MPOPTION_INFO_INTLINPROG('D')
VALID_OPTS   = MPOPTION_INFO_INTLINPROG('V')
EXCEPTIONS   = MPOPTION_INFO_INTLINPROG('E')

Returns a structure for INTLINPROG options for MATPOWER containing ...
(1) default options,
(2) valid options, or
(3) NESTED_STRUCT_COPY exceptions for setting options
... depending on the value of the input argument.

This function is used by MPOPTION to set default options, check validity
of option names or modify option setting/copying behavior for this
subset of optional MATPOWER options.
```

See also `mpoption()`.

mpoption_info_ipopt

mpoption_info_ipopt(*selector*)

mpoption_info_ipopt() (page 358) - Returns MATPOWER option info for IPOPT.

```
DEFAULT_OPTS = MPOPTION_INFO_IPOPT('D')
VALID_OPTS   = MPOPTION_INFO_IPOPT('V')
EXCEPTIONS   = MPOPTION_INFO_IPOPT('E')

Returns a structure for IPOPT options for MATPOWER containing ...
(1) default options,
(2) valid options, or
(3) NESTED_STRUCT_COPY exceptions for setting options
... depending on the value of the input argument.

This function is used by MPOPTION to set default options, check validity
of option names or modify option setting/copying behavior for this
subset of optional MATPOWER options.
```

See also `mpoption()`.

mpoption_info_knitro

mpoption_info_knitro(*selector*)

mpoption_info_knitro() (page 358) - Returns MATPOWER option info for Artelys Knitro.

```
DEFAULT_OPTS = MPOPTION_INFO_KNITRO('D')
VALID_OPTS   = MPOPTION_INFO_KNITRO('V')
EXCEPTIONS   = MPOPTION_INFO_KNITRO('E')

Returns a structure for Knitro options for MATPOWER containing ...
(1) default options,
(2) valid options, or
(3) NESTED_STRUCT_COPY exceptions for setting options
... depending on the value of the input argument.

This function is used by MPOPTION to set default options, check validity
of option names or modify option setting/copying behavior for this
subset of optional MATPOWER options.
```

See also `mpoption()`.

mpoption_info_linprog

mpoption_info_linprog(*selector*)

mpoption_info_linprog() (page 359) - Returns MATPOWER option info for LINPROG.

```
DEFAULT_OPTS = MPOPTION_INFO_LINPROG('D')
VALID_OPTS   = MPOPTION_INFO_LINPROG('V')
EXCEPTIONS   = MPOPTION_INFO_LINPROG('E')

Returns a structure for LINPROG options for MATPOWER containing ...
(1) default options,
(2) valid options, or
(3) NESTED_STRUCT_COPY exceptions for setting options
... depending on the value of the input argument.

This function is used by MPOPTION to set default options, check validity
of option names or modify option setting/copying behavior for this
subset of optional MATPOWER options.
```

See also `mpoption()`.

mpoption_info_mips

mpoption_info_mips(*selector*)

mpoption_info_mips() (page 359) - Returns MATPOWER option info for MIPS (optional fields).

```
DEFAULT_OPTS = MPOPTION_INFO_MIPS('D')
VALID_OPTS   = MPOPTION_INFO_MIPS('V')
EXCEPTIONS   = MPOPTION_INFO_MIPS('E')

Returns a structure for MIPS options for MATPOWER containing ...
(1) default options,
(2) valid options, or
(3) NESTED_STRUCT_COPY exceptions for setting options
... depending on the value of the input argument.

This function is used by MPOPTION to set default options, check validity
of option names or modify option setting/copying behavior for this
subset of optional MATPOWER options.
```

See also `mpoption()`.

mpoption_info_mosek

mpoption_info_mosek(*selector*)

mpoption_info_mosek() (page 360) - Returns MATPOWER option info for MOSEK.

```
DEFAULT_OPTS = MPOPTION_INFO_MOSEK('D')
VALID_OPTS   = MPOPTION_INFO_MOSEK('V')
EXCEPTIONS   = MPOPTION_INFO_MOSEK('E')

Returns a structure for MOSEK options for MATPOWER containing ...
(1) default options,
(2) valid options, or
(3) NESTED_STRUCT_COPY exceptions for setting options
... depending on the value of the input argument.

This function is used by MPOPTION to set default options, check validity
of option names or modify option setting/copying behavior for this
subset of optional MATPOWER options.
```

See also `mpoption()`.

mpoption_info_osqp

mpoption_info_osqp(*selector*)

mpoption_info_osqp() (page 360) - Returns MATPOWER option info for OSQP.

```
DEFAULT_OPTS = MPOPTION_INFO_OSQP('D')
VALID_OPTS   = MPOPTION_INFO_OSQP('V')
EXCEPTIONS   = MPOPTION_INFO_OSQP('E')

Returns a structure for OSQP options for MATPOWER containing ...
(1) default options,
(2) valid options, or
(3) NESTED_STRUCT_COPY exceptions for setting options
... depending on the value of the input argument.

This function is used by MPOPTION to set default options, check validity
of option names or modify option setting/copying behavior for this
subset of optional MATPOWER options.
```

See also `mpoption()`.

mpoption_info_quadprog

mpoption_info_quadprog(*selector*)

mpoption_info_quadprog() (page 361) - Returns MATPOWER option info for QUADPROG.

```
DEFAULT_OPTS = MPOPTION_INFO_QUADPROG('D')
VALID_OPTS   = MPOPTION_INFO_QUADPROG('V')
EXCEPTIONS   = MPOPTION_INFO_QUADPROG('E')

Returns a structure for QUADPROG options for MATPOWER containing ...
(1) default options,
(2) valid options, or
(3) NESTED_STRUCT_COPY exceptions for setting options
... depending on the value of the input argument.

This function is used by MPOPTION to set default options, check validity
of option names or modify option setting/copying behavior for this
subset of optional MATPOWER options.
```

See also `mpoption()`.

mpoption_old

mpoption_old(*varargin*)

mpoption_old() (page 361) - Used to set and retrieve old-style MATPOWER options vector.

```
OPT = MPOPTION_OLD
    returns the default options vector

OPT = MPOPTION_OLD(NAME1, VALUE1, NAME2, VALUE2, ...)
    returns the default options vector with new values for up to 7
    options, NAME# is the name of an option, and VALUE# is the new
    value.

OPT = MPOPTION_OLD(OPT, NAME1, VALUE1, NAME2, VALUE2, ...)
    same as above except it uses the options vector OPT as a base
    instead of the default options vector.

Examples:
    opt = mpoption_old('PF_ALG', 2, 'PF_TOL', 1e-4);
    opt = mpoption_old(opt, 'OPF_ALG', 565, 'VERBOSE', 2);

The currently defined options are as follows:

   idx - NAME, default          description [options]
   ---   -------------          ----------------------------------------
power flow options
    1  - PF_ALG, 1              AC power flow algorithm
         [   1 - Newton's method                                        ]
         [   2 - Fast-Decoupled (XB version)                            ]
         [   3 - Fast-Decoupled (BX version)                            ]
```

(continues on next page)

(continued from previous page)

```
        [   4 - Gauss-Seidel                                            ]
    2   - PF_TOL, 1e-8          termination tolerance on per unit
                                P & Q mismatch
    3   - PF_MAX_IT, 10         maximum number of iterations for
                                Newton's method
    4   - PF_MAX_IT_FD, 30      maximum number of iterations for
                                fast decoupled method
    5   - PF_MAX_IT_GS, 1000    maximum number of iterations for
                                Gauss-Seidel method
    6   - ENFORCE_Q_LIMS, 0     enforce gen reactive power limits
                                at expense of |V|
        [    0 - do NOT enforce limits                                  ]
        [    1 - enforce limits, simultaneous bus type conversion       ]
        [    2 - enforce limits, one-at-a-time bus type conversion      ]
    10  - PF_DC, 0              DC modeling for power flow & OPF
        [    0 - use AC formulation & corresponding algorithm options   ]
        [    1 - use DC formulation, ignore AC algorithm options        ]
OPF options
    11  - OPF_ALG, 0            solver to use for AC OPF
        [    0 - choose default solver based on availability in the     ]
        [        following order, 540, 560                              ]
        [  500 - MINOPF, MINOS-based solver, requires optional          ]
        [        MEX-based MINOPF package, available from:              ]
        [        http://www.pserc.cornell.edu/minopf/                   ]
        [  520 - fmincon, MATLAB Optimization Toolbox >= 2.x            ]
        [  540 - PDIPM, primal/dual interior point method, requires     ]
        [        optional MEX-based TSPOPF package, available from:     ]
        [        http://www.pserc.cornell.edu/tspopf/                   ]
        [  545 - SC-PDIPM, step-controlled variant of PDIPM, requires   ]
        [        TSPOPF (see 540)                                       ]
        [  550 - TRALM, trust region based augmented Langrangian        ]
        [        method, requires TSPOPF (see 540)                      ]
        [  560 - MIPS, MATPOWER Interior Point Solver                   ]
        [        primal/dual interior point method (pure MATLAB)        ]
        [  565 - MIPS-sc, step-controlled variant of MIPS               ]
        [        primal/dual interior point method (pure MATLAB)        ]
        [  580 - IPOPT, requires MEX interface to IPOPT solver          ]
        [        available from: https://projects.coin-or.org/Ipopt/    ]
        [  600 - Artelys Knitro, requires Knitro solver, available from:]
        [        https://www.artelys.com/solvers/knitro/                ]
    16  - OPF_VIOLATION, 5e-6    constraint violation tolerance
    17  - CONSTR_TOL_X, 1e-4     termination tol on x for fmincon/Knitro
    18  - CONSTR_TOL_F, 1e-4     termination tol on f for fmincon/Knitro
    19  - CONSTR_MAX_IT, 0       max number of iterations for fmincon
                                [       0 => default                    ]
    24  - OPF_FLOW_LIM, 0        qty to limit for branch flow constraints
        [   0 - apparent power flow (limit in MVA)                      ]
        [   1 - active power flow (limit in MW)                         ]
        [   2 - current magnitude (limit in MVA at 1 p.u. voltage)      ]
    25  - OPF_IGNORE_ANG_LIM, 0  ignore angle difference limits for branches
                                even if specified           [   0 or 1  ]
    26  - OPF_ALG_DC, 0          solver to use for DC OPF
```

(continues on next page)

(continued from previous page)

```
        [    0 - choose default solver based on availability in the     ]
        [        following order: 500, 600, 700, 100, 300, 200          ]
        [  100 - BPMPD, requires optional MEX-based BPMPD_MEX package   ]
        [        available from: http://www.pserc.cornell.edu/bpmpd/    ]
        [  200 - MIPS, MATLAB Interior Point Solver                     ]
        [        primal/dual interior point method (pure MATLAB)        ]
        [  250 - MIPS-sc, step-controlled variant of MIPS               ]
        [  300 - MATLAB Optimization Toolbox, QUADPROG, LINPROG         ]
        [  400 - IPOPT, requires MEX interface to IPOPT solver          ]
        [        available from: https://projects.coin-or.org/Ipopt/    ]
        [  500 - CPLEX, requires MATLAB interface to CPLEX solver       ]
        [  600 - MOSEK, requires MATLAB interface to MOSEK solver       ]
        [        available from: https://www.mosek.com/                 ]
        [  700 - GUROBI, requires Gurobi optimizer (v. 5+)              ]
        [        available from: https://www.gurobi.com                 ]
output options
    31 - VERBOSE, 1             amount of progress info printed
        [   0 - print no progress info                                  ]
        [   1 - print a little progress info                            ]
        [   2 - print a lot of progress info                            ]
        [   3 - print all progress info                                 ]
    32 - OUT_ALL, -1            controls pretty-printing of results
        [  -1 - individual flags control what prints                    ]
        [   0 - do not print anything                                   ]
        [       (overrides individual flags)                            ]
        [   1 - print everything                                        ]
        [       (overrides individual flags)                            ]
    33 - OUT_SYS_SUM, 1         print system summary        [   0 or 1  ]
    34 - OUT_AREA_SUM, 0        print area summaries        [   0 or 1  ]
    35 - OUT_BUS, 1             print bus detail            [   0 or 1  ]
    36 - OUT_BRANCH, 1          print branch detail         [   0 or 1  ]
    37 - OUT_GEN, 0             print generator detail      [   0 or 1  ]
                                (OUT_BUS also includes gen info)
    38 - OUT_ALL_LIM, -1        controls what constraint info is printed
        [  -1 - individual flags control what constraint info prints    ]
        [   0 - no constraint info (overrides individual flags)         ]
        [   1 - binding constraint info (overrides individual flags)    ]
        [   2 - all constraint info (overrides individual flags)        ]
    39 - OUT_V_LIM, 1           control output of voltage limit info
        [   0 - do not print                                            ]
        [   1 - print binding constraints only                          ]
        [   2 - print all constraints                                   ]
        [   (same options for OUT_LINE_LIM, OUT_PG_LIM, OUT_QG_LIM)     ]
    40 - OUT_LINE_LIM, 1        control output of line flow limit info
    41 - OUT_PG_LIM, 1          control output of gen P limit info
    42 - OUT_QG_LIM, 1          control output of gen Q limit info
    44 - OUT_FORCE, 0           print results even if success = 0
                                                        [   0 or 1  ]
    52 - RETURN_RAW_DER, 0      return constraint and derivative info
                                in results.raw (in fields g, dg, df, d2f)
FMINCON options
    55 - FMC_ALG, 4             algorithm used by fmincon for OPF
```

(continues on next page)

(continued from previous page)

```
                              for Optimization Toolbox 4 and later
        [  1 - active-set                                           ]
        [  2 - interior-point, w/default 'bfgs' Hessian approx      ]
        [  3 - interior-point, w/ 'lbfgs' Hessian approx            ]
        [  4 - interior-point, w/exact user-supplied Hessian        ]
        [  5 - interior-point, w/Hessian via finite differences     ]

Artelys Knitro options
    58 - KNITRO_OPT, 0          a non-zero integer N indicates that all
                                Knitro options should be handled by a
                                Knitro options file named
                                'knitro_user_options_N.txt'

IPOPT options
    60 - IPOPT_OPT, 0           See IPOPT_OPTIONS for details.

MINOPF options
    61 - MNS_FEASTOL, 0 (1e-3)  primal feasibility tolerance,
                                set to value of OPF_VIOLATION by default
    62 - MNS_ROWTOL, 0  (1e-3)  row tolerance
                                set to value of OPF_VIOLATION by default
    63 - MNS_XTOL, 0    (1e-3)  x tolerance
                                set to value of CONSTR_TOL_X by default
    64 - MNS_MAJDAMP, 0 (0.5)   major damping parameter
    65 - MNS_MINDAMP, 0 (2.0)   minor damping parameter
    66 - MNS_PENALTY_PARM, 0 (1.0)  penalty parameter
    67 - MNS_MAJOR_IT, 0 (200)  major iterations
    68 - MNS_MINOR_IT, 0 (2500) minor iterations
    69 - MNS_MAX_IT, 0 (2500)   iterations limit
    70 - MNS_VERBOSITY, -1
        [  -1 - controlled by VERBOSE option                        ]
        [   0 - print nothing                                       ]
        [   1 - print only termination status message               ]
        [   2 - print termination status and screen progress        ]
        [   3 - print screen progress, report file (usually fort.9) ]
    71 - MNS_CORE, 0 (1200 * nb + 2 * (nb + ng)^2) memory allocation
    72 - MNS_SUPBASIC_LIM, 0 (2*nb + 2*ng) superbasics limit
    73 - MNS_MULT_PRICE, 0 (30) multiple price

MIPS (including MIPS-sc), PDIPM, SC-PDIPM, and TRALM options
    81 - PDIPM_FEASTOL, 0       feasibility (equality) tolerance
                                for MIPS, PDIPM and SC-PDIPM, set
                                to value of OPF_VIOLATION by default
    82 - PDIPM_GRADTOL, 1e-6    gradient tolerance for MIPS, PDIPM
                                and SC-PDIPM
    83 - PDIPM_COMPTOL, 1e-6    complementary condition (inequality)
                                tolerance for MIPS, PDIPM and SC-PDIPM
    84 - PDIPM_COSTTOL, 1e-6    optimality tolerance for MIPS, PDIPM
                                and SC-PDIPM
    85 - PDIPM_MAX_IT,  150     maximum number of iterations for MIPS,
                                PDIPM and SC-PDIPM
    86 - SCPDIPM_RED_IT, 20     maximum number of MIPS-sc or SC-PDIPM
```

(continues on next page)

(continued from previous page)

```
                                reductions per iteration
    87 - TRALM_FEASTOL, 0       feasibility tolerance for TRALM
                                set to value of OPF_VIOLATION by default
    88 - TRALM_PRIMETOL, 5e-4   primal variable tolerance for TRALM
    89 - TRALM_DUALTOL, 5e-4    dual variable tolerance for TRALM
    90 - TRALM_COSTTOL, 1e-5    optimality tolerance for TRALM
    91 - TRALM_MAJOR_IT, 40     maximum number of major iterations
    92 - TRALM_MINOR_IT, 100    maximum number of minor iterations
    93 - SMOOTHING_RATIO, 0.04  piecewise linear curve smoothing ratio
                                used in SC-PDIPM and TRALM

CPLEX options
    95 - CPLEX_LPMETHOD, 0      solution algorithm for continuous LPs
        [   0 - automatic: let CPLEX choose                             ]
        [   1 - primal simplex                                          ]
        [   2 - dual simplex                                            ]
        [   3 - network simplex                                         ]
        [   4 - barrier                                                 ]
        [   5 - sifting                                                 ]
        [   6 - concurrent (dual, barrier, and primal)                  ]
    96 - CPLEX_QPMETHOD, 0      solution algorithm for continuous QPs
        [   0 - automatic: let CPLEX choose                             ]
        [   1 - primal simplex optimizer                                ]
        [   2 - dual simplex optimizer                                  ]
        [   3 - network optimizer                                       ]
        [   4 - barrier optimizer                                       ]
    97 - CPLEX_OPT, 0           See CPLEX_OPTIONS for details

MOSEK options
    111 - MOSEK_LP_ALG, 0       solution algorithm for continuous LPs
                                    (MSK_IPAR_OPTIMIZER)
        [   0 - automatic: let MOSEK choose                             ]
        [   1 - interior point                                          ]
        [   4 - primal simplex                                          ]
        [   5 - dual simplex                                            ]
        [   6 - primal dual simplex                                     ]
        [   7 - automatic simplex (MOSEK chooses which simplex method)  ]
        [   10 - concurrent                                             ]
    112 - MOSEK_MAX_IT, 0 (400)     interior point max iterations
                                        (MSK_IPAR_INTPNT_MAX_ITERATIONS)
    113 - MOSEK_GAP_TOL, 0 (1e-8)   interior point relative gap tolerance
                                        (MSK_DPAR_INTPNT_TOL_REL_GAP)
    114 - MOSEK_MAX_TIME, 0 (-1)    maximum time allowed for solver
                                        (MSK_DPAR_OPTIMIZER_MAX_TIME)
    115 - MOSEK_NUM_THREADS, 0 (1)  maximum number of threads to use
                                        (MSK_IPAR_INTPNT_NUM_THREADS)
    116 - MOSEK_OPT, 0              See MOSEK_OPTIONS for details

Gurobi options
    121 - GRB_METHOD, -1         solution algorithm (Method)
        [  -1 - automatic, let Gurobi decide                            ]
        [   0 - primal simplex                                          ]
```

(continues on next page)

(continued from previous page)

```
        [   1 - dual simplex                                          ]
        [   2 - barrier                                               ]
        [   3 - concurrent (LP only)                                  ]
        [   4 - deterministic concurrent (LP only)                    ]
    122 - GRB_TIMELIMIT, Inf    maximum time allowed for solver (TimeLimit)
    123 - GRB_THREADS, 0 (auto) maximum number of threads to use (Threads)
    124 - GRB_OPT, 0            See GUROBI_OPTIONS for details
```

psse_convert

psse_convert(*warns*, *data*, *verbose*)

psse_convert() (page 366) - Converts data read from PSS/E RAW file to MATPOWER case.

```
[MPC, WARNINGS] = PSSE_CONVERT(WARNINGS, DATA)
[MPC, WARNINGS] = PSSE_CONVERT(WARNINGS, DATA, VERBOSE)

Converts data read from a version RAW data file into a
MATPOWER case struct.

Input:
    WARNINGS :  cell array of strings containing accumulated
                warning messages
    DATA : struct read by PSSE_READ (see PSSE_READ for details).
    VERBOSE :   1 to display progress info, 0 (default) otherwise

Output:
    MPC : a MATPOWER case struct created from the PSS/E data
    WARNINGS :  cell array of strings containing updated accumulated
                warning messages
```

See also *psse_read()* (page 371).

psse_convert_hvdc

psse_convert_hvdc(*dc*, *bus*)

psse_convert_hvdc() (page 366) - Convert HVDC data from PSS/E RAW to MATPOWER.

```
DCLINE = PSSE_CONVERT_HVDC(DC, BUS)

Convert all two terminal HVDC line data read from a PSS/E
RAW data file into MATPOWER format. Returns a dcline matrix for
inclusion in a MATPOWER case struct.

Inputs:
    DC  : matrix of raw two terminal HVDC line data returned by
          PSSE_READ in data.twodc.num
    BUS : MATPOWER bus matrix
```

(continues on next page)

(continued from previous page)

```
Output:
    DCLINE : a MATPOWER dcline matrix suitable for inclusion in
             a MATPOWER case struct.
```

See also *psse_convert()* (page 366).

psse_convert_xfmr

psse_convert_xfmr(*warns*, *trans2*, *trans3*, *verbose*, *baseMVA*, *bus*, *bus_name*)

psse_convert_xfmr() (page 367) - Convert transformer data from PSS/E RAW to MATPOWER.

```
[XFMR, BUS, WARNINGS] = PSSE_CONVERT_XFMR(WARNINGS, TRANS2, TRANS3, ...
                                VERBOSE, BASEMVA, BUS)
[XFMR, BUS, WARNINGS, BUS_NAME] = PSSE_CONVERT_XFMR(WARNINGS, TRANS2, ...
                                TRANS3, VERBOSE, BASEMVA, BUS, BUS_NAME)

Convert all transformer data read from a PSS/E RAW data file
into MATPOWER format. Returns a branch matrix corresponding to
the transformers and an updated bus matrix, with additional buses
added for the star points of three winding transformers.

Inputs:
    WARNINGS :  cell array of strings containing accumulated
                warning messages
    TRANS2   : matrix of raw two winding transformer data returned
               by PSSE_READ in data.trans2.num
    TRANS3   : matrix of raw three winding transformer data returned
               by PSSE_READ in data.trans3.num
    VERBOSE :   1 to display progress info, 0 (default) otherwise
    BASEMVA : system MVA base
    BUS     : MATPOWER bus matrix
    BUS_NAME: (optional) cell array of bus names

Outputs:
    XFMR    : MATPOWER branch matrix of transformer data
    BUS     : updated MATPOWER bus matrix, with additional buses
              added for star points of three winding transformers
    WARNINGS :  cell array of strings containing updated accumulated
                warning messages
    BUS_NAME: (optional) updated cell array of bus names
```

See also *psse_convert()* (page 366).

psse_parse

psse_parse(*records*, *sections*, *verbose*, *rev*)

psse_parse() (page 368) - Parses the data from a PSS/E RAW data file.

```
DATA = PSSE_PARSE(RECORDS, SECTIONS)
DATA = PSSE_PARSE(RECORDS, SECTIONS, VERBOSE)
DATA = PSSE_PARSE(RECORDS, SECTIONS, VERBOSE, REV)
[DATA, WARNINGS] = PSSE_PARSE(RECORDS, SECTIONS, ...)

Parses the data from a PSS/E RAW data file (as read by PSSE_READ)
into a struct.

Inputs:
    RECORDS : cell array of strings, corresponding to the lines
              in the RAW file
    SECTIONS : struct array with indices marking the beginning
               and end of each section, and the name of the
               section, fields are:
        first   : index into RECORDS of first line of section
        last    : index into RECORDS of last line of section
        name    : name of the section, as extracted from the
                  END OF ... DATA comments
    VERBOSE      :  1 (default) to display progress info, 0 otherwise
    REV          :  (optional) assume the input file is of this
                    PSS/E revision number, attempts to determine
                    REV from the file by default

Output(s):
    DATA :  a struct with the following fields, each with two
            sub-fields, 'num' and 'txt' containing the numeric and
            text data read from the file for the corresponding section
        id
        bus
        load
        gen
        shunt
        branch
        trans2
        trans3
        area
        twodc
        swshunt
    WARNINGS :  cell array of strings containing accumulated
                warning messages
```

See also psse2mpc(), *psse_read()* (page 371), *psse_parse_section()* (page 369), *psse_parse_line()* (page 369).

psse_parse_line

psse_parse_line(*str*, *t*)

psse_parse_line() (page 369) - Reads and parses a single line from a PSS/E RAW data file.

```
[DATA, COMMENT] = PSSE_PARSE_LINE(FID)
[DATA, COMMENT] = PSSE_PARSE_LINE(FID, TEMPLATE)
[DATA, COMMENT] = PSSE_PARSE_LINE(STR)
[DATA, COMMENT] = PSSE_PARSE_LINE(STR, TEMPLATE)

Parses a single line from a PSS/E RAW data file, either directly read
from the file, or passed as a string.

Inputs:
    FID :       (optional) file id of file from which to read the line
    STR :       string containing the line to be parsed
    TEMPLATE :  (optional) string of characters indicating how to
                interpret the type of the corresponding column, options
                are as follows:
            d, f or g : integer floating point number to be converted
                via SSCANF with %d, %f or %g, respectively.
            D, F or G : integer floating point number, possibly enclosed
                in single or double quotes, to be converted via
                SSCANF with %d, %f or %g, respectively.
            c or s : character or string, possibly enclosed in single
                or double quotes, which are stripped from the string
        Note:   Data columns in STR that have no valid corresponding
                entry in TEMPLATE (beyond end of TEMPLATE, or a character
                other than those listed, e.g. '.') are returned as a
                string with no conversion. TEMPLATE entries for which
                there is no corresponding column are returned as NaN or
                empty string, depending on the type.
Outputs:
    DATA :      a cell array whose elements contain the contents of
                the corresponding column in the data, converted
                according to the TEMPLATE.
    COMMENT :   (optional) possible comment at the end of the line
```

psse_parse_section

psse_parse_section(*warns*, *records*, *sections*, *s*, *verbose*, *label*, *template*)

psse_parse_section() (page 369) - Parses the data from a section of a PSS/E RAW data file.

```
[DATA, WARNINGS] = PSSE_PARSE_SECTION(WARNINGS, RECORDS, SECTIONS, SIDX, ...
                                      VERBOSE, LABEL, TEMPLATE)
[DATA, WARNINGS] = PSSE_PARSE_SECTION(WARNINGS, RECORDS, SECTIONS, SIDX, ...
                                      VERBOSE, LABEL)
[DATA, WARNINGS] = PSSE_PARSE_SECTION(WARNINGS, RECORDS, SECTIONS, SIDX, ...
                                      VERBOSE)
[DATA, WARNINGS] = PSSE_PARSE_SECTION(WARNINGS, RECORDS, SECTIONS, SIDX)
```

(continues on next page)

(continued from previous page)

```
[DATA, WARNINGS] = PSSE_PARSE_SECTION(WARNINGS, RECORDS, VERBOSE, LABEL, ...
                                      TEMPLATE)
[DATA, WARNINGS] = PSSE_PARSE_SECTION(WARNINGS, RECORDS, VERBOSE, LABEL)
[DATA, WARNINGS] = PSSE_PARSE_SECTION(WARNINGS, RECORDS, VERBOSE)
[DATA, WARNINGS] = PSSE_PARSE_SECTION(WARNINGS, RECORDS)

Inputs:
    WARNINGS :  cell array of strings containing accumulated
                warning messages
    RECORDS :   a cell array of strings returned by PSSE_READ
    SECTIONS :  a struct array returned by PSSE_READ
    SIDX :      (optional) index if the section to be read
                if included, the RECORD indices are taken from
                SECTIONS(SIDX), otherwise use all RECORDS
    VERBOSE :   1 to display progress info, 0 (default) otherwise
    LABEL :     (optional) name for the section, to be compared with
                the section name typically found in the
                END OF <LABEL> DATA comment at the end of each section
    TEMPLATE :  (optional) string of characters indicating how to
                interpret the type of the corresponding column, options
                are as follows:
            d, f or g : integer floating point number to be converted
                via SSCANF with %d, %f or %g, respectively.
            D, F or G : integer floating point number, possibly enclosed
                in single or double quotes, to be converted via
                SSCANF with %d, %f or %g, respectively.
            c or s : character or string, possibly enclosed in single
                or double quotes, which are stripped from the string
        Note:   Data columns in RECORDS that have no valid corresponding
                entry in TEMPLATE (beyond end of TEMPLATE, or a character
                other than those listed, e.g. '.') are returned in DATA.txt
                with no conversion. TEMPLATE entries for which there is
                no corresponding column in RECORDS are returned as NaN and
                empty, respectively, in DATA.num and DATA.txt.

Output:
    DATA :      a struct with two fields:
        num :   matrix containing the numeric data for the section, for
                columns with no numeric data, num contain NaNs.
        txt :   a cell array containing the non-numeric (char/string)
                data for the section, for columns with numeric data,
                txt entries are empty
    WARNINGS :  cell array of strings containing updated accumulated
                warning messages
```

See also psse2mpc(), *psse_parse()* (page 368).

psse_read

psse_read(*rawfile_name*, *verbose*)

psse_read() (page 371) - Reads the data from a PSS/E RAW data file.

```
[RECORDS, SECTIONS] = PSSE_READ(RAWFILE_NAME)
[RECORDS, SECTIONS] = PSSE_READ(RAWFILE_NAME, VERBOSE)

Reads the data from a PSS/E RAW data file into a cell array of
strings, corresponding to the lines/records in the file. It
detects the beginning and ending indices of each section as well
as any Q record used to indicate the end of the data.

Input:
    RAWFILE_NAME :  name of the PSS/E RAW file to be read
                    (opened directly with FILEREAD)
    VERBOSE      :  1 to display progress info, 0 (default) otherwise

Output:
    RECORDS :   a cell array of strings, one for each line in
                the file (new line characters not included)
    SECTIONS  : a struct array with the following fields
        first : index into RECORDS of first line of the section
        last  : index into RECORDS of last line of the section
        name  : name of the section (if available) extracted
                from the 'END OF <NAME> DATA, BEGIN ... DATA'
                comment typically found in the terminator line
```

See also `psse2mpc()`.

5.3 Legacy Tests

5.3.1 Legacy MATPOWER Tests

t_apply_changes

t_apply_changes(*quiet*)

t_apply_changes() (page 371) - Tests for *apply_changes()* (page 328).

t_auction_minopf

t_auction_minopf(*quiet*)

t_auction_minopf() (page 372) - Tests for code in auction.m, using MINOPF solver.

t_auction_mips

t_auction_mips(*quiet*)

t_auction_mips() (page 372) - Tests for code in auction.m, using MIPS solver.

t_auction_tspopf_pdipm

t_auction_tspopf_pdipm(*quiet*)

t_auction_tspopf_pdipm() (page 372) - Tests for code in auction.m, using PDIPMOPF solver.

t_chgtab

t_chgtab()

t_chgtab() (page 372) - Returns a change table for testing *apply_changes()* (page 328).

t_cpf

t_cpf(*quiet*)

t_cpf() (page 372) - Tests for legacy continuation power flow.

t_dcline

t_dcline(*quiet*)

t_dcline() (page 372) - Tests for DC line extension in *toggle_dcline()* (page 304).

t_ext2int2ext

t_ext2int2ext(*quiet*)

t_ext2int2ext() (page 372) - Tests `ext2int()`, `int2ext()`, and related functions.

Includes tests for *get_reorder()* (page 259), *set_reorder()* (page 259), *e2i_data()* (page 254), *i2e_data()* (page 257), *e2i_field()* (page 255), *i2e_field()* (page 258), `ext2int()`, and `int2ext()`.

t_feval_w_path

t_feval_w_path(*quiet*)

t_feval_w_path() (page 373) - Tests for *feval_w_path()* (page 333).

t_get_losses

t_get_losses(*quiet*)

t_get_losses() (page 373) - Tests for *get_losses()* (page 337).

t_hasPQcap

t_hasPQcap(*quiet*)

t_hasPQcap() (page 373) - Tests for *hasPQcap()* (page 338).

t_hessian

t_hessian(*quiet*)

t_hessian() (page 373) - Numerical tests of 2nd derivative code.

t_islands

t_islands(*quiet*)

t_islands() (page 373) - Tests for *find_islands()* (page 334), *extract_islands()* (page 332), *connected_components()* (page 354) and *case_info()* (page 330).

t_jacobian

t_jacobian(*quiet*)

t_jacobian() (page 373) - Numerical tests of partial derivative code.

t_load2disp

t_load2disp(*quiet*)

t_load2disp() (page 374) - Tests for `load2disp()`.

t_loadcase

t_loadcase(*quiet*)

t_loadcase() (page 374) - Test that `loadcase()` works with a struct as well as case file.

t_makeLODF

t_makeLODF(*quiet*)

t_makeLODF() (page 374) - Tests for *makeLODF()* (page 326).

t_makePTDF

t_makePTDF(*quiet*)

t_makePTDF() (page 374) - Tests for *makePTDF()* (page 326).

t_margcost

t_margcost(*quiet*)

t_margcost() (page 374) - Tests for `margcost()`.

t_miqps_matpower

t_miqps_matpower(*quiet*)

t_miqps_matpower() (page 374) - Tests of MIQP solvers via (deprecated) *miqps_matpower()* (page 324).

t_modcost

t_modcost(*quiet*)

t_modcost() (page 374) - Tests for code in `modcost()`.

t_mpoption

t_mpoption(*quiet*)

t_mpoption() (page 375) - Tests for mpoption().

t_mpoption_ov

t_mpoption_ov()

t_mpoption_ov() (page 375) - Example of option overrides from file.

t_off2case

t_off2case(*quiet*)

t_off2case() (page 375) - Tests for off2case.

t_opf_dc_bpmpd

t_opf_dc_bpmpd(*quiet*)

t_opf_dc_bpmpd() (page 375) - Tests for legacy DC optimal power flow using BPMPD_MEX solver.

t_opf_dc_clp

t_opf_dc_clp(*quiet*)

t_opf_dc_clp() (page 375) - Tests for legacy DC optimal power flow using CLP solver.

t_opf_dc_cplex

t_opf_dc_cplex(*quiet*)

t_opf_dc_cplex() (page 375) - Tests for legacy DC optimal power flow using CPLEX solver.

t_opf_dc_default

t_opf_dc_default(*quiet*)

t_opf_dc_default() (page 375) - Tests for legacy DC optimal power flow using DEFAULT solver.

t_opf_dc_glpk

t_opf_dc_glpk(*quiet*)

t_opf_dc_glpk() (page 376) - Tests for legacy DC optimal power flow using GLPK solver.

t_opf_dc_gurobi

t_opf_dc_gurobi(*quiet*)

t_opf_dc_gurobi() (page 376) - Tests for legacy DC optimal power flow using Gurobi solver.

t_opf_dc_ipopt

t_opf_dc_ipopt(*quiet*)

t_opf_dc_ipopt() (page 376) - Tests for legacy DC optimal power flow using MIPS solver.

t_opf_dc_mips

t_opf_dc_mips(*quiet*)

t_opf_dc_mips() (page 376) - Tests for legacy DC optimal power flow using MIPS solver.

t_opf_dc_mips_sc

t_opf_dc_mips_sc(*quiet*)

t_opf_dc_mips_sc() (page 376) - Tests for legacy DC optimal power flow using MIPS-sc solver.

t_opf_dc_mosek

t_opf_dc_mosek(*quiet*)

t_opf_dc_mosek() (page 376) - Tests for legacy DC optimal power flow using MOSEK solver.

t_opf_dc_osqp

t_opf_dc_osqp(*quiet*)

t_opf_dc_osqp() (page 376) - Tests for legacy DC optimal power flow using OSQP solver.

t_opf_dc_ot

t_opf_dc_ot(*quiet*)

t_opf_dc_ot() (page 377) - Tests for legacy DC optimal power flow using Opt Tbx solvers.

t_opf_default

t_opf_default(*quiet*)

t_opf_default() (page 377) - Tests for legacy AC optimal power flow using default solver.

t_opf_fmincon

t_opf_fmincon(*quiet*)

t_opf_fmincon() (page 377) - Tests for legacy FMINCON-based optimal power flow.

t_opf_ipopt

t_opf_ipopt(*quiet*)

t_opf_ipopt() (page 377) - Tests for legacy IPOPT-based AC optimal power flow.

t_opf_knitro

t_opf_knitro(*quiet*)

t_opf_knitro() (page 377) - Tests for legacy Artelys Knitro-based optimal power flow.

t_opf_minopf

t_opf_minopf(*quiet*)

t_opf_minopf() (page 377) - Tests for legacy MINOS-based optimal power flow.

t_opf_mips

t_opf_mips(*quiet*)

t_opf_mips() (page 377) - Tests for legacy MIPS-based AC optimal power flow.

t_opf_model

t_opf_model(*quiet*)

t_opf_model() (page 378) - Tests for *opf_model* (page 219).

t_opf_softlims

t_opf_softlims(*quiet*)

t_opf_softlims() (page 378) - Tests for userfcn callbacks (softlims) w/OPF.

Includes high-level tests of soft limits implementations.

t_opf_tspopf_pdipm

t_opf_tspopf_pdipm(*quiet*)

t_opf_tspopf_pdipm() (page 378) - Tests for legacy PDIPM-based optimal power flow.

t_opf_tspopf_scpdipm

t_opf_tspopf_scpdipm(*quiet*)

t_opf_tspopf_scpdipm() (page 378) - Tests for legacy SCPDIPM-based optimal power flow.

t_opf_tspopf_tralm

t_opf_tspopf_tralm(*quiet*)

t_opf_tspopf_tralm() (page 378) - Tests for legacy TRALM-based optimal power flow.

t_opf_userfcns

t_opf_userfcns(*quiet*)

t_opf_userfcns() (page 378) - Tests for userfcn callbacks (reserves/iflims) w/OPF.

Includes high-level tests of reserves and iflims implementations.

t_pf_ac

t_pf_ac(*quiet*)

t_pf_ac() (page 379) - Tests for legacy AC power flow solvers.

t_pf_dc

t_pf_dc(*quiet*)

t_pf_dc() (page 379) - Tests for legacy DC power flow solver.

t_pf_radial

t_pf_radial(*quiet*)

t_pf_radial() (page 379) - Tests for legacy distribution power flow solvers.

t_printpf

t_printpf(*quiet*)

t_printpf() (page 379) - Tests for `printpf()`.

t_psse

t_psse(*quiet*)

t_psse() (page 379) - Tests for `psse2mpc()` and related functions.

t_qps_matpower

t_qps_matpower(*quiet*)

t_qps_matpower() (page 379) - Tests of QP solvers via (deprecated) *qps_matpower()* (page 324).

t_runmarket

t_runmarket(*quiet*)

t_runmarket() (page 379) - Tests for runmkt, smartmkt and auction.

t_runopf_w_res

t_runopf_w_res(*quiet*)

t_runopf_w_res() (page 380) - Tests *runopf_w_res()* (page 235) and the associated callbacks.

t_scale_load

t_scale_load(*quiet*)

t_scale_load() (page 380) - Tests for *scale_load()* (page 348).

t_total_load

t_total_load(*quiet*)

t_total_load() (page 380) - Tests for *total_load()* (page 350).

t_totcost

t_totcost(*quiet*)

t_totcost() (page 380) - Tests for `totcost()`.

t_vdep_load

t_vdep_load(*quiet*)

t_vdep_load() (page 380) - Test voltage dependent ZIP load model for legacy PF, CPF, OPF.

5.3.2 Legacy MATPOWER Test Data

opf_nle_fcn1

opf_nle_fcn1(*x*)

opf_nle_fcn1() (page 380) - Example user-defined nonlinear OPF constraint function.

opf_nle_hess1

opf_nle_hess1(*x*, *lambda*)

opf_nle_hess1() (page 381) - Example user-defined nonlinear OPF constraint Hessian.

t_auction_case

t_auction_case()

t_auction_case() (page 381) - Power flow data for testing auction code.

Please see caseformat for details on the case file format.

t_case30_userfcns

t_case30_userfcns()

t_case30_userfcns() (page 381) - Power flow data for 30 bus, 6 gen case w/reserves & iflims.

Please see caseformat for details on the case file format.

Same as `case30.m`, but with fixed reserve and interface flow limit data. The reserve data is defined in the fields of `mpc.reserves` and the interface flow limit data in `mpc.if` at the bottom of the file.

t_case9_dcline

t_case9_dcline()

t_case9_dcline() (page 381) - Same as *t_case9_opfv2()* (page 382) with addition of DC line data.

Please see caseformat for details on the case file format.

See also *toggle_dcline()* (page 304), *idx_dcline()* (page 343).

t_case9_opf

t_case9_opf()

t_case9_opf() (page 381) - Power flow data for 9 bus, 3 generator case, with OPF data.

Please see caseformat for details on the case file format.

t_case9_opfv2

t_case9_opfv2()

t_case9_opfv2() (page 382) - Power flow data for 9 bus, 3 generator case, with OPF data.

Please see caseformat for details on the case file format.

t_case9_pf

t_case9_pf()

t_case9_pf() (page 382) - Power flow data for 9 bus, 3 generator case, no OPF data.

Please see caseformat for details on the case file format.

t_case9_pfv2

t_case9_pfv2()

t_case9_pfv2() (page 382) - Power flow data for 9 bus, 3 generator case, no OPF data.

Please see caseformat for details on the case file format.

t_case9_save2psse

t_case9_save2psse()

t_case9_save2psse() (page 382) - Power flow data to test `save2psse()`.

Please see caseformat for details on the case file format.

t_case_ext

t_case_ext()

t_case_ext() (page 382) - Case data in external format used to test `ext2int()` and `int2ext()`.

t_case_int

t_case_int()

t_case_int() (page 382) - Case data in internal format used to test `ext2int()` and `int2ext()`.

t_cpf_cb1

t_cpf_cb1(*k*, *nx*, *cx*, *px*, *done*, *rollback*, *evnts*, *cb_data*, *cb_args*, *results*)

t_cpf_cb1() (page 383) - User callback function 1 for continuation power flow testing.

t_cpf_cb2

t_cpf_cb2(*k*, *nx*, *cx*, *px*, *done*, *rollback*, *evnts*, *cb_data*, *cb_args*, *results*)

t_cpf_cb2() (page 383) - User callback function 2 for continuation power flow testing.

Index

A

B

C

D

E

F

G

H

I

K

L

M

N

O

P

Q

R

S

T

U

V

W

X

Y

Z