

# Inspection Report



## Building Codes Permit: 23-0596

<b>Project Name:</b>	3400 Tipton Station 2023-A	<b>File Number:</b>	23-0596
<b>Address:</b>	3400 Tipton Station Rd 37920	<b>Parcel Number:</b>	147 16203
<b>Subdivision:</b>	Godfrey Gardens	<b>Lot #:</b>	3
<b>Type of Work:</b>	Framing - BC	<b>Task ID:</b>	0121142
<b>Result:</b>			
<b>Completed By:</b>	Wayne Williamson	<b>Completed Date:</b>	4/11/2024

## Inspection Details

**Inspection Notes:** Reject framing

- 1 submit engineer's letters on footings, under slab plumbing, and slab prep, include permit number and engineer's stamp
- 2 must obtain a building permit for detached shed
- 3 submit structural engineer's letter on construction with wood power poles supporting roof system. Address connections, sizes, and bracing
- 4 have structural engineer address three 2 x 12 girder spliced in open spans, and over spanned