

شركة أبناء عبد المحسن بن سحزري
ABDULLAH A.M. AL-KHODARI SONS CO.

RISK ASSESSMENT FORM	C-Consequence	F-Frequency
Operation: Temp Duct Diversion	1-Negligible/no effect	1-Negligible
	2- Minor injury	2-Unlikely
	3-Major Injury	3-Likely
	4-Fatality	4-Probable

Hazard	Effect	Persons Effected	R isk Before		Control	Risk After	
			F	C		F	C
Plant Movement	Risk of crushing, impact and death	All Site personnel	4	3	Plant shall have reversing bleeper where possible. All workers to wear PPE and banks men to be used	4	2
Disc Cutters, Small Tools	Risk of cuts, loss of limb, dust pollution	Operatives	3	3	Only trained personnel to be used. Masks and Goggles where required Tool Box Talks	2	2
Existing Services underground and over head	Risk of electrocution	operatives	2	3	Permit to Dig System. Tool Box talks	2	2
Lifting and carrying	Strains minor injuries	operatives	3	2	Instruction in safe methods of work. Induction. Tool box Talks	2	2

General	
---------	--

Person completing assessment.....(sign).....JIM POLLITT.....(print).....27.01.2007.....(date)