ReTrust-OT V1 / RT4

How the score is calculated

20 October 2026. Higher scores indicate more favourable evidence under the selected settings. The score is a decision aid, not a probability that equipment is safe.

Z = T x A x H x U

Factor	What it measures	V1 rule
T	Exploitation evidence	max(KEV, LEV, EPSS). Confirmed exploitation is 1; missing sources stay unavailable.
A	Attack access	1 for a feasible path with prerequisites met; 0 for a verified block; otherwise [0,1].
H	Credible OT harm	Safety/environment 1; control .8; recoverable disruption .5; minor .2; no material harm 0. Unknown is [0,1].
U	Affected and unfixed	1 for affected, unpatched firmware; 0 for verified fixed or not affected; otherwise [0,1].

Network access is a main input

Select isolated, OT-only, IT-OT, remote vendor access, direct Internet or unknown. Then establish actual reachability. An isolated controller may still be accessible from a compromised industrial workstation. Topology alone gives no numerical discount.

ReTrust does not scan the network. Site answers are operator-reported and need supporting evidence. A firewall changes attack access; it does not count as installing a firmware patch.

CVSS severity remains useful context, but is not multiplied into H. An engineer must establish the credible effect of the particular weakness, rather than assigning every weakness the importance of the whole plant.

A worked calculation

Illustrative inputs, calculated by the production scoring functions. These are not findings about an actual PLC.

Input	Value	Reason
T	.60	max(0, .60, .12)
A	1	Path reachable; required conditions satisfied
H	.80	Credible major loss of process control
U	1	Selected firmware affected and not patched

```
Z1 = .60 x 1 x .80 x 1 = .48
```

The highest contribution counts fully

```
R = min(1, Z1 + .20 Z2 + .10 Z3)
E = 100 x (1 - R)
```

Contributions	R	Exposure safety E
.48	.48	52
.48 and .20	.52	48
.48, .20 and .10	.53	47

Repeated advisory records for one CVE count once. Different CVEs are review units, not proof of independent attack paths. An engineer can explicitly group a reviewed shared path. Only the largest three units contribute; R clips at 1.

Combine the four pillars

```
S = E^.60 x P^.20 x V^.15 x C^.05
```

With E=47, P=70, V=80 and C=60: **S = 55.80/100**. The current 70/40 bands give CONDITIONAL, assuming verified inputs and no mandatory blocker.

Unknown means VERIFY

If only U is unknown in the worked weakness, Z is between 0 and .48. Exposure safety is between 52 and 100. ReTrust carries the bounds into the final score and lists the checks needed before deciding. It does not guess a middle value.

Example from the local index

ABB AC 800M: VERIFY; provisional score range **68.2-87.7/100**. No deployment or firmware inputs were supplied. Rebuild this sheet against a changed index to refresh the example.

Next check	Who can help
Network context and attack access	Network or OT security owner
Credible consequence of each weakness	Operations or safety engineer
Affected firmware and installed fixes	Asset owner or product supplier
Missing exploitation data	Security analyst; refresh public sources

Decision rules

PREFER: 70 or higher. CONDITIONAL: 40 to below 70. AVOID: below 40 or a mandatory blocker. VERIFY: material evidence remains unresolved. NOT ASSESSED: insufficient product evidence to calculate a score.

Pillars enter the final product with a floor of 1. Missing patch, vendor or certification evidence is excluded and the remaining exponents are adjusted. Unknown exposure stays in the range. Measured certification participates directly. Unfixed hardcoded credentials cap the result below PREFER.

Evidence and limits

Save JSON or HTML to retain RT4 settings, factor bounds, advisory citations and source capture dates. Per-finding reviews can retain rationale and evidence. Website answers apply across the findings in scope; review findings individually when their consequences or controls differ.

The weights, OT consequence values and multiplication are proposed ReTrust design choices that require validation. Historical benchmarks from earlier scoring models do not validate RT4 procurement decisions. KEV, LEV and EPSS have different time horizons; their maximum is a threat-priority index, not a calibrated compromise probability.