



Sri Lanka Institute of Information Technology

Report on Industrial Training

At

Zhongnan SZSG JH Joint Venture Company

Name: WASEEM M.S.M

Registration No: EN22153340

Course: BSc. Engineering (Hons) Degree

Field of Specialization: Electrical and Electronics Engineering

Period of Training: 10th June 2024 to 30th August 2024

Abstract

To finish their four-year degree, all undergraduate students in the Electrical and Electronics Engineering department must participate in a 12-week industrial training program. From June 10 to August 30, 2024, I had the honors of finishing my first industrial training at Zhongnan SZSG JH Joint Venture Company. I learnt a lot from practical experience during this time, working under the guidance of supervisors and engineers. My training encompassed a broad range of topics, such as instrumentation, motor and pump installation, surge vessel level maintenance, operating Variable Frequency Drives (VFDs), insulation testing, and relay operations. The knowledge and abilities I gained from this priceless training experience are outlined in this report.

Acknowledgement

Using this wonderful chance, I would want to sincerely thank everyone who helped me achieve in my industrial basic program by providing their best cooperation. First, I would like to express my gratitude to the SLIIT training division for giving students the chance to gain additional industry knowledge and practical experience while they are still enrolled in the school.

I would like to thank Zhongnan SZSG JH Join Venture Company's directors and employees for their assistance. I would like to express my sincere gratitude to the Technical Manager, Eng. Nuwan Tharanga, the Electrical and Engineer, Eng. Chamara Sandaruwan and Health and Safety Engineer, Eng. Manjula Jayasinghe, the Project Engineers, Eng. Lohitha and Kanchana, for their invaluable assistance and guidance during the training. Additionally, I would like to express my gratitude to the workers and other Ambathale Water Treatment Plant Project team members for their assistance in making my training time a success.

Lastly, I would like to express my gratitude to everyone who has been mentioned above as well as everyone else who has ever supported me. I further attest that this report is my original work and does not violate any copyrights.

List of Abbreviations

SCADA	: Supervisory Control and Data Acquisition
VFD	: Variable Frequency Drive
PVC	: Poly Vinyl Chloride
XLPE	: Cross Linked Polyethylene
MSB	: Main Switch Board
MCCB	: Molded Case Circuit Breaker
RCCB	: Residual Current Circuit Breaker
DE	: Drive End
NDE	: Non-Drive End
DOL	: Direct On-Line
CEB	: Ceylon Electricity Board
HV Panel	: High Voltage Panel
LV Panel	: Low Voltage Panel
ESB	: Essential Switch Board
BSP	: Band Screen Panel
SWA	: Steel Wire Armored

List of Figures

Figure 1.1 Company Logo	1
Figure 3.1 Phase to Ground Insulation Test.....	6
Figure 3.2 Phase to Phase Insulation Result	6
Figure 3.3 Phase to Phase Insulation Test	6
Figure 3.4 Phase to Ground Insulation Result	6
Figure 3.5 Winding Insulation Test.....	6
Figure 3.6 Winding Insulation Result	6
Figure 3.7 Pump Vibration.....	7
Figure 3.8 Pump Cooling System.....	7
Figure 3.9 Surge Vessels Level Indicator Measurement	8
Figure 3.10 Air Compressor Control Panel	8
Figure 3.11 Compressor Mode Selection.....	8
Figure 3.13 Pressure Gauge	8
Figure 3.12 Compressor Start.....	8
Figure 3.14 Air Supply Valve	9
Figure 3.15 Compressor Outlet Valve	9
Figure 3.16 After Air Supply Scale Measurement	9

List of Tables

Table 2.1 Instrumentation List 5

Table 2.2 Cables with Insulation types..... 5

List of Charts

Chart 1.1 Management Structure 2

Contents

Abstract.....	i
Acknowledgement	ii
List of Abbreviations.....	iii
List of Figures	iv
List of Tables	v
List of Charts	vi
1.0 INTRODUCTION TO TRAINING ESTABLISHMENT.....	1
1.1 Introduction	1
1.2 Vision and Mission	1
<i>1.2.1 Vision:.....</i>	<i>1</i>
<i>1.2.2 Mission:.....</i>	<i>1</i>
1.3 Company Background/History.....	1
2.0 TRAINING EXPERIENCE IN MANAGEMENT	2
2.1 Organizational management structures and reporting procedures.	2
2.2 Work progress monitoring techniques.....	2
2.2.1 SCADA.....	2
2.2.2 Manual Inspection and Log Keeping	3
2.2.3 Flow and Pressure Monitoring	4
2.2.4 Remote Monitoring	4
2.3 Administrative practices	5
2.3.1 Documentation	5
3.0 TRAINING EXPERIENCE IN TECHNICAL PROFICIENCY	6
3.1 Testing participated in or observed.....	6
3.2 Maintenance and Quality control.	7
3.2.1 Maintenance	7
3.2.2 Quality Control.....	10
3.3 Hands-on experience gained through testing instruments.....	11
3.4 Problems encountered and how they were resolved.....	13
3.4.1 Problem Encountered.....	13
3.4.2 how they were resolved.	13

4.0 ACQUIRED SOFT SKILLS	15
4.1 Soft Skills Gained.....	15
4.2 Soft Skill Training programs underwent.	16
4.3 Soft skill development activities.....	17
5.0 PRACTICE OF PROFESSIONAL STANDARDS AND ENGINEERING ETHICS, AND ENVIRONMENT & SUSTAINABILITY	19
5.1 Ethical considerations in decision-making processes.	19
<i>5.1.1 Safety</i>	19
<i>5.1.2 Compliance with Laws and Standards</i>	19
<i>5.1.3 Transparency and Honesty.....</i>	19
<i>5.1.4 Sustainability</i>	20
<i>5.1.5 Accountability</i>	20
<i>5.1.6 Confidentiality.....</i>	20
<i>5.1.7 Equity and Fairness</i>	20

1.0 INTRODUCTION TO TRAINING ESTABLISHMENT.

1.1 Introduction

Organization : Zhongnan SZSG JH Joint Venture Company

Logo :



Figure 1.1 Company Logo

Location of the Project Office: Ambathale Water Treatment Plant

Telephone : +94 11 3671821

Email : zhszjhjv@gmail.com

Website : <https://www.volza.com>

1.2 Vision and Mission

1.2.1 Vision:

To be the most prestigious utility Organization in Sri Lanka through technological and service excellence.

1.2.2 Mission:

Serve the nation by providing sustainable water and sanitation solutions ensuring total user satisfaction

1.3 Company Background/History

Several businesses work together in the Zhongnan SZSG JH Joint Venture (JV), contributing their individual specialties to the delivery of large-scale infrastructural, electrical, and engineering projects. The JV was probably formed to pool the strengths of partners like SZSG, which would concentrate on mechanical and electrical engineering, JH, which might provide project management or specialized technical services, and Zhongnan, which develops infrastructure. Utilizing the combined experience of its members, the JV seeks to implement complicated projects such as power plants, industrial installations, and energy systems to provide superior, cutting-edge solutions in industries that are expanding quickly.

2.0 TRAINING EXPERIENCE IN MANAGEMENT

2.1 Organizational management structures and reporting procedures.




Chart 1.1 Management Structure

2.2 Work progress monitoring techniques.

2.2.1 SCADA

Extremely sophisticated technology used to monitor and manage industrial operations' functions, including pump houses. SCADA systems are essential because they offer real-time monitoring of devices such as sensors, valves, and pumps. The system makes it possible for operators to remotely check vital indicators including water levels, pressure, flow rate, and power usage, guaranteeing the safe and effective operation of the pump house.

Automation of control procedures is one of SCADA's primary features. By using the technology, operators can remotely modify valves, start or stop pumps, and switch between manual and automated operations, all of which minimize the need for on-site staff. Because automation enables more accurate process control and speedier responses to shifting circumstances or possible issues, it improves operational efficiency.

Additionally, SCADA excels in gathering and storing data. It continuously collects data from sensors placed throughout the pump house and stores it for further analysis. To improve system performance, foresee errors, and streamline operations, this data is crucial. By looking for trends and patterns in this data, operators can make data-driven decisions on maintenance, energy management, and operational changes.

Furthermore, SCADA offers powerful notification and alarm systems. The system produces visual or audio alerts and notifies users via email or SMS if a problem occurs, such as a variation in pressure or flow rate. By enabling operators to take immediate action to resolve problems before they worsen, this early warning capability reduces the chance of process failure or equipment damage.

2.2.2 Manual Inspection and Log Keeping

Personnel perform scheduled, on-account checks on a regular basis to guarantee that all parts including pumps, valves, motors, and electrical systems—are operating as intended. By identifying tangible indicators of wear and tear, leaks, strange noises, or vibrations that automated systems could miss, manual inspections assist ensure a thorough evaluation of the pump house's condition.

Employees go through a checklist of things to check during these inspections, including temperature readings, fluid levels, pressure gauges, and the physical condition of the equipment. Inspectors make sure that safety procedures are followed as well as noting any anomalies for additional inquiry. The human aspect of monitoring is added by this hands-on method, which enables skilled operators to apply their judgement to spot any problems that sensors might overlook, such as minor mechanical faults or early corrosion symptoms.

An essential part of manual inspections is keeping logs. During inspections, all observations, measurements, and actions are documented in logbooks or digital systems. These records provide information about the equipment inspected, the time and date of the inspection, any anomalies discovered, and the corrective actions implemented. Maintaining accurate logs is essential for diagnosing and scheduling future maintenance since they offer a historical record of the pump house's performance and repair actions.

2.2.3 Flow and Pressure Monitoring

The measuring of the amount of liquid (such as water, oil, or other fluids) that travels through a pipeline or pump system in a specific amount of time is known as flow monitoring. It guarantees that the pumps are supplying the necessary volume of fluid to fulfil operating requirements. Flow meters are frequently used for this purpose and can give information on the overall volume transported, the flow rate, and whether the system is performing as efficiently as it should.

Contrarily, pressure monitoring is concerned with measuring the force that the fluid applies as it passes through the system. It is essential to maintain the proper pressure since excessively high or low pressures might create damage or inefficiency in the system. Low pressure may signal blockages or pump failure, resulting in decreased flow or total system shutdown, whereas high pressure may suggest leaks, bursts, or damage to pipes, valves, and pumps.

In pump systems, flow and pressure monitoring cooperate to keep the balance. These sensors continuously transmit data to SCADA and other centralized control systems, allowing operators to view the pump house's current state in real time. Alarms are set off by the system to notify the operators of any deviations from the typical range, such as a sudden spike in pressure or a dip in flow.

2.2.4 Remote Monitoring

Tracking pump and system performance in real-time from any location is one of the main advantages of remote monitoring. Through a secure web-based or mobile interface, operators can get data on flow rates, pressure levels, water levels, temperature, and equipment status. Wireless data transmission from pump house sensors to a cloud-based platform or centralized control system allows for continuous monitoring without requiring staff to be present on site.

2.3 Administrative practices

2.3.1 Documentation

Documented the following instruments that were partially or fully flooded or replaced:

Table 2.1 Instrumentation List

No.	Instrumentation	Make	Model	IP Rating
1	Differential Pressure Transmitter	Endress+Hauser	PMD55	IP66/IP68
2	Liquiline System	Endress+Hauser	CA80AL	IP55
3	Ultrasonic Level Transmitter	Endress+Hauser	FMU41	IP68/NEMA 6P
4	Prosonic S Sensor	Endress+Hauser	FDU92	IP68/NEMA6P
5	Prosonic S Display	Endress+Hauser	FMU90	IP66/67/NEMA4X
6	Pressure Transmitter	Endress+Hauser	PMC51	IP66/IP68/NEMA4/6P
7	Liquiline	Endress+Hauser	CM442	IP66/67/NEMA4X
8	Actuator	AUMA	D73747	IP68

Documented the following cables, including their location of use, insulation type, number of cores, area of conductance, insulation voltage, purpose, and length used:

Table 2.2 Cables with Insulation types

No.	Insulation Type	Circuit Voltage (V)	No of Cores	Area (mm ²)
1	Cu/XLPE/SWA/PVC	600/1000	4	185
2	Cu/XLPE/SWA/PVC	600/1000	4	150
3	Cu/XLPE/SWA/PVC	600/1000	4	95
4	Cu/XLPE/Cu-T/PVC	600/1000	3	120
5	Cu/XLPE/SWA/PVC	600/1000	4	120
6	WDZA-YJY33	3600/6000	3	150
7	Cu/XLPE/SWA/PVC	600/1000	4	70
8	Cu/XLPE/AWA/PVC	600/1000	6	30
9	Cu/XLPE/PVC	600/1000	4	150
10	Cu/PVC/PVC	600/1000	12	1.5
11	Cu/PVC/SCR/PVC	300/500	2	1.5
12	Cu/XLPE/SWA/PVC	600/1000	4	300
13	Cu/PVC/PVC	600/1000	10	1.5
14	Cu/PVC/PVC	600/1000	3	1.5
15	Cu/PVC/SWA/PVC	600/1000	10	1.5

3.0 TRAINING EXPERIENCE IN TECHNICAL PROFICIENCY

3.1 Testing participated in or observed.

Insulation testing in cables



Figure 3.1 Phase to Ground Insulation Test



Figure 3.4 Phase to Ground Insulation Result



Figure 3.3 Phase to Phase Insulation Test



Figure 3.2 Phase to Phase Insulation Result

Insulation testing in Winding



Figure 3.5 Winding Insulation Test



Figure 3.6 Winding Insulation Result

3.2 Maintenance and Quality control.

3.2.1 Maintenance

Checking the Pump Vibration




Figure 3.7 Pump Vibration

Checking the Pump Cooling Water Level



Figure 3.8 Pump Cooling System

Surge Vessels Level Maintenance



Figure 3.9 Surge Vessels Level Indicator Measurement



Figure 3.10 Air Compressor Control Panel



Figure 3.12 Pressure Gauge



Figure 3.11 Compressor Mode Selection



Figure 3.13 Compressor Start



Figure 3.15 Compressor Outlet Valve



Figure 3.14 Air Supply Valve



Figure 3.16 After Air Supply Scale Measurement

To check and adjust the level on the Surge vessels, ensure the level indicator reads 75 cm (Figure 3.9). If the level exceeds 75 cm, decrease it using the air supply from the compressor. Start by checking the compressor mode selection (Figure 3.11) on the Air Compressor Control Panel (Figure 3.10), as there are two available compressors. Once the desired compressor is selected, it will start (Figure 3.13). Monitor the pressure gauge and ensure the reading falls between 0.6 to 0.9 (Figure 3.12). When the pressure is within range, open the compressor outlet valve (Figure 3.14) and the Surge Vessels Air Supply Valve (Figure 3.15). Wait until the level indicator reaches 75 cm. Once it does, close the Air Supply Valve and stop the compressor (Figure 3.16).

3.2.2 Quality Control

Water Quality Monitoring

Regular water quality monitoring is one of the most important parts of quality management at a water supply pump house. In order to detect pollutants like heavy metals or nitrates, as well as pH levels and chlorine residues, chemical testing is required. Finding dangerous diseases like E. Coli or coliform bacteria also requires the use of microbiological tests. In addition, tests are performed on the water's turbidity to guarantee that no suspended particles are present, and tests on its hardness to gauge the concentration of minerals like calcium and magnesium.

Pump and Equipment Maintenance

Pumps, valves, pipes, and other vital equipment need to be regularly inspected and maintained to guarantee a steady and effective water supply. This entails looking for wear, leaks, or malfunctions that can jeopardize functionality. To guarantee reliable monitoring, calibration of devices like flow meters and pressure sensors is also necessary. Preventive maintenance promotes system dependability and helps to avert unplanned equipment breakdowns. Examples of preventive maintenance include lubricating pumps and replacing worn parts.

Filtration and Treatment System Checks

A pump house's filtration systems are essential parts, and it is important to routinely check their integrity. It is crucial that these filters stay clear of obstructions and continue to operate as intended, whether sand filters, carbon filters, or other systems are being used. To guarantee safe treatment levels, the chemical treatment of the water especially when using disinfectants like chlorine needs to be continuously checked. Under-treatment can produce contaminated drinking water, while over-chlorination can produce hazardous byproducts.

Pressure and Flow Rate Monitoring

Reliability in water distribution to end users and the prevention of infrastructure damage depend on maintaining constant water pressure. Continuous monitoring of pressure levels throughout the system is necessary to prevent variations that might point to leaks or problems with the pumps. Similarly, careful control over water flow rate is required. Sustaining the appropriate flow guarantees that the system's requirements are fulfilled without overtaxing it or subjecting the pumps to needless strain.

Automation and SCADA Systems

Supervisory Control and Data Acquisition (SCADA) systems are commonly used in modern water supply pump buildings because they provide remote operation monitoring and control. Real-time data on water quality, pressure, and system performance is provided by SCADA systems, which facilitates the early detection and resolution of problems. Features for data logging can monitor patterns over time, making it possible to spot anomalies before they become major issues and increasing productivity.

3.3 Hands-on experience gained through testing instruments.

Some transmitters and systems were flooded, so they were tested to see if they could be used after drying; otherwise, they were sent for replacement.



Figure 3.19 Ultrasonic Level Transmitter



Figure 3.17 Pressure Transmitter



Figure 3.18 Differential Pressure Transmitter



Figure 3.22 Liquiline



Figure 3.21 Prosonic S Sensor



Figure 3.20 Nivotester

Some panels were shipped from overseas. They were checked to see if they worked and if there was any damage.



Figure 3.24 Wet DCS SYSTEM/
ANALOG MASH CABINET




Figure 3.23 Wet DCS DIGITAL
MARSH CABINET

3.4 Problems encountered and how they were resolved.

3.4.1 Problem Encountered

The motor does not work during pre-commissioning.

3.4.2 how they were resolved.

A power supply problem is a frequent cause of three-phase motor failures. The first thing to do if the motor will not start or run smoothly is to make sure the power supply is steady and operating within the necessary voltage range. Verify that all the fuses and circuit breakers attached to the motor are intact and operating properly. Taking care of any power supply problems is necessary before moving on to additional troubleshooting procedures.

One further problem could be improper wiring. Motor wiring diagrams specify the exact connections that must be made. The motor might not run at all if the wiring is not connected correctly. Make sure the wiring connections match the wiring schematic for the motor by closely inspecting them in order to fix this. Verifying that each terminal is correctly connected to the power source is essential.

A motor that is overloaded may show signs like sudden shutdown or inability to start. This frequently occurs when the pump is subjected to an extreme mechanical load or when the motor is operating above its rated capacity. Examine the pump for any obstructions or mechanical problems to fix this. Verify that the motor's load is within its intended capability and make any required adjustments to avoid overload.

A crucial part of motor operation is the motor starter and related control circuits. Problems with these parts may make it impossible for the motor to start. Look for any indications of damage or dysfunction in the control circuits, contactors, and motor starter. Make sure all electrical connections are safe and set up correctly and replace any broken parts.

Operating faults may also be brought on by issues with the motor's shaft or bearings. A stuck shaft or worn-out bearings might make it difficult for the motor to operate properly. Examine the bearings and shaft for damage or excessive wear to fix these problems. Lubricate or swap out any worn-out bearings, and make sure the shaft can spin freely without hindrance.

A number of electrical parts, like relays and capacitors, are essential to the motor's correct operation. The motor might not function properly if any of these parts malfunction. Test relays, capacitors, and other electrical parts with diagnostic equipment. To get back to normal motor operation, replace any that are malfunctioning.

For optimal operation, a three-phase motor necessitates a balanced power supply. A mismatch between the phases of the power supply may result in the motor operating irregularly or failing to start. To look for any phase imbalances, use a phase sequence and balance tester. To guarantee that every phase is balanced and functioning properly, address any problems with the power supply.

Failures in the insulation surrounding the motor may result in ground faults or short circuits, which stop the motor from operating. To examine the state of the motor windings, use an insulation resistance tester. To guarantee safe and efficient motor performance, any broken insulation must be fixed or replaced.

4.0 ACQUIRED SOFT SKILLS

4.1 Soft Skills Gained

Technical Skills

I gained a thorough understanding of pump operation and maintenance during my training at the pump house of the water treatment facility. I gained knowledge of the several kinds of pumps including positive displacement and centrifugal and how they are used in the water treatment industry. During my training, I learnt how to do routine and preventive maintenance as well as troubleshoot and repair issues. I also improved my capacity to evaluate pump performance data to guarantee smooth operation and address any problems that might come up.

Including the design, testing, and troubleshooting of electrical circuits and systems utilized in pump operations, I had a great deal of knowledge with electrical systems and controls. I have experience with Supervisory Control and Data Acquisition (SCADA) systems, PLCs, and control panels. A practical knowledge of wiring and installing electrical components while following safety procedures was another aspect of my training.

My training also placed a strong emphasis on instrumentation. To monitor and regulate pump house operations, I had to learn how to utilize and calibrate instruments for detecting vital factors like flow and pressure. My ability to interpret data from different sensors and devices allowed me to make sure the system was working.

Comprehending compliance and safety was essential to my training. I became knowledgeable about safety procedures and legal requirements pertaining to mechanical and electrical systems. To have a safe workplace and avoid mishaps, I also studied risk management techniques.

Practical Skills

I gained a great deal of practical experience via the course. My understanding of the practical components of pump house operations and electrical system management improved as I applied my academic knowledge to real-world settings. During my training, I addressed and resolved operational challenges, which helped me to acquire strong problem-solving abilities.

I took part in project work, contributing to efforts to upgrade electrical components, improve pump systems, and increase overall efficiency. One of the most important aspects of my job was documenting everything I did, including troubleshooting reports, maintenance logs, and system modifications. This helped me develop strong documentation abilities.

Professional Skills

My training improved my capacity for cooperation and communication. My ability to communicate effectively with engineers, technicians, and other stakeholders has improved because of collaborating with a multidisciplinary team. I improved my ability to produce reports that are precise and easy to understand while recording technical discoveries and participating in group discussions.

I improved my organizational and time management abilities, which helped me manage jobs and projects more effectively. A key component of my training was learning how to priorities tasks to meet deadlines and make sure everything runs well. This helped me manage my workload well and support the success of my team.

4.2 Soft Skill Training programs underwent.

Communication Skills

In any technological sector, effective communication is critical to success. You most certainly refined your ability to communicate intricate technical information succinctly and clearly throughout your training, both in written reports and spoken exchanges. This ability makes sure that supervisors and other team members comprehend your thoughts and discoveries, which promotes improved teamwork and more efficient operations.

Teamwork and Collaboration

Collaborating with different team members, such as engineers, technicians, and support staff, is a requirement of working in a pump house. You would have honed your skills in identifying roles, delegating tasks, and contributing to group goals while working cooperatively in a team. This experience facilitates the development of solid interpersonal bonds and the successful accomplishment of shared objectives.

Problem-Solving

In any industrial situation, problem identification and resolution skills are essential. As part of your training, you would have learnt to diagnose problems with mechanical and electrical systems, troubleshoot them, and put workable fixes in place. This ability improves your analytical and critical thinking skills, giving you the ability to take proactive approaches to problems.

Time Management

Efficient time management guarantees that assignments are finished on time and resources are used to their fullest potential. You learnt how to arrange your work schedule, prioritize your activities, and manage many responsibilities throughout your training. These skills are essential for staying productive and finishing projects on time.

Leadership

There may have been occasions to take the lead on initiatives or exercise initiative even in a training environment. Gaining leadership experience entails managing a group, reaching choices, and inspiring people to do tasks. These encounters boost your self-esteem and get you ready for leadership positions in the future.

Safety Protocols

Following safety protocols is essential in every industrial setting. In order to prevent accidents and maintain a safe working environment, part of your training would have been learning and adhering to safety regulations. Having this knowledge is essential if you want to safeguard others and yourself when using technology.

4.3 Soft skill development activities

Communication skills

Communication was an essential part of your training. Communicating with managers and coworkers on a regular basis about technical problems, project updates, and operational difficulties sharpened your communication skills. This involved written and verbal communication, which is necessary for reporting results and recording processes.

Problem-solving

The ability to solve problems became increasingly important as you came across and dealt with different technical issues. Developing effective solutions necessitated a synthesis of analytical thinking and practical application, encouraging a proactive attitude to overcoming hurdles, whether it was troubleshooting equipment faults or optimizing processes.

Time Management

Another important component of your training was effective time management. You learnt how to prioritize and manage your time effectively by juggling many activities, meeting deadlines, and keeping things running smoothly. This allowed you to handle both ordinary and urgent work with the right care.

Adaptability

Your expertise required you to be adaptable to unforeseen conditions like equipment faults or changes in project needs, therefore this was a crucial skill. In any engineering profession, the capacity to maintain adaptability and responsiveness in a changing setting is essential.

Leadership

There were also chances to exercise leadership, whether it was by taking charge of little tasks or assigning team members to particular assignments. This aided in the development of your sense of accountability as well as your capacity to encourage and assist others.

5.0 PRACTICE OF PROFESSIONAL STANDARDS AND ENGINEERING ETHICS, AND ENVIRONMENT & SUSTAINABILITY

5.1 Ethical considerations in decision-making processes.

5.1.1 Safety

In any technical or industrial setting, protecting the public's and workers' safety is the primary ethical duty. Preventing harm must be a top priority when making decisions, especially in domains like engineering where poor designs or mistakes in operation can result in mishaps, injuries, or even fatalities. Making ethical decisions, for instance, would entail making sure that the water distribution and filtration systems are routinely maintained in a water treatment facility to avoid contamination that could endanger public health. In addition, safety involves making sure that operating risks are kept to a minimum by appropriate training, frequent safety inspections, and observance of safety procedures.

5.1.2 Compliance with Laws and Standards

In the engineering and industrial domains, all decisions must adhere to industry standards and legal requirements. This covers professional norms of conduct, such as those provided by the IEEE Code of Ethics for Engineers, in addition to national and international legislation. Serious legal ramifications, financial penalties, and reputational harm may ensue from breaking these. Following environmental laws and water quality standards is essential in a water treatment plant to guarantee that the activities of the facility do not harm the environment or the community's health.

5.1.3 Transparency and Honesty

Making ethical decisions requires being transparent, particularly when it comes to outlining the possible drawbacks, difficulties, or hazards associated with a particular course of action or system. Sincere communication is essential to preserving confidence amongst all parties involved, including customers, employees, and regulatory agencies. When it comes to a water treatment plant, for example, being open and honest about problems like possible system failures or variations in the quality of the water might enable stakeholders to take prompt action to avoid more serious difficulties. Information omission or falsification may result in grave moral violations and endanger life.

5.1.4 Sustainability

Decision-making processes are increasingly turning to sustainability as a critical ethical factor, especially in sectors of the economy that have a big environmental impact. It is the moral duty of decision-makers to create and execute systems that minimize waste, preserve energy, and make effective use of available resources. This may entail streamlining operations to use less energy in a water treatment facility or making sure that the water is treated to environmental regulations, which would cut down on pollution and preserve natural water supplies for future generations.

5.1.5 Accountability

Making ethical decisions necessitates accepting full accountability for the results of one's choices. Being accountable guarantees that corrective actions may be made and that the decision-making process is continuously improved, regardless of whether a decision results in success or failure. This could entail accepting accountability for operational errors and working to stop them from happening again in a water treatment facility. Long-term success in an organization depends on a culture of trust and dependability, which accountability also promotes.

5.1.6 Confidentiality

Confidentiality maintenance is a crucial component in making moral decisions, particularly when managing sensitive material like private information, proprietary technology, or security procedures. To avoid security lapses or sabotage, this may entail protecting information regarding the operational systems of a water treatment facility. Making ethical decisions requires making sure that only people with the appropriate authorization or clearance can access such information.

5.1.7 Equity and Fairness

The foundation of an ethical decision-making process should be equity and fairness. This entails treating all parties equally and making sure that decisions don't negatively impact any one group or community more than others. Ensuring that everyone has equitable access to clean, safe water is a key ethical responsibility in the context of public utilities like water treatment. Any choice that jeopardizes this, whether due to bias or carelessness, would be regarded as immoral.

5.2 Health, Safety, and Environment (HSE) regulations and best practices in engineering.

5.2.1 Health

One major problem in engineering settings such as water treatment plants is health hazards. Employees may be subjected to physical strain, electrical risks, and pollutants. Companies carry out extensive risk assessments to find potential health concerns to control these risks. Wearing personal protective equipment (PPE) is mandatory for workers, particularly while handling chemicals or operating electrical systems. Examples of PPE include gloves, helmets, safety boots, and respiratory masks. While health monitoring programs make sure that workers exposed to chemicals or harsh environments receive routine health examinations to identify early indicators of potential problems, proper ergonomics in the workplace also help to reduce physical strain from repeated jobs.

5.2.2 Safety

Any engineering setting must prioritize safety, but this is especially true for water treatment facilities where workers handle potentially dangerous chemicals in addition to electrical equipment. Before performing maintenance or repairs, electrical safety precautions including lockout/tagout (LOTO) protocols make sure that the equipment is correctly de-energized. In order to avoid mishaps like electrical fires or shocks, workers must also routinely inspect electrical systems. Strict procedures must be followed while handling chemicals, such as chlorine. Safety Data Sheets (SDS) must be used for safe handling, labelling, and storage. Emergency protocols, including evacuation strategies and availability of first-aid supplies, are essential for handling mishaps. When employees enter tanks or pump rooms, where gas monitoring and emergency procedures are critical, confined space safety is even more important.

5.2.3 Environment

One of the main goals of HSE laws in water treatment facilities is environmental protection. Water plants need to carefully monitor and regulate their output to prevent harming neighboring water sources. By implementing pollution management methods, hazardous or untreated wastewater is kept out of the environment. To minimize consumption, the factory also optimizes pump systems and employs energy-efficient motors. Sludge, chemical waste, and byproducts produced during the treatment process must all be disposed of properly. Additionally, implementing sustainable practices lessens the environmental impact of the plant. Examples of these measures include employing renewable energy and conserving water.

5.2.4 Best Practices in HSE Management

It takes best practices in HSE management to keep a workplace safe and healthy. To keep personnel knowledgeable about the most recent safety measures and emergency processes, they include frequent training and awareness campaigns. Regular safety audits and inspections aid in spotting possible risks and guaranteeing adherence to rules. Corrective action is ensured swiftly by establishing a clear mechanism for reporting events and investigating accidents. By including guardrails and safety interlocks, safe work environment design averts mishaps before they occur. Lastly, adherence to regional, national, and worldwide safety standards like those set forth by OSHA ensures that the workplace satisfies all environmental and safety criteria.

5.3 Applicable Codes, Standards, and References in Engineering Applications.

The Institute of Electrical and Electronics Engineers provides essential collection of standards (IEEE). For industrial electrical systems to be safe and reliable, IEEE standards like IEEE 142 (grounding), IEEE 519 (harmonic control), and IEEE 1584 (arc flash analysis) are applied. These standards can be crucial in high-voltage situations like pump houses because they assist regulate power quality concerns, lessen electrical interference, and protect workers from arc flash events.

worldwide Electrotechnical Commission (IEC) standards are frequently used for worldwide applications. Water treatment facilities should pay close attention to IEC 60079, which regulates electrical equipment in explosive settings, and IEC 60364, which addresses the safety of electrical systems. These guidelines guarantee that electrical systems fulfil international safety regulations and contribute to the preservation of safety when handling dangerous chemicals.

Regulations from the Occupational Safety and Health Administration (OSHA) are equally significant for workplace electrical safety. OSHA regulations require the use of lockout/tagout (LOTO) procedures to safeguard employees from unintentional equipment activation. Requirements for personal protective equipment (PPE) also protect workers from electrical risks in pump buildings, which frequently hold high-power apparatus like motors and pumps.

The safety and operational performance of electrical installations and equipment are governed in part by ANSI (American National regulations Institute) regulations. ANSI standards guarantee that all equipment, from control panels to switchgear, satisfies strict design and safety criteria for industrial environments like pump houses, protecting both personnel and equipment.

The National Electrical Manufacturers Association (NEMA) offers essential requirements for equipment-specific standards. Pump house components such as motor control centers (MCCs) and electrical enclosures are made to meet the performance and protection requirements of NEMA standards and are specifically developed for industrial use.

Ultimately, industry-specific standards for water treatment, such those set forth by the American Water Works Association (AWWA), guarantee that the systems utilized for water treatment, filtration, and pumping fulfil all necessary operational and safety requirements. These guidelines reduce downtime while preserving service quality and dependability.

6.0 SUMMARY AND CONCLUSIONS

The Water Treatment Plant in Ambathale offered a comprehensive 12-week industrial training program that provided participants with valuable real-world experience across various topics, including motor and pump installation, insulation testing, and VFD operation. This exposure significantly enhanced my understanding and application of the theoretical concepts I learned during my BSc in Engineering (Electrical and Electronics). As a result, I now possess the skills and knowledge necessary to make meaningful contributions in the field of electrical engineering. I am confident that the insights gained from this program will greatly benefit my future career goals. My experience has equipped me with hands-on skills in motor and pump installation, insulation testing, VFD operation, and the maintenance and operation of surge vessels.

REFERENCES

MANUAL THREE PHASE MOTORS. (n.d.). Available at:

https://www.euronormdesign.nl/porting/cat/Euronorm_Electricmotors_manual_%5BENG%5D.pdf [Accessed 20 Sep. 2024].

The Complete Guide to Electrical Insulation Testing. (n.d.). Available at:

<https://www.instrumart.com/assets/Megger-Guide-to-Insulation-Testing.pdf>. [Accessed 20 Sep. 2024].

www.valin.com. (n.d.). *Controlling Compressor Vibration and Surge* | Valin. [online]

Available at: <https://www.valin.com/resources/articles/controlling-compressor-vibration-and-surge#:~:text=Surge%20occurs%20when%20there%20is>. [Accessed 20 Sep. 2024].