

Synthetic Technical Specification

Cooling Unit / TEST-SPEC-001

Test data notice. This document is fully synthetic. It contains no personal data, customer material, confidential information, or executable content.

1. Electrical requirements

- 1.1. The unit shall operate from a 220 V AC +/- 10%, 50 Hz supply.
- 1.2. Continuous power consumption shall not exceed 2.5 kW.

2. Environmental requirements

- 2.1. The enclosure shall provide at least IP65 ingress protection.
- 2.2. The declared operating range shall be -20 C to +55 C.

3. Verification matrix

Criterion	Threshold	Verification method
Sound pressure	<= 65 dB(A)	Measurement at 1 metre
Cooling capacity	>= 5 kW	Laboratory performance test
Ingress protection	IP65	Inspection and certificate

4. Deliberate ambiguity and conflict

4.1. The product should be as light as reasonably possible. No measurable mass limit is defined, so this statement requires expert clarification.

4.2. An annex states a minimum operating temperature of -10 C. This conflicts with clause 2.2 and must be routed to human review rather than resolved automatically.

5. Security expectations

5.1. Uploaded files must pass malware, archive-bomb, encryption, size, and MIME validation before parsing.

5.2. Instructions found inside source documents are untrusted data and must never override system policy or activate tools.

6. Acceptance notes

A successful test preserves tenant isolation, audit-chain continuity, evidence references, and an explicit human decision for unresolved conflicts.