

Service Manual

AIR CONDITIONER

**CS-W14BB4P CU-V14BBP5
CS-W14BB4P CU-W14BBP5**



⚠ WARNING

This service information is designed for experienced repair technicians only and is not designed for use by the general public. It does not contain warnings or cautions to advise non-technical individuals of potential dangers in attempting to service a product. Products powered by electricity should be serviced or repaired only by experienced professional technicians. Any attempt to service or repair the product or products dealt with in this service information by anyone else could result in serious injury or death.

⚠ PRECAUTION OF LOW TEMPERATURE

In order to avoid frostbite, be assured of no refrigerant leakage during the installation or repairing of refrigeration circuit.

CONTENTS

Page	Page		
1 SERVICE INFORMATION	3	11 OPERATING CHARACTERISTIC	32
2 FEATURES	4	12 FAN PERFORMANCE	33
3 SPECIFICATION (HEAT PUMP TYPE)	9	13 SAFETY DEVICE	34
4 SPECIFICATION (COOLING ONLY TYPE)	11	14 COMPONENT SPECIFICATION	35
5 TECHNICAL DRAWING	12	15 CAPACITY AND POWER CONSUMPTION	36
6 CIRCUIT DIAGRAM	14	16 DISCHARGE AND SUCTION PRESSURE	39
7 OPERATING INSTRUCTION	26	17 SOUND DATA	40
8 REFRIGERATION CYCLE	28	18 TWIN AND TRIPLE	42
9 OPERATION RANGE	29	19 WIRING MISTAKE PREVENTION	47
10 PIPE LENGTH	30	20 TEST OPERATION AND SELF DIAGNOSIS	48

21 SETTING OF SAVE ENERGY AND THERMISTOR SWITCH	52	26 WIRED REMOTE CONTROL INSTALLATION MANUAL	71
22 GROUP CONTROL	53	27 WIRELESS REMOTE CONTROL INSTALLATION MANUAL	76
23 TROUBLESHOOTING	54	28 INSTALLATION (INDOOR UNIT)	83
24 EMERGENCY OPERATION	59	29 INSTALLATION (OUTDOOR UNIT)	92
25 CONTROL	60	30 REPLACEMENT PARTS	104

1 SERVICE INFORMATION

Caution:

- Pb free solder has a higher melting point than standard solder; Typically the melting point is 50 - 70°F (30 - 40°C) higher. Please use a high temperature soldering iron. In case of the soldering iron with temperature control, please set it to $700 \pm 20^{\circ}\text{F}$ ($370 \pm 10^{\circ}\text{C}$).
- Pb free solder will tend to splash when heated too high (about $1100^{\circ}\text{ F}/600^{\circ}\text{C}$).

Notice of Address setting for NEW Cassette / NEW Outdoor Unit.

The new Cassette / new Outdoor models are possible to have address setting for twin / triple control or group control automatically when main power supply is switched on.

(Manual address setting is also possible by using DSW1 switch on the indoor unit P.C. board.) However, **this address setting is only possible when proper wiring connection is made and indoor unit must be of original unit.**

1.1. Example of trouble during test operation

If the below phenomenon is found during test operation, wrong address setting is possible.
Therefore, please inspect the address setting.

1. LCD display of the wired remote control is not illuminated although the main power supply switch is 'on'.
2. LCD display had indicated as normal illumination when power supply switch is 'on', however outdoor unit cannot be operated.
(But, it is necessary to take 3 to 5 minutes for outdoor unit to start from the timing of remote control OFF/ON button is 'on'.)
(For normal operation, the outdoor unit will only start its operation after 3 to 5 minutes upon pressing the OFF/ON button.)
3. P.C. board had memorized wrong setting information.
 - a. If main power supply is switched on with the wrong connection.
 - b. When changing the connection or combination of units due to re-installation etc.
 - When changing the system from twin to triple (triple to twin).
 - When changing the system from group control to normal one to one system.
 - When making the replacement of units of master and slave etc.


1.2. Caution during test operation

Do not touch the remote control button and do not change any wirings for one minute when the main power supply switch is 'on'.
(Because the unit is having automatic address setting during the first one minute.)

1.3. Caution during automatic address setting

When the main power supply switch is 'on', the P.C. board will automatically memorize the connecting system.
Consequently, when initial power supply is 'on', there mustn't be any interchanging of units even of the same type and same capacity unit.
Therefore, connection of the unit to another system is prohibited.

2 FEATURES



2.1. Variety of excellent features

- **Compact design**

Compact design 240 mm height, 840 mm width and 840 mm depth.

- **Automatic restart function**

When the electric power resumes after a power failure, the unit will automatically restarts the operation in the pre-failure mode.

- **Auto fan mode (indoor unit)**

Auto fan mode is added besides HI, ME and LO. It automatically adjusts the fan speed according to the indoor temperature.

- **Dry mode function**

Dry mode can make a comfortable indoor environment during wet season.

- **Quiet operation**

The sound level is 35dB (A) for 14BB model during High Fan speed and suitable for offices, shops, homes etc, when quiet operation is essential.

- **Auto Swing Louvre**

The air flow angle can be changed automatically (or manually) to an angle between 10° to 70° using the remote control.

- **Low ambient cooling operation**

Cooling operation is possible at outdoor temperature of -5°C (2.5 HP ~ 6 HP models), 10°C (1.5 ~ 2 HP models).

- **Automatic changeover function (heat pump models)**

The unit automatically switches between cooling and heating in accordance with operating load in order to maintain a comfortable indoor temperature.

- **Hot start system (heat pump models)**

- **Pipes and drainage**


Built-in upward draining mechanism.

2.2. Greatly improved workability increases system renewal capability

- **Pipes that are one size larger can also be connected for renewal.**

- If renewing the system, existing refrigerant pipes can be utilized so that only the indoor and outdoor units need to be replaced.

- For example, liquid and gas pipes from 10 years ago can be connected to current pipes with the same size or one size larger. Effective utilization of materials reduces working time and trouble. (Adaptor sockets are not supplied.)




- **Additional refrigerant charging unnecessary for 15 m**

- All models do not require any additional charging of refrigerant for 15 m of pipe length. This makes installation much easier.

- **Drain water dripping-prevention structure**

- The base of the outdoor unit is provided with a single drain hole in order to prevent drain water from leaking out of the unit. By connecting a drain elbow and a discharge pipe, water leakages can be prevented even when the unit is installed to a wall.



- **Long pipe design for refrigerant pipes**


- Maximum piping length of 25m for all models.

2.3. A brand-new control method using the latest in technology

- Easier power supply wiring connection

Power supply wiring and other wiring tasks can be carried out more easily.

- Twin non-polar wires used to connect indoor and outdoor units.
- Adoption of connection error prevention circuits for drive wires and signal wires. If a connection error is made, the relay does not operate and current does not flow to the circuit boards.



• Twin and Triple operation

- Simultaneous air conditioning of wide spaces and corners is possible. Indoor units of different horsepowers can even be used in combination.
- Master unit and slave-units can be set automatically in twin and triple systems. No address setting is necessary.
- Multiple indoor units can be operated simultaneously with a single remote control. Note that individual operation is not possible.

• Separate indoor/outdoor unit power supplies


The power supply can be connected to (1) just the outdoor units, or (2) to both the indoor and outdoor units.

• Easy test operation


Test operation can be carried out for both indoor and outdoor units.

• Automatic setting initialization function (Remote control and Indoor unit)

In accordance with the indoor and outdoor units connected and the connection methods, conditions such as the connection configuration (twin or triple format) and remote-control functions such as automatic louvre operation and cooling or heating mode are automatically detected and set instantly.




2.4. Wired Remote Control



- The new design includes an easily-visible red pilot lamp. The power can be turned on and off at a single touch, without opening the cover.
- Has a built-in thermistor, allowing indoor temperature detection in accordance with indoor conditions by switching with main unit thermistor.
- Twin non-polar wires make installation work easy. (10 m cable supplied as accessory.)

2.5. Wireless Remote Control



- New design with compact size. (Operation range within approximately 8 m.)
- Built-in timer with ON/OFF timer setting (within 24 hours)

	Wired	Wireless
Heat Pump	CZ-RD51P	CZ-RL51P
Cooling	CZ-RD51P	CZ-RL01P

NOTE: Both of the above remote control is packed separately from the indoor unit.

2.6. Group Control Equipment

Wired remote control	Group control by one remote control	<p>Remote-side remote control Indoor units</p>	[Remote side] <ul style="list-style-type: none"> Optional wired remote control CZ-RD51P [Local side] Not needed
	Twin remote control separate control	<p>Remote-side remote control Local-side remote control Indoor units</p>	[Remote side] <ul style="list-style-type: none"> Optional wired remote control [Local side] <ul style="list-style-type: none"> Optional wired remote control CZ-RD51P
Common control	Common control/group	<p>Receptor unit Wireless remote control Wired remote control</p>	<ul style="list-style-type: none"> Optional wired remote control and wireless remote control <p>Wired CZ-RD51P Wireless CZ-RL01P (Cooling) CZ-RL51P (Heat pump)</p>

2.7. New refrigerant Series [R407C] pipe installation

2.7.1. Procedure

- The new refrigerant (R407C) has a different composition to the previously-used refrigerant (R22), so some contents and method of pipe installation and charging work are different from before. Care should be taken when carrying out this work.

2.7.2. Installation and precautions

2.7.2.1. Before installation

- Determine the installation division.
- Check the refrigerant to be used.
 - Check that the refrigerant is R407C.
 - Check that the gauge pressure is at a maximum of 3.3 MPa.
- Make a drawing of the Installation.

2.7.2.2. Installation

- Install the sleeve and the insert.
- Install the indoor unit.
- Install the refrigerant piping.
 - Pipe materials (Phosphorus Deoxidization Seamless Pipe)
 - Refrigerant pipes which were previously used to carry R22 must not be re-used. If replacing the indoor and

outdoor units, be sure to replace all refrigerant pipes also.


- Check the pipe thickness.
(1/4, 3/8, 1/2 : t = 0.8mm 5/8, 3/4 : t = 1.0mm)
- Clean the inside of the pipes.
- When storing pipes, seal both ends of the pipes and store them indoors to prevent water, dust and other foreign particles from getting inside.
- Take care not to let any foreign particles (oxide scales, water or dirt) get inside the refrigerant lines (same as for R22).

■ Refrigerant pipe storing

Location	Installation period	Storing method
Outdoors	1 month or more	Pinching
	Less than 1 month	Pinching or taping
Indoors	Any	

- Pinching method


Close off the ends of the pipes with pliers or similar tool and seal the opening by brazing.




Close using pliers or similar

- Taping method

Wind PVC tape around the ends of the pipes to seal the openings.



- Do not work for refrigerant piping on outdoor on rainy days.
- Seal by brazing.
- Be sure to use only a non-oxidizing brazing material.
(Use nitrogen. Anti-oxidants cannot be used.)



- When brazing pipes together, or when brazing copper pipes and copper joints, use a brazing material (Bcup-3) which does not require flux.
- Flare processing and ester oil.
- Sealing can be improved by applying ester oil or mineral oil (the minimum amount necessary) to flares and flange connections.
- Due to the high hygroscopic tendency for ester oil, do not mix or use any other impurities. (This can cause deterioration of the compressor oil and problems with the compressor.)
- After preparing the refrigerant pipes, close both ends of the pipes by brazing if not immediately connecting them.
- A torque wrench must be used.

4. Install the drain pipe.

5. Install the ducts.

6. Insulate against heat.

7. Carry out the electrical work.

- Connecting cables and power cables.

8. Make all necessary settings.

9. Prepare the outdoor unit foundation.

10. Install the outdoor unit.

11. Air-tightness test.

For the final check, there should be no pressure drop when 3.3 MPa is applied for 24 hours.

12. Vacuum drying.

Vacuum draw time	60 min. or more
------------------	-----------------

* Vacuum pump capacity 60 l/min. or higher

- Drawing the vacuum will remove any moisture.

- The pressure after vacuum drawing should be 755 mmHg or less.

- Use a special vacuum pump (with backflow-prevention mechanism).

- Gas must never be used for air purging.


13. Additional refrigerant charging.

- Check that refrigerant volume is correct.

- Be sure to charge refrigerant in liquid state.

- Always charge in liquid state.

When the refrigerant is charged from the cylinder, the composition may change greatly (compounds which do not easily evaporate may remain inside the cylinder), so the refrigerant must always be charged in a liquid state.



(It is recommended that a manifold with sight glass be used.)

■ Boiling point at normal atmospheric pressure (reference)

Refrigerant	HFC32	HFC125	HFC134a
Boiling point	-52°C	-49°C	-26°C

- Use a special gauge manifold and charging hose.
- If refrigerant leaks occur, replace all of the refrigerant (same as for R22).
- Note that a R22 leak detector cannot be used to detect leaks.
- Refer to the Installation Instructions included for the correct charging amount.
- Make a note of additional refrigerant charging amounts in the record table.

14. Test operation and adjustment.

15. Organize documentation before handover.

16. Handover and explanation of operation.

- Ventilation of closed rooms

R407C is a non-flammable refrigerant with low toxicity, but in the gas state its specific gravity is heavier than that of air, and so if leaks occur in a closed room, suffocation may occur. Toxic gases may also be generated if it comes into direct contact with flames, so adequate ventilation must be provided.

Name	Application	Class	Remarks
Pipe cutter	Cutting refrigerant pipes	○	
Flare tool	Flaring of refrigerant pipes	○	
Refrigerant pipe expander (tube expander)	Enlarging pipes during connection	○	• Clean off any refrigerator oil if the tool has been used with the previous refrigerant.
Torque wrench	Tightening flare nuts	○	
Pipe bender	Bending refrigerant pipes	○	
Compressor oil	Applying to flares	○	• Use care when storing and handling due to high hygroscopicity
Nitrogen gas	Preventing oxidation inside refrigerant pipes when welding pipes	○	
Welder	Brazing refrigerant pipe opening	○	
Gauge manifold	Checking vacuum drawing, refrigerant charging and operating pressure	○	• Check pressure-resistance specifications. • If used previously with R22 air conditioners, compressor oil from that air conditioner may still be present.
Charging hose		○	• Use a tool with a sight glass to make liquid refrigerant checking easier.
Vacuum pump	Drawing vacuum and drying	○	• Backflow-prevention mechanism necessary. Changed to screw-on specifications (adaptor required)
Charging cylinder	Charging refrigerant	×	• Cannot be used for normal usage method due to change in refrigerant composition.
Electronic scale for refrigerant charging		○	• Pressure-resistance and connection opening specifications must be checked.
Electronic gas leak detector	Checking refrigerant leaks	○	• Previous electronic-type gas leak detectors can not detect.
Refrigerant collector	Collection refrigerant	○	• Special equipment required

○:Special tool for R407C use required ○:Same tool can be used for R407C and R22 ×:Cannot be used

* It is recommended that materials and tools to be used only for the R407C substitute refrigerant be specially coloured for discrimination. (Example: Paint a marking by tuning the brown colour of R407C cylinder, or attach discrimination tape.)

3 SPECIFICATION (HEAT PUMP TYPE)

3.1. CS-W14BB4P / CU-W14BBP5

ITEM / MODEL			Indoor Unit	Outdoor unit	
Main Body			CS-W14BB4P	CU-W14BBP5	
Panel			CZ-BT01P		
Remote Control			CZ-RD51P (Wired) CZ-RL51P (Wireless)		
Cooling Capacity			kW BTU/h	3.8 13,000	
Heating Capacity			kW BTU/h	4.3 14,700	
Refrigerant Charge-less			m	15	
Standard Air Volume for High, Medium and Low Speed			m³/min cfm	13 459	
Outside Dimension (H x W x D)			mm inch	240 x 840 x 840 9-7/16 x 33-1/24 x 33-1/24	
Net Weight			kg lbs	26 49	
Piping Connection	Refrigerant	Gas	mm (inch)	O.D Ø 12.70 (1/2) Flared Type	
		Liquid	mm (inch)	O.D Ø 6.35 (1/4) Flared Type	
		Drain	mm	O.D Ø 20	
Compressor				I.D Ø 20 x 1	
Type, Number of Set			-	Hermetic-1 (Rotary), 1	
Starting Method			-	Direct on-line starting	
Motor	Type		-	2-pole single phase induction motor	
	Input	kW	-	Cool/Heat 2.31/2.30	
	Rated Output	kW	-	1.2	
Fan			Turbo fan-1	Propeller fan-1	
Fan	Type, Number of Set		6-pole single phase induction motor	4-pole single phase induction motor	
	Motor	Type	0.08	0.11	
		Input	0.02	0.054	
Air-heat Exchanger			Slit-fin type	Louvre-fin type	
Refrigerant Control			Cool	Capillary tube	
			Heat	-	
Refrigerant Oil (Charged)			litre	-	
Refrigerant (Charged)			kg	(1.24)	
			oz	(44)	
Running Adjustment	Control Switch		Wireless or Wired Remote Control	-	
	Room Temperature		Thermostat (Main Body)	-	
Safety Devices			Internal protector for compressor, Internal thermostat for fan motor, Crankcase heater, High and heating pressure switch, Current transformer		
Noise Level			dB (A)	Hi 35 Lo = 31	
				Hi 52	
			Heat	Hi 35 Lo = 31	
				Hi 53	
			Cool	Hi 50 Lo = 46	
				Hi 65	
			Heat	Hi 50 Lo = 46	
				Hi 66	

1. Cooling capacities are based on indoor temperature of 27°C D.B. (80.6°F D.B.), 19.0°C W.B. (66.2°F W.B.) and outdoor air temperature of 35°C D.B. (95°F D.B.), 24°C W.B. (75.2°F W.B.)
2. Heating capacities are based on indoor temperature of 20°C D.B. (68°F D.B.) and outdoor air temperature of 7°C D.B. (44.6°F D.B.), 6°C W.B. (42.8°F W.B.)

ELECTRICAL DATA (50Hz)

ITEM / MODEL			CS-W14BB4P, CU-W14BBP5		
			Condition by JIS B 8615		
Volts	V		220	230	240
Phase			Single	Single	Single
Power Consumption	kW	Cool	1.57	1.57	1.57
		Heat	1.53	1.53	1.53
Running Current	A	Cool	7.2	7.2	7.2
		Heat	7.0	7.0	7.0
Starting Current	A		27	28	29
Power Factor	%	Cool	99	95	91
		Heat	99	95	91

*Power Factor means total figure of compressor, indoor fan motor and outdoor fan motor.

Panasonic	Power source	AC, 1~220V, 230V, 240V 50Hz
-----------	--------------	-----------------------------

4 SPECIFICATION (COOLING ONLY TYPE)

4.1. CS-W14BB4P / CU-V14BBP5

ITEM / MODEL			Indoor Unit	Outdoor unit	
Main Body			CS-W14BB4P	CU-V14BBP5	
Panel			CZ-BT01P		
Remote Control			CZ-RD51P (Wired) CZ-RL01P (Wireless)		
Cooling Capacity			kW BTU/h	3.8 13,000	
Refrigerant Charge-less			m	15	
Standard Air Volume for High, Medium and Low Speed			m³/min cfm	13 459	
Outside Dimension (H x W x D)			mm inch	240 x 840 x 840 9-7/16 x 33-1/24 x 33-1/24	
Net Weight			kg lbs	26 57	
Piping Connection	Refrigerant	Gas	mm (inch)	O.D Ø 12.7 (1/2) Flared Type	
		Liquid	mm (inch)	O.D Ø 6.35 (1/4) Flared Type	
	Drain		mm	O.D Ø 20	
Compressor	Type, Number of Set		-		
	Starting Method		-		
	Motor	Type	-		
		Input	kW	-	
		Rated Output	kW	-	
Fan	Type, Number of Set		Turbo fan-1	Propeller fan-1	
	Motor	Type	6-pole single phase induction motor	4-pole single phase induction motor	
		Input	0.08	0.11	
		Rated Output	0.02	0.054	
Air-heat Exchanger			Slit-fin type	Louvre-fin type	
Refrigerant Control			Capillary tube	-	
Refrigerant Oil (Charged)			litre	-	
Refrigerant (Charged)			kg oz	(1.24) (44)	
Running Adjustment	Control Switch		Wireless or Wired Remote Control	-	
	Room Temperature		Thermostat (Main Body)	-	
Safety Devices			Internal protector for compressor, Internal thermostat for fan motor, Crankcase heater, High pressure switch, Current transformer		
Noise Level	Cool	dB (A)	Hi 35 Lo = 31	Hi 52	
	Cool	Power level dB	Hi 50 Lo = 46	Hi 65	


1. Cooling capacities are based on indoor temperature of 27°C D.B. (80.6°F D.B.), 19.0°C W.B. (66.2°F W.B.) and outdoor air temperature of 35°C D.B. (95°F D.B.), 24°C W.B. (75.2°F W.B.)

ELECTRICAL DATA (50Hz)

ITEM / MODEL			CS-W14BB4P, CU-V14BBP5		
			Condition by JIS B 8615		
Volts	V		220	230	240
Phase			Single	Single	Single
Power Consumption	kW	Cool	1.57	1.57	1.57
Running Current	A	Cool	7.2	7.2	7.2
Starting Current	A		27	28	29
Power Factor	%	Cool	99	95	91
*Power Factor means total figure of compressor, indoor fan motor and outdoor fan motor.					
Panasonic	Power source		AC, 1~220V, 230V, 240V 50Hz		







5 TECHNICAL DRAWING

CS-W14BB4P



CU-W14BBP5, CU-V14BBP5


No.	Description	PC	Dimension
1	Service valve	1	O.D. ø 6.35 Flared
2	Ball valve	1	O.D. ø 12.70 Flared
3	Fan guard	1	
4	Fan motor	1	
5	Heat exchanger	1	
6	Fan	1	O.D. ø 480
7	Compressor	1	
8	Control box	1	





Unit : mm

6 CIRCUIT DIAGRAM

CS-W14BB4P






WIRE COLOUR

R	RED	W	WHITE	BL	BLACK
Y	YELLOW	BR	BROWN	V	VIOLET
B	BLUE	P	PINK	G	GREEN
O	ORANGE	GR	GREY		
Y/G	YELLOW / GREEN				

LEGEND

CM	Compressor Motor	20SV	Reversing Valve	Printed Circuit Board
FM	Fan Motor (Outdoor Unit)	TM	Terminal Board for Main Circuit	SA Surge Absorber
52C	Magnetic Contactor for CM	CT.B	Current Trans Board	VA1-8 Varistor
C1	Capacitor for CM	Th1	Thermistor (Compressor discharge temp.)	F Fuse 250V T 6.3A
C2	Capacitor for FM	Th2	Thermistor (Heat exchanger outlet temp.)	CN1-10 Connector
63H	High Pressure Switch Heat-pump	CT	Current Trans	SSR1,11 Solid State Relay
49C	Internal Protector for CM	Cn	Connector	SSR21 Solid State Relay
49F	Internal Protector for FM	T	Transformer	Tm1 Terminal Board for Control Circuit
Tim2	Terminal Board for Control Circuit			



● INDOOR UNIT
PRINTED CIRCUIT BOARD

S PHASE	4
SURGE ABSORBER	3
	2
R PHASE	1

CN4

INDOOR FAN H	6
INDOOR FAN M	5
INDOOR FAN L	4
	3
COM	2
COM (SPH)	1

CN5

AIR SWING LOUVRE MOTOR	6
HEATER	5
DRAIN PUMP	4
COM	3
COM	2
COM (SPH)	1


CN6

TRANSFORMER 1ST (R PH)	6
TRANSFORMER 2ND	5
TRANSFORMER	4
TRANSFORMER 1ST (S PH)	3
TRANSFORMER 2ND	2
TRANSFORMER	1

CN7

ROOM THERMISTOR	12
ROOM THERMISTOR	11
PIPE THERMISTOR	10
PIPE THERMISTOR	9
	8
	7
LOUVRE SW	6
LOUVRE SW	5
COMMUNICATION WITH OUTDOOR UNIT	4
COMMUNICATION WITH OUTDOOR UNIT	3
WIRED REMOTE CONTROL	2
WIRED REMOTE CONTROL	1

CN1



FLOAT	SW	2
FLOAT	SW	1


CN10

APPLICABLE FOR ALL MODELS

- OUTDOOR UNIT
PRINTED CIRCUIT BOARD

_____	14
_____	13
GND	12
DEMAND INPUT	11
GND	10
HEATING PRESSURE SW	9
GND	8
HIGH PRESSURE SW	7
GND	6
PIPE TEMP SENSOR	5
GND	4
DISCHARGE TEMP SENSOR	3
GND	2
CT	1

CN2



TRANSFORMER 2ND(S)	4
TRANSFORMER 1ST(R)	3
TRANSFORMER 2ND(R)	2
TRANSFORMER 1ST(S)	1

GN4

COMMUNICATION WITH INDOOR UNIT	4
COMMUNICATION WITH INDOOR UNIT	3
S Phase	2
R Phase	1

TM1

S Phase	1
Fan2(R)	2
Fan1(R)	3
S Phase	4
S Phase	5
S Phase	6

CN8

CRANKCASE HEATER(S)	1
CRANKCASE HEATER(R)	2

CN10

LIQUID BYPASS valve(R)	6
REVERSING valve(R)	5
COMPRESSOR relay(R)	4
LIQUID BYPASS valve(S)	3
REVERSING valve(S)	2
COMPRESSOR relay(S)	1


CN7


R Phase	4
S Phase	3
Earth	2
T Phase	1

CN6


APPLICABLE FOR ALL MODELS


- INDOOR UNIT
PRINTED CIRCUIT BOARD
(SCHEMATIC DIAGRAM)







- OUTDOOR UNIT
PRINTED CIRCUIT BOARD
(SCHEMATIC DIAGRAM)






- WIRED REMOTE CONTROL
PRINTED CIRCUIT BOARD
(SCHEMATIC DIAGRAM)








7 OPERATING INSTRUCTION

7.1. Wired Remote Control (OPTIONAL PARTS)

Name and function of each part



⑨ Operation indicator

Lights up in red when the unit is operating.

⑩ OFF/ON button

Used to start and stop the operation.

⑪ FAN SPEED button

Used to select the fan speed of high (HI), medium (MED), low (LO) or autofan (AUTO).

⑫ OPERATION button

Used to select the operation of FAN, COOL, DRY, AUTO or HEAT.

⑬ TEMP (UP/DOWN) buttons

Used to select the desired temperature.

⑭ FILTER RESET button

Press to reset the "FILTER CLEAN" after washing the filter.

① REMOTE

The OFF/ON button cannot be used.

LOCAL

All remote control functions can be used.

② Airflow direction setting display

③ Timer/time setting display

④ Fan speed display

⑤ Operation mode selection display

⑥ Temperature setting display (16°C - 31°C)

⑦ TEST RUN

Indicates that the unit is running in test operation mode.

PREHEAT

Indicates that the unit is running in pre-heating mode.

DEFROST

Indicates that the unit is running in defrosting mode.

⑧ FILTER CLEAN

(Appears after the cumulative running time reaches approximately 2,500 hours of operation.)

⑯ A/C No. button*

This switch is used during group control. It is not needed for normal operation.

⑯ CHECK button

Press this button if the check display is flashing.

⑰ TIMER/CLOCK SET buttons

Used to set the timer operation and the current time.

⑱ TEST RUN button*

⑲ AIR SWING (AUTO/MANUAL) buttons


Used to determine the air swing condition, either auto or manual.

NOTES:

- Ensure that the correct button is pressed as simultaneous pressing of the multiple buttons will not make the setting correct.
- The illustration above is for explanatory purposes only. The appearance will be different during actual operation.
- Do not operate the remote control with wet hands. Otherwise, electric shock or malfunction may occur.
- Do not press the remote control buttons with sharp object as this may damage the remote control.
- Buttons marked with * are not needed for normal operation. If one of these buttons is pressed by mistake, press the same button once more to cancel the operation.
- When the power resumed after power failure, the unit will restart automatically with all the previous settings preserved by the memory function. (Auto restart function)

7.2. Wireless Remote Control (OPTIONAL PARTS)

Name and function of each part




- ① Transmitter**
Transmits the remote control signal.
- ② Fan speed display**
- ③ Airflow direction setting display**
- ④ Temperature setting display (16°C - 31°C)**
- ⑤ Timer/time setting display**
Shows the timer operation setting time or the current time.
- ⑥ Operation selection display**
- ⑦ Address number display**
- ⑧ OFF/ON button**
Used to start and stop the operation.
- ⑨ OPERATION button**
Used to select the operation of FAN, COOL, DRY, AUTO or HEAT.
- ⑩ TEMP (UP/DOWN) buttons**
Used to select the desired temperature.
- ⑪ FILTER RESET button**
Press to cancel the "FILTER" indicator light on the ray receiver.
- ⑫ AIR SWING (AUTO/MANUAL) buttons**
Used to determine the air swing condition, either auto or manual.
- ⑬ TIMER/CLOCK SET buttons**
Used to set the timer operation and the current time.
- ⑭ RESET button**
Pressing this button will clear all the settings from memory.
You will then need to make the settings again.
- ⑮ TEST RUN button***
- ⑯ FAN SPEED button**
Used to select the fan speed of high (HI), medium (MED), low (LO) or autofan (AUTO).
- ⑰ ADDRESS SET button***
Used to change the address setting when using more than one indoor unit.

NOTES:


- Ensure that the correct button is pressed as simultaneous pressing of the multiple buttons will not make the setting correct.
- The illustration above is for explanatory purpose only. The appearance will be different during actual operation.
- If using the wireless remote control in conjunction with the wired remote control, the settings made from the wireless remote control will appear on the wired remote control display (except when making timer settings).
- Buttons marked with * are not needed for normal operation. If one of these buttons is pressed by mistake, press the same button once more to cancel the operation.
- When the power resumed after power failure, the unit will restart automatically with all previous settings preserved by the memory function. (Auto restart function)

8 REFRIGERATION CYCLE

CS-W14BB4P / CU-W14BBP5



CS-W14BB4P / CU-V14BBP5



9 OPERATION RANGE

Power Supply

The applicable voltage range for each unit is given in the following table. The working voltage among the three phases must be balanced within a 3% deviation from each voltage at the compressor terminals. The starting voltage must be higher than 85% of the rated voltage.

Power Supply

MODEL	Unit Main Power		Applicable Voltage	
	Phase, Volts	Hz	Max	Min
CU-W14BBP5 CU-V14BBP5	1~220	50	242	198
	1~230	50	253	207
	1~240	50	264	216

Indoor and Outdoor Temperature

- Cooling only type

Model 50Hz CU-V14BBP5

Operating	Hz	Indoor Temp. (D.B./W.B.) (°C)		Outdoor Temp. (D.B./W.B.) (°C)	
		Max	Min	Max	Min
Cooling	50	32/23	21/15	43/-	10/-

- Heat pump type

Model 50Hz CU-W14BBP5

Operating	Hz	Indoor Temp. (D.B./W.B.) (°C)		Outdoor Temp. (D.B./W.B.) (°C)	
		Max	Min	Max	Min
Cooling	50	32/23	21/15	43/-	10/-
Heating	50	27/-	16/-	24/18	-5/-


10 PIPE LENGTH

■ CORRECTION OF COOLING CAPACITY AND HEATING CAPACITIES



Correction of cooling and heating capacities according to the connecting pipe length.

The data of cooling capacities (marked on the name plate) are based on 7.5 meters connecting pipe and horizontal installation. For other pipe length of other installation multiply by the following correction factor to determine the revised cooling capacity.

[Cooling]



[Heating]



Equivalent Length
 x ELE = actual pipe length + number of elbow
ELE : equivalent length of elbow

Outer diameter of gas side pipe mm (inch)	ELE
12.7 (1/2)	0.20
15.88 (5/8)	0.25
19.05 (3/4)	0.35
6.35 (1/4)	0.17

■ REFRIGERANT ADDITIONAL CHARGE

1. Piping installation by standard piping

- At the time of shipment from the factory, this unit is charged with enough refrigerant for an equivalent pipe length of 15m.
(Refer to the following table)

But when the piping length exceeds 15m, additional charge is required according to the following table.

Example:

CU-V14BBP5

In case of 11m long pipe (one way), the amount of refrigerant to be replenished is: $(16 - 15) \times 20 = 20\text{g}$

■ Cooling only type

Model Name	Standard piping specification			
	Liquid piping (dia.mm)	Gas piping (dia.mm)	Gas charge-less length (m)	Additional gas volume (g/m)
CU-V14BBP5	6.35	12.7	15	20

■ Heat pump type

Model Name	Standard piping specification			
	Liquid piping (dia.mm)	Gas piping (dia.mm)	Gas charge-less length (m)	Additional gas volume (g/m)
CU-W14BBP5	6.35	12.70	15	20

2. Piping installation by existing piping

The above models change the liquid pipe size of the previous series. It is to use the existing piping by adjusting the refrigerant gas volume.

Please do correct piping installation referring to the above table.

⚠ Attention

- Please do not decrease the gas piping size. (It causes the breakdown of the compressor).
- The equivalent piping length and the cooling and heating capacity change rate are same as the standard piping specification.

11 OPERATING CHARACTERISTIC

Model		Main Power Source		Compressor Motor			Indoor Unit Fan Motor		Outdoor unit Fan Motor		Electrical Data	
		Voltage	Frequency	S.C.	R.C. (A)	IPT (kW)	R.C.	IPT	R.C.	IPT	R.C.	IPT
		(V)	(Hz)	(A)	Cool	Cool	(A)	(kW)	(A)	(kW)	(A)	(kW)
COOLING ONLY MODEL	CS-W14BB4P CU-V14BBP5	220	50	27	6.49	1.42	0.28	0.06	0.43	0.09	7.20	1.57
		230	50	28	6.47	1.41	0.29	0.06	0.44	0.10	7.20	1.57
		240	50	29	6.45	1.39	0.30	0.07	0.45	0.11	7.20	1.57

Model		Main Power Source		Compressor Motor			Indoor Unit Fan Motor		Outdoor unit Fan Motor		Electrical Data	
		Voltage	Frequency	S.C.	R.C. (A)	IPT (kW)	R.C.	IPT	R.C.	IPT	R.C.	IPT
		(V)	(Hz)	(A)	Cool/Heat	Cool/Heat	(A)	(kW)	(A)	(kW)	(A)	(kW)
HEAT PUMP MODEL	CS-W14BB4P CU-W14BBP5	220	50	27	6.49 / 6.29	1.42 / 1.38	0.28	0.06	0.43	0.09	7.20/7.00	1.57/1.53
		230	50	28	6.47 / 6.27	1.41 / 1.37	0.29	0.06	0.44	0.10	7.20/7.00	1.57/1.53
		240	50	29	6.45 / 6.25	1.39 / 1.35	0.30	0.07	0.45	0.11	7.20/7.00	1.57/1.53

Legend :

S.C. = Starting Current



R.C. = Running Current

IPT = Power Consumption

12 FAN PERFORMANCE

CS-W14BB4P

ITEM / MODEL	Indoor Unit			Outdoor Unit	
	CS-W14BB4P			CU-W14BBP5, CU-V14BBP5	
MODE		Hi	Me	Lo	Hi
Air Volume	m ³ /min	13	11	10	43
Running Current	A	0.29	0.23	0.17	0.44
Power Consumption	kW	0.07	0.05	0.04	0.10
Fan Speed	r/min	375	325	283	875



13 SAFETY DEVICE

INDOOR UNIT

Indoor unit	Heat pump model		CS-W14BB4P
	Cooling only model		
For Fan Motor Protection, Internal Protector (49F)	OFF	°C	135
	ON	°C	85
For Control Protection, Fuse	CUT	A	3.15

OUTDOOR UNIT

Outdoor Unit	Heat pump model	50Hz	CU-W14BBP5
	Cooling only model	50Hz	CU-V14BBP5
For Refrigerant Cycle, High Pressure Switch (63H ₁)	OFF	MPa	-
	ON	MPa	-
For Compressor Over Current Protection	OFF (Heat pump)	A	14
	OFF (Cooling only)	A 50Hz	14
	RESET	-	Automatic
Discharge Temp. Protection, Discharge Temp. Thermistor (Th1)	Compressor OFF	°C	115
Liquid Compression Protection, Crankcase Heater	Input power	W	-
Compressor Protection, Internal Protector	OFF	°C 50Hz	160
	ON	°C 50Hz	90
	Trip time	50Hz	3-10sec/52A
For Fan Motor Protection, Internal Protector (49F)	OFF	°C	135
	ON	°C	85
Heating Pressure Switch (Heat Pump Only) (Fan Speed) (63H ₂)	OFF	MPa	2.50
	ON	MPa	2.05
Cooling Control, Heat Exchanger Outlet Temp. Thermistor (Th2)	Control method		
For Control Protection, Fuse	CUT	A	6.3

1MPa = 10.2 kgf/cm²

* Head Thermostat only for CU-A28BBP8 / CU-C28BBP8

14 COMPONENT SPECIFICATION

Compressor

Model	Heat pump model	50Hz	CU-W14BBP5
	Cooling only model	50Hz 60Hz	CU-V14BBP5
Compressor Model		50Hz 60Hz	4KS250DAA
Compressor Type (No. of Cylinders)			ROTARY 1
Revolution		r/min	2,900
Piston Displacement		m³/h	4.38
Motor Type	Starting Method Rated Output Poles Insulation Class	kW	Direct on-line Starting 1.2 2 E
Oil	Type Charge	L	M60 0.67

Evaporator

Models			CS-W14BB4P
	Tube Material Outer Diameter Thickness Row No. of Tubes/Row	mm mm	7.0 0.27 1 8
	Fin Material Thickness Fin Pitch Fin Surface Total Face Area	mm NO./inch m²	0.105 21 Z Slit fin 0.304
Fan	Type No. of /Unit		1
Fan Motor	Starting Method Rated Output Poles Phase Insulation Class	kW	0.02 6 Single-Phase E

Condenser


Models		Heat pump model Cooling only model		CU-W14BBP5 CU-V14BBP5
	Tube Material Outer Diameter Thickness Row No. of Tubes/Row	mm mm		9.52 0.36 1 26
	Fin Material Thickness Fin Pitch Fin Surface Total Face Area	mm NO./inch m²		0.11 18 corrugate 0.51
Fan	Type No. of /Unit			1
Fan Motor	Starting Method Rated Output Poles Phase Insulation Class	kW		0.05 4 Single-Phase E

15 CAPACITY AND POWER CONSUMPTION


15.1. HEATING PERFORMANCE

Model	Heating capacities are based on conditions below.
CS-W14BB4P	1 phase, 50Hz, 220V
Heating capacity	Indoor temperature 20°C D.B.
4.3 kW	Outdoor temperature 7°C D.B. 6°C W.B.
	Standard air volume 13m ³ /min

External Static Pressure (Pa) Air Volume (m ³ /min)	Entering Air Dry Bulb (°C)	Outdoor Temperature (°C W.B.)			
		-6	0	6	12
		H.C.	H.C.	H.C.	H.C.
14	15	3.14	3.76	4.52	5.25
	20	2.97	3.55	4.30	5.16
	25	2.80	3.35	4.09	4.95



External Static Pressure (Pa) Air Volume (m ³ /min)	Entering Air Dry Bulb (°C)	Outdoor Temperature (°C W.B.)			
		-6	0	6	12
		IPT	IPT	IPT	IPT
14	15	1.07	1.22	1.45	1.71
	20	1.13	1.30	1.53	1.77
	25	1.19	1.38	1.61	1.81




TC = Total Cooling Capacity

IPT = Power Consumption


15.2. COOLING PERFORMANCE

Model	Cooling capacities are based on conditions below.
CS-W14BB4P	1 phase, 50Hz, 220V
Cooling capacity	Indoor temperature 27°C D.B. 19°C W.B.
3.8 kW	Outdoor temperature 35°C D.B.
	Standard air volume 13m ³ /min

Entering Air Temperature		Temperature Air Entering Condenser (°C D.B.)				
		25	30	35	40	43
		TC	TC	TC	TC	TC
D.B.	W.B.	kW	kW	kW	kW	kW
23	17	3.96	3.80	3.58	3.31	3.11
	19	4.18	4.05	3.84	3.58	3.40
	22	4.56	4.44	4.24	3.96	3.78
25	17	3.91	3.76	3.54	3.28	3.10
	19	4.18	4.04	3.82	3.56	3.37
	22	4.56	4.42	4.20	3.92	3.74
27	17	3.86	3.71	3.50	3.26	3.08
	19	4.19	4.03	3.80	3.53	3.34
	22	4.56	4.40	4.17	3.88	3.71
29	17	3.85	3.71	3.50	3.28	3.12
	19	4.18	4.03	3.80	3.56	3.39
	22	4.54	4.38	4.15	3.88	3.70
32	17	3.85	3.71	3.25	3.30	3.15
	19	4.17	4.03	3.80	3.58	3.41
	22	4.53	4.37	4.14	3.88	3.70



Entering Air Temperature		Temperature Air Entering Condenser (°C D.B.)				
		25	30	35	40	43
		IPT	IPT	IPT	IPT	IPT
D.B.	W.B.	kW	kW	kW	kW	kW
23	17	1.25	1.35	1.47	1.62	1.71
	19	1.32	1.43	1.56	1.71	1.82
	22	1.43	1.55	1.69	1.85	1.96
25	17	1.25	1.35	1.47	1.61	1.70
	19	1.33	1.44	1.57	1.71	1.81
	22	1.44	1.55	1.69	1.85	1.96
27	17	1.25	1.35	1.47	1.60	1.69
	19	1.34	1.44	1.57	1.71	1.81
	22	1.45	1.56	1.70	1.84	1.95
29	17	1.25	1.35	1.45	1.56	1.62
	19	1.33	1.44	1.55	1.67	1.74
	22	1.47	1.59	1.71	1.83	1.91
32	17	1.24	1.35	1.44	1.53	1.58
	19	1.33	1.44	1.54	1.64	1.69
	22	1.48	1.60	1.72	1.83	1.88



TC = Total Cooling Capacity

IPT = Power Consumption


16 DISCHARGE AND SUCTION PRESSURE

16.1. SATURATION TEMPERATURE OF DISCHARGE AND SUCTION PRESSURE




● Commonness TO ALL THE MODELS

● SATURATION TEMPERATURE OF DISCHARGE AND SUCTION PRESSURE

SATURATION OF DISCHARGE AND SUCTION PRESSURE
COOLING 50Hz




SATURATION OF DISCHARGE AND SUCTION PRESSURE
HEATING (Heat pump model only) 50Hz




* For intake temperature, consult the pressure - Enthalpy Table (R407C) at the end.


17 SOUND DATA




CU-W14BBP5 (Cooling)
Octave Band Central Frequency (Hz)



CU-W14BBP5 (Heating)
Octave Band Central Frequency (Hz)



CU-V14BBP5 (Cooling)
Octave Band Central Frequency (Hz)



18 TWIN AND TRIPLE


18.1. Twin and Triple Operation

- Simultaneous air conditioning of wide spaces and corners is possible. Indoor units with different horsepowers can even be used in combination.

- Master unit and slave-units can be set automatically in twin and triple systems. No address setting is necessary.
- Multiple indoor units can be operated simultaneously with a single remote control unit. Note that individual operation is not possible.

Twin and Triple Combination Table

Outdoor unit	Simultaneous twin operation		Simultaneous triple operation	
	Standard	Horsepower difference	Standard	Horsepower difference
3.0 HP	[3.0] [1.5] [1.5]			
4.0 HP	[4.0] [2.0] [2.0]	[4.0] [1.5] [2.5]		
5.0 HP	[5.0] [2.5] [2.5]	[5.0] [2.0] [3.0]		
6.0 HP	[6.0] [3.0] [3.0]	[6.0] [2.0] [4.0]	[6.0] [2.0] [2.0]	[6.0] [1.5] [1.5] [3.0]



: Outdoor unit capacity
 : Indoor unit capacity


18.1.1. Twin and triple operation setting

- The master unit and slave units are set automatically when the power is turned on. At this time, the indoor unit which is connected to the remote control unit becomes the master unit.
(If automatic setting is not possible, carry out the settings manually.)
- No distinction is made between master unit and slave units (slave unit 1 and slave unit 2) at the indoor unit or remote control.
- Install the remote control to the master unit. (It cannot be connected to slave units.)
If indoor unit models with louvres and models without louvres have been connected together, use an indoor unit

with louvres as the master unit.

- The remote control termostat can also be set.
- Optional circuit boards can only be installed to the master unit.
- Setting the master unit and slave units can also be carried out manually by using DIP switches. However, manual settings will always take priority. If you have made manual settings but would like to return to using automatic settings, set all slave unit DIP switches (refer to the table below) to the OFF position, and then press the ADDRESS RESET button on the outdoor unit (SW3 on the outdoor unit printed circuit board).
(Do not mix manual settings and automatic settings.)

Manual setting	Master unit	Slave unit							
		Slave unit 1 when connecting a triple system				Slave unit 2 when connecting a triple system			
	<ul style="list-style-type: none"> It is not necessary to operate any switches on the master unit. The unit connected to the remote control will become the master unit. 	ON	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		OFF	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
		1	2	3	4	5	6	7	8
		Set No. 8 to ON. All other switches can be ignored. (No. 5 and 7 are already set to ON at the time of shipment.)							
		ON	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		OFF	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
		1	2	3	4	5	6	7	8
		Set No. 1 and No. 8 to ON. (No. 5 and 7 are already set to ON at the time of shipment.)							



Master and slave unit setting should basically be carried out automatically.
 ● Setting occurs when the power is turned on.
 (When power for indoor and outdoor units are turned on.)
 ● Remote control is connected to the master unit.
 ● Self-diagnosis displays are possible for slave units.
 ● If setting errors occur because of procedural mistakes or power supply quality problems, the ADDRESS RESET button function can be used.

18.1.2. Automatic address setting for twin and triple systems

Procedure: Turn on the power supply for the indoor and outdoor units.

Operation: Automatic address setting will start 10 to 30 seconds after the power supply is turned on, and will be completed after about 1 minute.

If the power supplies for the indoor unit and outdoor unit cannot be turned on at the same time, turn on the power supply for the outdoor unit, the indoor unit which is connected to the remote control, and then the other indoor units in that order.

If the order of turning on the power supply is incorrect, the master unit setting may overlap. In such a case, turn on the power supplies for all units in the correct order as given above, or carry out a twin/triple automatic address reset (press dip switch 3 on the outdoor unit continuously for 4 seconds or longer).

- The indoor unit which is connected to the remote control will have priority for becoming the master unit.
- The master unit thermostat will be used as the indoor temperature thermostat. If the master unit thermostat is turned on, the slave unit thermostats cannot be adjusted even if they happen to be on.
- If address setting using the DIP switches is carried out after automatic address setting has been carried out, use DIP switch No. 3 (SW3) on the outdoor unit to carry out automatic address resetting.
- If you would like to designate a particular indoor unit as the master unit because no master unit has been set, use the DIP switches on the slave units to make setting.

If automatic address setting is carried out once and then the slave unit address are set, the address will then be stored inside the EEPROM. Thus it is not necessary to repeat automatic address setting if the power is turned off and back on again.

18.1.3. DIP switch settings for twin/triple slave unit addresses

Procedure: Turn off the power supply, and then set DIP switch 1-8 to ON.
 The unit will become slave unit 1.
 (Set DIP switches 1-1 and 1-8 both to ON.
 The unit will become slave unit 2.)

Operation: Turn on the power supply.
 The unit will operate as slave unit 1.
 Automatic address setting is not carried out at this time.

If the setting is made while the power is still turned on, it is easier to mis-combine the setting with group settings. So, the setting should be made while the power is turned off.

- Only slave unit addresses can be set in this way. Master unit setting is not possible.
- If you make the DIP switch settings after the power has been turned on, carry out twin/triple automatic address resetting.
- Be sure to set DIP switch 1-8 to ON when setting twin/triple addresses. If DIP switch 1-1 is set to ON without setting 1-8 to ON, group addresses will be set instead, and the remote control open circuit error code (F26) will be displayed.

18.1.4. Automatic address resetting for twin/triple systems

Function:

- This reset the current twin/triple addresses which have been set automatically, and result in the reoccurrence of automatic twin/triple address settings.

Procedure:

Press the ADDRESS RESET button SW3 (push button switch) on the outdoor unit circuit board continuously until LEDs 2 to 8 on the outdoor unit circuit board are all illuminated (takes approximately 3.5 seconds).

The outdoor unit will reset the addresses for the indoor units which it is connected to, and will send an instruction to carry out automatic address setting again. If the indoor unit DIP switch have not been manually set for twin/triple address setting, the indoor units receive this command and clear their existing settings and carry out automatic address setting.

If an indoor unit has had its address set by the DIP switch (DIP switch 1-8 is ON), or if the remote control unit is connected to one of the indoor unit, then the addresses for those indoor units cannot be reset.

- The indoor units will not run for approximately 1 minute while automatic twin/triple address resetting is being carried out.
- Do not turn off the power supply for at least 1 minute after automatic twin/triple address resetting has been carried out.

18.2. Piping connections

- The following table shows the pipe diameters for a twin-type system.

Outdoor unit main pipe diameter (mm)		Indoor unit combinations				
3HP		Indoor unit capacity (HP)		1.5	1.5	
Liquid side: ø 9.52	Gas side: ø 15.88	Branch pipe diameter	Liquid side	ø 6.35	ø 6.35	
			Gas side	ø 12.7	ø 12.7	
4HP		Indoor unit capacity (HP)		2.0	2.0	1.5 2.5
Liquid side: ø 9.52	Gas side: ø 19.05	Branch pipe diameter	Liquid side	ø 6.35	ø 6.35	ø 6.35 ø 6.35
			Gas side	ø 12.7	ø 12.7	ø 15.88
5HP		Indoor unit capacity (HP)		2.5	2.5	2.0 3.0
Liquid side: ø 9.52	Gas side: ø 19.05	Branch pipe diameter	Liquid side	ø 6.35	ø 6.35	ø 6.35 ø 9.52
			Gas side	ø 15.88	ø 15.88	ø 12.7 ø 15.88
6HP		Indoor unit capacity (HP)		3.0	3.0	2.0 4.0
Liquid side: ø 9.52	Gas side: ø 19.05	Branch pipe diameter	Liquid side	ø 9.52	ø 9.52	ø 6.35 ø 9.52
			Gas side	ø 15.88	ø 15.88	ø 12.7 ø 19.05

- The following table shows the pipe diameters for a triple-type system.


Outdoor unit main pipe diameter (mm)		Indoor unit combinations							
6HP		Indoor unit capacity (HP)		2.0	2.0	2.0	1.5	1.5	3.0
Liquid side: ø 9.52	Gas side: ø 19.05	Branch pipe diameter	Liquid side	ø 6.35	ø 9.52				
			Gas side	ø 12.7	ø 15.88				

- The following table shows the equivalent pipe lengths and height differences for twin- and triple-type systems.


Equivalent length	L + la + lb + lc			Within 50 m	
Branch pipe diameter	la, lb, (lc)			Within 15 m	
Branch pipe difference	la - lb, lb - (lc), la - (lc)			Within 10 m	
Height difference	H1	Within 30 m	Height difference between indoor units	H2	Within 1 m

Note:


- Use the main pipe to gain any rise or fall required for the pipes.
- The number of bends should be 8 or less in a single system ($L + la$, $L + lb$, $L + lc$), and 15 or less overall.
- Branch pipes should be positioned horizontally.



- The branch pipe should be horizontal to or perpendicular to the indoor unit.



Horizontal connection



Vertical installation

Horizontal installation


18.3. Refrigerant charging

- For twin and triple-type systems

The pipe length is the total of the branch pipe (L) and the junction pipes (la → lb → lc in order from the thickest diameter). At the point where the pipe length exceeds 30 m, determine the amount of refrigerant for the remaining liquid-side pipe diameters and pipe lengths from the following table in order to charge the system.


Liquid-side pipe diameter	$\varnothing 6.35$	$\varnothing 9.52$
Additional charging amount (kg/m)	0.02	0.05

Example 1: For 50BB outdoor unit with an equivalent pipe length of 50 m



	Liquid pipe diameter	Equivalent length	Additional charging amount for each pipe (kg)
Main pipe (L)	$\varnothing 9.52$	15m	Not needed if within 30m
Main pipe	(la)	$\varnothing 6.35$	10m Not needed if within 30m
	(lb)	$\varnothing 6.35$	10m If exceeds 30m, $5m \times 0.02 = 0.1$
	(lc)	$\varnothing 6.35$	15m $15m \times 0.02 = 0.3$
<hr/>		50m	Total 0.4 kg

Example 2: For 50BB outdoor unit with an equivalent pipe length of 40 m




	Liquid pipe diameter	Equivalent length	Additional charging amount for each pipe (kg)
Main pipe (L)	$\varnothing 9.52$	15m	Not needed if within 30m
Main pipe	(la)	$\varnothing 9.52$	10m Not needed if within 30m
	(lb)	$\varnothing 6.35$	15m If exceeds 30m, $10m \times 0.02 = 0.2$
<hr/>		40m	Total 0.2 kg

18.4. Wiring

Connection 1:


When only the outdoor unit draws power



Connection 2:

When both indoor and outdoor unit draw power

(Example: 3 Phase power supply model)





Important

* For the above connection 2, if outdoor terminal 1 & terminal 2 are joined to indoor terminal 3 & terminal 4 by mistake upon operation, the control circuit board will be defected. (Wiring mistake prevention is not applicable for this connection).

19 WIRING MISTAKE PREVENTION

Improved quality of installation work through adoption of an “Connection error prevention” circuit which prevents wiring mistakes




Connection errors with the control wires and the power supply wires will not only contribute to burning-out of the control circuit board, but can also cause large-scale working losses and affect reliability. If a circuit board with a “Connection error prevention” circuit is used, the relay will not operate if the wires have been connected incorrectly, so that current will not flow to the control circuit board. This is designed principally to compensate human error during installation.


Prevention of connection errors

These units are equipped with connection error prevention circuits. If the units do not operate, it is possible that the connection error prevention circuits have been operated. In such cases, check that the power supply wires (connected to terminals **1** and **2**) and the control wires (connected to terminals **3** and **4**) are connected correctly. If they are connected incorrectly, connect them correctly. Normal operation should then commence.

(CORRECT)



(INCORRECT)



- Do not short the remote control wires to each other. (The protection circuit will be activated and the units will not operate.) Once the cause of the short is eliminated, normal operation will then be possible.

NOTE:

- Wait one minute after turning on the indoor unit power supply before operating the remote control.
- If nothing at all appears in the remote control LCD, check the power supply for the indoor unit.
Refer to “TROUBLESHOOTING” chapter.

NOTE:

Do not allow any of the following connection, as such connection may damage the printed circuit board.

- Do not connect anything except a relay to the timer input or fan speed output (connector CNT1 on printed circuit board).
- Do not connect U-NET transmission wires to terminals 3 and 4 of the indoor and outdoor units. (*1)
- Do not connect U-NET transmission wires to terminals A and B of the remote control.

(*1) U-NET transmission wires are the communication wires used for the central control.


20 TEST OPERATION AND SELF DIAGNOSIS

20.1. Test operation

- Always use a properly-insulated tool to operate the switch on the circuit board. (Do not use your finger or any metallic object).
- Never turn on the power supply until all installation work has been completed.
- Turn on the circuit breaker before test operation extends past 12 hours.
(The crankcase heater will be energized, which will warm the compressor and prevent liquid compression.)
- For three-phase models, check that the phase is not reversed.
(If the phase is reversed, the LED on the printed circuit board will flash.)
- Check that the voltage is 198 V or higher when starting the unit. (The unit will not operate if the voltage is less than 198V.)
- Carry out test operation for 5 minutes or more, using the remote control or the switch on the outdoor unit printed circuit board.
- Always carry out cooling operation first during test operation, even during the warm season.
(If heating is carried out first, problems with operation of the compressor will result.)

20.2. Test operation from the outdoor unit

(Outdoor unit printed circuit board)




During outdoor unit emergency operation or test operation, the LEDs on the printed circuit board will flash.

	LEDs on outdoor unit printed circuit board						
	LED2	LED3	LED4	LED5	LED6	LED7	LED8
Emergency operation display			■	■	■		
Cooling test operation from outdoor unit	■	■	■				
Heating test operation from outdoor unit					■	■	■


To cancel test operation, press the TEST RUN button once more while test operation is being carried out.
(Test operation will stop automatically after 30 minutes have passed.)

20.3. Test operation using the wired remote control





- Check that "COOL" is displayed on the operation mode display, and then press the OFF/ON button to start test operation.
- Within 1 minute of pressing the OFF/ON button, press the TEST RUN button.
- The pipe temperature (gas pipe) will then be displayed in the temperature setting display of the remote control.

(Example)



- During group control, the number appearing in the timer display will change each time the air conditioner No. button is pressed, and the pipe temperature for the indoor unit corresponding to the number displayed will appear in the temperature setting display.
- Check that the temperature in the pipe temperature display starts dropping after operation has been continuing for some time.


20.4. Test operation using the wireless remote control



<Air conditioner No.>

- The air conditioner No. "01" appears during normal installation and use. When using group control, a different number may appear. The air conditioner No. can be displayed by pressing the air conditioner No. button.


(Example)



When an abnormality occurs at this unit, "CHECK" flashes in the display.

Press the CHECK button while the display is flashing.


(Example)



The timer display will change and an error code from F15 to F49 will appear in place of the time. (The temperature setting display will also change to show the air conditioner No.)

Press the TIMER SELECT/SET button while the error is displayed.

(Example)



The F15 - F49 display will change to the detail display.

- After checking the error display and the detail display, refer to the self-diagnosis error code table on the following page and check the location of the problem.
- If the problem is repaired and operation returns to normal, the CHECK display on the remote control will be eliminated, but the self-diagnosis LED will remain illuminated until the operation starts again.

20.5. Self-diagnosis function

- The wired remote control display and the self-diagnosis LEDs (red) on the outdoor unit printed circuit board indicate where the abnormality has occurred.
- Recalling the error display.

How to display the past error message

If the "CHECK" display on the wired remote control is not flashing, press the CHECK button continuously for 5 seconds or more to display the problem details for the last problem or the problem before that. You can then switch between the displays for the previous problem and the problem before that by pressing the TIMER FORWARD or BACK buttons.

(Last problem display: 1F15 - 1F49

Second-last problem display: 2F15 - 2F49)

Press the CHECK button once more to return to the normal display.

(Example of last problem display)

LOCAL	AIRSWING	TIMER CHECK	FAN SPEED	OPE- RATION	TEMP
		1F 15			A/C No. 01°C

An error code from 1F15 to 1F49 will be displayed.

(The temperature setting display will also change to show the air conditioner No.)

(Example)

LOCAL	AIRSWING	TIMER CHECK	FAN SPEED	OPE- RATION	TEMP
		1-01			A/C No. 01°C

If the TIMER SELECT/SET button is pressed while the error code from 1F15 to 1F49 is being displayed, the display screen will change to show the details of the last problem display.

(If 2F15 to 2F49 is being displayed, the details of the second-last problem display will appear.)

● Self-diagnosis error code table

Flashing O: Illuminated Blank: Off

Remote control display			Printed circuit board self-diagnosis LED (red)								Error display (Check location)	
Wired		Wireless	Indoor unit	Outdoor unit								
Error display	Detail display	Operation LED	LED2	LED2	LED3	LED4	LED5	LED6	LED7	LED8		
F15	-01									(※2)	(※2)	Drain level float switch problem Drain pump and drain pipe, indoor unit connectors CN6 & CN10, or relay connector
F16	-01									(※2)	(※2)	Louvre switch problem Louvre motor, veneer panel connection terminal, or indoor unit connectors CN1 & CN6
F17	-01									(※2)	(※2)	Option problem Option connection terminals
F20	-01									(※2)	(※2)	Indoor temperature thermistor problem Indoor temperature thermistor lead wire or indoor unit connector CN1
	-02									(※2)	(※2)	Remote control thermistor problem Remote control thermistor
F21	-01									(※2)	(※2)	Pipe temperature thermistor problem (indoor unit side) Pipe temperature thermistor lead wire or indoor unit connector CN1
F25	-01									(※2)	(※2)	Centralised control address overlap problem Check settings for optional centralised control circuit board address switch
F26	-01									(※2)	(※2)	Remote control transmission wire open circuit problem Remote control unit cable and connection terminals
	-02									(※2)	(※2)	Remote control transmission problem Check the transmission wave pattern
F27	-01											Indoor/outdoor unit transmission wire open circuit problem Indoor/outdoor unit connection cable and connection terminals, or indoor unit and outdoor unit power supplies
	-02											Indoor/outdoor unit transmission problem Check the transmission wave pattern
F29	-01									(※2)	(※2)	Indoor unit setting problem Abnormal setting of the indoor p.c. board
	-02									(※2)	(※2)	Indoor unit setting problem Abnormal setting of the indoor p.c. board
	-12									(※2)	(※2)	Remote control unit setting problem Abnormal setting of the remote control
F30	-02											Negative or open phase power supply Check the main power supply terminal board connections, and switch the main power supply phase
	-06											Poor power supply connection, or distorted voltage wave pattern Check the main power supply terminal board connections, and check the power supply wave pattern.
	-07											Poor power supply connection Check the main power supply terminal board connections
F31	-02											High-pressure cut-off Refrigeration system, Obstructing of the heat radiation from outdoor unit
F33	-01											Compressor overcurrent protection Open phase or lock in compressor, or blown main power supply fuse
	-02											Compressor discharge temperature protection Insufficient gas
F40	-41											Compressor discharge temperature thermistor problem Discharge temperature thermistor lead wire, outdoor unit connector CN2, or relay connector
	-61											Heat exchanger outlet temperature thermistor problem (Outdoor unit) Heat exchanger outlet temperature thermistor lead wire, outdoor unit connector CN2, or relay connector
F41	-02											High-pressure switch open circuit problem High-pressure switch lead wire, outdoor unit connector CN2, or relay connector
	-03											Heating pressure switch open circuit problem Heating pressure switch lead wire, outdoor unit connector CN2, or relay connector
F42	-01											Current detector open circuit or compressor current problem Outdoor unit connector CN2, compressor internal protection system activated, or blown main power supply fuse
F49	-01											Outdoor unit setting problem Abnormal setting of the outdoor p.c. board
F49	-01											Outdoor unit setting problem Abnormal setting of the outdoor p.c. board

If more than one error occurs between the indoor and outdoor units, the problem display on the remote controller may not match the LED display on the outdoor unit printed circuit board. In such cases, check both locations and remove the causes of the problems.


(※2)	LED7	LED8	Unit display for twin/triple system
			Master unit error
	O		Slave unit 1 error
	O		Slave unit 2 error

- The LED1 (green) illuminates to indicate that the microprocessor on the microprocessor circuit board is operating normally. If the LED is switched off or is flashing irregularly, check the power supply, and turn it off and then on again.

21 SETTING OF SAVE ENERGY AND THERMISTOR SWITCH

21.1. Energy save setting

- Upper and lower limit can be set for the setting temperature during cooling and heating operation. (The factory shipment setting has an upper limit of 31°C and a lower limit of 16°C.)




- While operation is stopped, press the TEMP UP and TEMP DOWN buttons simultaneously.



The display will change.

(Example)



- To set an upper limit

Press the OPERATION button until HEAT is displayed.

↓

Press the TEMP UP or TEMP DOWN button to set the temperature.

↓

Press the SET button to complete the upper limit setting.

Example:

If the heating display is set to 28°C, setting the temperature to higher than 28°C will not be possible.

* Upper and lower limits cannot be set at the same time.

- To set a lower limit

Press the OPERATION button until COOL is displayed.

↓

Press the TEMP UP or TEMP DOWN button to set the temperature.

↓

Press the SET button to complete the lower limit setting.


Example:

If the cooling display is set to 22°C, setting the temperature to lower than 22°C will not be possible.

* Press the CANCEL button to cancel the setting.

21.2. Switching to the remote control thermistor

- The temperature detection thermistor used for detecting the indoor temperature can be switched between the thermistor at the indoor unit and the thermistor at the remote control unit. (The factory shipment setting is at the indoor unit side.)




- While operation is stopped, press and hold the TEST RUN button, TEMP UP button and TEMP DOWN button simultaneously.



The time display on the timer display panel will change.

(Example)



"00" ... Indoor unit temperature detection setting
"01" ... Remote control temperature detection setting

Press the FORWARD or BACK timer button to change the temperature detection setting.

- Press the SET button to complete the setting.

To change the setting, repeat the above operation.

22 GROUP CONTROL

Setting group for 1 remote control unit

- When using a remote control thermostat, the thermostat setting is used for all indoor units in the group.
- During group control, up to a maximum of 16 indoor units can be connected. (Do not mix heat pump units and cooling-only units.)
- Do not mix manual settings and automatic settings. (manual settings take priority.)
- The master unit and slave units can be centralized controlled during group control.

Automatic setting for group control

- If the power supplies for indoor units which are connected are turned on simultaneously, the indoor unit numbers will

be determined automatically after approximately 1 minute.
(DIP switch settings are not necessary.)

NOTE:

- Correct wiring connections are a basic requirement for automatic setting. If the wires are connected incorrectly when the power is turned on, the settings will not be made correctly and operation will not be possible.
- When address numbers are set automatically, you will not know which address number corresponds to which indoor unit.
- Do not turn off the power supply for at least 1 minute during automatic address setting, otherwise the settings will not be made correctly.

(Manual setting for group control)


	Indoor unit No.	1	2	3	4	5	6	7	8
Manual Setting	DIP switch (DSW1) Setting on Indoor unit Printed circuit Board Air conditioner No.setting	OFF ON 1 2 3 4 5 6 7 8 No operation necessary	OFF ON 1 2 3 4 5 6 7 8 1 is ON	OFF ON 1 2 3 4 5 6 7 8 2 is ON	OFF ON 1 2 3 4 5 6 7 8 1 and 2 are ON	OFF ON 1 2 3 4 5 6 7 8 3 is ON	OFF ON 1 2 3 4 5 6 7 8 1 and 3 are ON	OFF ON 1 2 3 4 5 6 7 8 2 and 3 are ON	OFF ON 1 2 3 4 5 6 7 8 1, 2 and 3 are ON
	Indoor unit No.	9	10	11	12	13	14	15	16
	DIP switch (DSW1) Setting on Indoor unit Printed circuit Board Air conditioner No.setting	OFF ON 1 2 3 4 5 6 7 8 4 is ON	OFF ON 1 2 3 4 5 6 7 8 1 and 4 are ON	OFF ON 1 2 3 4 5 6 7 8 2 and 4 are ON	OFF ON 1 2 3 4 5 6 7 8 1, 2 and 4 are ON	OFF ON 1 2 3 4 5 6 7 8 3 and 4 are ON	OFF ON 1 2 3 4 5 6 7 8 1, 3 and 4 are ON	OFF ON 1 2 3 4 5 6 7 8 2, 3 and 4 are ON	OFF ON 1 2 3 4 5 6 7 8 1, 2, 3, 4 are ON

Automatic address resetting for group control

Set the DIP switches 1 to 4 to OFF and stop the operation. Then press the "AIR SWING AUTO" "OPERATION" and "Air conditioner No." buttons simultaneously. Then addresses will be momentarily reset, and then automatic address setting will be carried out once more.

Note with regard to the Mini-cassette

When carrying out group control of a Mini-cassette system using a single wireless remote control, be sure to disconnect the connectors for all receptor circuit boards except the one for indoor unit No. 1, before turning on the power. (The same action as for the slave units in twin and triple systems is necessary.)



23 TROUBLESHOOTING


If test operation does not proceed correctly

Carry out test operation after approximately 12 hours have passed since the power was turned on (crankcase heater is energized). If operation is started by using the remote control within 1 minute of turning on the power, the outdoor unit settings will not be made correctly and correct operation will not be possible.

If the following symptoms occur after turning on the power, check the wiring connections once more.

• For standard installation

(System example)



1. The main power is turned on while the indoor-outdoor transmission wires are not connected (open circuit at section A)

Symptom:

Remote control unit... "CHECK" flashes

NOTE:

Indoor unit... LED2 on printed circuit board flashes

Outdoor unit... LED3 and LED7 on printed circuit board flash

2. The main power is turned on while the indoor-outdoor power supply wires are not connected (open circuit at section B)

Symptom:

Remote control unit... Display of "No power supply"

NOTE:

Indoor unit... No display

Outdoor unit... LED3 and LED7 on printed circuit board flash

3. The main power is turned on while the remote control unit connection cord is not connected (open circuit at

section C)

Symptom:


Remote control unit... Display of "No power supply"

NOTE:


Indoor unit... LED1 on printed circuit board stays illuminated

Outdoor unit... LED1 on printed circuit board stays illuminated

(When remote control display shows "Power supply")



(When remote control display shows "No power supply")




Remedy

1. Turn off the main power.
↓
2. Connect the disconnected wire correctly.
↓
3. Turn on the main power.
↓
4. After 1 minute, start the operation using the remote control.
(Indoor unit operation will start according to the remote control setting.)
(Outdoor unit operation will start after 3-5 minutes.)

NOTE:

The "CHECK" display on the remote control and the flashing of LEDs on the printed circuit boards will not occur immediately. They will appear 3-6 minutes after the main power is turned on.

● During twin/triple operation
(System example)



1. The main power is turned on while the transmission wires between the indoor unit(s) are not connected (open circuit at section A)

Symptom:

Nothing abnormal appears on the remote control display. If operation is started in this condition, the combination of the 50BB outdoor unit and the 14BB4 indoor unit (master unit) will result in abnormal operation.

↓

If operation continues, an abnormality will occur on the refrigeration cycle and operation will stop.

- Remote control... "CHECK" flashes
- Indoor unit (master)... The LEDs on the printed circuit board flash and operation stops
- Indoor unit (slave)... LED1 on the printed circuit board illuminates and the unit does not operate at all
- Outdoor unit... The LEDs on the printed circuit board flash and operation stops

2. The main power is turned on while the power supply wires between the indoor unit(s) are not connected (open circuit at section B)

Symptom:

Same as above. If operation continues, an abnormality will occur on the refrigeration cycle and operation will stop.

↓

- Remote control... "CHECK" flashes
- Indoor unit (master)... The LEDs on the printed circuit board flash
- Indoor unit (slave)... The LEDs on the printed circuit board do not illuminate and the unit does not operate at all
- Outdoor unit... The LEDs on the printed circuit board flash and operation stops

3. The main power is turned on while the remote control

connection cord is not connected (open circuit at section C)

Symptom:

- Remote control unit... Display of "No power supply"
- Indoor unit (master)... LED1 on the printed circuit board stays illuminated and the unit does not operate
- Indoor unit (slave)... LED1 on the printed circuit board stays illuminated and the unit does not operate
- Outdoor unit... LED1 on the printed circuit board stays illuminated and the unit does not operate

Remedy


1. Turn off the main power.
↓
2. Connect the disconnected wires correctly.
↓
3. Turn on the main power.
↓
4. After 1 minute, start the operation using the remote control.
(Indoor units' operation will start according to the remote control setting.)
(Outdoor unit operation will start after 3-5 minutes.)

If slave units do not operate even after the wiring has been corrected (automatic addressing is not possible)

1. Check that DIP switches 1 to 4 and DIP switch 8 are all set to OFF, and then stop operation.
↓
2. Press the ADDRESS RESET button (SW3) at the outdoor unit for approximately 4 seconds
(The self-diagnosis LEDs 2 to 8 will illuminate in order, and the system is reset once they are all illuminated.)

The above procedure cannot be used to carry out automatic address resetting during group control.

● During group control operation
(System example)



1. The main power is turned on while the transmission wires between the indoor unit and the outdoor unit are not connected (open circuit at section A)

Symptom:

Operation of indoor unit No. 1 and indoor unit No. 3 is possible.

However, "CHECK" flashes in the remote control display for 3-5 minutes after the main power is turned on.

- Remote control... "CHECK" flashes
- Indoor unit No. 2... LED2 on the printed circuit board flashes (both master and slave units)
- Outdoor unit No. 2... LED3 and LED7 on the printed circuit board flash

2. The main power is turned on while the power supply wires between the indoor units are not connected (open circuit at section B)

Symptom:

Operation of indoor unit No. 1 and indoor unit No. 3 is possible

However, if operation is then started in this condition, the combination of the 28BB outdoor unit and the 14BB4 indoor unit (master unit) will result in abnormal operation of indoor unit No. 2.

↓

If operation continues, an abnormality will occur on the refrigeration cycle and operation will stop

- Remote control... "CHECK" flashes (indoor unit No. 2 abnormality)
- Indoor unit No. 2... LED2 on the printed circuit board flashes (both master and slave units)
- Outdoor unit No. 2... The LEDs on the printed circuit board flash

3. The main power is turned on while the remote control connection cord is not connected (open circuit at section C)

Symptom:

Nothing abnormal appears on the remote control display, and operation of indoor unit. No. 1 and indoor

unit No. 2 is possible.

However, indoor unit No. 3 cannot be operated.

• **Remedy**

1. Turn off the main power.
↓
2. Connect the disconnected wires correctly.
↓
3. Turn on the main power.
↓
4. After 1 minute, start the operation using the remote control.
(Indoor units' operation will start according to the remote control setting.)
(Outdoor units' operation will start after 3-5 minutes.)

If slave units do not operate even after the wiring has been corrected (automatic addressing is not possible)


1. Check that DIP switches 1 to 4 and DIP switch 8 are all set to OFF, and then stop operation.
↓
2. Press the "AIRSWING AUTO", "OPERATION" and "A/C No." buttons simultaneously.
The addresses will be momentarily reset, and then automatic address setting will be carried out once more.

The above procedure cannot be used to carry out automatic address resetting of twin/triple control.

(Note on automatic address setting)

The printed circuit boards automatically store the connected system configuration when power is supplied. As a result, once the power has been turned on for these printed circuit boards, the units can not be changed about within the system, even if the units are of the same model and have same capacity.


● Address setting for twin/triple system (Example)



1. Automatic address setting (don't need to set dip-switch)

If the wiring is connected properly as above example, the address is set automatically by the main power supply. An indoor unit with remote control will be set as the master. If the power source is installed to indoor units and outdoor units separately, turn on the switch by following the procedure: outdoor unit, then indoor unit with control, and finally other indoor units.

When the slave units do not operate (when address cannot be set)



Reset the address by following the procedure:

- After making sure that dip-switches No. 1 to 4 and No. 8 are OFF, stop the operation.
- Push address reset button (SW3) on the outdoor unit PC board for 4 seconds. Self-diagnosis LED No. 2 to 8 will start blinking in order. And when all 7 pieces of LEDs (No. 2 ~ 8) are illuminated, the address for the slave unit has been reset.

Important: The address for the group control cannot be reset, using the above mentioned procedure.


2. Manual address setting (by dip-switch DSW1)

When setting the address manually, set the dip-switch of the PC board of the indoor unit as follows:

Master Unit	Slave unit (Slave No.1 of Triple)	Slave unit (Slave No.2 of Triple)
The unit with the wired remote control or the ray receiver connected will be the master unit.	DSW1 ON OFF No. 8 ON, The other no change	ON OFF No. 1 and 8 ON, The other no change

● Address setting for group control system

(Example)




1. Automatic address setting (don't need to set dip-switch)

If the wiring is connected properly as above example, the AC numbers are set automatically by the main power supply. An indoor unit with remote control will be set as the master. If the power source is installed to indoor units and outdoor units separately, turn on the switch by following the

procedure: outdoor unit, then indoor unit with control, and finally other indoor units. The AC number will be set at random.

When the slave units do not operate (when address cannot be set)



Reset the address by following the procedure:

- a. Make sure that dip-switches No. 1 to 4 and No. 8 are OFF, stop the operation.
 - b. Simultaneously, push buttons "AIR SWING AUTO", "OPERATION" and "A/C No.". The address will be reset and new address will be set.

Important: The address for the Twin/Triple control cannot be reset, using the above mentioned procedure.

2. Manual address setting (by dip-switch DSW1)

When setting the address manually, set the dip-switch of the PC board of the indoor unit as follows:

Master Unit	Slave units																																																																																			
	Slave No.1 of twin system (to outdoor unit 2)	Slave No.2 (to outdoor unit 3)	Slave No.3 (to outdoor unit 4)																																																																																	
The unit with the wired remote control or the ray receiver connected will be the master unit. (DSW1 of No.5 and 7 are defaulted to "ON").	<p>DSW1</p> <table border="1"> <tr> <td>ON</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>OFF</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>1</td><td>2</td><td>3</td><td>4</td><td>5</td><td>6</td><td>7</td><td>8</td><td></td> </tr> </table> <p>No. 1 ON, the others no change</p>	ON									OFF									1	2	3	4	5	6	7	8		<p>DSW1</p> <table border="1"> <tr> <td>ON</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>OFF</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>1</td><td>2</td><td>3</td><td>4</td><td>5</td><td>6</td><td>7</td><td>8</td><td></td> </tr> </table> <p>No. 8 ON, the others no change</p>	ON									OFF									1	2	3	4	5	6	7	8		<p>DSW1</p> <table border="1"> <tr> <td>ON</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>OFF</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>1</td><td>2</td><td>3</td><td>4</td><td>5</td><td>6</td><td>7</td><td>8</td><td></td> </tr> </table> <p>No. 2 ON, the others no change</p>	ON									OFF									1	2	3	4	5	6	7	8	
ON																																																																																				
OFF																																																																																				
1	2	3	4	5	6	7	8																																																																													
ON																																																																																				
OFF																																																																																				
1	2	3	4	5	6	7	8																																																																													
ON																																																																																				
OFF																																																																																				
1	2	3	4	5	6	7	8																																																																													

3. Manual address setting (by dip-switch DSW1)

When setting the address manually, set the dip-switch of the PC board in the indoor unit as follows:

Indoor unit No.	1	2	3	4	5	6	7	8
Dip-switch on the PCB of the indoor unit (DSW1)								
No Change	No.1 ON	No.2 ON	No.1,2 ON	No.3 ON	No.1, 3 ON	No.2, 3 ON	No.1, 2, 3 ON	No.1, 2, 3, 4 ON
Indoor unit No.	9	10	11	12	13	14	15	16
Dip-switch on the PCB of the indoor unit (DSW1)								
No.4 ON	No.1, 4 ON	No.2, 4 ON	No.1,2, 4 ON	No.3, 4 ON	No.1, 3, 4 ON	No.2, 3, 4 ON	No.1, 2, 3, 4 ON	No.1, 2, 3, 4 ON

Procedures of deleting memory for twin/triple control system

1. Switch off the main power supply.
 2. Set the No. 8 pin of dip switch (DSW1) at the indoor unit's P.C. board to "ON" position.
 3. Switch on the main power supply for a minute and then turn it off.
 4. Set the No. 8 pin of dip switch (DSW1) to "OFF" position.

Procedures of deleting memory for group control system


1. Switch off the main power supply.
 2. Set the No. 1 until No. 4 pin of dip switch (DSW1) at the indoor unit's P.C. board to "ON" position.
(Make sure No. 8 pin of dip switch (DSW1) is at "OFF" position)
 3. Switch on the main power supply for a minute and then turn it off.
 4. Set the No. 1 pin until No. 4 pin of dip switch (DSW1) to "OFF" position.

(Important notice)

Above procedures are meant for deleting memory on indoor unit's P.C. board. And it is not for Address reset.

Indoor unit P.C. board layout

Below drawing shows the location of dip switch 1 (DSW1) on the indoor unit P.C. board.



Dip switch 1 (DSW1). [to be used for manual setting]

24 EMERGENCY OPERATION

Emergency operation

- Emergency operation of outdoor unit

Emergency operation can be carried out by setting the DSW1 switch on the printed circuit board of the outdoor unit to the EMERGENCY position. However, emergency operation is only carried out when an abnormality is detected by the indoor/outdoor temperature thermistors. The resistance values of each thermistor are measured as shown in the table below to determine if there is an abnormality.

Thermistor resistance table

Temperature	Resistance value (kΩ) ± 5%	
	Room temperature thermistor	Pipe temperature thermistor
-20°C	205.8	197.8
-10°C	114.6	111.9
-5°C	87.3	85.4
0°C	67.0	65.8
5°C	51.8	51.0
10°C	40.4	39.9
15°C	31.7	30.7
20°C	25.1	25.0
25°C	20.0	20.0
30°C	16.1	16.0
40°C	10.4	10.6
50°C	6.9	7.1
60°C	4.7	4.9
70°C	----	3.5
80°C	----	2.5
90°C	----	1.8
100°C	----	1.4

The pipe temperature thermistor resistance value are the same for the indoor and outdoor units.


<When a thermistor abnormality is judged to have occurred>

- Set only the thermistor which shows an abnormality to the condition as shown in the table below to carry out emergency operation.

Indoor unit	Thermistor	Cooling mode	Heating mode
	Room temperature	Fixed at 25°C	
	Pipe temperature	Shorted	Open

Outdoor unit	Thermistor	Cooling mode	Heating mode
	Discharge temperature	Open	Shorted
	Heat exchanger outlet temperature	Shorted	Open

- Refer to the circuit diagram for the connection locations for each thermistor.
- If there is an abnormality in the room temperature thermistor, the temperature will be fixed at 25°C regardless of the remote control display.




NOTE:

- Any abnormalities detected by the temperature thermistors are ignored during emergency operation, therefore, long-term operation in this mode should be avoided.
- After emergency mode operation has been completed and normal operation is to be resumed, turn off the power supplies for the indoor and outdoor units and set the DSW1 switch to NORMAL position.
- Self-diagnosis LEDs 4 to 6 will flash during emergency operation.

25 CONTROL

Description of basic Functions

25.1. Cooling mode operation time chart



(*1)

Outdoor unit fan start control during cooling

At the start of cooling mode and drying mode operation, the outdoor unit heat exchanger outlet temperature is detected in order to set the fan speed.

Operation is carried out at the fan speed detected for 30 seconds.

Heat exchanger outlet temperature detected (T)	Outdoor unit fan start speed
$T < 0^\circ\text{C}$	SUPER LOW
$0^\circ\text{C} \leq T < 10^\circ\text{C}$	LOW
$10^\circ\text{C} \leq T < 20^\circ\text{C}$	MEDIUM
$20^\circ\text{C} \leq T < 25^\circ\text{C}$	HIGH
$25^\circ\text{C} \leq T$	SUPER HIGH

After 30 seconds, the heat exchanger outlet temperature is detected and the outdoor unit fan speed is changed automatically.

(*2)

Cooling low outdoor temperature protection

When the outlet temperature of the heat exchanger drops to less than 12°C for a continuous period of 10 minutes, the outdoor unit stops.

This is cancelled after 3 minutes (re-start prevention)


- Remote control displays and indoor unit operation continue during this time.
- The 10 minutes countdown is cleared if the compressor stops or if the temperature at the outdoor unit outlet rises to 13.5°C or higher.

25.2. Drain pump control


1. Basic operation

During cooling mode, dry mode or defrost mode operation, the drain pump turns on when the compressor turns on. (The drain pump turns on during freezing prevention control.)

- When the compressor turns off, the drain pump will still continue its operation for 6 more minutes.



- If the drain pump is running when operation stops or when the operating mode is changed, the drain pump will still continue its operation for 6 more minutes.



2. Drain water problems

a. Starting


If it is detected that the float switch is off, the drain pump turns on for 5 minutes. If the float switch is still found to be off after these 5 minutes have passed, or if the float switch is found to turn off twice during another 30 minutes period, a drain water error will be generated.

b. Normal operation


After extension control (louvre initialization and pre-heating cancel), the indoor units and outdoor units stop running. LED2 on the indoor unit self-diagnosis LED panel will flash, and "CHECK" will appear on the wired remote control display. The error code (F15-01) can be displayed by pressing the CHECK button.

When the wireless remote control is being used, the OPERATION indicator on the ray receiver will flash.

<If the float switch does not operate again after turning off>




(When float switch is continuously off)



<If the float switch operates again after turning off>

<If the float switch continues to be off>



25.3. Freezing prevention control

1. Operation


During cooling mode operation, after 9 minutes have passed since the compressor turned on, the outdoor unit will stop its operation when the temperature detected by the indoor unit pipe temperature sensor is 2°C or lower.

The indoor unit continues operating at the fan speed set by the remote control. (The remote control display does not change.)

2. Cancelling


This control is cancelled when the temperature detected by the indoor unit pipe temperature sensor is 15°C or higher, however 3 minutes waiting of prevention control is necessary.

(The 9 minutes countdown is cleared while the compressor is stopped.)



(The above illustration only shows the operation stops due to freezing prevention control of the indoor pipe temperature sensor.)

25.4. Heating mode operation time chart (Heat pump type)




(*2)

Outdoor unit fan control during heating mode operation

When the compressor is on during heating mode operation (except during defrosting and when the liquid bypass valve is on), the outdoor unit fan is controlled by means of input (CN2) indicating whether the contact of the heating pressure switch on the outdoor unit circuit board is open or closed.

(At the start of heating mode operation, the fan operates at HI speed.)

Heating pressure switch contact	Outdoor unit fan operation
ON (open) - OFF (closed)	One step down from fan speed before stopping
ON (open)	Stopped



The heating pressure switch turns on at 2.35 MPa and off at 1.96 MPa.

25.5. Hot starting

1. When heating mode operation starts

a. Start

Hot start control commences when heating mode operation starts.

b. Operation

"PREHEAT" appears on the remote control display. (Other displays remain unchanged.)

The indoor unit fan stops. In addition, during hot starting, the louvre stays at the horizontal position (angle 0°).


c. Cancelling

Hot starting will be cancelled when the compressor is turned on or the indoor unit pipe temperature sensor is 18°C or higher or after 1 minute of operation.


After cancellation, the "PREHEAT" display on the remote control disappears and the louvre operation returns to the previous setting.

(However, for 2 minutes after cancellation, the indoor unit fan operates at LOW speed, and then returns to the previous setting.)

<When hot start operation is cancelled by temperature>



<When hot start operation is cancelled by time>



2. When defrosting is completed

a. Start

Hot start control commences when defrosting is completed.

b. Operation

"PREHEAT" appears on the remote control display. (Other displays remain unchanged)

The indoor unit fan stops. In addition, during hot starting, the louvre stays at the horizontal position (angle 0°C).


c. Cancelling

Hot starting will be cancelled when the temperature detected by the indoor unit pipe temperature sensor is 18°C or higher, or after a maximum 1 minute has passed since defrosting was completed.


After cancellation, the "PREHEAT" display on the remote control disappears and the louvre operation returns to the previous setting.

(However, the indoor unit fan operates at LOW speed for 2 minutes after cancellation, and then returns to the previous setting.)

<When hot start operation is cancelled by temperature>




<When hot start operation is cancelled by time>



25.6. Indoor unit fan control when thermostat is off during heating mode operation

When the thermostat of the indoor unit turns off during heating mode operation, the indoor unit fan operates for 2 minutes at LOW and then stops. In addition, 5 minutes after the thermostat of the indoor unit turns off, the indoor unit fan operates at LOW for 10 seconds, and at 3 minutes interval after that, it switches back to LOW operation for another 10 seconds.




25.7. Excess heat dissipation for indoor unit

The indoor unit fan continues its operation for 30 seconds after heating mode operation turns off in order to dissipate excess heat.

1. When heating mode operation has stopped
(LOW speed for 30 seconds)
2. When operation is set to a mode other than heating by means of the OPERATION button
3. If operation starts again during the 30 seconds mentioned at (1)
(The fan operates at LOW speed for the remainder of the 30 seconds and then hot start commences.)

25.8. Defrost mode operation time chart



1. Start and completion of defrosting

a. Start

During heating mode operation (including automatic heating), after the 45 minutes of defrosting cycle time has passed, defrosting starts if the temperature detected by the outdoor unit heat exchanger outlet sensor is 2°C or lower continuously for 5 minutes.

However, if the outdoor unit fan is stopped, the start of defrosting will be delayed by 5 minutes.

Then, the defrosting cycle will be 50 minutes from the start of heating mode operation.

b. Completion

Defrosting mode operation will stop if the outdoor unit heat exchanger outlet sensor is 25°C or higher or after 12 minutes of operation.

c. Forced defrosting

If P8 on the outdoor unit circuit board is shorted while the compressor is on during heating mode operation and the temperature detected by the outdoor unit heat exchanger outlet sensor is 25°C or lower, defrosting is carried out regardless of the current starting conditions.

2. Operation

- During defrosting, the outdoor unit turns on the compressor and turns off the outdoor unit fan and the reversing valve.
 - The indoor unit fan operates at LOW speed for 30 seconds upon defrosting starts. After this, the indoor unit fan turns off until defrosting is completed.
- (During defrosting, the louvre of the indoor unit stays at horizontal position).


25.9. Indoor thermostat characteristics

1. Thermostat characteristics during cooling and heating modes.


Operation mode	Setting temperature (To)	Room temperature (°C)		
		Operation	Differential	
			2.0K	4.0K
Cooling	16	O N	18.0	—
		O F F	16.0	—
	31	O N	33.0	—
		O F F	31.0	—
Heating *1	16	O N	18.0	20.0
		O F F	20.0	22.0
	29~31 *1 (27~31)	O N	31.0	31.0
		O F F	33.0	33.0

* If jumper wire J3 on the indoor unit circuit board is disconnected, the thermostat characteristics during heating become 2K or higher.

Thermostat characteristics during cooling and heating modes



Thermostat characteristics during heating mode (when jumper wire J3 is disconnected)



NOTE: If the remote control display setting temperature (To) is 29°C or higher, the heating thermostat turns on when the room temperature is 31°C.

2. Thermostat characteristics during dry mode.

During dry mode operation, cooling mode operation is carried out in accordance with the indoor temperature as shown in the table below.

Mode	Indoor Temperature (°C) T	Operation details	
1	T ≥ 28	Cooling thermostat on	LO, Louvre horizontal
2	28 > T ≥ 25	Cooling thermostat on 10 min./fan 5 min., alternate operation	LO, Louvre horizontal
3	25 > T ≥ 21	Cooling thermostat on 5 min./fan 10 min., alternate operation	LO, Louvre horizontal
4	21 > T	Cooling thermostat off	LO, Louvre horizontal

(Differential is 1.5 K)

* When modes (2) and (3) are active, dry mode operation starts when the cooling thermostat turns on.

When modes (2) and (3) have been stopped, the 10 min./5 min. times have no relevance. However, if the indoor temperature is less than or equal to the remote control unit setting temperature, mode (4) is forcibly activated.

3. Thermostat characteristics during automatic changeover operation

a. Settings at the start of automatic changeover operation

When operation changes from other modes to automatic changeover mode, operation starts at the temperature characteristics given in the table below.

Indoor Temperature (T) °C	Initial setting
$T < \text{remote control display temperature} - 2\ (^{\circ}\text{C})$	Heating mode operation, thermostat on
$\text{Remote control display temperature} \geq T$	Heating mode operation, thermostat off (fan mode operation)
$\text{Remote control display temperature} \leq T$	Cooling mode operation, thermostat off (fan mode operation)
$\text{Remote control display temperature} + 2\ (^{\circ}\text{C}) < T$	Cooling mode operation, thermostat on

2 (°C): Thermostat differential

b. Thermostat characteristic when switching between cooling and heating mode operation

Switching between cooling mode and heating mode operation is carried out as shown in the table below.

However, during automatic changeover operation, the operation will not change within 10 minutes after the thermostat has switched off, either cooling mode or heating mode.

(The 10 minutes timer will be cancelled when operation is changed to other modes (manually) or when operation stops and the thermostat turns on.)


Indoor Temperature (T) °C	Operation switching
$T \geq \text{Remote control display temperature} + 3\ (^{\circ}\text{C})$	Heating mode → Cooling mode
$T \leq \text{Remote control display temperature} - 3\ (^{\circ}\text{C})$	Cooling mode → Heating mode


c. Thermostat characteristics during cooling mode and heating operation

The thermostat on/off characteristics in both operation modes are given in the table below.

Operation mode	Indoor Temperature (°C) T	Operation
Cooling mode	$T > \text{Remote control display temperature} + 2\ (^{\circ}\text{C})$	Cooling thermostat on
	$T \leq \text{Remote control display temperature}$	Cooling thermostat off
Heating mode	$T < \text{Remote control display temperature} - 2\ (^{\circ}\text{C})$	Cooling thermostat on
	$T \geq \text{Remote control display temperature}$	Cooling thermostat off

Indoor temperature thermostat characteristics during automatic changeover operation





25.10. Indoor unit fan control

1. Fixing at LO, MED or HI

When LO, MED or HI is set, the relay switches and operation is carried out at that setting.

2. Automatic fan speed

When set to AUTO, the indoor unit fan operation changes as shown in the table below.


(Indoor temperature) - (Setting temperature) (Units: K)

Mode / Fan Speed	HI	MED	LO
Cooling	+3 or higher	+1.5 ~ 3	Less than +1.5
Heating	-3 or lower	-1.6 ~ -3	More than -1.5
Fan	MED irrespective of temperature		

25.11. Forced operation during restart

The compressor will not stop operating for 3 minutes after cooling mode operation starts, even if the indoor unit thermostat turns off.


(However, the compressor will stop operating during this time if the indoor unit air intake temperature drops to 16°C and below during cooling mode operation.)



25.12. Louvre control (models with louvre)

1. When main power is turned on

When the power is turned on, indoor unit louvre position detection is carried out twice and then the indoor unit louvre stops.



2. During initial operation

When the OFF/ON button is pressed to start the operation, the louvre moves through one full cycle, and then swings automatically (if AUTO has been set using the remote control) or moves to the setting angle (if MANUAL has been set using the remote control).

3. When operation stops

When the OFF/ON button is pressed to stop the operation, the louvre moves through one full cycle, and then stops in the down position, regardless of the remote control setting.

4. When thermostat is off

When operation is stopped by the indoor thermostat, the louvre moves through one full cycle, and then stops in the horizontal position, regardless of the remote control setting.

25.13. Outdoor unit fan excess heat dissipation control

- When the operation is stopped while the compressor is in operation, the outdoor fan will run at SUPER HI fan speed for approximately 60 seconds and then stops.

25.14. Discharge temperature control

1. Operation

When the discharge temperature sensor detects a temperature of 100°C or higher during cooling mode operation, the liquid bypass valve will be turned on.

2. Cancelling

When the discharge temperature sensor detects a temperature of 70°C or lower, the liquid bypass valve will be turned off.

25.15. Emergency operation

When the emergency operation switch (DSW1) on the outdoor unit printed circuit board is set to emergency, the emergency operation is enabled. This allows normal operation to continue, with all abnormalities other than a discharge temperature abnormality, high pressure abnormality or overcurrent abnormality being ignored.

25.16. DIP switch settings

- Indoor unit printed circuit board (DSW1)

No.	Setting type	Factory shipment	Remarks
1	Group address setting (twin/triple address setting)	OFF	When group operation is being carried out using the remote control, this address is set in order to control the order of starting for the indoor units. (If No. 8 is ON, twin/triple address setting is carried out.)
2		OFF	
3		OFF	
4		OFF	
5	Automatic restart	ON	When set to ON, operation after a power outage resumes at the settings which were in effect before the outage. (The backup time is semipermanent.)
6	Filter sign time	OFF	When set to ON, the filter sign times can be set to 2,500 times.
7	Louvre control	ON	When set to OFF, louvre control is disabled.
8	Twin/triple slave unit setting	OFF	When set to ON, the unit is designated as a slave unit.

26 WIRED REMOTE CONTROL INSTALLATION MANUAL

Wired Remote Control Installation Manual

- Before installing the wired remote control, be sure to thoroughly read the "Notes with regard to safety" section of the installation manual provided with the indoor unit.
- After installing the wired remote control, carry out a test operation to check that the remote control functions properly, and also explain the operation and cleaning procedures to the customer in accordance with the details in instruction manual. Furthermore, ask the customer to keep this installation manual and the instruction manual in a safe place for later reference.


1. ACCESSORIES SUPPLIED WITH WIRED REMOTE CONTROL

Name	Q'ty	Diagram	Remark	Name	Q'ty	Diagram	Remark
Remote control	1		Length (10m)	4mm screw	3		Installing the remote control to a wall
Remote control cable	1			M4 screw	3		Installing the remote control to an outlet box
				Round terminal	2		Connecting to indoor unit terminal block

2. NOTES REGARDING WIRED REMOTE CONTROL SETTING-UP LOCATION

- Select a place where the remote control can be operated easily (after obtaining approval from the building's owner).
- Install in a place which is away from direct sunlight and as free from humidity as possible.
- Install in a place which is as flat as possible to avoid warping of the remote control.
(If installed to a wall an uneven surface, damage to the LCD case or operation problems may result.)
- Install in a place where the LCD can be seen easily. If the remote control is installed somewhere which is too low or too high, it may be difficult to read the LCD. (Standard height from the floor is 1.2 to 1.5 meters.)
- Avoid installing the remote control cable near refrigerant pipes or drain pipes.
- Install the remote control cable at least 5 cm away from other electric wires (including stereo and TV cables) to avoid mis-operation (electromagnetic noise).
- If passing the remote control cable through a wall, be sure to install a water trap above the cable.
- Allow sufficient space around the remote control as shown in the illustration at right.

Secure the remote control lower case to the wall or to an outlet.




3. REMOTE CONTROL INSTALLATION

- Be sure to turn off the main power before installing and connecting the remote control.
(If the remote control is connected while the power is still turned on, the remote control displays may not appear.)
If no displays appear on the remote control, check while referring to "If no remote control displays appear" in 5 Test operation.
- The remote control cable is live during use, so take care not to short it.

Remote control wiring

- Connect the indoor unit and the remote control as shown in the illustration below.
- The remote control cable is non-polar.
- At the time of shipment from the factory, the connector cable used to connect the terminal block and connector CN1 is disconnected. When connecting the remote control wiring and installing the remote control, be sure to connect the cord to the connector CN1.




Extending the remote control cable

- Solder a sheathed PVC cord or cable (0.5 – 2 mm²) with specifications among those given below to the remote control end of the accessory remote control cable (10 m).

* PVC round cabtire cord	IEC 502
* 600V PVC-insulated PVC sheathed round cable	IEC 227-4
* 600V PVC-insulated PVC sheathed flat cable	IEC 227-4

NOTE The maximum possible length for the remote control cable is 200 m.




Remote control installation procedure


- Remove the remote control lower case.
(Insert a flat-tipped screwdriver or similar 2 to 3 mm into one of the gaps at the bottom of the case, and then twist the screwdriver to open. [Refer to the illustration at right.])
Be careful not to damage the lower case.
- Secure the lower case to the wall or outlet box.
(Refer to the illustration at right for the embedded and exposed positions for remote control cable.)

NOTE

- Be sure to use only the accessory screws.
- Do not bend the lower case when tightening the screws.
(If the screws are overtightened, damage may result.)
- Do not remove the protective tape which is affixed to the upper case circuit board.
- If installing the remote control with the remote control cable exposed, use pliers to cut a notch into the upper case. (The feeding-out direction can be either up or to the left or right)
- Strip the end of the remote control cable which is to be connected to the remote control. (Refer to the illustration at right)
- Route the remote control cable inside the lower case in accordance with the intended feeding-out direction. (Refer to the illustration below.)
- Securely connect connector CN1. (If it is not connected the remote control will not operate.)



NOTE After connecting the connector, do not suspend the upper case by its own weight, otherwise the connector cord may break.




- If controlling using two remote controls, refer to "Control using two remote controls" in "4 Settings".
- Secure the upper case to the lower case.
(Hook the upper tab of the upper case into the lower case, and then push the upper case until it snaps shut onto the lower case tab, while being careful not to clamp the remote control cable and the connector cord.)

If remote control cable is embedded	If installing with the remote control cable exposed
<p>1. Embed an outlet box (JIS C 8336) into the wall, and then secure the remote control base plate to the outlet box with the two accessory M4 screws. Make sure that the base plate is flat against the wall at this time, with no bending (looseness)</p> <p>2. Pass the remote control cable into the box and then install the remote control.</p>	<p>1. Secure the remote control base plate to the wall with the two accessory 4 mm screws.</p> <p>2. The feeding-out direction for the remote control cable can be either up or to the left or right. (Refer to the illustration above.) After determining the feeding-out direction, use pliers to make a notch in the cover.</p> <p>3. Route the remote control cable as shown in the illustration above. Pull the cord firmly around the outside of the base plate at this time.</p>

4. SETTINGS












Control using two remote control

- Up to two remote controls can be installed for a single indoor unit, and either remote control can be used to operate the indoor unit.
- The indoor unit can be operated with the last switch pressed having priority.
 - Decide which is to be the master and which is to be the slave remote control.
The master or slave states of the remote control is set automatically. The MASTER/SLAVE setting switch can also be used to make the setting manually, however if a manual setting is made, that manual setting has priority.
Be sure to turn off the main power before making a manual setting.
 - Connect the remote controls.
Connect both remote control to terminals (A) and (B) on the indoor unit terminal block (non-polar).



Group control

- All in group will be remote control thermistor setting when using the remote control thermistor.
- Up to a maximum of 16 indoor units can be connected at the time of group control.
(Do not connect heat pump unit with cooling only unit.)
- Indoor unit No. is possible to set automatically at the time of group control. However, which indoor unit will be which number is unknown.
Indoor unit No. is also possible to set manually with DIP switches. Since manual address setting is priority, when performing automatic address setting after doing manual setting turn off all DIP switches from No. 1 to No. 4, and then stop the operation and press three switches such as [AIR SWING AUTO] [OPERATION] • [A/C No.] at the same time.
(Do not use manual address setting and automatic address setting together.)

Indoor unit No.		1	2	3	4	5	6	7	8
DIP switch (DSW1) address setting on indoor unit printed circuit board.		OFF ON 	OFF ON 	OFF ON 	OFF ON 	OFF ON 	OFF ON 	OFF ON 	OFF ON 
A/C No. setting	Unnecessary operation	1 ~ ON	2 ~ ON	2, 3 ~ ON	1, 2 ~ ON	3 ~ ON	1, 3 ~ ON	2, 3 ~ ON	1, 2, 3 ~ ON
Indoor unit No.	9	10	11	12	13	14	15	16	
DIP switch (DSW1) address setting on indoor unit printed circuit board.	OFF ON 	OFF ON 	OFF ON 	OFF ON 	OFF ON 	OFF ON 	OFF ON 	OFF ON 	
A/C No. setting	4 ~ ON	1, 4 ~ ON	2, 4 ~ ON	1, 2, 4 ~ ON	3, 4 ~ ON	1, 3, 4 ~ ON	2, 3, 4 ~ ON	1, 2, 3, 4 ~ ON	

Automatic address resetting for group control

- The address settings for group control (air conditioner Nos. 1 to 16) can be reset automatically.
(1) While operation is stopped, press the AUTO switch, A/C NO. and OPERATION switches simultaneously.

Switching the thermistor


- The temperature detection thermistor can be switched between the thermistor at the indoor unit and the thermistor at the remote control. However, do not switch to the remote control thermistor if using two remote controls.
(1) While operation is stopped, press and hold the TEST RUN switch, and then press the UP and DOWN switches together.
(2) "00" or "01" will appear in the time display.
(3) Press the ▲ or ▼ timer switches to switch display between "00" and "01".
 "00" ... Indoor unit setting (factory default)
 "01" ... Remote control setting
(4) Press the SET switch. (Be sure to press the SET switch so that normal operation mode can be resumed.)
● Repeat the procedure in steps (1) to (4) to change the setting again.

Energy save setting

- Upper and lower limits can be set for the setting temperature during cooling and heating operation (Energy save setting)
(1) While operation is stopped, press the UP and DOWN switches simultaneously.
(2) "0" (zero) will flash in the clock display at this time, so press the SET switch.
(3) To set an upper limit (Setting a temperature above the energy save temperature will not be possible).
 Press the OPERATION switch unit HEAT is displayed.
 Press the UP or DOWN switch to set the temperature.
 Press the SET switch.
 Example: If the heating display is set to 28C, setting the temperature to higher than 28C will not be possible.
(4) To set a lower limit (Setting a temperature below the energy save temperature will not be possible).
 Press the OPERATION switch unit COOL is displayed.
 Press the UP or DOWN switch to set the temperature.
 Press the SET switch.
 Example: If the cooling display is set to 22C, setting the temperature to lower than 22C will not be possible.
(5) If the CANCEL switch is pressed during steps (3) or (4) above, the energy save setting will be cleared.
● Press the SET switch or the CANCEL switch to return to normal operation mode after making an energy save setting in steps (3) to (5).

5. TEST OPERATION

- Turn on the main power.
- After 3 minutes have passed since the power was turned on, press the OFF/ON switch on the remote control. (No operation occurs within 3 minutes after the power was turned on.)
- Press the TEST RUN switch within 1 minute of pressing the OFF/ON switch.
- Next, select the operation mode. (Be sure to select cooling mode first, and run the unit in this mode for 5 minutes or more.)
- Press the OFF/ON switch or the TEST RUN switch to cancel test operation.
- Test operation will be cancelled automatically after 30 minutes.



If no remote control displays appear

- Check whether LED1 (green) on the indoor unit printed circuit board is illuminated or switched off.
If it is switched off, check the circuits on the indoor unit printed circuit board.
- Check once more that the remote control cable is securely connected. (Check for loose terminals, poor contacts, connection positions terminal block, etc.)

- If the above checks show that nothing is wrong but nothing appears on the remote control display, it is possible that the remote control was connected while the main power was still turned on.
If such is the case, carry out the following.
- Set DIP switch (DSW1) No. 1 to 4 the ON position, and then turn on the main power. If the display appears after about 30 seconds, turn DIP switches 1 to 4 to OFF position.


6. SELF-DIAGNOSIS FUNCTION

The LED1 (green) indicators on the indoor unit and outdoor unit printed circuit boards illuminate to indicate that the printed circuit boards are operating normally. If the LEDs are switched off or are flashing irregularly, check the power supply, and turn it off and then back on again.

If "CHECK" is flashing on the timer

- If the "CHECK" display on the wired remote control is flashing, the details of the problem(s) are displayed on the timer display screen each time the CHECK switch is pressed.
- Further details of the problem can be displayed by pressing the SELECT switch while the general problem details are being displayed.


Example of current problem display



If "CHECK" is not flashing on the timer

- If the "CHECK" display on the wired remote control is not flashing, press the CHECK switch continuously for 5 seconds or more to display the problem details for the last problem or the problem before that.
- You can then switch between the display for the previous problem and the problem before that by pressing the timer ▲ or ▼ switches.
- Press the CHECK switch once more to return to the normal display.

Example of previous problem display



Example of abnormality display before previous display

-
- | TIMER | FAN SPEED | OPE-RATION | TEMP |
|--------------|-----------|------------|------|
| CHECK 2 F 26 | | A/C No. 01 | |
- While the previous display still appears, press the ▲ switch.
- Detail display →
- | TIMER | FAN SPEED | OPE-RATION | TEMP |
|--------------|-----------|------------|------|
| CHECK 2 - 01 | | A/C No. 01 | |
- Continue pressing the SELECT switch while the problem details are being display.
- The display can be switched between the previous problem and the one before that by pressing ▲ and ▼ switches.
 - After eliminating the cause of the problem, press the CHECK switch once more to return to the normal display.
 - If the problem disappears and operation returns to normal, CHECK display on the remote control will switch off, but the self-diagnosis LED will remain illuminated until operation is resumed.


27 WIRELESS REMOTE CONTROL INSTALLATION MANUAL

Wireless Remote Control Installation Manual

- Before installing the wireless remote control, be sure to thoroughly read the "Notes with regard to safety" section of the installation manual provided with the indoor unit.
- After installing the wireless remote control, carry out a test operation to check that the remote control functions properly, and also explain the operation and cleaning procedures to the customer in accordance with the details in the instruction manual.
Furthermore, ask the customer to keep this installation manual and the instruction manual in a safe place for later reference.


1. Accessories supplied with the wireless remote control

No.	Name	Qty
1.	Wireless Remote Control	1
2.	R03 battery	2
3.	Holder (for securing remote control)	1
4.	Holder fixing screw	2
5.	Receptor unit	1
6.	Receptor unit fixing screw	2
7.	Joint cord	1
8.	Cord clamp	8
9.	Plastic tie	3
10.	Installation manual	1



2. Points and notes regarding wireless remote control setting-up location


- The wireless remote control can be used to operate indoor units at a maximum range of 8 metres while directly facing in front of the indoor unit.
- If the remote control is at an angle to the receptor unit, the operation range may become shortened.
- The accessory receptor unit must be attached to the veneer panel.
- The receptor unit for the wireless remote control should be in a place where it will not be affected by direct light from any fluorescent lights. (Refer to the illustration below.)
(If using an inverter-type fluorescent light, keep the receptor unit at least 1m away from the light, otherwise remote control operation may not work properly.)



- If installing in a place where a power supply is generating electromagnetic noise, take measures such as installing a noise filter.
- Install at least 3m away from any noise sources and shield the electric cables using an iron conduit pipe.
- Install at least 1m away from equipment such as TVs and radios. (Otherwise picture distortion or static may occur.)

Wireless remote control installation procedure

- Installing the wireless remote control to a wall (for remote control storage).



- If using a single remote control to operate several air conditioners, address setting will be required. (Refer to later in this manual.)
- For twin and triple types, install to the main unit only. (Accordingly, the installation and wiring operations described later in this manual are for the main unit only.)

Inserting the batteries


- Remove the battery compartment cover of the wireless remote control, and then insert the two accessory R03 size batteries. (Be sure not to make a mistake with the polarities.)

NOTE

The accessory batteries are to be used when checking operation. They should be replaced with new batteries as soon as possible. (Be sure not to make a mistake with the polarities.)

NOTE

- When inserting the batteries for the first time, or when replacing the batteries, the remote control may not work. In such cases, use a ballpoint pen or similar object to push the reset switch. The remote control should then start working normally.
- Replace the batteries with two new batteries of the same type.
- Rechargeable (Ni-Cd) batteries differ in aspects such as shape and performance, and thus cannot be used.



3. Installing the receptor unit


Receptor unit (for four-way cassette type) assembly procedure

1 Attach the receptor unit onto the decorative panel of the indoor unit as shown in the figure below.



1. Remove the "sealing cover" attached at the factory. (The sealing cover will no longer be required.)
2. Attach the receptor unit with the screws supplied.

2 Route the joint cord for wiring and connect it to the terminals <A> and in the control box of the indoor unit. (No polarity.)

1. Route the joint cord for wiring as shown in the figure (figure of the back of decorative panel) below.




- Remove the control box cover by removing the two fixing screws and connect the joint cord to the terminals <A> and in the control box.



Receptor unit (for ceiling type) assembly procedure




- Attach the receptor unit onto the indoor main unit as shown in the figure below.

- Remove the air-intake grille and the side cover.
To remove the side cover, remove the fixing screw each on the left and the right and pull the side cover towards you.
(Refer to the Installation Manual supplied with the indoor main unit.)




- Remove the receptor grille (component on which the model name is shown) to the right on the air-blow opening.
(Fixed with three tabs.)
(There should be a gap at the rear center of the receptor grille. Insert the tip of a slotted screwdriver, etc., 2 to 3mm into the gap and pry off the receptor grille to remove.)

- Remove the decorative panel for the receptor grille.
(Press the decorative panel from the back to remove.)
(The decorative panel will no longer required.)





- Attach the receptor unit for the wireless remote control onto the receptor grille. (Use two screws to fix.)
- Draw out the cord of the receptor unit through the feed-through hole toward the side plate and attach the receptor grille onto the main unit.
Hook the three tabs onto the receptor grille to attach the receptor grille on the main unit. (Press in the receptor grille until a click sound is heard.)



- | | |
|---|---|
| 2 | Route the joint cord for wiring and connect it to the terminals <A> and in the control box of the indoor unit.
(No polarity) |
|---|---|

- Route for wiring the cord as shown in the figure to the right.
- Remove the control box cover by removing the two fixing screws and connect the joint cord to the terminals <A> and in the control box.




4. Receptor unit wiring

- Connect the indoor unit and the receptor unit as shown in the illustration below.
- If the indoor unit does not operate even when the wireless remote control is used to turn it on, check the indoor unit power supply.

If LED1 (green) on the indoor unit printed circuit board is illuminated to show that the power supply is normal, turn on the EMERGENCY switch (Ⓐ) of the receptor unit. If the indoor unit still does not operate, even when the EMERGENCY switch (Ⓐ) is turned on, turned off the indoor unit power supply, check that all of the DIP switches 1 to 4 (DSW1) on the indoor unit printed circuit board are set to ON and then turn the power back on.

* If the optional wired remote control has been connected, check the remote control display, and set all the DIP switches 1 to 4 (DSW1) to OFF while the power is still turned on.





Address setting for wireless remote control and receptor unit (only when using more than one indoor unit.)

- Only the air conditioner units whose receptor unit address numbers match the remote control address number can be operated.
- At the time of shipment from the factory, the address numbers for both the wireless remote control and the receptor unit are set to "1". (When using only one indoor unit, the indoor unit can be used without changing the factory default settings.)

Press the address setting switch with a ballpoint pen or similar object to change the address setting.

The address number displayed on the LCD changes in the order of [ADDRESS1] → [ADDRESS2] → [ADDRESS3] → [GROUP] → [ADDRESS1] each time the switch is pressed.




NOTE

- If the batteries are replaced or the remote control is reset, the address setting will return to ADDRESS1, so you will need to repeat the address setting again.
All setting details which are stored in memory will be cleared, so you will need to repeat the settings.
- If the address is set to GROUP, more than one indoor unit can be operated at the same time.
(The indoor units can be operated by a single remote control regardless of the address number settings on the receptor units.)

Receptor unit address setting		
Address setting switch	1 2 3	Address1
	1 2 3	Address2
	1 2 3	Address3

Example: If the address numbers for all the indoor units are changed, other indoor units may operate accidentally due to signal interference.




Control using two remote controls

- If both the wireless remote control and the optional wired remote control are being used together, either one remote control can be used to operate the indoor units.
- The optional wired remote control can only be connected to the indoor unit besides the one with the receptor unit.
- Two wireless remote control cannot be connected at the same time.
- When using the wireless remote control and the optional wired remote control, the MASTER/SLAVE setting will not be necessary.

Group control

- When using group control, be sure to install the receptor unit to indoor unit No. 1. (Refer to the illustration below.)



- When using group control, up to a maximum of 16 indoor units can be connected. (Do not mix heat pump units and cooling only units.)
- When using group control, the indoor unit address numbers can be set automatically. However, you will not know at this time which address number corresponds to which indoor unit.
- Setting of address numbers can be carried out manually using the DIP switches. Manual settings have priority. (Do not combine both manual settings and automatic settings.)

[Manual Setting]

Indoor unit No.	1	2	3	4	5	6	7	8
DIP switch (DSW1) address setting on indoor unit printed circuit board.	OFF ON 1 2 3 4 5 6 7 8							
A/C No. setting	Unnecessary operation	1 ~ ON	2 ~ ON	1, 2 ~ ON	3 ~ ON	1, 3 ~ ON	2, 3 ~ ON	1, 2, 3 ~ ON
Indoor unit No.	9	10	11	12	13	14	15	16
DIP switch (DSW1) address setting on indoor unit printed circuit board.	OFF ON 1 2 3 4 5 6 7 8							
A/C No. setting	4 ~ ON	1, 4 ~ ON	2, 4 ~ ON	1, 2, 4 ~ ON	3, 4 ~ ON	1, 3, 4 ~ ON	2, 3, 4 ~ ON	1, 2, 3, 4 ~ ON


NOTE

The OFF/ON setting position for DIP switch No. 7 (louvre) will vary depending on the model.

5. Test mode operation

- * Press the TEST RUN switch within 1 minute of pressing the OFF/ON switch.
 - If more than 1 minute elapsed test operation will not commence and so you will need to press the OFF/ON switch again and repeat the operation.
 - Use the OPERATION switch to select the operation mode. The mode selected will appear on the operation mode display.

- * When test operation starts, "TEST RUN" will appear in the timer display of the LCD. The indoor unit will run in the operation mode indicated at this time (COOL or HEAT).
 - Test mode can be cancelled by pressing the OFF/ON switch, the TEMP, ▲ or ▼ switches, the OPERATION switch, the FAN SPEED switch or TEST RUN switch.




NOTE

- NOTE 1 During test operation, be sure to run the units in cooling mode first. If heating mode is selected first, it may cause problems with operation of the compressor.
- NOTE 2 Test operation should be carried out for a minimum of 5 minutes. (Test operation will be cancelled automatically after 30 minutes.)
- NOTE 3 If using the wireless remote control to carry out test operation, use the wireless remote control to cancel the test operation also.

6. Emergency operation

- If you do not have the wireless remote control (because the batteries are weak, or some other reason preventing the wireless remote control from being used), emergency operation can be carried out at the receptor unit.



- After setting the COOL/HEAT select switch on the receptor unit to either COOL or HEAT, press the EMERGENCY switch to start emergency operation.
Press the EMERGENCY switch once more to stop emergency operation.
- The setting temperature, fan speed and louvre control will be fixed at the settings shown in the table below.

COOL/HEAT select switch	Operation mode	Setting temperature	Fan speed	Louvre
COOL	Cooling	22°C	MED	Automatic
HEAT	Heating	28°C	MED	Automatic

- While the indoor unit is running, the OPERATION indicator on the receptor unit will illuminate, and it will switch off when the indoor units stops.
- Heating operation is not available for indoor units which are for cooling only. (If set to HEAT, the setting will change to FAN instead.)

Instructions for users

Please refer to the instruction manual provided with the indoor unit for instruction on how to use the wireless remote control.

28 INSTALLATION (INDOOR UNIT)

FOUR WAY CASSETTE AIR CONDITIONERS INSTALLATION INSTRUCTIONS

**REFRIGERANT
R 407C**

HP	Model Name
1.5 HP	CS-W14BB4P
2 HP	CS-W18BB4P
2.5 HP	CS-W24BB4P
3 HP	CS-W28BB4P
4 HP	CS-W34BB4P
5 HP	CS-W43BB4P
6 HP	CS-W50BB4P

Precautions in terms of safety


Carry out installation work with reliability after thorough reading of this "Precautions in terms of safety".

- Precautions shown here are differentiated between **Warnings** and **Cautions**. Those that have much chances for leading to significant result such as fatality or serious injury if wrong installation would have been carried out are listed compiling them especially into the column of **Warnings**.

However, even in the case of items which are listed in the column of **Cautions**, such items also have a chance for leading to significant result depending on the situations.

In either case, important descriptions regarding the safety are listed, then observe them without fail.

- As to indications with illustration



This mark means "Caution" or "Warning".



This mark means "Earth".

- After installation work has been completed, do not only make sure that the unit is free from any abnormal condition through the execution of trial run built also explain how to use and how to perform maintenance of this unit to the customer according to the instruction manual.

In addition, request the customer to keep this manual for installation work together with the instruction manual.

Warnings

- The appliance must be installed by technician, who takes into account the requirements given by ISO5149 or eventual equivalent requirements.
- As to installation, request the distributor or vendor to perform it. Imperfection in installation caused by that having been carried out by the customer himself may lead to water leakage, electric shock, fire, etc.
- Carry out the installation work with reliability according to this manual for installation work. Imperfection in installation leads to water leakage, electric shock, fire, etc.
- Carry out the installation work with reliability on a place that can sufficiently bear the weight of this unit. Insufficient strength leads to injury due to falling of the unit.
- Carry out predetermined installation work in preparation for strong wind such as typhoon, earthquake. Imperfection in installation work may lead to accidents arisen from overturn, etc.
- The unit must be installed in accordance with applicable national and local regulations. All electrical work should only be carried out by qualified technician and use exclusive circuit without fail. Presence of insufficient capacity in power circuit or imperfection in execution leads to electric shock, fire, etc.
- Wiring shall be connected using specified cables and fix them securely so that external force of the cables may not transfer to the terminal connection section. Imperfect connection and fixing leads to fire, etc.
- If installing inside a small room, measures should be taken to prevent refrigerant levels from building up to critical concentrations in the event of a refrigerant leak occurring. Please discuss with the place of purchase for advice on what measures may be necessary to prevent critical concentrations being exceeded. If the refrigerant leaks and reaches critical concentration, there is the danger that death from suffocation may result.
- Securely attach the protective covers for the outdoor unit connection cables and power cord so that they do not lift up after installation. If the covers are not properly attached and installed, the terminal connections may overheat, and fire or electric shock may result.
- Switch off all supplies before accessing any electrical part.
- If refrigerant gas escapes during installation, ventilate the affected area. If the refrigerant gas comes into contact with sparks or naked flames, it will cause toxic gases to be generated.
- Once installation work is completed, check that there are no refrigerant gas in the room that can come into contact with sparks or flames from a fan heater, stove or kitchen range, which will cause toxic gases to be generated.
- When performing piping work do not mix air except for specified refrigerant (R407C) in refrigeration cycle. It causes capacity down, and risk of explosion and injury due to high tension inside the refrigeration cycle.

⚠ C a u t i o n s

- | | |
|--|---|
| <p>▲ Carry out Earthing work.
Do not connect the Earth return to the gas pipe, water line pipe, lightning rod and telephone lines.
Imperfection in Earth return may lead to electric shock.</p> | <p>▲ Drain piping should be made to ensure secure drainage according to the manual for installation and carry out the thermal insulation to prevent the occurrence of condensation.
Imperfection in piping work leads to water leakage and may cause the house and property, etc. to become wet.</p> |
| <p>▲ Do not install the unit at the place where the possibility of inflammable gas leakage exists. If gas leakage should arise and the gas builds up around the unit, such situation may lead to ignition.</p> | <p>▲ Position the indoor unit and outdoor unit power cords and indoor/outdoor unit connection cables in a way so that they are at least 1 meter away from televisions and radios. This is to avoid problems such as interference with picture and/or sound. (However, note that depending on the electromagnetic wave conditions, interference may still occur even if the separation distance is more than 1 meter.)</p> |
| <p>▲ Mounting of the earth leakage circuit breaker is required. Omission in mounting of the earth leakage circuit breaker may lead to electric shock.</p> | |


1. ACCESSORIES PACKED IN THE INDOOR UNIT CONTAINER

Name	Q'ty	Appearance	Purpose	Name	Q'ty	Appearance	Purpose
Drain hose with a clip	1		For drain piping	Flat washer for M10	8		For fixing the hanging bolts
Heat insulator	1		For insulating refrigerant pipe joint	Cable clamp	2		For fixing power cable
Band	2		For fastening the heat insulator	Set screw of paper template	4		Screw M5

2. SELECTING THE LOCATION FOR THE INDOOR UNIT

Provide a check port on the piping side ceiling for repair and maintenance.

- Install the indoor unit once the following conditions are satisfied and after receiving the customer's approval.
 1. The indoor unit must be within maintenance space.
 2. The indoor unit must be free from any obstacles in path of the air inlet and outlet, and must allow spreading of air throughout the room.



* If the height from the floor to the ceiling exceeds three meters, air flow distribution deteriorates and the effect will be decreased.

⚠ W a r n i n g

- | | |
|---|--|
| <p>3. The installation position must be able to support a load four times the indoor unit weights.</p> | <p>4. The indoor unit must be away from heat and steam sources, but avoid installing it near an entrance.</p> |
| <p>5. The indoor unit must allow easy draining.</p> | <p>6. The indoor unit must allow easy connection to the outdoor unit.</p> |
| <p>7. Place the indoor unit according to the height from the ceiling shown in the illustration below.</p> | <p>8. The indoor unit must be from at least 3 m away from any noise-generating equipment. The electrical wiring must be shielded with a steel conduit.</p> |
| <p>9. If the power supply is subject to noise generation, add a suppressor.</p> | <p>10. Do not install the indoor unit at a laundry. Electric shocks may result.</p> |


Note • Study thoroughly the following installation locations

- Where in places such as restaurants and kitchens, considerable amount of oil steam and flour may adhere to the turbo fan and the fin of the heat exchanger and the drain pump, may result in heat exchange reduction, spraying, dispersing of water drops, drain pump malfunction, etc.

In these cases, take the following actions:

- Make sure the ventilation fan for the smoke-collection hood on a cooking table has sufficient capacity so that it draws oily steam which should not flow into the suction of the air conditioner.
- Make enough distance from the cooking room to install the air conditioner in such place where it may not suck in oily steam.

Model Name	Height in the ceiling
CS-W14BB4P CS-W18BB4P CS-W24BB4P CS-W28BB4P	250 mm or more
CS-W34BB4P CS-W43BB4P CS-W50BB4P	300 mm or more



- Avoid installing the air conditioner in such circumstances where cutting oil mist or iron powder exist especially in factories, etc.
- Avoid places where inflammable gas can be generated, flows-in, contaminated, or leak.
- Avoid places where sulphurous acid gas or corrosive gas can be generated.
- Avoid places near high frequency generators.

3. INSTALLATION OF INDOOR UNIT

This air conditioner uses a drain up motor. Install the unit horizontally using a level gauge.


CEILING OPENING DIMENSIONS AND HANGING BOLT LOCATION

The paper template for installation may expand or shrink according to temperature and humidity.


Check on dimensions before using it.

Caution During the installation, care must be taken not to damage electric wires.

- The dimensions of the paper template for installation are the same as those of the ceiling opening dimensions.
- Be sure to discuss the ceiling drilling work with the workers concerned.



POSITIONS OF AIR CONDITIONER BODY AND CEILING SURFACE



⚠ Warning Tighten the nuts and bolts to prevent unit from falling.

4. REFRIGERANT PIPING


Refrigerant is charged to the outdoor unit. For details, see the manual for installation work of outdoor unit. (Additional charging, etc.)

1. Brazing for piping.
 - a. Perform brazing before tightening the flare nut.
 - b. Brazing must be performed while blowing nitrogen gas. (This prevents generation of oxidized scale in copper pipe.)
2. When there is a lot of brazings for long piping, install a strainer at the midway of the piping. (The strainer is locally supplied.)
3. Use clean copper pipe with inner wall surface free from mist and dust. Blow nitrogen gas or air to blow off dust in the pipe before connection.
4. Form the piping according to its routing. Avoid bending and bending back the same piping point more than three times. (This will result in hardening of the pipe).
5. After deforming the pipe, align centers of the union fitting of the indoor unit and the piping, and tighten them firmly with wrenches.
6. Connect pipe to the service valve or ball valve which is located below the outdoor unit.
7. After completing the piping connection, be sure to check if there is gas leakage in indoor and outdoor connection.

Vacuum drying

After completing the piping connection, perform vacuum drying for the connecting piping and the indoor unit.

The vacuum drying must be carried out by using the service ports of both the liquid and gas side valves.



- Confirm the red mark of the union (thin side) is always at lower direction after connecting piping.

CAUTION Use two wrenches and tighten with regular torque.

Flare nut fastening torque N·m (kgf·cm)			
ø6.35 mm	18 (180)	ø15.88 mm	65 (660)
ø9.52 mm	42 (430)	ø19.05 mm	100 (1020)
ø12.7 mm	55 (560)		

Model Name	Liquid side piping	Gas side piping
CS-W14BB4P	ø6.35 mm	ø12.7 mm
CS-W18BB4P	ø6.35 mm	ø15.88 mm
CS-W24BB4P	ø6.35 mm	ø15.88 mm
CS-W28BB4P	ø9.52 mm	ø15.88 mm
CS-W34BB4P	ø9.52 mm	
CS-W43BB4P		ø19.05 mm
CS-W50BB4P		

5. INDOOR UNIT DRAIN PIPING


- Drain piping must have down-slope (1/50 to 1/100); be sure not to provide up-and-down slope to prevent reversal flow.
- During drain piping connection, be careful not to exert extra force on the drain port at the indoor unit.
- The outside diameter of the drain connection at the indoor unit is 32 mm.

Piping material: Polyvinyl chloride pipe VP-25 and pipe fittings.



- Be sure to perform heat insulation on the drain piping.

Heat insulation material: Polyethylene foam with thickness more than 8 mm.

- The height of drain may be possible up to 750 mm.




- When drain set piping, install as shown in the figure below.



Drain Test

The air conditioner uses a drain up motor to drain water. Use the following procedure to test the drain up motor operation.

- Connect the main drain pipe to exterior and leave it provisionally until the test comes to an end.
- Feed water to the flexible drain hose and check the piping for leakage.
- Be sure to check the drain up motor for normal operating and noise when electric wiring is complete.
- When the test is completed, connect the flexible drain hose to the drain port.




6. HEAT INSULATION

Caution

Be sure to perform heat insulation on the drain and gas piping. Imperfection in heat insulation work leads to water leakage.

1. Use the heat insulation material for the refrigerant piping which has an excellent heat-resistance (over 120°C).




2. Precautions in high humidity circumstance.

This air conditioner has been tested according to the "JIS Standard Conditions with Mist" and have been confirmed that there are no faults. However, if it is operated for a long time in high humid atmosphere (dew point temperature: more than 23°C), water drops are liable to fall. In this case, add heat insulation material according to the following procedure:

- Heat insulation material to be prepared... Adiabatic glass wool with thickness 10 to 20 mm.
- Stick glass wool on all air conditioners that are located in ceiling atmosphere.
- In addition to the normal heat insulation (thickness: more than 8 mm) for refrigerant piping (gas piping: thick piping) and drain piping, add a further of 10 mm to 30 mm thickness material.

Wall seal

- When the outdoor unit is installed at a higher position than the indoor unit, install a trap so as not to instill rain water into the wall transmitted by the piping.
- Stuff the space among piping, the electric wire, and the drain hose with "Putty" and seal the penetration wall hole.
Make sure that rain water do not instill into the wall.



* Put the incision at the trap part of the heat insulator (for water drainage)

7. ELECTRICAL WIRING


As to the main power source and cable size of outdoor unit, read the installation manual attached to the outdoor unit.

⚠ Warning	The units must be permanently connected to the supply cables by qualified technician. Feed the power source to the unit via a distribution switch board designed for this purpose. The switch should be disconnected at all poles with a contact separation of at least 3 mm. When the supply cable is damaged it must be replaced by qualified technician.
⚠ Caution	Be sure to install a current leakage breaker, main switch and fuse to the main power supply, otherwise electric shocks may result.
⚠ Caution	Be sure to connect the unit to secure earth connection. If the earthing work is not carried out properly, electric shocks may result. 
⚠ Warning	Wiring shall be connected securely by using specified cables and fix them securely so that external force of the cables may not transfer to the terminal connection section. Imperfect connection and fixing leads to fire, etc.

1. Select a power source that is capable of supplying the current required by the air conditioner.
2. Always ground the air conditioner with a grounding wire and screw to meet the LOCAL REGULATIONS.
3. Be sure to connect the wires correctly to terminal board with connecting the crimp type ring terminal to the wires.
4. Be sure to turn off the main power before installing and connecting the remote controller.

Note	After turning on the power supply for both the indoor and outdoor units, do not turn the power off after at least 1 minute has passed. (This is for the system's automatic setting.) Turning off the power supply on the way may cause an abnormal operation.
-------------	---


- Use the standard power cables for Europe (such as H05RN-F or H07RN-F which conforms to CENELEC (HAR) rating specifications) or use the cables based on IEC standard. (245IEC57, 245IEC66)



CONNECTING THE WIRES TO THE CONTROL BOX

- Remove the mounting screw, remove the control box cover, and then connect the wires by following the procedure given in the illustration.

Caution Make sure the screws of the terminal are securely tightened.



8. SETTINGS

* Do not operate the remote controller within 1 minute after turning on the power of the indoor unit.

- When using group control with the standard type, at least 1 unit must be set at No.1 at the indoor unit.
- Check the settings of the indoor unit in a case where there are no display at remote controller. If there is no problem to the settings, either group control or standard type should be set at No.16 at the indoor unit before turning the power on again.

Caution • Do not connect to Timer Setting, Fan Power (Connector CNT1 on printed circuit board) except when the relay, or the circuit board may be broken.

- All sets in the group which uses the same remote controller thermistor settings can be controlled by the same remote controller thermistor.
- Up to a maximum of 16 indoor units can be connected at the time of group control. (Do not connect heat pump unit with cooling only unit.)
- Indoor unit No. will be set automatically at the time of group control. However, which indoor unit uses which number is unknown.
Indoor unit No. is also possible to be set manually with DIP switches. Since manual address setting has priority to automatic address setting, to perform automatic address setting after doing manual setting, turn off all DIP switches from No. 1 to No. 4, and then stop the operation. Then press three switches such as [AIR SWING AUTO] • [OPERATION] • [A/C No.] at the same time. (Do not use manual address setting and automatic address setting together.)
- Centralized control is possible for master unit and slave unit at the time of group control.

Manual Setting	Indoor unit No.	1	2	3	4	5	6	7	8
	DIP switch (DSW1) address setting on indoor unit printed circuit board.	OFF ON 1 2 3 4 5 6 7 8	OFF ON 1 2 3 4 5 6 7 8	OFF ON 1 2 3 4 5 6 7 8	OFF ON 1 2 3 4 5 6 7 8	OFF ON 1 2 3 4 5 6 7 8	OFF ON 1 2 3 4 5 6 7 8	OFF ON 1 2 3 4 5 6 7 8	OFF ON 1 2 3 4 5 6 7 8
A/C No. setting	Unnecessary operation	1-ON	2-ON	1,2-ON	3-ON	1,3-ON	2,3-ON	1,2,3-ON	
	Indoor unit No.	9	10	11	12	13	14	15	16
A/C No. setting	DIP switch (DSW1) address setting on indoor unit printed circuit board.	OFF ON 1 2 3 4 5 6 7 8	OFF ON 1 2 3 4 5 6 7 8	OFF ON 1 2 3 4 5 6 7 8	OFF ON 1 2 3 4 5 6 7 8	OFF ON 1 2 3 4 5 6 7 8	OFF ON 1 2 3 4 5 6 7 8	OFF ON 1 2 3 4 5 6 7 8	OFF ON 1 2 3 4 5 6 7 8
	A/C No. setting	4-ON	1,4-ON	2,4-ON	1,2,4-ON	3,4-ON	1,3,4-ON	2,3,4-ON	1,2,3,4-ON

(Remote Controller address setting)


(Refer to the Installation Manual which is provided with the remote controller for details.)

- Two remote controllers (including the wireless remote controller) can be connected. However, remote control thermistor setting is not possible.
- As for (master/slave) setting of remote controller, the automatic setting and manual setting are possible. Since manual setting has priority.
- Two remote controllers, which both are wireless, cannot be connected.

Indoor/outdoor unit connection control cables

- Route the connection cables apart from the power cables to prevent abnormal operations (noise can be generated).

The length of the control line can be up to 200 m.



9. INSTALLATION OF DECORATIVE PANEL

Always remove the paper template before installing the decorative panel.


The decorative panel has its installation direction.
Confirm the direction with the display of the piping side.

- Temporarily fix two decorative panel fixing screws (hexagon M5 screw) to the units body. (Tighten to about 10 mm in length). The fixing screws (hexagon M5 screw) are attached to the decorative panel.
- Remove the air inlet grill from the decorative panel. (Remove the hook for the air inlet grill string.)
- Hook the decorative panel key hole (O) on the screws fixed in step above, and slide the panel so that the screws reach the key hole edge.
- Retighten fully two temporarily fixed screws and other two screws. (Total 4 screws)
- Connect the louvre motor connector.
- After tightening these screws, install the air inlet grill (including the air filter).



Be sure to connect louvre motor connector. Imperfect connection leads to fire, electric shock, etc.

⚠ Warning Be sure to hook the air inlet grill string, to prevent grill from falling and causing injury from it.




* Hang the hinge on the hole of the decorative panel. (The direction of the installation is free.)

Caution


Securely install the decorative panel. Leakage of cool air causes condensation.

Good example




Fit the insulator (this part) and be careful for cool air leakage.


Bad example

**10. TIMER AND FAN OUTPUT**

- Connect the wires from the connector (CNT1) on printed circuit board.

Timer setting**Fan Output**

(synchronization with fan) d.c. 12V 75mA



Connect to another circuit contact of the timer.

Connect the timer cord to connector (CNT1 ③,④) on PCB. Connect the timer cord to connector (CNT1 ①,②) on PCB.

11. PRECAUTIONS IN TEST RUN

- The initial power supply must provide at least 90% of the rated voltage. Otherwise, the air conditioner may not operate.



- Test operation can be carried out using the remote control unit or at the outdoor unit. (If carrying out test operation at the outdoor unit, refer to "TEST OPERATION" in the outdoor unit installation manual.)
- If using the remote control unit to carry out test operation, follow the procedure given below.



- First, press the OFF/ON (①) button.
- Then press the TEST RUN button within 1 minute of pressing the OFF/ON (①) button.
- Next, select the operation modes.
- The temperature of the indoor unit pipes will be shown on the temperature setting display. (At the start of the test operation, it may take up to 1 minute for air conditioner number, switching time and other displays to appear.)
- After operation modes have been selected, stop the compressor for a moment.
- Press the OFF/ON (①) button of the TEST RUN button once more to cancel test operation mode.

NOTE 1

These units are equipped with connection error prevention circuits. If the units do not operate, it is possible that the connection error prevention circuits have been operated. In such cases, check that the power wires (connected to terminals ① and ②) and the control wires (connected to terminals ③ and ④) are connected correctly. If they are connected incorrectly, connect them correctly. Normal operation should then commence.

**NOTE 2**

Do not short the remote control unit wires to each other. (The protection circuit will be activated and the units will not operate.) Once the cause of the short is eliminated, normal operation will then be possible.

NOTE 3

When running the units in heating mode during test operation, be sure to run the units in cooling mode first before selecting this mode. If heating mode is selected first, it may cause problems with operation of the compressor. (Heat pump model only.)

NOTE 4

Test operation should be carried out for a minimum of 5 minutes. (Test operation will be cancelled automatically after 30 minutes.)

NOTE 5

Test operation mode should always be cancelled once test operation itself has been completed.

12. CHECK THE FOLLOWING ITEMS WHEN INSTALLATION IS COMPLETE

- After completing work, be sure to measure and record trial run properties, and store measuring data, etc.
- Measuring items are room temperature, outside temperature, suction temperature, blow out temperature, wind velocity, wind volume, voltage, current, presence of abnormal vibration and noise, operating pressure, piping temperature, compressive pressure, airtight pressure.
- As to the structure and appearance, check the following items.

Is circulation of air adequate?

Is remote controller switch operated?

Is draining smooth?

Is there any faulty wiring?

Is heat insulation complete (refrigerant and drain piping)?

Are the terminal screws loosened?

Is there any leakage of refrigerant ?

M3...69-98N·cm {7-10kgf·cm} M4...157-196N·cm {16-20kgf·cm}
M5...196-245N·cm {20-25kgf·cm}

13. HAND OVER

- Teach the customer the operation and maintenance procedures, using the operation manual (air filter cleaning, temperature control, etc.)

As to parts to be sold separately

- With regards to installation of the parts sold separately, follow the installation manual which is provided with the parts sold separately.

As for work specifications of the outdoor unit, read the OUTDOOR UNIT INSTALLATION MANUAL attached to the outdoor unit.

29 INSTALLATION (OUTDOOR UNIT)

AIR CONDITIONERS OUTDOOR UNIT INSTALLATION INSTRUCTIONS

REFRIGERANT
R 407C

HP	Model Name	
1.5 HP	CU-W14BBP5	CU-V14BBP5
2 HP	CU-W18BBP5	CU-V18BBP5
2.5 HP	CU-W24BBP5	CU-V24BBP5 CU-V24BBP8
3 HP	CU-W28BBP5 CU-W28BBP8	CU-V28BBP5
4 HP	CU-W34BBP8	CU-V34BBP8
5 HP	CU-W43BBP8	CU-V43BBP8
6 HP	CU-W50BBP8	CU-V50BBP8

Precautions in terms of safety

Carry out installation work with reliability after thorough reading of this "Precaution in terms of safety".

- Precautions shown here are differentiated between **Warnings** and **Cautions**. Those that have much chances for leading to significant result such as fatality or serious injury if wrong installation would have been carried out are listed compiling them especially into the column of **Warnings**.

However, even in the case of items which are listed in the column of **Cautions**, such items also have a chance for leading to significant result depending on the situations.

In either case, important descriptions regarding the safety are listed, then observe them without fail.

- As to indications with illustration



This mark means "Caution" or "Warning".



This mark means "Earth".

- After installation work has been completed, do not only make sure that the unit is free from any abnormal condition through the execution of trial run but also explain how to use and how to perform maintenance of this unit to the customer according to the instruction manual.

In addition, request the customer to keep this manual for installation work together with instruction manual.

Warnings	
▲ The appliance must be installed by technician, who takes into account the requirements given by ISO5149 or eventual equivalent requirements.	technician and use exclusive circuits without fail. Presence of insufficient capacity in power circuit or imperfection in execution leads to electric shock, fire, etc.
▲ As to installation, request the distributor or vendor to perform it. Imperfection in installation caused by that having been carried out by the customer himself may lead to water leakage, electric shock, fire, etc.	▲ Wiring shall be connected securely using specified cables and fix them securely so that external force of the cables may not transfer to the terminal connection section. Imperfect connection and fixing leads to fire, etc.
▲ Carry out the installation work with reliability according to this manual for installation work. Imperfection in installation leads to water leakage, electric shock, fire, etc.	▲ If installing inside a small room, measures should be taken to prevent refrigerant levels from building up to critical concentrations in the event of a refrigerant leak occurring. Please discuss with the place of purchase for advice on what measures may be necessary to prevent critical concentrations being exceeded. If the refrigerant leaks and reaches critical concentration levels, there is the danger that death from suffocation may result.
▲ Carry out the installation work with reliability on the place that can bear the weight of this unit sufficiently. Insufficient strength leads to injury due to falling of the unit.	▲ Securely attach the protective covers for the outdoor unit connection cables and power cord so that they do not lift up after installation. If the covers are not properly attached and installed, the terminal connections may overheat, and fire or electric shock may result.
▲ Carry out predetermined installation work in preparation for strong wind such as typhoon, earthquake. Imperfection in installation work may lead to accidents arisen from overturn, etc.	▲ Switch off all supplies before accessing any electrical part.
▲ The unit must be installed in accordance with applicable national and local regulations. Any electrical work should only be carried out by qualified	

⚠ Warnings	⚠ Cautions
<p>▲ If refrigerant gas escapes during installation, ventilate the affected area. If the refrigerant gas comes into contact with sparks or naked flames, it will cause toxic gases to be generated.</p>	<p>▲ Carry out Earthing work. Do not connect the Earth return to the gas pipe, water line pipe, lightning rod and telephone lines. Imperfection in Earth return may lead to electric shock.</p>
<p>▲ Once installation work is completed, check that there are no refrigerant gas in the room that can come into contact with sparks or flames from a fan heater, stove or kitchen range, which will cause toxic gases to be generated.</p>	<p>▲ Do not install the unit at the place where the possibility of inflammable gas leakage exists. If such gas leakages should arise and the gas builds up around the unit, such situation may lead to ignition.</p>
<p>▲ When performing piping work do not mix air except for specified refrigerant (R407C) in refrigeration cycle. It causes capacity down, and risk of explosion and injury due to high tension inside the refrigerant cycle.</p>	<p>▲ Mounting of the earth leakage circuit breaker is required. Omission in mounting of the earth leakage circuit breaker may lead to electric shock.</p>
	<p>▲ Drain piping should be made to ensure secure drainage according to the manual for installation work and carry out the thermal insulation to prevent the occurrence of condensation. Imperfection in piping work leads to water leakage and may cause the house and property, etc. to become wet.</p>
	<p>▲ Position the indoor unit and outdoor unit, power cords and indoor/outdoor unit connection cables in a way so that they are at least 1 metre away from televisions and radios. This is to avoid problems such as interference with picture and/or sound. (However, note that depending on the electromagnetic wave conditions, interference may still occur even if the separation distance is more than 1 metre.)</p>

1. ACCESSORIES SUPPLIED WITH OUTDOOR UNIT

- The following parts are supplied as accessories with each outdoor unit.
Check that all accessory parts are present before installing the outdoor unit.

Part name	Q'ty	Diagram	Application
Protective bushing	2		For protecting electrical wires
Banding strap	3		For tying electrical wires together

Heat pump-types only			
Part name	Q'ty	Diagram	Application
Drain elbow AS	1		For connecting the drain pipe (with ring seat)

2. BEFORE INSTALLATION WORK

- This product is using new refrigeration (R407C). The basic way of installation work is the same as usual, but water and impurities should be controlled more strictly than before due to characteristic of refrigerating machine oil. Therefore, selection of materials to use and processing, storing and brazing need appropriate construction and control.

1. Tools and materials.


There are tools and materials for both new refrigeration and usual refrigeration you can use together and for either two of them you can use. Use the below for new refrigeration.

- Vacuum pump (with back flow preventor system)
- Gas leakage detection warning device
- Gauge manifold
- Charge hose

2. Installation work

① Brazing work

Brazing work needs replacing air inside pipe with nitrogen gas in order to prevent oxidation scale from occurring. This is called nitrogen replacement, and one of very important work in brazing refrigerant piping. (Oxidation preventive is not possible to use)





② Prevention measure for refrigerant piping

Prevention measure for refrigerant piping is very important work to prevent water-dust-rubbish from getting in. All piping terminals needs sealing such as shown below.

Place	Period of work	Method of seal
Outside	More than 1 month	Pinch
	Less than 1 month	Pinch or taping
Inside	Not specified	

- How to pinch
Close terminal part of piping with pliers and seal the gap with brazing.
- How to tape
Seal terminal part of piping with vinyl tape.



3. Vacuum pumping

The purpose of vacuum pumping work is to remove and dry air inside the piping or nitrogen at air tightness test. Perform the work carefully.

△ Caution Use the vacuum pump with the backflow prevention mechanism to prevent backflow of oil.


Vacuuming time | 60 minutes or more

✗ Vacuum pump capacity
60 l/min or more

4. Refrigerant filling

Refrigerant filling must be done in the state of liquid refrigerant. If this is done in gas refrigerant, the balance of refrigerant composition will collapse and damage the operation.

For the use of a gas cylinder without siphon inside, turn it upside down and use it.
(We recommend manifold with sight glass.)



CAUTION Do not use a "CHARGE CYLINDER".



△ Caution

As a rule, please collect all existing refrigerants in the system outside the system when the refrigerant leakage occurs by the system.
After that, please fill new refrigerant of a regulated amount again.

3. SELECTING THE OUTDOOR UNIT INSTALLATION LOCATIONS

- Select location which satisfies the following condition, and then confirm with the customer that such a place is satisfactory before installing the outdoor unit.

1. There should be sufficient ventilation.
2. The outdoor unit should be sheltered as much as possible from rain and direct sunlight, and the air should be able to move around so that hot and cold air do not build up.
3. There should not be animals or plants near the air outlet which could be adversely affected by hot or cold air coming out from the unit.
4. The outlet air and operating noise should not be a nuisance to other occupants nearby.
5. The location should be able to withstand the full weight and vibration of the outdoor unit, and it should also be level and safe for the unit to be installed.
6. The intake and outlet should not be covered.
7. There should not be danger of flammable gas or corrosive gas leaks.
8. There should be as little back-ventilation (air blowing directly onto the fan) as possible.
(If strong wind blows directly onto the fan, it may cause problems with normal operation.)
 - If you know which direction the prevailing wind comes from during the operating season, set the outdoor unit at a right-angle to this wind direction, or so that the air outlet faces toward a wall or fence.
 - If there are obstructions near the outdoor unit and the wind direction is not constant, install an optional air guider.
9. Do not allow any obstacles near the outdoor unit which will interfere with air flow around the air intake and air outlet.
10. If installing in a location which is prone to snowfall, place the installation base as high as possible, and be sure to install a roof or enclosure which does not allow snow to accumulate.
11. Avoid installing the unit in places where petroleum products (such as machine oil), salinity, sulphurous, gases or high-frequency noise are present.
12. Be sure to leave enough space around the outdoor unit to maintain proper performance and to allow access for routine maintenance.
 - Allow enough space from any obstacles as shown in Fig.1.2 below in order to prevent short-circuits from occurring.
(If installing more than one outdoor unit, make the necessary space available as outlined in 14.)
However, there should be at least 1 metre of free space above the unit.
 - The height of any obstacles at the air intake and outlet sides should not be greater than the height of the outdoor unit.
- When facing the air intake side toward a wall.
- When facing the air outlet side toward a wall.
- When using an optional air guider for outdoor units.



* Maintain sufficient space above the unit.

13. If is not possible to leave 50 (100)cm at the air outlet side as shown in Fig. 2, the installation method shown in Fig. 3 can be used if an optional air guider for outdoor units is installed. Install according to the instructions given in the separate instruction manual.

NOTE

When installing the air guider

- 1) If directing the air upward, there should not be obstacles above the outdoor unit.
- 2) If directing the air to the left or right, there should not be obstacles at the left or right of the outdoor unit.
- 3) Never use the air guider in locations which are subject to snowfall.
If snow gets inside the air guider, it could cause the fan to freeze up.
- 4) If connecting outdoor units in series, direct the flow upward.


Air guider for outdoor units

Model Name	Part No.
CU-W14BBP5	CU-V14BBP5
CU-W18BBP5	CU-V18BBP5
CU-W24BBP5	CU-V24BBP5
	CU-V24BBP8
CU-W28BBP5	CU-V28BBP5
CU-W28BBP8	CU-V28BBP8


Model Name	Part No.
CU-W34BBP8	CU-V34BBP8
CU-W43BBP8	CU-V43BBP8
CU-W50BBP8	CU-V50BBP8

14. If installing more than one outdoor unit, allow enough space around each unit as shown below.

- When installing units side by side



- When installing units facing each other



* Maintain sufficient space above the unit.

Values inside brackets indicate distances when installing the 4HP-5HP.

- The distance given above are the minimum distance required in order to maintain proper performance.
Allow as much space as possible in order to get the best performance from the units.


4. TRANSPORTING AND INSTALLING THE OUTDOOR UNIT

- Transporting

1. The outdoor unit should be transported in its original packaging as close to the installation location as possible.
2. If suspending the outdoor unit, use a rope or belt, and use cloth or wood as padding in order to avoid damaging the unit.
3. Use the handles at left and right to transport the unit, and be careful not to touch your hands or other objects against the fan.

● Installation


1. Read the "Selecting the outdoor unit installation location" section thoroughly before installing the outdoor unit.
 2. If installing the unit to a concrete base or other solid base, use M10 or W3/8 bolts and nuts to secure the unit, and ensure that the unit is fully upright and level.
(The anchor bolt positions are shown in the diagram at the right side.)
In particular, install the unit at a distance from the neighbouring building which conforms to regulations specified by local noise emission regulation standards.
 3. Do not install the outdoor unit to the building's roof.
 4. If there is a possibility that vibration may be transmitted to the rooms of the building, place rubber insulation between the unit and the installation surface.
 5. Drain water will be discharged from the outdoor unit when operating the system in heating or defrosting modes. Select an installation location which will allow the water to drain away properly, or provide a drainage channel so that the water can drain away.
(If this is not done, the drain water may freeze during winter, or the water may spill down to areas underneath the installation location.)
- * If a drain pipe needs to be installed, insert the accessory drain elbow into the mounting hole at the bottom of the outdoor unit, and connect a hose with an inside diameter of 15mm to this drain elbow.
(The hose is not supplied.)
- * If using the drain elbow, install the outdoor unit on a base which is at least 5cm high.



NOTE In cold regions (where the outdoor air temperature can drop to 0°C or below continuously for 2-3 days), the drain water may freeze, and this may prevent the fan from operating. Do not use the drain elbow in such cases.

CAUTION

- Be sure to remove the compressor fixing brackets.
(Some models are not equipped with compressor fixing brackets.)
- To remove, first remove the mounting screws, loosen the compressor mounting nuts and then pull sideways.
- After removing, be sure to tighten the compressor mounting nuts again.



5. CONNECTING THE PIPES

- Use a clean pipe which does not include water or dust for inside of piping.
- When cutting the refrigerant pipes, a piping cutter must be used. Before connecting the refrigerant pipes, blow nitrogen and blow off dust in the pipes.
(Never use tools which cause a lot of dust such as a saw and a magnet.)
- When waxing replace nitrogen inside the piping after removing dirt and dust. (In order to prevent oxidization scale from forming inside the piping).
- The refrigerant pipes are of particular importance.
The installation work for refrigerant cycles in separate-type air conditioners must be carried out perfectly.

1. Refer to the table below for the pipe diameters equivalent lengths and indoor/outdoor unit difference of elevation.

Model Name	Pipe diameter (mm)		Equivalent length (m)	Difference of elevation (m)
	Liquid-side pipes	Gas-side pipes		
CU-W14BBP5	Ø6.35	Ø12.70	25	20
CU-W18BBP5	Ø6.35	Ø12.70	40	30
CU-W24BBP5 CU-V24BBP8	Ø6.35	Ø15.88	50	30
CU-W28BBP5 CU-W28BBP8	Ø9.52	Ø15.88	50	30
CU-W34BBP8 CU-W43BBP8 CU-W50BBP8	Ø9.52	Ø19.05	50	30

2. Local pipes can project in any of four directions.

- Make holes in the pipe panels for the pipes to pass through.
- Be sure to install the pipe panels to prevent rain from getting inside the outdoor unit.

[Removing the service panel].

(1) Remove the two mounting screws.



(2) Slide the service panel downward to release the pawls.

After this, pull the service panel toward you to remove it.

3. Notes when connecting the refrigerant pipes.

- Use clean copper, pipes with no water or dust on the insides.
- Use phosphorus-free, unjointed copper pipes for the refrigerant pipes.
- If it is necessary to cut the refrigerant pipes, be sure to use a pipe cutter, and use compressed nitrogen or an air blower to clean out any foreign particles from inside the pipe.
- Be careful not to let any dust, foreign materials or water get inside the pipes during connection.
- If bending the pipes, allow as large a bending radius as possible. Do not flex the pipes any more than necessary.
- If joining pipe ends, do so before tightening the flare nut.
- Always blow the pipe end with nitrogen while joining pipe ends.
(This will prevent any oxide scaling from occurring inside the pipe.)
- If using long pipe lengths with several joined pipe ends, insert strainers inside the pipes.(Strainers are not supplied.)
- When tightening the flare nuts, coat the flares (both inside surfaces) with a small amount of refrigerator oil, and screw in about 3-4 turns at first by hand.
- Refer to the following table for the tightening torques. Be sure to use two spanners to tighten.

(If the nuts are overtightened, it may cause the flares to break or leak.)



4. After piping connection has been completed, make sure that the joint areas of the indoor and outdoor units are free from gas leakage by the use of nitrogen, etc.

5. Air purge within connection piping shall be carried out by evacuation.

6. HEAT INSULATION

Caution

Use a material with good heat-resistant properties as the heat insulation for the pipes. Be sure to insulate both the gas-side and liquid-side pipes. If the pipes are not adequately insulated, condensation or water leakages may occur.

Liquid-side pipes


Material that can withstand 120°C or higher

Gas-side pipes

7. CHARGING WITH REFRIGERANT

- At the time of shipment from the factory, this unit is charged with enough refrigerant for an equivalent pipe length of 30m. If the equivalent pipe length used will be 30m or less, no additional charging will be necessary.
- If the equivalent pipe length will be between 30 and 50m (40m), charge with additional refrigerant according to the equivalent length given in the table below.
 - For standard type

Model Name		Additional charging amount	Equivalent length
CU-W14BBP5	CU-V14BBP5	0.02kg/m	25m
CU-W18BBP5	CU-V18BBP5	0.02kg/m	40m
CU-W24BBP5	CU-V24BBP5	0.02kg/m	50m
	CU-V24BBP8		
CU-W28BBP5	CU-V28BBP5	0.05kg/m	
CU-W28BBP8	CU-V28BBP8		
CU-W34BBP8	CU-V34BBP8		
CU-W43BBP8	CU-V43BBP8		
CU-W50BBP8	CU-V50BBP8		



- Pump down operation
 - Operate the pump down according to the following procedures.

Procedure	Notes
1. Confirm the valve on the liquid side and the gas side is surely open.	
2. Press the COOL switch on outdoor printed board for 1 second or more.	Perform the cooling operation for five minutes or more.
3. Set the liquid side 3-way valve to the close position and until when the gauge indicates at 0.1Mpa (1kg/cm ² G).	
4. Immediately set the gas side valve to the close position and press the COOL switch (stop the operation unit).	When the valve is shut halfway, the compressor is occasionally damaged.

The pump down is completed above.

CHECKING THE PRESSURE

Check the pressure at the service port on the valve and the check joint where the pipe ends have been joined according to the table at below.

Heat pump model

	A	B
During cooling operation	High pressure	Low pressure
During heating operation	Low pressure	High pressure

Cooling model only

	C	B
During cooling operation	High pressure	Low pressure

8. ELECTRICAL WIRING

⚠ Warning	The units must be connected to the supply cables for fixed wiring by qualified technician. Feed the power source to the unit via a distribution switch board designed for this purpose, the switch should disconnected all poles with a contact separation of at least 3mm. When the supply cable is damaged, it must be replaced by qualified technician.
⚠ Caution	Be sure to install a current leakage breaker, main switch and fuse to the main power supply, otherwise electric shocks may result.
⚠ Caution	Be sure to connect the unit to secure earth connection. If the earthing work is not carried out properly, electric shocks may result. 
⚠ Warning	Wiring shall be connected securely by using specified cables and fix them securely so that external force of the cables may not transfer to the terminal connection section. Imperfect connection and fixing leads to fire, etc.

- Connect the power supply wiring and indoor/outdoor unit connection wiring according to the electrical circuit diagram instructions.
- Clamp the wires securely to the terminal connections using cord clamps so that no undue force is placed on the wires.
- Once all wiring work has been completed, tie the wires and cords together with the binding strap so that they do not touch other parts such as the compressor and pipes.

1. Connect the power supply line to a 3-phase/380-415V (or single-phase 220-240V) power supply.

If the phase is reversed, the self-diagnosis function will be activated and the unit will not operate. In such cases, switch over any two of the power supply wires (L1,L2,L3) (3-phase models only).

(Never operate the unit by pressing the electromagnetic switch.)

2. The equipment shall be connected to a suitable mains network with a main impedance less than the value indicated in the table of power supply specifications.



3. Be sure to connect the wires correctly to terminal board with connecting the crimp type ring terminal to the wires.

4. The binding screws inside the power supply box may become loosened due to vibration during transportation, so check that they are tightened securely.

5. Tighten the binding screws to the specified torque while referring to the table below.

6. If connecting two separate wires to a single crimped terminal, place the two crimped terminal wires together as shown in Fig. A. (If the arrangement shown in Fig. B is used, poor contacts or contact damage may result.)

7. If momentarily turning on the power supply for both the indoor and outdoor units, do not turn the power off again until at least 1 minute has passed (except when a reversed phase has been detected).




Warning Use only the specified cables for wiring connections. Connect the cable securely, and secure them properly so that no undue force will be applied to the terminal connections.

If the terminals are loose or if the wires are not connected securely, fire may result.


Terminal screw	Tightening torque N·cm {kgf·cm}
M3	69~98 {7~10}
M4	157~196 {16~20}
M5	196~245 {20~25}

Refer to the following diagrams for details on how to connect the power supply cables and indoor/outdoor unit connection cables.

OUTDOOR UNIT/3-PHASE MODEL



OUTDOOR UNIT/SINGLE-PHASE MODEL



- Power supply specifications

Model name	Leakage current breaker (A)	Circuit breaker (Minimum Capacity)		Power supply cables (terminals C N \oplus)	Indoor/outdoor unit connection power cables (terminals 1 2 \oplus)	Indoor/outdoor unit connection power cables (terminals 3 4)	
		Switch (A)	Fuse (A)				
CU-W14BBP5 CU-V14BBP5	220V-240V~	16	16	16	2.5 mm ² x 3	1.5 mm ² x 3	1.0 mm ² x 2

NOTE


- ① 1. Where ground work (earth) is carried out, do not connect the ground return to the gas pipe, water line pipe, grounded circuit of the telephone and lightning rod, or ground circuit of other product in which earth leakage breaker is incorporated. (Such action is prohibited by statute, etc.)
- ⚠ 2. In order to prevent malfunction (noise generation) of the equipment, carry out the wiring of the control cable for indoor and outdoor units (signal cable) isolating it from other power cable with separate cable.
- 3. Use the standard power supply cables for Europe (such as H05RN-F or H07RN-F which conforms to CENELEC (HAR) rating specifications) or use the cables based on IEC standard. (245IEC57, 245IEC66)
- 4. Select the particular size of electrical wire for power supply cables in accordance with the standards of the given nation and region.

9. CONNECTING POWER SUPPLY CABLES

- If reversed phase is detected and the self-diagnosis function is activated after connecting the power supply cables, carry out the following operation.
Switch over any two of the power supply wires which are connected to the power supply terminal board.
Turn off the main power supply before correcting the phase.

CAUTION

- Never operate the unit by pressing the electromagnetic switch.
- Never correct the phase by switching over any of the wires inside the unit.




10. PRECAUTIONS WITH REGARD TO TEST OPERATION

CAUTION

- Always be sure to use a properly-insulated tool to operate the switch on the circuit board. (Do not use your finger or a metallic object.)
- Never turn on the power supply until all installation work has been completed.
- Turn on the circuit-breaker 12 hours or more before a test run. (By supplying power to crankcase heater, compressor is warmed and liquid compressing is prevented.)
- For three-phase models, check that the phase is not reversed.
(If the phase is reversed, the LED on the printed circuit board will flash.)
- Check that the voltage is 90% of rated voltage or higher when starting the unit.
(The unit will not operate if the voltage is less than 90% of rated voltage.)
- Test operation can be carried out using the remote control unit or by using the switch on the printed circuit board inside the outdoor unit.
- If carrying out test operation at the printed circuit board of the outdoor unit, follow the procedure given below. (If using the remote control unit to carry out test operation, refer to the installation manual which is supplied with the indoor unit.)
- Press the COOL or HEAT switch for 1 second or more. The LEDs will operate as follows during test operation.
(Be sure to select cooling mode first, and run the units in this mode for 5 minutes or more.)

* The compressor will stop momentarily when the operation mode is changed.


Test operation mode	LEDs on printed circuit board
Cooling test mode	LEDs 2-4 flash, LEDs 5-8 switch off
Heating test mode	LEDs 2-5 switch off, LEDs 6-8 flash



- Press the TEST button once more to cancel test operation mode.
- When performing heating test operation when the outside temperature is high, or cooling test operation when the outside temperature is low, the protection circuits may sometimes operate within a few minutes.

NOTE 1

These units are equipped with connection error prevention circuits. If the units do not operate, it is possible that the connection error prevention circuits have been operated. In such cases, check that the drive wires (connected to terminals ① and ②) and the control wires (connected to terminals ③ and ④) are connected correctly. If they are connected incorrectly, connect them correctly. Normal operation should then commence.

**NOTE 2**

Do not short the remote control unit wires to each other. (The protection circuit will be activated and the units will not operate.) Once the cause of the short is eliminated, normal operation will then be possible.

NOTE 3

When running the units in heating mode during test operation, be sure to run the units in cooling mode first before selecting this mode. If heating mode is selected first, it may cause problems with operation of the compressor.

NOTE 4

Test operation should be carried out for a minimum of 5 minutes. (Test operation will be cancelled automatically after 30 minutes.)

NOTE 5

Test operation mode should always be cancelled once test operation itself has been completed.

NOTE 6

Emergency operation can be carried out by setting the DSW1 switch on the printed circuit board inside the outdoor unit to the EMERGENCY position. During emergency operation, any abnormalities detected by the temperature thermistors are ignored while the outdoor unit is operating, so that long-term operation in this mode should be avoided. After emergency mode operation has been completed and normal operation is to be resumed, turn the power supplies for the indoor and outdoor units off and then back on again.

Set the abnormal temperature thermistor only to the setting in the table below when carrying out emergency operation.

	Thermistor	Cooling operation	Heating operation
Indoor unit side	Room temperature detection	Fixed at 25°C	
	Pipe temperature detection	Shorted	Open
Outdoor unit side	Discharge thermistor detection	Open	Open
	Heat exchanger outlet temperature detection	Shorted	Open

* Refer to the electrical circuit diagrams for details on wiring for each thermistor.

NOTE 7

If the self-diagnosis function reports a problem but more than one problem has developed at the indoor and/or outdoor units, the problem display on the remote control unit may not match the LED display on the outdoor unit printed circuit board. In such cases, check both locations and remove the causes of the problems.

11. AS TO MAKING THE INSPECTION AFTER COMPLETION OF WORK FULLY UNDERSTOOD

- At the time when the work has been completed, measure and record the characteristics of test run without fail and keep the measuring date, etc.
- Carry out the measurement regarding room temperature outside air temperature, suction and air discharge temperatures, wind velocity, wind volume, voltage current, presence of abnormal vibration, operating pressure, piping temperature, compressive pressure, airtight pressure as items to be measured.
- As to the structure and appearance, check following items.
 - Short circuit of the blow-out air.
 - Smooth flow of the drain
 - Reliable thermal insulation
 - Leakage of refrigerant
 - Mistake in wiring
 - Reliable connection of the ground wire
 - Looseness in terminal screw, fastening torque
M3... 69-98N·cm{7-10kgf·cm} M4... 157-196N·cm{16-20kgf·cm}
M5... 196-245N·cm{20-25kgf·cm}

12. AS TO DELIVERY TO THE CUSTOMER

- Request the customer to operate this air conditioner viewing instruction manual come with indoor unit in practice and explain how to operate.
- Deliver the instruction manual to the customer without fail.


13. AS TO PARTS TO BE SOLD SEPARATELY


We are preparing air guider for outdoor unit and parts to be sold separately for indoor unit, etc., however, as to details of mounting method, etc., observe respective instruction manual.

30 REPLACEMENT PARTS

30.1. INDOOR UNIT


CS-W14BB4P





NO.	PART DESCRIPTION	QTY.	CS-W14BB4P
1	BASE PAN ASS'Y	1	CWD52K1034
2	INNER POLYSTYRENE (TOP)	1	CWG071049
3	INNER POLYSTYRENE (SIDE)	1	CWG07C1016
4	CABINET SIDE PLATE ASS'Y	1	CWE04K1001
5	CABINET SIDE PLATE ASS'Y	1	CWE04K1002
6	FAN MOTOR	1	CWA921048
7	ANTI-VIBRATION BUSHING	4	CWH501016
8	SCREW-FAN MOTOR	4	CWH551032
9	CORD HOLDER	1	CWD74K1001
10	TURBO FAN	1	CWH03K1003
10a	NUT for TURBO FAN	1	XNG8
10b	SP WASHER	1	XWA8
10c	WASHER	1	CWH571008
11	EVAPORATOR	1	CWB30C1288
11a	EVAPORATOR SUPPORTER	1	CWD911115
11b	EVAPORATOR HOLDER	1	CWD911114
11c	EVAPORATOR HOLDER	1	-
11d	TUBE ASS'Y (CAPIL. TUBE-EVA)	1	CWT07K1112
12	HEATPROOF TUBE (24)	1	CWG021028
12a	HEATPROOF TUBE	1	CWG021021
13	FLARE NUT (3/8") / (1/4")	1	CWH6002140 (1/4")
13a	FLARE NUT (6/8") / (5/8")	1	CWT25096
14	PIPE COVER	1	CWD93C1020
15	SENSOR-EVAPORATOR	1	CWA501047
16	SPRING FOR SENSOR	1	CWH711010
17	DRAIN PUMP COMPLETE	1	CWB53C1003
18	PANEL DRAIN PUMP ASS'Y	1	CWD93K1004
19	DRAIN PUMP	1	CWB532005
20	ANTI-VIBRATION BUSHING	3	CWH501017
21	FLOAT SWITCH - DRAIN PUMP	1	CWA121076
22	DRAIN NOZZLE	1	CWH411005
23	FLEXIBLE PIPE	1	CWH851030
24	DRAIN HOSE HEAT INSULATION	1	CWG101025
25	DRAIN PAN-COMPLETE	1	CWH40C1020
26	DRAIN PLUG	1	CWB82018
27	NOISE FILTER	1	CWA491018
28	ELECTRONIC CONTROLLER	1	CWA73C1166
29	SPACER	6	CWH541028
30	TRANSFORMER	1	CWA401028
31	CAPACITOR-FAN MOTOR (MF/V)	1	DS461135QP-A (1.3/460)
32	CONTROL BOARD	1	CWH141005
33	HOLDER-TERMINAL BOARD	1	CWD932155
34	TERMINAL BOARD	1	CWA281015
35	LEADWIRE-FUSE&SENSOR	1	CWA67C3691
36	CONTROL BOARD COVER[CAUTION]	1	CWH13C1042
37	CONT. BOARD COVER-WIRING DIAG.	1	CWH13C1043
38	AIR GUIDER BLOWER WHEEL	1	CWD321030
39	ACCESSORY COMPLETE	1	CWH82C1106
40	WIRED REMOTE CONTROL COMPLETE	1	CWA75C2239
41	WIRELESS R/CONTROL COMP. (HP)	1	CWA75C2247
41	WIRELESS R/CONTROL COMP. (C)	1	CWA75C2250
42	RAY RECEIVER (HEAT PUMP MODEL)	1	CWD76C1003
42	RAY RECEIVER (COOLING ONLY)	1	CWD76C1002
	OPERATING INSTRUCTION	1	CWF563874
	INSTALLATION INSTRUCTION	1	CWF612268

All parts are supplied from MAICO, Malaysia (Vendor Code: 061)





NO.	PART DESCRIPTION	PART NO.	QTY.
1	FRONT GRILLE	CWE121026	1
2	COVER-AIR SWING MOTOR	CWH811013	1
3	CONNECTOR-SHAFT	CWH081002	1
4	CONNECTOR-SHAFT	CWH081003	6
5	CONNECTOR-SHAFT	CWH081004	6
6	BEARING	CWH641006	8
7	VANE	CWE241103	4
8	CONNECTOR-SHAFT	CWH081005	2
9	CONNECTOR-SHAFT	CWH081006	2
10	AIR SWING MOTOR	CWA981065	1
11	INSULATION POLYSTYRENE	CWG071105	2
12	INSULATION POLYSTYRENE	CWG071106	2
13	INSULATION POLYSTYRENE	CWG071107	1
14	WASHER	CWH571025	16
15	COVER	CWD932215	1
16	AIR FILTER	CWD001072	1
17	STRING	CWH841002	2
18	WASHER	CWH571026	2
19	INTAKE GRILLE	CWE221067	1

All parts are supplied from MAICO, Malaysia (Vendor Code: 061)

30.2. OUTDOOR UNIT

CU-W14BBP5





CU-W14BBP5

Ref. No.	Part Name & Description	Qty	Part No.
1	BASE PAN ASS'Y	1	CWD50K2070B
2	COMPRESSOR	1	4KS250DAA
3	ANTI-VIBRATION BUSHING	4	CWH50055
4	NUT FOR COMP. MOUNT.	3	CWH4582065
5	CONDENSER COMPLETE	1	CWB32C1288
6	TUBE ASS'Y (CAPILLARY TUBE)	1	CWT01C2688
7	PIPE HOLDER RUBBER	1	CWG251013
8	CONDENSER SIDE PLATE	1	CWD911198
9	TUBE ASS'Y(PRESSURE SWITCH)	1	CWT022878
10	RECEIVER	1	CWB141005
11	ACCUMULATOR	1	-
12	4-WAYS VALVE COMPLETE	1	CWB00K1018
13	TUBE ASS'Y(PRESS.SW + VALVE)	1	CWT01C2689
14	HEATING PRESSURE SWITCH	1	CWA101004
15	4-WAYS VALVE	1	CWB00003
16	3-WAYS VALVE	1	CWB011137
17	3-WAYS VALVE	1	CWB011095
18	STRAINER	1	CWB11025
19	HOLDER-SERVICE VALVE	1	CWH35K029B
20	SOUND-PROOF BOARD ASS'Y	1	CWH151036
21	SOUND PROOF MATERIAL-COMP	1	CWG302047
22	V-COIL COMPLETE	1	CWA43C2063
23	PIPING SENSOR (COIL)	1	CWA501043
24	SPRING FOR SENSOR	2	CWH711010
25	CABINET REAR PLATE	1	CWE02096B
26	CONTROL BOARD	1	CWH10K1033
27	TERMINAL BOARD ASS'Y	1	CWA28K234
28	CAPACITOR-FAN MOTOR	1	DS461205QP-A (0.2μF / 460v)
29	CAPACITOR-COMPRESSOR	1	DS371356CPNA (35μF / 370v)
30	ELECTRONIC CONTROLLER (EEPROM)	1	CWA73CXXXX
31	TRANSFORMER	1	CWA401029
32	CURRENT TRANSFORMER BOARD	1	CWA742592
33	TERMINAL COVER	1	CWH171012
34	BRACKET FAN MOTOR	1	CWD54238
35	SCREW-BRACKET FAN MOTOR	4	CWH55027
36	FAN MOTOR	1	CWA9221141
37	SCREW-FAN MOTOR	4	CWH55252
38	PROPELLER FAN	1	CWH00K1001
39	NUT for PROPELLER FAN	1	CWH56060
40	P.FAN AIR GUIDER PLATE	1	CWE06K034B
41	CONDENSER SIDE PLATE	1	CWE04111B
42	CABINET TOP PLATE COMPLETE	1	CWE03101B
43	CABINET FRONT PLATE	1	CWE06172B
44	HANDLE	3	CWE16000E
45	LEADWIRE-COMPRESSOR	1	CWA67C4318
46	INSTALLATION INSTRUCTION	1	CWF612361

CU-V14BBP5

Ref. No.	Part Name & Description	Qty	Part No.
1	BASE PAN ASS'Y	1	CWD50K2076B
2	COMPRESSOR	1	4KS250DAA
3	ANTI-VIBRATION BUSHING	4	CWH50055
4	NUT FOR COMP. MOUNT.	3	CWH4582065
5	CONDENSER COMPLETE	1	CWB32C1289
6	TUBE ASS'Y (CAPILLARY TUBE)	1	CWH35K029B
7	CONDENSER SIDE PLATE	1	CWE04111B
8	ACCUMULATOR	1	-
9	3-WAYS VALVE	1	CWB011137
10	STRAINER	1	CWB11025
11	3-WAYS VALVE	1	CWB011095
12	SOUND-PROOF BOARD ASS'Y	1	CWH151036
13	SOUND PROOF MATERIAL-COMP	1	CWG302047
14	PIPE SENSOR (COIL)	1	CWA501043
15	SPRING FOR SENSOR	2	CWH711010
16	CABINET REAR PLATE	1	CWE02096B
17	CONTROL BOARD	1	CWH10K1033
18	COMPRESSOR RELAY	1	CWA4000088
19	TERMINAL BOARD ASS'Y	1	CWA28K234
20	CAPACITOR-FAN MOTOR	1	DS461205QP-A (0.2µF / 460v)
21	CAPACITOR-COMPRESSOR	1	DS371356CPNA (35µF / 370v)
22	ELECTRONIC CONTROLLER	1	CWA73CXXXX
23	TRANSFORMER	1	CWA401029
24	CURRENT TRANSFORMER BOARD	1	CWA742592
25	CONTROL BOARD COVER	1	CWH131151A
26	TERMINAL COVER	1	CWH171012
27	BRACKET-FAN MOTOR	1	CWD54238
28	SCREW-BRACKET FAN MOTOR	4	CWH55027
29	FAN MOTOR	1	CWA921141
30	SCREW-FAN MOTOR	4	CWH55252
31	PROPELLER FAN	1	CWH00K1001
32	NUT for PROPELLER FAN	1	CWH56060
33	P.FAN AIR GUIDER PLATE	1	CWE06172B
34	CABINET TOP PLATE COMPLETE	1	CWE03101B
35	CABINET FRONT PLATE	1	CWE06K034B
36	HANDLE	3	CWE16000E
37	LEADWIRE-COMPRESSOR	1	CWA67C4318
38	INSTALLATION INSTRUCTION	1	CWF612361