*** SYNTHETIC TEST DOCUMENT · NOT AN OFFICIAL RECORD ***

OFFICE OF THE CHIEF FIRE OFFICER

REF: PMRDA/FIRE/NOC-44819

PUNE METROPOLITAN REGION DEVELOPMENT AUTHORITY (PMRDA) · FIRE BRIGADE HQ

FIRE SAFETY COMPLIANCE CERTIFICATE / NO OBJECTION CERTIFICATE (NOC)

NOC Reference Number:	NOC No: CFO/PMR/2025/FIRE-44819
Issuing Authority:	Chief Fire Officer, Fire & Emergency Services PMRDA
Date of Issue:	Dated: 16-05-2022
Validity Period:	Valid until: 15-05-2023
Premises / Building Inspected:	Apex Institute of Technology & Advanced Studies
Site / Parcel Location:	Plot No. 42-B, Knowledge City, Phase II, Pune - 411057
Survey / Khasra Identification:	Survey No: 142/2A and 142/2B, Haveli Taluka
Building Height & Construction:	Ground + 4 Storeys (Height: 14.85 Meters, Type-A Institutional)
Total Inspected Carpet Area:	14,850 Sq. Meters (Instructional & Lab Blocks)

INSPECTION FINDINGS & FIRE PROTECTION SYSTEMS VERIFIED

Wet Riser & Downcomer System:	Installed with 150mm internal risers, landing valves and hose reels on each floor.
Underground & Overhead Water Reserves:	Static Fire Water Tank of 150,000 Liters and Terrace Tank of 25,000 Liters operational.
Automatic Sprinkler & Smoke Detection:	Photoelectric smoke detectors installed in all server rooms, seminar halls, and laborator
Emergency Exits & Staircase Clearances:	Two independent 2.0-meter fire-rated staircases provided with outward opening doors.

Issued under Seal of Authority:

V. S. Thorat, CFO

Chief Fire Officer, Fire & Emergency Services

Pune Metropolitan Region Development Authority