



INSTITUTE OF PRESSURE VESSEL INSPECTION (CEYLON)

Statutory Inspection of Steam Boilers and Pressure Vessels

CERTIFICATE OF INSPECTION

Steam Boiler — Thorough Examination (Internal, External and Hydraulic)

Certificate No:	BIC/2026/0088
Owner / Occupier:	Kandy Knits (Pvt) Ltd
Location of Boiler:	Boiler House, Pallekele Industrial Zone
Boiler Registration No:	BLR-KK-01
Type of Boiler:	Horizontal fire-tube (3-pass), oil fired, 2.5 t/h
Maker and Year of Manufacture:	Thermax Ltd, 2014
Maximum Permissible Working Pressure:	10.5 bar (g)
Hydraulic Test Pressure:	15.8 bar (g)
Date of Inspection:	15.02.2026
Date of Issue:	20.02.2026
Date of Expiry:	19.02.2027

The boiler described above was thoroughly examined on the date stated and is in a fit condition to be worked at the pressure shown, subject to: (a) safety valves being set at or below the permissible working pressure; (b) water level gauges and low-water cut-off being tested daily by the attendant; (c) the boiler being operated only by a certified attendant.

Eng. T. Kanagaratnam
Chartered Engineer, Inspecting Officer

