

LOTUS APPAREL (PVT) LTD

Wastewater Management Procedure

Document No	Revision	Effective Date	Document Owner	Approved By
LA-ENV-003	02	15/09/2025	Dilhani Rodrigo (Compliance Manager)	Chandana Liyanage (Factory Manager)

1. Purpose

This procedure describes how wastewater generated at the factory is collected, treated and monitored so that discharges meet the tolerance limits set in the factory's Environmental Protection Licence (EPL No. BOI/ENV/EPL/2025/0871) and the requirements of the export processing zone.

2. Sources of wastewater

The factory carries out cutting, sewing, finishing and packing only; there is no dyeing, printing or garment washing on site. Wastewater therefore consists of sanitary wastewater from toilets and washrooms, canteen kitchen wastewater and minor floor-cleaning water. Average generation is approximately 85 m³ per day.

3. Treatment process

All wastewater is treated in the on-site sewage treatment plant (STP), an extended aeration activated sludge system with a design capacity of **120 m³ per day**. Canteen wastewater first passes through a grease trap that is cleaned weekly.

Stage	Unit	Function
1	Bar screen	Removes solids, plastics and fabric waste
2	Equalisation tank	Balances flow and load over 24 hours
3	Aeration tank	Biological treatment with diffused air (two blowers, duty and standby)
4	Secondary clarifier	Settles biological sludge; part is returned to aeration
5	Chlorine contact tank	Disinfection before discharge
6	Sludge drying beds	Dewatering of excess sludge, disposed of by a licensed contractor

Treated effluent is discharged to the zone's central wastewater treatment plant through a metered connection. The STP operator records flow, dissolved oxygen, pH and chlorine residual daily in the STP log book.

4. Monitoring and testing

A sample of treated effluent is tested **monthly by an accredited external laboratory** for pH, BOD5, COD, total suspended solids, and oil and grease. Results are compared with the licence tolerance limits and filed by the Compliance Manager. Any exceedance is reported to the Factory Manager within 24 hours, the cause is investigated, and a re-test is done within seven days.

5. Records

- STP daily log book (retained for three years)
- Monthly laboratory test reports
- Sludge disposal manifests
- Grease trap cleaning checklist