



File No: IPVI/BI/2026/6630

# INSTITUTE OF PRESSURE VESSEL INSPECTION (CEYLON)

Statutory Inspection of Steam Boilers and Pressure Vessels

## CERTIFICATE OF INSPECTION

*Steam Boiler — Thorough Examination (Internal, External and Hydraulic)*

|                                              |                                                   |
|----------------------------------------------|---------------------------------------------------|
| <b>Certificate No:</b>                       | BIC/2026/0904                                     |
| <b>Owner / Occupier:</b>                     | Blue Lagoon Apparel (Pvt) Ltd                     |
| <b>Location of Boiler:</b>                   | Boiler House, Horana Industrial Park              |
| <b>Boiler Registration No:</b>               | BLR-88-02                                         |
| <b>Type of Boiler:</b>                       | Horizontal fire-tube (3-pass), oil fired, 2.5 t/h |
| <b>Maker and Year of Manufacture:</b>        | Cochran Ltd, 2016                                 |
| <b>Maximum Permissible Working Pressure:</b> | 10.5 bar (g)                                      |
| <b>Hydraulic Test Pressure:</b>              | 15.8 bar (g)                                      |
| <b>Date of Inspection:</b>                   | 16.01.2026                                        |
| <b>Date of Issue:</b>                        | 21.01.2026                                        |
| <b>Date of Expiry:</b>                       | 20.01.2027                                        |

The boiler described above was thoroughly examined on the date stated and is in a fit condition to be worked at the pressure shown, subject to: (a) safety valves being set at or below the permissible working pressure; (b) water level gauges and low-water cut-off being tested daily by the attendant; (c) the boiler being operated only by a certified attendant.

Eng. H. D. Samarasekara  
Chartered Engineer, Inspecting Officer

