AS/NZS 2845.1:2010

Incorporating Amendment No. 1

Australian/New Zealand Standard

Water supply—Backflow prevention devices

Part 1: Materials, design and performance requirements

Superseding AS/NZS 2845.1:1998

STANDARDS NEW ZEALAND

PAEREWA AOTEAROA

AS/NZS 2845.1:2010

STANDARDS Australia

This joint Australian/New Zealand standard was prepared by Joint Technical Committee WS-023, Backflow Prevention Devices for Water Supply. It was approved on behalf of the Council of Standards Australia on 24 May 2010 and on behalf of the Council of Standards New Zealand on 28 May 2010.

This standard was published on 30 June 2010.

The following are represented on Committee WS-023:

ACT Planning and Land Authority
Australian Industry Group
Master Plumbers Association of NSW
Master Plumbers, Gasfitters and Drainlayers New Zealand
Plastics Industry Pipe Association of Australia
Plumbing Products Industry Group
Queensland Brassware Industry Advisory Panel
South Australian Water Corporation
Sydney Water Corporation
Water New Zealand
Water Services Association of Australia

Keeping standards up to date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current standard, which should include any amendments which may have been published since the standard was purchased.

Detailed information about joint Australian/New Zealand standards can be found by visiting the standards webshop at www.standards.com.au or Standards New Zealand's website at www.standards.co.nz.

Alternatively, Standards Australia publishes an annual printed catalogue with full details of all current standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national standards organisation.

We also welcome suggestions for improvement in our standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the title page.

This standard was issued in draft form for comment as DR 10003.

Australian/New Zealand Standard

Water supply—Backflow prevention devices

Part 1: Materials, design and performance requirements

Originated as AS 2845—1986.
AS 2845—1986 revised and redesignated AS 2845.1—1991.
Second edition 1995.
AS 2845.1—1995 jointly revised and redesignated AS/NZS 2845.1:1998.
Second edition 2010.
Reissued incorporating Amendment No. 1 (June 2014).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140.

ISBN (Print) 978-1-77551-323-0
ISBN (PDF) 978-1-77551-324-7

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee WS-0023, Backflow Prevention Devices for Water Supply, to supersede AS/NZS 2845.1:1998.

This Standard incorporates Amendment No. 1 (June 2014). The changes required by the Amendment are indicated in the text by a marginal bar and amendment number against the clause, note, table, figure or part thereof affected.

The objective of this Standard is to provide health and safety and protection of the environment by providing suitable devices that qualify with established type testing.

This Standard does not include all types of backflow prevention devices currently on the market. It includes only those which at the time of publication were considered to be most relevant to the protection of drinking water supplies.

This revision includes amendments and requirements for additional devices arising from industry requirements.

The terms 'normative' and 'informative' have been used in this Standard to define the application of the appendix to which they apply. A 'normative' appendix is an integral part of a Standard, whereas an 'informative' appendix is only for information and guidance.

Illustrations used in this Standard are diagrammatic only and have been chosen without prejudice.

CONTENTS

Page

Page

Page

Page

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Australian/New Zealand Standard
Water supply—Backflow prevention devices

Part 1: Materials, design and performance requirements

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard specifies requirements for the materials, design, performance and testing of mechanical backflow prevention devices that are used for the protection of water supplies.

This Standard covers backflow prevention devices classified as PN 10, PN 12 or PN 16, of the following types:

(a) Atmospheric vacuum breaker (AVB).

(b) Hose connection vacuum breaker (HCVB).

(c) Dual check valve with atmospheric port (DCAP).

(d) Dual check valve (Dual CV).

(e) Dual check valve with intermediate vent (Du CV).

(f) Pressure-type vacuum breaker (PVB).

(g) Double check valve (DCV).

(h) Double check detector assembly (DCDA).

(i) Reduced pressure zone device (RPZD).

(j) Reduced pressure detector assembly (RPDA).

(k) Spill-resistant pressure vacuum breaker (SPVB).

(l) Beverage dispenser dual check valve with atmospheric port (BDDC).

(m) Pipe interrupter device (PID).

(n) Single check valve (testable) (SCVT).

(o) Single check detector assembly testable (SCDAT).

NOTE: Unless otherwise specified, the nominal size of a device is determined by the inlet connection.

1.2 APPLICATION

The means for demonstrating compliance with this Standard for the purposes of the Watermark Certification Scheme shall be in accordance with Appendix A.

All backflow prevention devices shall comply with Sections 1 to 3, and 19. Each backflow prevention device type shall comply with the relevant Section as follows:

Section 4 Atmospheric vacuum breaker (AVB).

Section 5 Hose connection vacuum breaker (HCVB).

Section 6 Dual check valve with atmospheric port (DCAP).

Section 7 Dual check valve (Dual CV).

AS/NZS 2845.1:2010

Water supply - Backflow prevention devices - Part 1: Materials, design and performance requirements

Freephone:	0800 782 632 (New Zealand)
Phone:	+64 4 498 5990
Fax:	+64 4 498 5994
Email	enquiries@standards.co.nz