

Certificate of Compliance



You have been awarded:

Intertek WH US Mark for Access Door/frame Assemblies

Standards: NFPA 288 (2021) Ed. 2022

Certificate number: WHI24-41682601

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

Organization: Nisreen Factory for Special and Safety Works
Building No 3492, Osayd Bin Thalaba Street, Ar Rabwah Dist.
Riyadh 12815
Kingdom of Saudi Arabia

Product: Nisreen - Horizontal Steel Hatch Door Assembly - NFPA 288

Spec ID: 79067

Fire Rating: 2 Hour Fire Rated, 90 Minute Fire Rated

Listing Information: See following page(s)

Certification body: Intertek Testing Services NA, Inc.

Initial registration: August 25, 2024

Date of expiry: December 31, 2025

Issue status: 2

Authorized By:

A handwritten signature in black ink, appearing to read 'Jean-Philippe Kayl'.

Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA
Phone: 847-439-5667 Fax: 847-439-7320

www.intertek.com

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

LISTING INFORMATION

Product Covered

Nisreen - Horizontal Steel Hatch Door Assembly - NFPA 288

Product Description

Door frame is constructed with 10mm thick angular steel frame and attached to 6mm thick fiberglass C-channel framing and 3mm thick buildup angle, infilled with 4 layers of 15mm thick ceramic fire core.

Door leaf is nominal 238mm thick constructed with 6mm thick checkered steel sheet at the top of the door and insulated with ceramic fire core and mineral wool with 2mm thick perforated steel bottom cover.

Maximum allowed sizes:

Frame size: 3185 x 3188 mm (w x h)

Single leaf door: 1544 x 3112 x 238 mm (w x h x thk.)

Double leaf door (each leaf): 1544 x 3112 x 238 mm (w x h x thk.)

Limitations:

- Maximum Load Capacity (on minimum 10" x 20" load foot print area): 16,000 pounds (7258kg).
- Rotary latches are required.
- For installation in minimum 400mm (16") thick concrete slabs.
- Frame must be filled with cement grout.

Fire Ratings

The product noted above has qualified for the following fire resistance rating according to NFPA 288 (2022).

Details	Rating
Single leaf floor access hatch assembly	120 minutes (2 hours)
Double leaf floor access hatch assembly	90 minutes (1 1/2 hours)