



LISTING INFORMATION OF

Nisreen - Horizontal Steel Hatch Door Assembly - NFPA 288

SPEC ID: 79067

Nisreen Factory for Special and Safety Works
Building No 3492, Osayd Bin Thalaba Street, Ar Rabwah Dist.
Riyadh 12815
Kingdom of Saudi Arabia

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

LISTING INFORMATION

Product Covered
Nisreen - Horizontal Steel Hatch Door Assembly - NFPA 288

Product Description
Door frame is constructed with 10mm thick angular steel frame and attached to 6mm thick fiberglass C-channel framing and 3mm thick buildup angle, infilled with 4 layers of 15mm thick ceramic fire core.
Door leaf is nominal 238mm thick constructed with 6mm thick checkered steel sheet at the top of the door and insulated with ceramic fire core and mineral wool with 2mm thick perforated steel bottom cover.

Maximum allowed sizes:
Frame size: 3185 x 3188 mm (w x h)
Single leaf door: 1544 x 3112 x 238 mm (w x h x thk.)
Double leaf door (each leaf): 1544 x 3112 x 238 mm (w x h x thk.)

- Limitations:
- Maximum Load Capacity (on minimum 10" x 20" load foot print area): 16,000 pounds (7258kg).
 - Rotary latches are required.
 - For installation in minimum 400mm (16") thick concrete slabs.
 - Frame must be filled with cement grout.

Fire Ratings
The product noted above has qualified for the following fire resistance rating according to NFPA 288 (2022).

Details	Rating
Single leaf floor access hatch assembly	120 minutes (2 hours)
Double leaf floor access hatch assembly	90 minutes (1 1/2 hours)

Attribute	Value
Certificate Date of Expiry	December 31, 2025
Certificate Date of Initial Registration	August 25, 2024
Certificate Number	WHI24-41682601
Criteria	NFPA 288 (2021) Ed. 2022
CSI Code	08 30 00 Specialty Doors and Frames
CSI Code	08 31 00 Access Doors and Panels
Fire Resistance	2 Hour Fire Rated
Fire Resistance	90 Minute Fire Rated
Listing Section	ACCESS DOOR/FRAME ASSEMBLIES
Spec ID	79067