

KINGDOM OF SAUDI ARABIA
MINISTRY OF DEFENCE
GENERAL DIRECTORATE OF MILITARY WORKS
PROJECT 1 / 6 / 138 (ARRERAH)



DATE	PACKAGE No.
13 JULY 2014	6-138
PROJECT No.	CONTRACT No.
1 / 6 / 138	3 / 8 / 435
SUBJECT	SUBMITTAL No.
ANTI-BLAST DOORS AND BLAST RESISTANCE VALVES.	BQE/MM-301

ENGINEERING REVIEW COMMENTS

COMMENTS

ITEM	DRAWING NUMBER/MATERIAL SUBMITTAL NUMBER		ACTION CODE
	*** CONSTRUCTION OF: PROJECT BUILD UP WAREHOUSE FOR ARMS AND SAVINGS IN ARRERRAH, KSA *** (CONTRACTOR: BOURUQ EL-SHARQIA) MATERIAL SUBMITTAL FOR - ***APPROVAL OF ANTI-BLAST DOORS AND BLAST RESISTANCE VALVES*** SUBMITTED BY MFR-SUPPLIER, I.E.: SPECIAL & SAFETY WORK - NISREEN FACTORY TEL# (014) 986794, FAX# (014)4989255	ARCHITECTURAL: (1) DOOR OPENING DIMENSIONS TO BE FOLLOWED AS PER CONTRACT DRAWING, I.E. 6500 X 4000 MM. UPDATE DRAWINGS ACCORDINGLY. (2) PROVIDE NECESSARY HARDWARE AS SPECIFIED IN THE CONTRACT SPECIFICATIONS. MECHANICAL: (1) SUBMITTED NISREEN FACTORY/SSW MANUFACTURER FOR BLAST VALVES IS APPROVED ACTION CODED- "B". (2) QUANTITY OF BLAST VALVES MUST BE AS PER B.O.Q. AND CONTRACT DESIGN DRAWING. (3) WORKABILITY OF BLAST VALVES AGAINST EXPLOSIONS/BLAST PRESSURE SHALL BE CONTRACTOR THRU THEIR MANUFACTURER/SUPPLIER NISREEN FACTORY (SSW) RESPONSIBILITIES. STRUCTURAL: (1) CONTRACTOR TO SUBMIT THE FOLLOWING TEST REPORTS/CERTIFICATES FROM AN INDEPENDENT LABORATORY/ AGENCY AS PER PROJECT SPECIFICATIONS (083954). (2) FIRE RATING TEST/CERTIFICATES. (3) ALL FIELD OPERATING TEST REPORTS. (4) STATIC TEST. (5) BLAST RESISTANCE TEST. MATERIAL: (1) STRUCTURAL STEEL SHALL CONFORM A-36M. (2) STRUCTURAL TUBING SHALL CONFORM A-618M. WARRANTY: (1) CONTRACTOR TO SUBMIT ALL WARRANTIES FROM THE MANUFACTURER/SUPPLIER FOR MATERIAL AND WORKMANSHIP.	--- " B " " B "

- CONTRACTOR COPY -

BOURUQ EL-SHARQIA FOR GENERAL CONTRACTING EST

1. WE TRANSMIT FOR APPROVAL THE FOLLOWING ITEMS :

[illegible]

2. REMARKS	
------------	--

1. DRAW STANDARD TITLE BLOCK ON ALL DRAWINGS AND TO BE SIGNED BY THE PROJECT MANAGER.
2. FOR TECHNICAL COMMENTS, SEE DRAWINGS AND "ERC" ATTACHED.

THIS SECTION WILL ONLY BE USED BY THE APPROVING AUTHORITY.

3. ENCLOSURES RETURNED :

I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with all the requirements of the contract except as otherwise stated herein.

NAME, TITLE AND SIGNATURE OF CONTRACTOR:

ENGR. HASSAN EID , PROJECT MANIGER

DATE _____

03/07/2014

NAME, TITLE & SIGNATURE OF APPROVING AUTHORITY:

DATE _____

1LT./ENGR. KAMAL AL MALKEY, PROJECT ENGINEER

ACTION CODES: THE FOLLOWING CODES ARE GIVEN TO ITEMS SUBMITTED:

A = APPROVED AS SUBMITTED

B = APPROVED EXCEPT AS NOTED ON SUBMITTED ITEM;
RESUBMISSION NOT REQUIRED

C = APPROVED, EXCEPT AS NOTED ON SUBMITTED ITEM;

REFER TO ATTACHED SHEET; RESUBMISSION REQUIRED

(Procurement and/or construction is not permitted to proceed).

D = WILL BE RETURNED BY SEPARATE CORRESPONDENCE

E = DISAPPROVED, SEE ATTACHED SHEET

F = SEE COMMENTS ON ATTACHED SHEET

G = RETURNED WITHOUT ACTION, SEE ATTACHED SHEET