



TO:	GENERAL DIRECTORATE OF MILITARY WORKS				DATE	06-May-18	FIRST SUBMITTAL	[☐]	SHOP DRAWING SUBMITTAL NO.		
FROM:	Al Jabreen Contracting Co.	 			PROJECT No.:	3 / 7 / 4	RE-SUBMITTAL	[☒]	MATERIAL SUBMITTAL NO.	MAT-FP-C-16B	
					DOC SUBMITTAL NO.				AS BUILT DWG. SUBMITTAL NO.		
					PREVIOUS TRANS. NO.				PREVIOUS TRANS. NO.	MAT-FP-C-16A	
1.	WE TRANSMIT FOR APPROVAL THE FOLLOWING ITEMS :										
ITEM NO.	DESCRIPTION OF ITEM SUBMITTED				MANUFACTURER OR CONTRACTOR CATALOG CUT DRAWING OR BROCHURE NUMBER	No. OF COPIES	SPECIFICATION PARAGRAPH NUMBER	DRAWING SHEET PLATE OR FILE NUMBER	ACTION CODE		
								B.O.Q. ITEM NO.			
	FENCING OF KING SAUD AIR BASE AT KKMC										
	MATERIAL SUBMITTAL FOR CIVIL WORKS										
	HYDRAULIC ROAD BLOCKER										
1.	TECHNICAL SUBMITTAL					3			B		
	SPECIAL & SAFETY WORK NISREEN FACTORY (SSW)										
	TEL: 96614986794 FAX: 96614986255										
RECEIVED BY GDMW DATE: 06-MAY-2018											
2. REMARKS					I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with all the requirements of the contract except as otherwise stated herein.						
COMPLIED AS PER PREVIOUS COMMENTS' REQUIREMENT.					NAME, TITLE AND SIGNATURE OF CONTRACTOR :						
					ENGR. MOH. AMJAD ALI 					DATE	06-May-18
THIS SECTION WILL ONLY BE USED BY THE APPROVING AUTHORITY.					NAME, TITLE & SIGNATURE OF APPROVING AUTHORITY :						
3. ENCLOSURES RETURNED :					 13/05/18					DATE	13 May 2018
ACTION CODES: THE FOLLOWING CODES ARE GIVEN TO ITEMS SUBMITTED:											
A = APPROVED AS SUBMITTED					C = APPROVED, EXCEPT AS NOTED ON SUBMITTED ITEM; REFER TO ATTACHED SHEET; RESUBMISSION REQUIRED (Procurement and/or construction is not permitted to proceed).						
B = APPROVED EXCEPT AS NOTED ON SUBMITTED ITEM; RESUBMISSION NOT REQUIRED					E = DISAPPROVED, SEE ATTACHED SHEET						
					F = SEE COMMENTS ON ATTACHED SHEET						
					G = RETURNED WITHOUT ACTION, SEE ATTACHED SHEET						
					D = WILL BE RETURNED BY SEPARATE CORRESPONDENCE						



Ref # 2018/AZ/24

Date: 26 - APRIL - 2018

TO : AL JABREEN TRADING & CONTRACTING
Project : 3 / 7 / 4 - HAFA AL BATEN - ROAD BLOCKER
Subject : ROAD BLOCKER SUBMITTAL REVIEW COMMENTS

Dear Sir,

Reference to the Engineering Review Comments dated 12th April 2018 on your Transmittal (MAT-FP-C-16A dated in 10th April 2018), please find our reply as following:

1. Comment 1:
Provide Installation Instruction Drawings, including Foundation Layout and Anchorage
- Reply for Comment 1:
Please find the Attachment 1
2. Comment 2:
Provide Original Warranty Letter attested by SSW
- Reply for Comment 2:
Please find the Attachment 2
3. Comment 3:
Provide Original Certificate for Independent Laboratory Test
- Reply for Comment 3:
Please find the Attachment 3
4. Comment 4:
Electrical Characteristic for Motor shall be 380 V, 3 Ø, 60 Hz
- Reply for Comment 4:
Noted

With Regards,

Engr. AZZAM ASFOUR

Factory Manager

Mob: +966 55 333 1850

E-mail: Special_Safety@yahoo.com

Special & Safety Work
Nisreen Factory

GENERAL DIRECTORATE OF MILITARY WORKS NORTHERN REGION OFFICE	
ACTION CODE	
DATE: 13/05/18	
CHECKED BY	
☒ A APPROVED	
☒ B APPROVED AS NOTED	
☒ C APPROVED AS NOTED, RESUBMIT	
☐ D NOT APPROVED, RESUBMIT	

CONTRACTOR COPY

DATE: _____

FP-C-16B