

Client Specification - Mechanical Cooling Plant

Project: PRJ-MUM-2026 | Code: SPEC-MECH-002

Requirement: Chilled water distribution systems must maintain continuous N+1 redundancy.

Mandate: Maximum operational power draw profile cannot exceed 45kW per compressor fan unit.

Fluid Dynamics: Chilled water delivery set point configured precisely to 7.2 degrees Celsius.

Parameter	Value	Notes / Tolerance
Cooling Capacity	1200 TR	N+1 redundant array
Max Compressor Draw	45 kW	Per fan unit, hard ceiling
Chilled Water Supply Temp	7.2 C	+/- 0.5 C
Chilled Water Return Temp	12.5 C	Design delta-T = 5.3 C
Redundancy Level	N+1	Mandatory