

Client Specification - Emergency Backup Generation

Project: PRJ-MUM-2026 | Code: SPEC-ELE-003

Requirement: Standby diesel generators must kick in and assume critical facility load inside a maximum of 10 seconds.

Mandate: Engine speed must dynamically govern at 1500 RPM to sustain steady 50Hz frequency output.

Emissions: Exhaust treatment configurations must pass regional environmental safety metrics.

Parameter	Value	Notes / Tolerance
Rated Output	3 MW	Standby rating
Max Transfer Time	10 seconds	ATS engagement ceiling
Governed Speed	1500 RPM	For 50 Hz output
Rated Frequency	50 Hz	+/- 1% steady state
Emissions Compliance	CPCB-IV+	Regional standard