

Client Specification - Computer Room Air Handler System

Project: PRJ-MUM-2026 | Code: SPEC-MECH-005

Requirement: Precision CRAH frameworks must enforce downflow variable speed fan controls.

Mandate: Moisture profiles must stay within 40% to 55% relative humidity to meet design baselines.

Parameter	Value	Notes / Tolerance
Airflow Configuration	Downflow, VFD Fan	Variable speed
Relative Humidity Range	40% - 55%	Design baseline
Supply Air Temp	18 C	Target setpoint
Redundancy Level	N+1	Per cooling zone