

Commissioning Level 5 Functional Test Report: EQ-CRAH-505

System Asset Identifier: EQ-CRAH-505

Execution Stage: Level 5 Integrated Systems Testing (IST).

Acceptance Matrix Criteria: Verification of localized control interfaces, failsafe loops, and automatic failovers.

Status: PASS

Status Summary: Airflow and humidity control verified across a simulated full data hall load profile. Fan modulation response confirmed within BMS command tolerances.